STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

ADELLA F. CROZIER

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF ADELLA F. CROZIER

Line <u>No.</u>

10.		
1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Adella F. Crozier (she/her/hers). My business address is One Energy
3		Plaza, Detroit, MI 48226. I am employed by DTE Energy Corporate Services LLC,
4		a subsidiary of DTE Energy Company (DTE Energy), within Regulatory Affairs as
5		a Director.
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric or Company).
9		
10	Q3.	What is your educational background?
11	A3.	I received a Bachelor of Science degree in Metallurgical Engineering from Iowa
12		State University and a Master of Business Administration degree from the
13		University of Chicago. I have also completed several Company sponsored courses
14		and attended various seminars to further my professional development.
15		
16	Q4.	What is your work experience?
17	A4.	Prior to my employment at DTE Energy, I was employed by LTV Steel Company
18		(LTV) in various roles including Metallurgical and Quality Control Engineer in
19		positions of increasing responsibility for different product lines. My last role with
20		LTV was as Product Manager in the Sales and Marketing Department. In this role,
21		I had responsibility for managing the relationship between the Sales and Marketing
22		Department and one of LTV's major production plants. As part of my
23		responsibilities, I ran financial and engineering analyses related to product line
24		offerings.
25		

Line
No.

1	I joined DTE Energy in 2003 as a Technological Specialist in the Fossil Generation
2	Department's Engineering Support Organization. In 2004, I was promoted to
3	Supervisor – Mechanics and Metallurgy. In 2005, I joined the Regulatory Affairs
4	Department as Manager of Special Projects. In this role, I assisted the
5	Environmental Affairs Department with their portions of Detroit Edison's general
6	rate case filings and served as a member of several workgroups related to Governor
7	Granholm's 21st Century Energy Plan and Capacity Need Forum. I helped with
8	the Company's implementation of Michigan's 2008 energy legislation, particularly
9	those areas related to energy optimization. I managed several Detroit Edison
10	energy optimization filings as well as provided witness testimony regarding the
11	revenue requirement of several energy optimization plans and reconciliations.
12	During this time, I also assisted the case managers of general rate cases.
13	
14	I was promoted to Manager of Electric Regulatory Strategy in 2013 where my
15	responsibilities included research of regulatory matters and my team also provided
16	management of DTE Electric's general rate cases.
17	
18	I was promoted to Director within Regulatory Affairs in 2016. In this role, I was
19	responsible for managing the Company's activities at the Michigan Public Service
20	Commission (MPSC or Commission) and at the Federal Energy Regulatory
21	Commission (FERC). Members of my team that work on State activities provided
22	case management for some of the Company's compliance filings, research
23	activities pertinent to our electric utility, and coordinated activities related to the
24	state's 2016 energy legislation.
25	

1	Q5.	What are yo	ur current duties and responsibilities?
2	A5.	I remain a	Director within DTE Energy's Regulatory Affairs Department.
3		Currently, in	this role, my team is responsible for managing the Company's state
4		filings and a	activities at the Michigan Public Service Commission (MPSC or
5		Commission). Members of my team also provide various research activities
6		pertinent to o	ur electric utility and provide cost of service and revenue requirement
7		modeling.	
8			
9	Q6.	Have you pr	eviously sponsored testimony before the Michigan Public Service
10		Commission	(MPSC or Commission)?
11	A6.	Yes. I spons	ored testimony in the following DTE Electric cases:
12		U-15806	Detroit Edison's Energy Optimization (EO) Plan
13		U-15806 A	Detroit Edison's EO Amended Plan
14		U-16358	Detroit Edison's 2009 EO Reconciliation
15		U-16359	Detroit Edison's 2010 EO Reconciliation
16		U-16737	Detroit Edison's 2011 EO Reconciliation
17		U-20561	DTE Electric 2019 Rate Case
18		U-18232	DTE Electric 2020 Renewable Energy Plan (REP) Amendment
19		U-18091	DTE Electric 2021 PURPA Avoided Costs
20		U-20836	DTE Electric 2022 Rate Case
21		U-21193	DTE Electric 2022 Integrated Resource Plan (IRP)
22		U-21297	DTE Electric 2023 Rate Case
23		U-18091	DTE Electric 2024 PURPA Avoided Costs

1 **Purpose of Testimony**

Line

No.

2	Q7.	What is the purpose of your testimony in this proceeding?
3	A7.	The purpose of my testimony is to:
4		• Provide an overview of the Company's entire general electric rate case
5		including a summary of the drivers for filing this case at this time, and the
6		amount of the Company's projected revenue deficiency starting January 1,
7		2025;
8		• Review the overall methodology used to develop the Company's projected
9		test year amounts in this case;
10		• Address the following ratemaking and policy; propose unique or different
11		ratemaking treatments; respond to prior Commission orders; highlight
12		noteworthy regulatory issues; or address topics of interest expressed by
13		stakeholders:
14		\circ The Company's future securitization of costs associated with the
15		Company's tree trimming surge;
16		• Recovery of certain outage credits paid to customers;
17		• Corporate memberships and costs included for ratemaking as ordered in
18		the Company's last general rate case, U-21297; and
19		• Introduce the Company's other witnesses.
20		
21	Q8.	Are you sponsoring any exhibits in this proceeding?
22	A8.	Yes. I am supporting the following exhibit:
23		Exhibit Schedule Description
24		A-27 Q1 Corporate Memberships
25		

Line <u>No.</u>		
1	Q9.	Was this exhibit prepared by you or under your direction?
2	A9.	Yes, it was.
3		
4	Case	<u>Overview</u>
5	Q10.	Can you summarize the circumstances that have led to the Company's request
6		for rate relief?
7	A10.	Yes. DTE Electric is pursuing two strategic imperatives. First, we are working to
8		rebuild, modernize, and automate our 46,000 miles of electric circuits (the "grid")
9		to achieve reliability that is better than industry average by 2029. Second, we are
10		replacing aging coal plants with modern power generation assets, such as wind
11		turbines, large scale solar arrays, and large battery installations. Both pursuits
12		represent multi-year initiatives that can only be accomplished with the support of
13		our customers, the Michigan Public Service Commission (MPSC), and the
14		investors that provide the capital needed to fund the necessary investments.
15		
16	Q11.	What benefits should the Company's customers expect to realize from these
17		initiatives?
18	A11.	The benefits to DTE Electric's customers of these strategic initiatives are:
19		• Fundamental improvements in the reliability of the grid and in its ability to
20		accommodate electric vehicles and other distributed energy resources.
21		• Reduced carbon emissions from more efficient and cleaner sources of
22		power generation.
23		
24	Q12.	What is the expected level of capital investment for grid modernization and
25		generation transformation initiatives?

Line	
<u>No.</u>	

1	A12.	Fully realizing these benefits will require significant investment - approximately \$9
2		billion of investment in the grid and \$7 billion of investment in cleaner generation
3		between 2024 and 2028. We appreciate that we are asking our customers to support
4		these investments in the form of bill increases. However, as described below, we
5		believe that these investments will generate significant benefits and value to our
6		customers.
7		
8	Q13.	Specifically, what improvements is DTE Electric expecting to achieve relative
9		to grid reliability?
10	A13.	These system investments, for which this rate case represents the next step in the
11		multi-year journey described above, can provide tremendous benefits to our
12		customers and to the state. More specifically, DTE Electric is focused on improving
13		reliability for our customers - reducing power outages by 30% and cutting outage
14		time in half in the next five years. As explained in more detail by the Company's
15		Distribution Operations (DO) witnesses in this case (i.e., Company Witnesses
16		Kryscynski, Deol, Elliott Andahazy, Hartwick, and Steudle) the Company is
17		strengthening, rebuilding, and/or using technology to create a smarter, stronger,
18		more resilient grid that will reliably deliver the energy our customers demand and
19		deserve. Our commitment can be summarized as: "30% fewer 50% faster by
20		2029."
21		
22		As can be seen in Figure 1 and Figure 2, this commitment translates to better than
23		industry median performance by 2029 for Average System Availability Index and





¹ System Average Interruption Duration Index



4 Q14. Besides the benefit of improved reliability, are there other potential benefits 5 that customers could realize from DTE Electric's grid modernization 6 initiative?

-- Industry Median

Normal weather

7 A14. Yes. These forecasted improvements will not only substantially improve DTE 8 Electric customers' qualitative experience but have the potential to unlock 9 significant economic value. The publicly available Interruption Cost Estimator 10 (ICE) Calculator, which was developed by the Lawrence Berkeley National 11 Laboratory, provides one approach to examine and estimate the potential value that 12 might be realized through improved electric system reliability. While not definitive, 13 based on the ICE Calculator the Company's forecasted reliability improvements 14 could generate more than \$15 billion of positive economic impact. Realizing such

Line <u>No.</u>		
1		estimated benefits is dependent upon achieving improved reliability through
2		continued investment in the Company's grid, enabled by timely recovery of capital
3		expenditures.
4		
5	Q15.	What benefits will customers realize due to DTE Electric's generation
6		modernization initiative?
7	A15.	DTE's planned investments in new generation assets will enable the transition to
8		cleaner generation and allow a reduction of $C0_2$ emissions of 65% by 2028 when
9		compared to the 2005 baseline, as shown in Figure 3.
10		

Figure 3. DTE Green Generation Journey



Q16. Can you summarize the Company's plans to execute on the proposed
investments?

Line	
No.	

1	A16.	The Company is fully prepared to execute our plans and have built an organization
2		that is capable of making these historic investments. We have proven our ability to
3		significantly ramp up project and program execution as evidenced by the increase
4		in electric distribution strategic capital deployment over the last few years.
5		
6		Our specific capital investments and associated plans are discussed in detail by the
7		Company's DO witnesses identified earlier, and can be summarized as follows:
8		• Maintain high performing circuits so that they remain high performing
9		circuits
10		• Fundamentally improve low performing circuits
11		• Build capacity for the future
12		
13		Figure 4 illustrates this strategy as we look at the performance of our circuits and
14		the 46,000 miles of electric lines that make up the DTE Electric grid covering 7,600
15		square miles of DTE Electric service territory.
16		





3 Q17. How will investors support these initiatives?

A17. Investors will provide the necessary capital to execute DTE Electric's planned
investments assuming reasonable recovery of costs through the Company's rates.
As shown in Figure 5, to execute its investments DTE Electric requires cash in
excess of what it generates internally from its operations (cash that includes DTE
Electric profits). As such, external investors are needed to provide the incremental
capital that enables us to execute our plans.

10

² Only circuits with at least 50 customers are shown on chart



Q18. Have there been any reliability impacts from ongoing grid modernization efforts?

A18. Yes, where investments have been made, we are seeing benefits. For example, as
 supported by Company Witness Elliott Andahazy and shown in Figure 6, the
 Company's 4.8 kV Hardening program has led to a 61% reduction in frequency of
 outages (SAIFI⁴) on hardened circuits compared to non-hardened circuits.

³ Source: DTE Electric Form 10k

⁴ System Average Interruption Frequency Index











A19. This case supports approximately \$2.6 billion of total new capital investment in
2025, the projected test year in this case, as well as additional capital in the bridge
and historical test year. The Company is also seeking approval to extend its
Distribution Infrastructure Recovery Mechanism (IRM), with associated revenues,
through 2027. As discussed previously, DTE will need additional support from
customers to execute on its capital plans and achieve the forecasted reliability
improvements. That support takes the form of the requested rate relief, which is

1driven primarily by capital investments. When combined with other factors2described in the case, the total requested test year base rate relief is approximately3\$456 million, of which \$321 million (70% of the total) is related to capital recovery4and financing (\$285 million for direct capital costs and \$36 million for the increased5cost of debt and changes in capital structure).

6

7 Q20. What is the present status of the Company initiatives you described?

8 A20. In prior years, the Company has made investments in line with its strategic plans to 9 improve reliability and provide cleaner generation, even if those investments were 10 not fully authorized for recovery in a prior rate case. Specifically, as of 2024 the 11 Company anticipates that actual net plant in-service will be approximately \$775 12 million higher than what is currently authorized for recovery in rates. Given the 13 carrying costs associated with this plant in-service balance, timely recovery of 14 prudent capital investment is necessary to support the Company continuing to make 15 the investments that are needed to improve reliability and transition to cleaner 16 generation.

17

18 With that said, and as described by Company Witness Foley, the Company 19 acknowledges the Commission's desire that, within a reasonable range of 20 flexibility, the Company make capital investments consistent with Commission 21 approvals in rate cases. To that end, in this case the Company is proposing to extend 22 its Distribution IRM through 2027 and indicating its support for an expansion of 23 the IRM in the test year (2025). Such an approach would have the dual benefits of 24 both ensuring that investments are made consistent with Commission orders and 25 supporting timely recovery of those investments.

AFC-15

- 1
- Q21. How will the Company's grid modernization and generation transformation
 initiatives impact the cost to its customers?

A21. The Company understands that with the requested rate relief it is asking its
customers to pay more to support improvements in reliability and the transition to
cleaner generation. According to the Energy Information Administration (EIA)
average bills for DTE Electric customers remained below the national average in
2023, as seen in Figure 8. Specifically, in 2023 DTE Electric's Residential Electric
Bills were 13% below the national average, and in 2022 were 11% below the
national average⁵.

11







⁵ DTE Electric 2022 Average Residential Bill: \$118.45; 2022 National Average Residential Bill: \$132.90. Source: EIA 861M

⁶ Source: EIA 861M

Line	
1	In addition to having below average bills, since 2021 DTE Electric's residential bill
2	growth has remained below the rate of inflation and below the rate of increase for
3	peers in both the Great Lakes and nationally. Rate relief as proposed by the
4	Company in this case would continue this trend. The requested test year rate relief
5	of approximately \$456M would result in an increase of 37 cents/day for the average
6	residential customer and would translate to average annual bill growth of 3.1%
7	since 2021., This is below the projected level of average inflation of 4.2% over the
8	same time. Between 2021 and 2023, Great Lakes region residential electric bill
9	growth has been 4.5% per year, and national electric bill growth has been 5.8% per
10	year.
11	
12	Rate relief of \$321M, which would cover the recovery and financing costs for the
13	capital as described above, would result in a bill CAGR over that same period of
14	2.3%. This is illustrated below in Figure 9.
15	



In summary, the rate relief sought in this case will allow DTE Electric to take another important step on its multi-year journey toward improved reliability and cleaner generation. As discussed previously, we are already realizing the reliability benefits of our grid investments where they have been made, but there is much work to be done. Approval of the requested rate relief supports the Company's plan to deliver reliability that is better than industry average by 2029 and unlock potential economic value, while also continuing the transition to cleaner generation.

11

Q22. Can you elaborate on how the requests in this general rate case filing support the Company's strategic imperatives described above?

A22. This rate case represents the Company's continued commitment to improved
reliability and innovation. The Company is seeking approval of significant

⁷ 12-month trailing average through May 2021; DTE forecasted through Jan 2025, peers actual through November 2023; inflation is actual CPI through Jan 2024 and core inflation projection from the Federal Open Markets Committee for 2024



1 infrastructure investments to improve the reliability and resilience of its electric 2 distribution system as detailed in its 2023 Distribution Grid Plan filed in Case No. 3 U-20147. This involves redesigning, hardening, and rebuilding antiquated 4 infrastructure, modernizing how the electric grid is monitored and operated, and 5 performing preventive and proactive maintenance and tree trimming at standards 6 that reflect today's operating conditions, including security risks and more extreme These investments will not only reduce how often and how long 7 weather. 8 customers experience power outages but will also enable the Company to support 9 greater optionality for customers in adopting technologies such as batteries, solar, 10 and electric vehicles (EVs).

11

12 To support innovation during this period of transformational change in the energy 13 industry, the Company is also proposing new technology deployments, including 14 enhanced information technology capabilities to reduce costs and improve the 15 customer experience; energy storage in the form of batteries; non-wires 16 alternatives; and expanded programs to support deployment of EVs. The 17 Company's generation fleet continues to evolve towards cleaner resources with 18 new renewable energy facilities and the recently approved conversion of the Belle 19 River Power Plant to a natural gas peaking resource. The Belle River Unit 1 20 conversion is scheduled for completion in 2025 while Belle River Unit 2's 21 conversion is scheduled for completion in 2026. DTE Electric has retired six of its 22 coal-fired facilities, which accounts for all of its Tier 2 coal units (Marysville, 23 Harbor Beach, Conners Creek, River Rouge, St. Clair, and Trenton Channel). In 24 addition, the Company's Integrated Resource Plan (Case No. U-21193) resolved in 25 2023 will require the development of additional renewable energy and battery

1

2

3

storage resources, while accelerating the retirement of its remaining two coal-fired facilities, Belle River and Monroe. The Company committed to all these actions prior to the State's recently passed legislation establishing a 100% clean energy standard by 2040 and as such, is well positioned for compliance.

5

4

6 Q23. Why has DTE Electric filed this general rate case at this time?

7 A23. DTE Electric strives to provide safe, reliable, and affordable electric service to its 8 customers. In pursuit of these objectives, DTE Electric seeks to deliver reasonable 9 and appropriate compensatory returns to DTE Energy shareholders while 10 maintaining the Company's financial health. As discussed above, DTE Electric has 11 undertaken a major capital investment program to improve reliability and 12 resilience, most notably for the distribution system and is also moving toward 13 cleaner sources of generation. However, the Company's existing rates and 14 projected electricity sales cannot sustain this level of infrastructure investment 15 without a rate increase. The level of investments undertaken by the Company since 16 2022 and projected to be spent through the projected test year in this case requires 17 the Company to make this filing. The only way that DTE Electric can adequately 18 provide the required service levels that our customers desire and deserve is by being 19 financially healthy. The Company's current authorized rates are not expected to 20 provide DTE Electric with adequate revenues to make necessary infrastructure 21 investments while providing a reasonable opportunity to earn a fair return on equity 22 beginning in January 2025.

23

24 Q24. What are the measures used to determine the Company's financial health?

Line
No.

1	A24.	Maintaining DTE Electric's financial health requires that the Company has a
2		reasonable opportunity to earn its cost of capital, that the Company has a well-
3		balanced capitalization (no less than 50% equity to total permanent capitalization),
4		and that the Company is able to maintain its A/Aa3/A+ credit ratings for senior
5		secured debt from the three major rating agencies. These preconditions are
6		necessary to ensure DTE Electric has full access to capital markets at reasonable
7		rates, terms, and conditions regardless of business cycle timing or industry
8		conditions. As discussed by Company Witness Lepczyk, without full access to
9		capital markets at reasonable terms and conditions, the cost of providing utility
10		services can increase significantly.

12 Q25. Why is the Company's financial health important for customers?

13 A25. To attract the capital necessary for the prudent operation and maintenance of its 14 facilities, the Company must be able to demonstrate its ongoing financial health. 15 Inadequate rates will ultimately result in higher financing costs and have a 16 significant negative impact on the ability to adequately serve our customers and 17 maintain the integrity of the Company's electric distribution and generation assets. 18 This negative impact will occur because greater expenditures would be required to 19 support financing costs, and therefore, would not be available for system 20 maintenance or customer service. Similarly, inadequate funding for capital and 21 maintenance programs, over time, would result in the deterioration of DTE 22 Electric's generation and distribution infrastructure, ultimately resulting in reduced 23 system reliability and service quality.

1		Thus, it is essential to DTE Electric's financial health that the ultimate cost that
2		customers are asked to pay for the Company's services generate sufficient cash
3		flow from operations to fund the necessary capital expenditures to maintain and
4		improve service as well as pay a reasonable dividend.
5		
6	Q26.	Does DTE Electric's continued implementation of infrastructure maintenance
7		and investment programs provide additional benefits to customers and the
8		region?
9	A26.	Yes. DTE Electric has an important positive economic impact on the communities
10		it serves. DTE Electric is one of the largest employers in Southeast Michigan with
11		over 4,800 employees. Through the Pure Michigan Business Connect campaign,
12		the Company utilizes the services of numerous local contractors and vendors. DTE
13		Energy spent over \$2.5 billion with Michigan based companies in 2023. Through
14		property taxes, DTE Electric contributes to the financial health of local
15		communities. In the historical test year, DTE Electric paid approximately \$280
16		million in property taxes to Michigan communities. To maintain facilities, comply
17		with various regulations, implement its Distribution Grid Plan, and continue the
18		transformation of its generation fleet, DTE Electric continues to make major capital
19		investments in the communities in which it operates. Thus, DTE Electric supports
20		additional job growth opportunities and provides continuing and incremental tax
21		revenue for our local communities.
22		
23	Q27.	Does DTE Electric provide assistance to customers who have trouble paying
24		their utility bill or provide opportunities to customers needing assistance to
25		participate in some of the Company's offerings?

participate in some of the Company's offerings?

Line	
No.	

1	A27.	Yes. The Company has programs to help customers who are having trouble paying
2		their utility bill as well as offerings that help low-income customers participate in
3		some of the Company's other programs. For example, DTE Electric works to help
4		customers maintain service and reduce arrears and also offers residential income
5		assistance (RIA) and low-income assistance (LIA) credits to help vulnerable
6		customers manage utility bills. These are discussed by Witness Sparks along with
7		details regarding a percentage of income payment plan pilot the Company launched
8		in 2022. Additionally, Witness Bennett discusses our electric vehicle program
9		which will help income qualified customers. Lastly, any customer taking service
10		under the Company's MIGreenPower (Rider 17) tariff, as well as any other
11		interested parties, can support a low-income donation pilot on a monthly basis or
12		as a one-time contribution. These voluntary contributions provide fully subsidized
13		subscriptions to low-income customers who are eligible to participate.

15 Requested Relief

Q28. What rate relief was approved in the Commission's Order in the Company's last general rate case, Case No. U-21297?

A28. The Company's last general rate case, Case No. U-21297, was filed in February
2023 requesting \$618.5 million in rate relief. This deficiency assumed that the
Company's proposed IRM would be approved. In the Commission's December 1,
2023 Order, DTE Electric received approval for \$368 million in rate relief and
approval to establish an IRM.

23

24 Q29. What rate relief is DTE Electric requesting in this case?

Line	
No.	

1	A29.	As calculated by Company Witness Vangilder, DTE Electric expects a revenue
2		shortfall of \$456.4 million for the January 1, 2025 through December 31, 2025
3		projected test year. As supported by various Company witnesses, factors
4		contributing to this shortfall are the revenue requirement associated with increased
5		investments made in plant and the associated depreciation and property tax
6		increases as well as the impact of inflation on DTE Electric's O&M and borrowing
7		costs.
8		
9	Q30.	Can you highlight some of the major investments and expenses included in the
10		Company's request for rate relief?
11	A30.	This general rate case sets forth the rationale, spending, timing, and expected
12		customer benefits associated with significant investments in distribution,
13		generation, and customer service. Several programs to highlight are summarized
14		below.
15		• Strategic infrastructure investments in substations, poles, wires,
16		transformers and other electric distribution assets to modernize equipment,
17		support growth in customer demand in specific areas, improve worker and
18		public safety, and reduce the frequency and duration of power outages. This
19		also includes plans to accelerate the conversion of the 4.8 kV system to a
20		higher voltage, ramping up the pole top maintenance program, and
21		increased investment in distribution automation and telecommunications
22		technologies.
23		• Continuation of the multi-year tree trimming "surge" program that reduces
24		outages on circuits trimmed to the new, more protective standard. The
25		continuation of the Commission-approved tree trimming program will

AFC-24

Line	
<u>No.</u>	

1		allow the Company to complete the surge, which is expected in 2025. This
2		program remains critical to improving reliability and resilience across the
3		system and is foundational to the Company's overall efforts to improve
4		reliability.
5		• Conversion of Belle River Power Plant's fuel source from coal to natural
6		gas, consistent with the IRP Order in Case No. U-21193, which included
7		preapproval of the Belle River Fuel Conversion project.
8		• Plant removal associated with the retirement and decommissioning of
9		power generation assets at Harbor Beach, Conners Creek, River Rouge, St.
10		Clair, and Trenton Channel Power Plants. With the Company's final Tier
11		2 plants having been retired in 2022, DTE Electric is committed to the
12		removal of these retired steam generating units. The process involves three
13		primary activities, namely decommissioning, decontamination, and
14		demolition. Witness Guillaumin addresses this project in detail in her
15		testimony.
16		
17	Q31.	What investments is the Company making to promote greater levels of
18		advanced technology and customer satisfaction?
19	A31.	The Company is working to deploy advanced technologies in all areas of its
20		business as well as furthering its commitment to deploy proven technology to
21		improve our customers' experience with DTE Electric's services. Examples are
22		briefly described below:
23		• Energy storage projects proposed for the Energy Supply portfolio include
24		two grid-scale battery applications. One is the continuation of the 14 MW
25		Slocum battery pilot project slated to replace retiring peaking generation

AFC-25

Line
No.

located in Trenton, Michigan. The other project, also located in the City of
 Trenton, is a 220 MW battery that is consistent with the build plan included
 in the Company's 2022 IRP planned course of action. This project will be
 located at the site of the recently retired Trenton Channel Power Plant.
 Witness Guillaumin addresses this project in detail in her testimony.

- Distribution Operations also continues to evaluate different use cases for
 energy storage. Examples include the use of batteries to help relieve certain
 substation overloads and a battery trailer which can be sited in place of
 traditional portable generators. Witness Hartwick addresses these projects
 in detail in her testimony.
- As outlined in the Company's information technology (IT) plans, the
 customer IT portfolio of investments prioritizes the enhancement of
 customer experiences and increased operational efficiencies. Witness
 Hatsios addresses these customer service IT plans in detail in his testimony.
- 15

16 Rate Case Methodology

Q32. Can you describe the methodology the Company is using to support its projected test year positions and its recommendations in this case?

19 A32. Yes. DTE Electric has used actual historical data as the point of departure for most 20 estimated cost levels for the projected test year. These historical costs were then 21 adjusted for the impact of inflation. As has been DTE Electric's practice in prior 22 rate cases, certain other costs reflect specific estimates or projections where general 23 impacts of inflation alone would be insufficient to capture known changes. For 24 example, some of these include, but are not limited to, capital expenditures for new

Line <u>No.</u>		
1		plant and uncollectible expense. All these cost components and the circumstances
2		involved are explained and supported by other Company witnesses.
3		
4	Q33.	What historical and projected test year periods are being used by DTE Electric
5		for purposes of calculating its projected revenue deficiency?
6	A33.	The historical test year used by DTE Electric is the calendar year ended December
7		31, 2022. This 12-month period was then normalized and adjusted for known and
8		measurable changes, as supported by the Company's witnesses in this case, to
9		arrive at the Company's January 1, 2025 through December 31, 2025 projected test
10		year. As this case is being filed in early 2024, the Company has included 10 months
11		(January – October) of actual capital investments in the 2023 bridge period.
12		
13	Q34.	Are there any new recovery mechanisms being requested in this rate case?
14	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new
14 15	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration
14 15 16	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company.
14 15 16 17	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company.
14 15 16 17 18	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an
14 15 16 17 18 19	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case
14 15 16 17 18 19 20	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case No. U-21297, the Company requested a roughly three-year IRM starting concurrent
14 15 16 17 18 19 20 21	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case No. U-21297, the Company requested a roughly three-year IRM starting concurrent with the forward test year in that case (December 1, 2023) and extending through
 14 15 16 17 18 19 20 21 22 	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case No. U-21297, the Company requested a roughly three-year IRM starting concurrent with the forward test year in that case (December 1, 2023) and extending through calendar year 2026. The Commission approved the first two years (December 1,
 14 15 16 17 18 19 20 21 22 23 	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case No. U-21297, the Company requested a roughly three-year IRM starting concurrent with the forward test year in that case (December 1, 2023) and extending through calendar year 2026. The Commission approved the first two years (December 1, 2023 through December 31, 2025) of the proposed IRM but not the last (calendar
 14 15 16 17 18 19 20 21 22 23 24 	A34.	Yes. Through the testimony of Witness Foley, the Company is requesting a new storm restoration O&M cost sharing mechanism to better align storm restoration O&M cost recovery with the actual costs incurred by the Company. Through the testimony of Witness Foley, the Company is also proposing an extension of the IRM approved by the Commission in Case No. U-21297. In Case No. U-21297, the Company requested a roughly three-year IRM starting concurrent with the forward test year in that case (December 1, 2023) and extending through calendar year 2026. The Commission approved the first two years (December 1, 2023 through December 31, 2025) of the proposed IRM but not the last (calendar year 2026). The Company is requesting the IRM be extended to cover calendar

Line <u>No.</u>		
1		expansion of the IRM in 2025 if the Commission finds it appropriate to do so as a
2		way to grow the stakeholder benefits realized through the IRM.
3		
4	Tree 7	Trimming Surge
5	Q35.	Has the Commission previously approved tree trim "surge" funding in the
6		Company's recent rate cases?
7	A35.	Yes. In the Company's last four general electric rate cases (Case No. U-20162,
8		Case No. U-20561, Case No. U-20836, and Case No. U-21297), the Commission
9		approved the deferral of "surge" amounts for the Company's tree trimming
10		program. These "surge" amounts represent an increase in annual funding above the
11		baseline tree trimming O&M and have been supporting the Company's goal of
12		achieving a five-year trim cycle for its distribution system.
13		
14		The Commission approved \$43.7 million in surge funding for calendar year 2025
15		in the Company's most recent general rate case, U-21297. As discussed in detail
16		by Company Witness Ms. Steudle, this "surge" in tree trimming spending was
17		established to occur over an approximately seven-year period ($2019 - 2025$). At
18		the program's termination, the Company expects to maintain all circuits on-cycle
19		to the enhanced tree trimming specification, as discussed by Witness Steudle.
20		
21	Q36.	Is the Company requesting that the Commission approve incremental funding
22		for the 2025 surge?
23	A36.	Yes. The program remains on track to be completed in the seven years originally
24		contemplated but as detailed and supported by Witness Steudle, the Company has
25		identified a funding gap to complete the surge in 2025 and maintain on-cycle miles

Line	
<u>No.</u>	

1		at the intended 5-year cycle. As such, the Company is requesting an incremental
2		\$87 million be approved for the 2025 surge deferral. To complete the tree trim
3		surge program, the Company is requesting that the Commission approve a total
4		surge funding deferral of \$131 million for calendar year 2025. Witness Steudle
5		provides a detailed explanation of the funding gaps and the proposal to complete
6		the surge and maintain on-cycle miles.
7		
8	Q37.	What other parameters did the Commission specify related to the deferral of
9		the tree trimming surge amounts in previous orders?
10	A37.	In the Case U-20162 May 2, 2019 Order, the Commission specified that the return
11		earned on the tree trim surge regulatory asset deferrals would accrue at the short-
12		term debt rate. Lastly, the Commission stated that the Company may seek recovery
13		of the regulatory asset in a future rate case or through securitization.
14		
15	Q38.	Has the Company sought the securitization of any of the previously deferred
16		tree trimming assets yet?
17	A38.	Yes. In Case No. U-21015, the Company requested securitization of \$116.2 million
18		of its tree trim deferred asset balance through June 30, 2021. The requested amount
19		represented the total qualified assets of \$156.9 million (\$43.3 million in 2019, \$74.1
20		million in 2020, and \$38.3 million through June 30, 2021, plus interest of \$1.2
21		million) net of deferred federal income tax charges (DFIT) of \$40.6 million. The
22		Commission approved the securitization of and recovery up to the total qualified
23		costs for the tree trim deferred asset of \$156.9 million inclusive of DFIT and the
24		Company has securitized that expense.
25		

AFC-29

Q39. How has the Company treated the tree trim surge regulatory asset in this general rate case filing?

3 The Company has included a "return on" the tree trim surge regulatory asset at the A39. 4 cost of permanent capital (i.e., long-term debt and equity) included in this case. 5 Witness Lepczyk discusses why the Company believes the return on should be 6 comprised of both permanent debt and equity. The Commission's Order in the Case 7 No. U-21015 securitization filing required the proceeds from the securitization be 8 used to retire both permanent debt and equity for the tree trim surge regulatory 9 asset. Consistent with that determination, the Company should be allowed to 10 recover its actual financing cost in a commensurate manner. The revenue 11 requirement for the deferred amount is calculated by Company Witness Vangilder 12 on Exhibit A-11, Schedule A1.1 using debt and equity costs supported in this case 13 by Witness Lepczyk.

14

Q40. When does the Company anticipate making its next securitization filing for the tree trim surge regulatory asset?

17 A40. Previously, the Company proposed securitizing balances once they reach 18 approximately \$150 million. Current projections show the Company will reach this 19 cumulative balance in 2025, the proposed last year of the surge program. However, 20 since the upfront costs associated with securitization bonds are sizable and largely 21 fixed, the Company intends to wait until the projected 2025 surge completion 22 before making its next securitization filing. The larger deferred balance will more 23 efficiently spread the fixed costs and reduce overall securitization costs to 24 customers. Although a securitization filing capturing costs through early 2025 is 25 technically feasible in 2025, the Company also needs to consider the size of the

Line	
<u>No.</u>	

1		anticipated surge amounts through the remainder of the surge scheduled to end late
2		in 2025. Given the fixed costs of securitizing and the time between reaching a \$150
3		million balance and the conclusion of the program, DTE Electric is planning to file
4		a final tree trim related securitization after the surge program concludes in 2025,
5		capturing all expenditures not previously securitized.
6		
7	<u>Outag</u>	ge Credit Recovery
8	Q41.	Is the Company currently recovering the costs of any credits paid to customers
9		for outages?
10	A41.	No. In the last two general rate cases, the Company has not included any expenses
11		for the cost of credits it has paid to customers for outages.
12		
13	Q42.	Did DTE Electric propose a framework for the future inclusion of these costs
14		in either of its last two general rate cases?
15	A42.	Yes. In Case U-20836, the Company proposed that those credits paid for outages
16		caused by events outside DTE Electric's control be deferred for subsequent
17		recovery starting with the final order in that case. On page 366 of the order in that
18		case, the Commission directed:
19		DTE Electric to work with the Staff toward the full development of the
20		Staff's proposed limited recovery of outage credits. The Commission
21		upholds the company's responsibility to timely restore electric service to
22		customers in all circumstances under the Commission's Service Quality and
23		Reliability Standards for Electric Distribution Systems (Mich Admin Code,
24		R 460.701-752) and customers' entitlement to an outage credit on their
25		power bill in circumstances where the company fails to do so. However, it

1		is reasonable that the company have the ability to recover outage credits
2		when the outage was caused by customer negligence or the transmission
3		system operator, among other limited circumstances as developed in
4		collaboration with the Staff.
5		
6	Q43.	Did the Company and Staff meet to discuss outage credit cause codes and
7		Company recoverability?
8	A43.	Yes. Prior to the filing of this case, the Company and Staff discussed outage cause
9		codes as well as the reasonableness of recoverability for credits paid as a result of
10		outages that exceed the outage duration limits and those outages exceeding the
11		outage frequency limits outlined in the Commission's Service Quality and
12		Reliability Standards (rules R460.744 and R460.745 respectively).
13		
14	Q44.	What is the Company's position regarding the outage causes that should have
15		their related credits recovered by the Company?
16	A44.	The Company's position is that recoverability of the credits paid for outages differs
17		based on which of the two broad categories of outages triggers the payment: 1)
18		duration limit or 2) frequency limit.
19		
20		DTE Electric believes that credits paid for outages that exceed the duration limit
21		should include the following outage causes:
22		• Transmission operator or other utility
23		• Public interference
24		Animal interference
25		

<u>No.</u>		
1		The Company also believes that for credits paid to customers for exceedance of the
2		outage frequency limits, that recoverability would include the following outage
3		causes in addition to the two above:
4		• Ice
5		• Lightening
6		• Wind
7		• Other weather
8		
9	Q45.	What is the rationale for including weather related events for recoverability
10		when there is an exceedance of outage frequency limits but not recommending
11		the same for exceedances of the duration limit?
12	A45.	The rationale is that the Company controls the restoration time when there is a
13		weather event but not the frequency with which weather events occur.
14		
15	Q46.	How is the Company proposing to recover the expense for credits related to
16		those outage causes approved by the Commission for recovery?
17	A46.	The Company's proposed recovery treatment of outage credit costs is consistent
18		with its original proposal in Case No. U-20836. With the Commission's approval
19		of the underlying outage causes that result in recoverable credits, the Company will
20		defer the costs related to those credits starting after an order in the instant case. The
21		deferred amounts would be reviewed for reasonableness and prudency in the
22		subsequent general electric rate case. Only after the deferred amounts are approved
23		would the Company begin amortizing and recovering them. Witness Uzenski
24		describes the deferral mechanism including the amortization period in her
25		testimony.

Line

AFC-33

1

2

3

Q47. Does the Company have a proposal for how recoverable credits related to frequent outages would be calculated?

4 A47. The Company would like to spend more time with Staff to design a methodology 5 for the recovery of these credits but has an initial proposal. If a customer meets the 6 criteria for the outage credit based on outage frequency, there will likely be a mix 7 of underlying causes. Though mathematically simple to determine the percentage 8 of the outage credit that is recoverable, it will be expensive and complicated to 9 implement an algorithm into the billing system to calculate a unique percentage to 10 apply to each \$38 credit that is being deferred for recovery. The Company 11 proposes that a common percentage be applied to all outage credits paid for outage 12 frequency exceedances that reflects some analytics from the previous year. In this 13 way, a simple and consistent factor can be applied to each outage credit paid for 14 frequency exceedances, avoiding the need for complicated and costly system 15 programming.

16

17 It would be less costly to analyze the prior year's data and apply a common 18 percentage than to analyze each payment real-time and apply a unique factor. The 19 Company would like to work with Staff to develop a methodology that is reasonable 20 and able to be implemented without billing system complexities.

21

22 Corporate Memberships

Q48. How does the Company determine which corporate memberships to acquire?
A48. The Company acquires and maintains corporate memberships that help in its
mission to provide safe, affordable, clean and reliable energy. Decisions regarding

Line	
<u>No.</u>	

1		which memberships to obtain are typically made by individual business units. A
2		list of the corporate memberships included in DTE Electric's O&M expense are
3		shown on Exhibit A-27, Schedule Q1. As shown in this exhibit, each membership
4		generally falls under the auspices of one business unit.
5		
6	Q49.	Has the Commission provided guidance on how the Company should support
7		its Corporate Memberships in this and future rate cases?
8	A49.	Yes. In its November 18, 2022 Order in Case No. U-20836 on page 306, the
9		Commission directs the Company as follows:
10		"The Commission directs DTE Electric to file in its future rate cases an
11		exhibit containing an itemized list of projected costs associated with
12		membership fees and justification for why these costs are in customers'
13		interest."
14		Further, in its December 1, 2023 Order in Case No. U-21297, on page 221, the
15		Commission directs the Company as follows:
16		"Therefore, to ensure continued recovery of these corporate membership
17		fees, DTE Electric shall provide in its next general rate case a detailed
18		description of how these organizations specifically impact/benefit
19		customers as outlined by the DAAOs, which will convey DTE Electric's
20		roles and responsibilities in advancing ratepayer interests through its
21		participation in each organization."
22		
23	Q50.	Has the Company itemized the projected costs associated with membership
24		fees and included justifications for why these costs are in customers' best
25		interest?
Line		
------	--	
No.		

1	A50.	Yes. Exhibit A-27, Schedule Q1 includes the customer benefits and cost for each
2		membership included in the Company's projected test year. The exhibit is seven
3		pages with pages 1 - 2 displaying, in alphabetical order, the corporate memberships
4		which are nondiscretionary. Pages $3 - 7$ display, in alphabetical order, those
5		memberships which are discretionary. The descriptions include the specific benefit
6		these memberships offer. Additionally, corporate memberships which are
7		discretionary and exceed \$100,000 are further supported by other witnesses in the
8		case representing the primary business unit that utilizes the membership. Exhibit
9		A-27, Schedule Q1 columns (d) and (e) provides the witness names along with their
10		associated business unit for those customer and membership benefits.
11		
12	Q51.	Do any of the membership costs included in the Company's revenue
13		requirement in this case involve lobbying activities?
14	A51.	No. Any memberships, or portions of memberships, related to lobbying activities
15		are excluded from DTE Electric's revenue requirement. Witness Uzenski supports
16		how certain memberships and their related costs have been excluded. As mentioned
17		above the costs shown on Exhibit A-27 Schedule Q1 represent the costs that are
18		proposed for inclusion in rates, exclusive of lobbying fees. The amounts have not
19		been adjusted for inflation on Exhibit A-27 Schedule Q1 but are included in the
20		Company's revenue requirement with an inflation adjustment.
21		
22	Q52.	What benefits are realized from DTE Electric's memberships in the
23		organizations listed on Exhibit A-27, Schedule Q1?
24	A52.	In addition to the benefits included in each membership's description and
24 25	A52.	In addition to the benefits included in each membership's description and supporting witnesses' testimony (reference column e of Exhibit A-27, Schedule Q1

AFC-36

<u>No.</u>		
1		pages 2 -7), the benefits the Company and its customers receive from the
2		memberships listed in Exhibit A-27, Schedule Q1 pages 2 through 7 generally fit
3		into one or more of the following broad categories:
4		• Benchmarking - helps the Company understand how its performance and
5		practices compare to its peers,
6		• Best practices - provides insights into industry best practices and potential
7		opportunities for implementation based on those insights,
8		• Research – provides access to research that the Company would otherwise
9		have to perform on its own, and leads to access to information at a lower
10		cost than if each member organization performed the research on their own,
11		• Networking – helps build relationships with peers that improves the flow of
12		communication between people and companies leading to a greater
13		awareness of industry trends, emerging technologies, emerging issues, and
14		resources.
15		
16	Q53.	Are you providing additional support for any of the corporate memberships
17		requested for recovery?
18	A53.	Yes. As noted above, Exhibit A-27, Schedule Q1 lists the supporting witness for
19		non-discretionary memberships over \$100,000. The one membership that I am
20		supporting is the Edison Electric Institute (EEI).
21		
22		In addition to our operating groups (e.g., Distribution, Generation), the Company
23		leverages EEI to the benefit of its customers through many of the Company's
24		workstreams (e.g., IT, Supply Chain) as outlined below. EEI members are afforded
25		the opportunity to establish connections with other companies through the EEI

Line

Line <u>No.</u>		
1		network. Some examples of how the Company's EEI participation benefits
2		customers include:
3		• Mutual assistance coordination across the nation which enables DTE
4		Electric to quickly secure resources for storm restoration. The industry has
5		no other mutual assistance structure;
6		• Information on technology industry security initiatives and best practices;
7		• Assistance identifying and networking with diverse suppliers specific to the
8		utility industry as well as sharing best practices regarding supplier diversity;
9		• Benchmarking on utility-driven economic development;
10		• Knowledge building regarding FERC Order 2222 (addressing Distributed
11		Energy Resource participation in electricity markets) and its implications
12		for utility system preparation and operation;
13		• Best practice sharing from transportation electrification programs around
14		the nation; and
15		• Learning from industry experts and leaders on important topical subjects
16		such as battery operations and risk mitigation, decarbonization, and non-
17		wire alternatives.
18		
19	<u>Introc</u>	luction of Other Witnesses
20	Q54.	How will the Company present evidence in support of its requested relief in
21		this case?
22	A54.	The Company will present its case through 28 witnesses, including myself, as
23		described below (in alphabetical order).
24		1) Mr. Robert A. Bellini, Manager – Community Lighting, supports the energy
25		forecast for outdoor lighting; the development of the proposed rate design

Line
No.

1		for the outdoor lighting rate schedules (municipal lighting and other) as well
2		as supports the reasonableness of the historic and projected Community
3		Lighting O&M and the Community Lighting capital expenditures. He also
4		discusses the preventative maintenance programs and outage restoration
5		activities for community lighting.
6		
7	2)	Ms. Pina Bennett, Director - Electric Marketing supports the expenditure
8		status for existing Charging Forward programs and pilots and discusses the
9		Transportation Electrification Plan. She also supports Merchant Fees
10		expense and certain expenditures related to the 2023 full time-of-day roll
11		out; and the Electric Regulated Marketing O&M expense.
12		
13	3)	Mr. Shawn D. Burgdorf, Manager of the Power Supply Strategy &
14		Modeling - Generation Optimization, establishes the projected wholesale
15		market energy sales revenue net of fuel.
16		
17	4)	Mr. Michael S. Cooper, Director - Compensation, Benefits & Wellness,
18		presents an overview of benefit expense for DTE Electric for the 2022
19		historical test period and the January 1, 2025 through December 31, 2025
20		projected test period. He supports the Company's pension costs, other post-
21		employment benefits (OPEB) costs, active employee health care and other
22		employee benefits costs; supports labor cost escalation assumptions
23		assumed in the projected period; provides an overview of the Company's
24		compensation philosophy for non-represented employees and the role that
25		the Company's incentive plans play in the overall reasonableness of its total

Line
<u>No.</u>

1	compensation; provides an analysis of the reasonableness of the current
2	total compensation levels; describes the components of the Company's
3	short and long-term incentive plans and supports the inclusion of such costs
4	in the Company's revenue requirement, exclusive of the costs related to
5	DTE Energy's top five executives. In addition, Witness Cooper
6	demonstrates that the quantifiable customer benefits of the Company's
7	incentive plans exceed the expense, as required by the Commission's
8	traditionally mandated cost/benefit analysis of incentive compensation
9	expense.
10	
11 5)	Mr. Jeffery C. Davis, Expert - Nuclear Strategic Business Operations,
12	supports the Company's actual nuclear O&M and capital expenditures for
13	the 12-month historical test period ended December 31, 2022. He also
14	discusses and supports the reasonableness of the projected nuclear O&M
15	and capital expenditures for the interim forecast period and the 12-month
16	projected test period ending December 31, 2025. In addition, he supports
17	the reasonableness of the projected Nuclear Surcharge for the projected test
18	period ending December 31, 2025.
19	
20 6)	Mr. Satvir Deol, Director – Substation Operations, supports, as reasonable
21	and prudent, the historical capital expenditures for 2022 and projected
22	capital expenditures for 2023 through December 31, 2025, in the
23	distribution strategic investment category of Infrastructure Redesign and
24	Modernization and discusses programs associated with the Company's IRM
25	discussed by Company Witness Foley.

1

1		
2	7)	Ms. Morgan Elliott Andahazy, Director – Project Management
3		Organization, supports, as reasonable and prudent, the historical capital
4		expenditures for 2022 and projected capital expenditures for 2023 to
5		December 31, 2025, in the distribution strategic category of Infrastructure
6		Resilience and Hardening. In addition, her testimony will include support
7		for specific programs included in the IRM proposed by Company Witness
8		Foley.
9		
10	8)	Mr. Keegan Farrell, Manager - Demand Response (DR), discusses the
11		development of DR efforts that DTE Electric is conducting and provides
12		support for the expenditures and activities associated with the continuation
13		of existing programs and pilots, as well as the Company's proposals for new
14		pilots. He also discusses the DTE Insight Program and projected capital
15		expenditures.
16		
17	9)	Mr. Neal T. Foley, Director - Regulatory Affairs, describes the key
18		components of the Company's proposal in this case for the scope and
19		duration of IRM He also supports a proposal to establish a Storm
20		Restoration Cost Sharing Mechanism.
21		
22	10)	Ms. Margaret E. Guillaumin, Plant Director, Energy Supply Operations
23		Performance, supports the reasonableness and prudency of the O&M and
24		capital expenditures for Energy Supply steam power generation, hydraulic
25		power generation (Ludington), and other power generation for the historical

Line	
<u>No.</u>	

1		test year ended December 31, 2022, the 24-month bridge period ending
2		December 31, 2024, and the 12-month projected test period ending
3		December 31, 2025. She provides a review of the Fossil Generation base
4		coal unit availability performance for five years prior and five years
5		following the projected test year in this instant case. She also discusses how
6		the Environmental Protection Agency's Steam Electric Effluent Limitation
7		Guidelines Rule affects required coal-fired generation investment and
8		supports the historical 2022 level of capital expenditures on a plant level
9		basis and the forecast of capital expenditures planned for 2023 through
10		December 31, 2025.
11		
12	11)	Ms. Shannen M. Hartwick, Director of Automation supports, as reasonable
13		and prudent, the historical capital expenditures for 2022, the projected
14		capital expenditures for 2023 through December 31, 2025 in the distribution
15		strategic investment category of the Technology and Automation Pillar, and
16		the programs associated with the Company's IRM.
17		
18	12)	Mr. Michael J. Hatsios, Director - Customer Service Operations supports
19		the reasonableness and prudency of a subset of the capital projects in the
20		Company's Customer IT Portfolio. Specifically, he discusses the details
21		and benefits to customers of those projects that align with DTE Electric's
22		priorities to save customers money, enhance the customer experience, and
23		promote and provide energy efficiency (EE) and renewable energy
24		opportunities for customers. He also supports the Customer Service O&M
25		for the 2022 historical test year and the 2025 projected test period.

Line	
No.	

1

2	13)	Mr. Brian L. Hill, Director –Southwest Regional Customer Operations and
3		Scheduling & Coordination, supports, as reasonable and prudent, the
4		historical capital expenditures and proposed capital expenditures related to
5		base capital programs (emergent replacements, customer connections,
6		relocations, and others). In addition, he provides an explanation of the
7		Company's purchase and use of Portable Generators and an update on MISS
8		DIG (which is not a capital program or expenditure) reporting changes made
9		since Case No. U-21297.
10		
11	14)	Mr. Allen J. Kryscynski, Acting Director - Distribution Operations

Regulatory Strategy and Grid Modernization, supports the historical Operations and Maintenance (O&M) expenses related to electric distribution activities for 2022 historical period and for the projected test period 12-months ending December 31, 2025, the Distribution Operations' Global Prioritization Model, Infrastructure Investment and Jobs Act funding grants, updates the Distribution Operations approach to Environmental Justice, as well as supports several other DO related issues.

20 15) Mr. Robert J. Lee, Manager - Environmental Strategy, describes the status
21 of two significant Environmental Protection Agency regulations: the Steam
22 Electric Effluent Limitation Guidelines Rule and the Coal Combustion
23 Residuals Rule which impact the Company's coal-fired power plants.

24

19

Line
No.

1	16)	Mr. Timothy J. Lepczyk, Assistant Treasurer and Director - Corporate
2		Finance, Insurance and Development supports DTE Electric's projected
3		capital structure and the cost of its long and short-term debt to be used in
4		the determination of DTE Electric's overall rate of return in this proceeding.
5		
6	17)	Mr. Markus B. Leuker, Manager – Corporate Energy Forecasting, provides
7		the Company's current electric sales, maximum demand, and system output
8		forecast for the period 2023-2028, including the projected 12-month test
9		period January 1, 2025 through December 31, 2025. He discusses the
10		outlook for the national and local economy which is the basis of the forecast.
11		Witness Leuker also describes how the forecast of electric sales, maximum
12		demand and system output is developed and supports the reasonableness of
13		the electric sales forecast used by DTE Electric in this proceeding.
14		
15	18)	Mr. Habeeb J. Maroun, Regulatory Strategy Consultant - Revenue
16		Requirements Department, presents Unbundled Cost of Service (UCOS)
17		Studies for DTE Electric's projected test year ending December 31, 2025.
18		He also provides an Alternate Cost of Service Study (Alternate COSS) with
19		DC Fast Charging (DCFC) as a separate class, as required by the
20		Commission in its December 1, 2023 Order in Case No. U-21297. He also
21		supports revenue requirement calculations for: (1) customer-related costs,
22		(2) capacity charge by customer class, and (3) IRM by voltage class.
23		
24	19)	Mr. David C. Milo, Fuel Resource Specialist – Fuel Supply, supports DTE
25		Electric Fuel Supply's and Midwest Energy Resources Company's (MERC)

AFC-44

Line
<u>No.</u>

1		operations and maintenance expense and capital expenditures for the twelve
2		months ended December 2022 historical actual, and as projected for 2023
3		through December 31, 2025. He also addresses how the Company's
4		transition from coal generated electricity will affect MERC transshipment
5		operations and the railcar fleet for the Company as well as the planned
6		retirement of operations at MERC.
7		
8	20)	Mr. Pankaj Sharma, Director – Information Officer within the Information
9		Technology Services organization, discusses the IT Capital investment
10		framework and planning process that drives prioritization of both single and
11		multi-year projects and programs; supports the Company's IT capital
12		expenditures beginning with the historic test year and extending through the
13		projected test year; and describes the variances in the actual 2022 capital
14		spend compared to the spend approved in the Company's previous general
15		rate case.
16		
17	21)	Mr. Jason E. Sparks, Director - Revenue Management and Protection
18		supports the details of the Company's Low-Income programs and provides
19		explanation and support for the uncollectible expense. He proposes changes
20		to the Rate Schedule D1.6 tariff provision. He also discusses details of our
21		Low-Income Assistance credits and their impact with the Low-Income Self
22		Sufficiency Program as well as the Payment Stability Plan pilot.
23		
24	22)	Ms. Rachel Steudle, Director of Tree Trim, discusses the importance of and
25		progress made in DTE Electric's vegetation management ("Tree

Line	
<u>No.</u>	

1		Trimming") program; provides details related to the Company's Tree
2		Trimming Surge Program that will deliver on the reliability goals
3		established in the Company's Distribution Grid Plan (DGP); and describes
4		the customer benefits of the Company's Tree Trimming Surge Program to
5		date. In addition, she supports the O&M expenses related to tree trimming
6		efforts for the historical test period ending December 31, 2022, the projected
7		base O&M expenses and the Tree Trim Regulatory Asset Surge funding
8		amount for January 1, 2025, to December 31, 2025.
9		
10	23)	Ms. Theresa Uzenski, Manager - Regulatory Accounting, supports DTE
11		Electric's financial statements for the historical test year ended December
12		31, 2022, the interim forecast period and a twelve-month projected test
13		period ending December 31, 2025, with certain adjustments necessary for
14		presenting the financial information in the appropriate format for
15		ratemaking purposes. She supports the development of the projected test
16		year adjusted electric operating income based on forecasted changes from
17		the normalized historical electric operating income. She supports that costs
18		recovered from other mechanisms are excluded from the financial
19		statements in this case (including the Renewable Energy Program, and
20		Energy Waste Reduction). She also supports the Corporate Staff Group
21		capital and O&M expenses for the historical and forecasted periods and
22		explains the function of this group including the method for allocating costs
23		to DTE Electric and other DTE Energy subsidiaries through the Shared
24		Asset charge. She also, explains the accounting treatment of the Monroe
25		regulatory asset and amortization over 15 years and requests approval of

Line	
<u>No.</u>	

1		regulatory asset and liability accounts for the Company's storm cost tracker
2		proposal supported by Witness Foley.
3		
4	24)	Mr. Kirk M. Vangilder, Principal Financial Analyst - Revenue
5		Requirements, supports DTE Electric's twelve months ended December 31,
6		2022 historical revenue sufficiency. In addition, he is sponsoring Net
7		Operating Income (NOI) adjustments for interest synchronization and
8		income tax savings, as well as the revenue conversion factor. Mr. Vangilder
9		is sponsoring DTE Electric's twelve months ending December 31, 2025
10		projected revenue deficiency. He also calculates the incremental revenue
11		requirement for DTE Electric's Tree Trim Surge Regulatory Asset and the
12		return on the Monroe Regulatory Asset. Lastly, he supports the incremental
13		revenue requirements for DTE Electric's IRM as well as the Company's
14		proposed reconciliation process should a different amount of IRM capital be
15		placed in service than what has been approved.
16		
17	25)	Dr. Bente Villadsen, Principal at The Brattle Group, supports the cost of
18		capital for the Company. Specifically, Dr. Villadsen estimates the cost of
19		equity that DTE Electric should be allowed an opportunity to earn on the
20		equity-financed portion of its regulated utility rate base. Dr. Villadsen's
21		recommendation also considers the business and financial risk of the
22		Company relative to the proxy companies to arrive at her recommendation
23		for the allowed Return on Equity for DTE Electric of 10.5%.
24		

Line <u>No.</u>			
1		26)	Mr. Aaron Willis, Manager - Regulatory Economics, discusses and
2			supports forecast allocation schedules, power supply costs, rate design, IRM
3			surcharge design, and other tariff changes.
4			
5		27)	Ms. Sherri Wisniewski, Director - Tax Operations, supports the DTE
6			Electric Federal Income Tax, Michigan Corporate Income Tax, Municipal
7			Income Tax, property tax and other general taxes for the 2022 calendar year
8			historical period as well as the twelve months projected test period ending
9			December 31, 2025.
10			
11	Q55.	Does t	this complete your direct testimony?
12	A55.	Yes, it	does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

ROBERT A. BELLINI

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF ROBERT A. BELLINI

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Robert A. Bellini (he/him/his). My business address is 8001 Haggerty,
3		Belleville, Michigan 48111. I am employed by DTE Electric Company (DTE
4		Electric or Company) as Manager of Community Lighting.
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	I graduated from Central Michigan University with a Bachelor of Science degree
11		in Business Administration in 1999. In 2005, I graduated from Oakland University,
12		with a Master of Accountancy degree.
13		
14	Q4.	What is your work experience?
15	A4.	From 2005 until 2008, I was employed by Deloitte & Touche LLP as a Financial
16		Auditor. While employed at Deloitte & Touche, I passed the Certified Public
17		Accountant (C.P.A.) examination and became a licensed C.P.A. in 2007. In 2007,
18		I was promoted to Senior Auditor on client engagements. In this role, I was
19		
		responsible for tailoring each audit based on a client's industry and the risks
20		responsible for tailoring each audit based on a client's industry and the risks inherent in their operations, supervising the audit fieldwork, and communicating
20 21		responsible for tailoring each audit based on a client's industry and the risks inherent in their operations, supervising the audit fieldwork, and communicating the audit issues and results with client management.
20 21 22		responsible for tailoring each audit based on a client's industry and the risks inherent in their operations, supervising the audit fieldwork, and communicating the audit issues and results with client management.
 20 21 22 23 		responsible for tailoring each audit based on a client's industry and the risks inherent in their operations, supervising the audit fieldwork, and communicating the audit issues and results with client management. In 2008, I joined DTE Energy as a Financial Auditor. My responsibilities included

1		Energy 10-K annual filing under the guidance of our external auditor,
2		PriceWaterhouseCoopers (PWC). In 2010, I was promoted to Senior Auditor. My
3		responsibilities included planning, scoping, and executing both financial and
4		operational audits. In 2013, I was promoted to Principal Supervisor of the Joint
5		Use department. My responsibilities included developing budgets, forecasting, and
6		negotiating joint use agreements with various attaching entities. In 2016, I was
7		promoted to Manager, Joint Use. In 2018, I was promoted to Manager, Community
8		Lighting.
9		
10	Q5.	Do you hold any certifications or are you a member of any professional
11		organizations?
12	A5.	Yes. I am a registered Certified Public Accountant (CPA).
13		
10		
14	Q6.	What are your current duties and responsibilities?
14 15	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and
14 15 16	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately
14 15 16 17	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I
14 15 16 17 18	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned
14 15 16 17 18 19	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in
14 15 16 17 18 19 20	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in accordance with DTE Electric's MPSC-approved tariffs. DTE Electric's assets
14 15 16 17 18 19 20 21	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in accordance with DTE Electric's MPSC-approved tariffs. DTE Electric's assets related to these services include mercury vapor, metal halide, high pressure sodium,
14 15 16 17 18 19 20 21 22	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in accordance with DTE Electric's MPSC-approved tariffs. DTE Electric's assets related to these services include mercury vapor, metal halide, high pressure sodium, and light-emitting diode (LED) luminaires.
14 15 16 17 18 19 20 21 22 23	Q6. A6.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in accordance with DTE Electric's MPSC-approved tariffs. DTE Electric's assets related to these services include mercury vapor, metal halide, high pressure sodium, and light-emitting diode (LED) luminaires.
14 15 16 17 18 19 20 21 22 23 24	Q6. A6. Q7.	What are your current duties and responsibilities? I am currently responsible for managing the marketing and sales, budgeting and forecasting, planning and construction and asset management for approximately 199,000 DTE Electric-owned streetlights and outdoor protective lights (OPLs). I also manage the maintenance and provision of energy to municipally owned streetlights and the provision of energy-only service to municipalities, in accordance with DTE Electric's MPSC-approved tariffs. DTE Electric's assets related to these services include mercury vapor, metal halide, high pressure sodium, and light-emitting diode (LED) luminaires.

Line No.			R. A. BELLINI U-21534		
1	A7.	Yes. I have s	sponsored testimony in the following cases:		
2		U-20561	2019 DTE Electric General Rate Case		
3		U-20836	2022 DTE Electric General Rate Case		
4		U-21297	2023 DTE Electric General Rate Case		
5					
6	<u>Purp</u>	<u>ose of Testimo</u>	ny		
7	Q8.	What is the	purpose of your testimony?		
8	A8.	The purpose	of my testimony is to support the following topics related to DTE		
9		Electric's lig	hting assets: a) cost recovery of O&M and capital expenditures, and		
10		b) rate design	n. Specifically, I will discuss the following issues:		
11		• Descr	ibe the portfolio of Community Lighting assets;		
12		• Suppo	ort the sales forecast for the various outdoor lighting rates including		
13		auton	automated traffic signal (ATS) rates and metered street lighting rates;		
14		• Descr	ibe the Company's preventative maintenance programs;		
15		• Discu	ss the Company's outage restoration activities;		
16		• Suppo	ort and discuss the Company's actual Community Lighting O&M		
17		exper	uses for the historical period which ended December 31, 2022, and the		
18		projec	cted Community Lighting O&M expenses for the 12-month projected		
19		test p	eriod ending December 31, 2025;		
20		• Suppo	ort and discuss Community Lighting's actual capital expenditures for		
21		the h	storical period which ended December 31, 2022, and the projected		
22		Comr	nunity Lighting capital expenditures for the 12-month projected test		
23		perio	d ending December 31, 2025;		

<u>No.</u>					
1		• Discuss the r	easonableness	of DTE's LED selection methodology as it	
2		relates to HID	relates to HID to LED conversions, as well as the disallowance of LED pla		
3		costs as order	ed in Case No.	U-21297;	
4		• Discuss the	sunsetting c	of Community Lighting's installation and	
5		maintenance	of high-pressu	are sodium (HPS) technology, and proposed	
6		tariff changes	;		
7		• Discuss the st	tatus of munic	ipal streetlight outage reporting and proposed	
8		tariff changes	as ordered by	the MPSC Commission in Case No. U-21297;	
9		• Support the p	proposed rate d	lesign for the outdoor lighting (municipal and	
10		other) and AT	S tariff offerin	ngs using the lighting model.	
11					
12	Q9.	Are you sponsoring	any exhibits i	n this proceeding?	
13	A9.	Yes. I am sponsoring	in whole, or in	n part, the following exhibits:	
14		<u>Exhibit</u>	Schedule	Description	
15		A-12	B5.5	Projected Capital Expenditures – Community	
16				Lighting	
17		A-13	C5.6	Projected Operation and Maintenance	
18				Expenses – Distribution Expenses	
19		A-16	F3	Present and Proposed Revenues by Rate	
20				Schedule – 12 months ending December 31,	
21				2025	
22		A-16	F8	Proposed Tariff Sheets	
23		A-25	01	Community Lighting Outdoor Lighting	
24				Outage Duration	

Line

		R. A.]	BELLINI U-21534
Community	Lighting	Outdoor	Lighting
Outage Cost			
HPS to LED	Customer 1	Notification	n Letter
WD Calaulat		M Dicalla	1

3	A-25	O3	HPS to LED Customer Notification Letter
4	A-25	O4	WP Calculation of \$5.8M Disallowance by
5			MI-MAUI in U-21297
6	A-25	05	Don McLean DTE HID-LED Selection
7			Methodology Opinion Letter
8	A-25	06	DMD – Intersection Performance Summary
9	A-25	07	DMD – Revised Rdwy Performance
10			Summary
11	A-25	08	Don McLean_Curriculum Vitae
12	A-25	09	Gibbons – DTE Energy Response Document
13			& CV

O2

14

Line <u>No.</u>

1

2

A-25

I am sponsoring line 23 within Exhibit A-13, Schedule C5.6, page 1 of 2, and the pages specific to the residential and commercial outdoor protective lighting (OPL) and municipal classes within Exhibit A-16, Schedule F3. This includes pages 46 through 57. On Exhibit A-16, Schedule F8, I sponsor the OPL and municipal tariffs, while Company Witness Willis sponsors the tariffs for the remaining customer classes.

21

22 Q10. Were these exhibits prepared by you or under your direction?

A10. Yes, they were.

1 <u>Community Lighting Assets</u>

Q11. Could you describe the portfolio of Community Lighting assets that DTE Electric owns, operates, and maintains on behalf of its customers?

4 A11. DTE Electric owns, operates, and maintains approximately 199,000 Community 5 Lighting assets which serve municipal, commercial, and residential customers. 6 Additionally, there are approximately 82,000 streetlights which are owned by 7 municipal customers (E1 Option III), and approximately 6,400 municipal-owned 8 Automated Traffic Signals (E2). Municipal streetlights (E1 Option I and II) include 9 roadway and residential streetlights within municipal and/or city limits. These 10 streetlights owned by DTE Electric are installed at the request of the city or 11 municipality. DTE Electric also installs Outdoor Protective Lighting (OPL) for 12 commercial (D9 Commercial) and residential (D9 Residential) customers. 13 Examples of commercial OPL solutions include parking lot lighting systems (i.e. 14 restaurants or strip malls) and residential OPL solutions such as lights installed on 15 a customer's property. Ownership of Community Lighting assets is detailed in 16 Table 1 below:

17

Table 1: Community Lighting Assets¹

	Asset			
Asset Type	Ownership	Rate Type	# Of Assets	Description
Municipal OH & UG Streetlights	DTE Electric	E1 Option I	165,932	DTE Electric owned and maintained system
Municipal OH & UG Streetlights	Customer	E1 Option II	119	Municipal owned and DTE Electric maintained system
Municipal OH & UG Streetlights	Customer	E1 Option III	82,399	Municipal owned and maintained system
Commercial Outdoor Protective Lights	DTE Electric	D9	24,179	DTE Electric owned and maintained equipment
Residential Outdoor Protective Lights	DTE Electric	D9	9,147	DTE Electric owned and maintained equipment
Municipal Automated Traffic Signals (ATS)	Customer	E2	6,436	Municipal owned and maintained equipment

¹ Light counts as of November 1st, 2023

1 Q12. Briefly describe the various lighting technologies in service and the movement 2 toward more energy-efficient Company-owned LED lighting technology. 3 A12. There are 4 lighting types currently in use within DTE Electric's service territory: 4 Light Emitting Diode (LED), High Pressure Sodium (HPS), Metal Halide (MH), 5 and Mercury Vapor (MV), the first three of which are still actively maintained and 6 installed upon request. LED lighting is the most energy efficient lighting type 7 available, while the remaining light types are less efficient in terms of energy 8 consumption (MV is the least efficient of the 4 light types). 9 10 Pursuant to the Energy Policy Act of 2005, Mercury Vapor lamps became obsolete 11 due to their inefficient use of energy and inclusion of mercury as a component, and 12 effective January 2008, were banned from production in the United States. At the 13 end of 2007, MV's comprised almost 52% of DTE Electric's company owned 14 lighting assets, and the balance consisted primarily of HPS lighting (a nominal 15 number of lights were MH at the time). DTE Electric began to convert failed MV 16 lighting to LED for E1 Option I customers starting in 2017 in accordance with the 17 Commission's order on January 31, 2017, in Case No. U-18014. 18

19 The Company has worked closely with its municipal partners, commercial and 20 residential customers over the past decade as they transition to LEDs as a preferred 21 lighting technology. In 2022, the Southeast Michigan Council of Governments 22 (SEMCOG) made available grant funding for several types of carbon reduction 23 initiatives, which included municipal lighting conversions to LEDs. DTE made 24 aware and assisted several communities to complete their applications. In 2023, 25 almost \$3.4M in grant funds were awarded to several DTE municipal customers to help fund HID to LED conversion projects totaling approximately 11,000 lights
 anticipated between 2024 – 2025. Table 2 below provides a snapshot of the changes
 over time in DTE Electric's company owned lights, from 2012 to 2023:

4

Line

No.

Table 2:	Community	Lighting .	Assets by	Lighting	Type ($(2012-2023)^2$
	00000000				- ,	(

Lighting Type	2012	2017	2023
Light Emitting Diode (LED)	2,851 (1%)	53,018 (27%)	124,565 (62%)
High Presure Sodium (HPS)	98,070 (49%)	91,422 (46%)	53,374 (27%)
Mercury Vapor (MV)	94,681 (48%)	52,518 (26%)	19,895 (10%)
Metal Halide (MH)	2,977 (2%)	2,468 (1%)	1,622 (1%)
Total Assets	198,579	199,426	199,377

5

12

6	Q13.	Can you provide an overview of the various lighting technologies employed
7		within DTE's Municipal Street Lighting Business, E1 Option I?
8	A13.	The current lighting portfolio for street lighting customers served on DTE Electric's
9		E1 Option I Rate Schedule referenced in Table 1 above, includes approximately
10		166,000 total Company owned lights as of November 1st, 2023. Table 3 below
11		shows the light type breakout by total count and percentage:

Table 3: E1 Option I Light Counts by Type

Lighting Type	Asset Count	% of Total Assets
Light Emitting Diode (LED)	113,584	69%
High Presure Sodium (HPS)	40,417	24%
Mercury Vapor (MV)	10,695	6%
Metal Halide (MH)	1,355	1%
Total E1 Option I Assets	166,051	100%

² Light counts as of November 1st, 2023.

1		While the quantity of high-pressure sodium and mercury vapor luminaires has been
2		steadily dropping over the past several years, the total number of LED luminaires
3		continues to increase in-kind due primarily to municipal driven conversions. Metal
4		halide lighting luminaires represent approximately 1,400, or less than 1% of DTE
5		Electric's company owned lighting luminaires. As noted earlier, more than 20% of
6		the remaining non-LED municipal streetlights are targeted for conversion to LED
7		as a result of the recently awarded SEMCOG project grants.
8		
9	Q14.	Can you provide an overview of the various lighting technologies for street
10		lights that are municipality owned (E1 Options II & III)?
11	A14.	The lighting for DTE Electric's E1 Option II Rate Schedule reflects a mix of 85
12		(71%) high pressure sodium lights and 34 (29%) mercury vapor lights. As
13		previously indicated, this service has been closed to new customers since 2009, and
14		existing E1 Option II Rate Schedule customers electing to convert to LED are
15		required to convert to DTE Electric's E1 Option I or Option III Rate Schedules.
16		The mix of lighting for DTE Electric's E1 Option III Rate Schedule includes
17		approximately 70,000 (84%) LED luminaires, 12,000 (15%) high pressure sodium
18		luminaires, and the remainder consisting of MV and MH lighting. The high
19		concentration of energy-efficient LED lighting in this class reflects the City of
20		Detroit's conversion of most of its streetlights to LED.
21		
22	Q15.	Can you provide an overview of DTE Electric's Community Lighting D9 OPL,
23		E2 ATS, and E1.1 metered municipal-owned lights rate schedules?
24	A15.	DTE Electric's D9 OPL rate schedule and its proposed pricing reflect recovery of
25		costs associated with the ownership, maintenance, and provision of energy to a

1		portfolio of approximately 24,000 commercial and 9,000 residential outdoor
2		protective lights. OPL lighting uses the same technologies as streetlighting and,
3		consistent with conversions of failed mercury vapor streetlights to LED, the
4		Company began converting failed mercury vapor OPLs to LED starting in February
5		2017.
6		
7		DTE Electric's E2 Rate Schedule and proposed pricing reflect the recovery of costs
8		for the production and distribution of energy for automated traffic signal (ATS)
9		lights owned and maintained by municipalities and other public authorities.
10		DTE Electric also provides metered, municipal-owned streetlight service under the
11		E1.1 Rate Schedule. I support the energy forecast for this Rate Schedule and
12		Witness Willis supports the proposed rate for this service.
13		
14	016	Is DTE Electric meansing any changes with respect to the maintenance and
	Q10.	is DIE Electric proposing any changes with respect to the maintenance and
15	Q10.	installation of HPS lighting technology?
15 16	Q10. A16.	Is DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology?Yes. In 2023, our key lighting vendors informed us that they will be or are
15 16 17	Q10.	installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued
15 16 17 18	A16.	installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active
15 16 17 18 19	A16.	IS DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active maintenance and support for HPS fixtures effective the earlier of January 1 st , 2025,
15 16 17 18 19 20	A16.	IS DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active maintenance and support for HPS fixtures effective the earlier of January 1 st , 2025, or depletion of remaining HPS inventory. We have discontinued the purchase of
15 16 17 18 19 20 21	A16.	IS DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active maintenance and support for HPS fixtures effective the earlier of January 1 st , 2025, or depletion of remaining HPS inventory. We have discontinued the purchase of all HPS stock effective November 2023.
 15 16 17 18 19 20 21 22 	A16.	Is DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active maintenance and support for HPS fixtures effective the earlier of January 1 st , 2025, or depletion of remaining HPS inventory. We have discontinued the purchase of all HPS stock effective November 2023.
 15 16 17 18 19 20 21 22 23 	Q10. A16. Q17.	IS DTE Electric proposing any changes with respect to the maintenance and installation of HPS lighting technology? Yes. In 2023, our key lighting vendors informed us that they will be or are considering phasing out their HPS product lines in 2024. Given the continued movement toward LED technology, we have decided to sunset our active maintenance and support for HPS fixtures effective the earlier of January 1 st , 2025, or depletion of remaining HPS inventory. We have discontinued the purchase of all HPS stock effective November 2023. Why has the Company decided to wait until 2025 to stop maintaining HPS

Line	
<u>No.</u>	

1	A17.	Similar to the approach taken by the U.S. Department of Energy (DOE) in its April
2		2022 announcement of the phaseout of most incandescent lightbulbs that went into
3		effect mid-2023, we've elected to wait until 2025 to formally adopt this change.
4		This will allow time to 1) inform our customers of this change in policy and address
5		any concerns they may have, and 2) provide our customers time to socialize this
6		change with stakeholders within their communities. Though there has been broad
7		community support in the adoption of LED lighting technology, it is not
8		unanimous. Therefore, the remaining inventory will be used to accommodate these
9		requests in the short term and further support an orderly transition to LEDs. We
10		will continue to maintain HPS lights as currently proscribed in the tariff throughout
11		2024 unless HPS stock has been depleted prior to 2025.
12		
13	Q18.	How is the Company proposing to manage replacement of HPS fixtures that
14		require maintenance upon depletion of stock or after 2024?
15	A18.	Similar to its policy for MV fixtures, DTE is proposing to maintain HPS fixtures
16		through replacement upon failure with equivalent LED luminaires at no additional
17		charge to the customer. In support of this transition, the Company has also decided
18		to offer a HPS per light labor credit starting in 2024 for those municipalities that
19		have decided to proactively convert to LEDs for which projects have not yet begun.
20		The labor credit of \$65 is the same as the MV labor credit applied to such
21		conversions.

Q19. What steps has the Company taken to inform its' municipal customers of this change?

Line <u>No.</u>

1	A19.	In November of 2023, DTE notified all of its' municipal customers which continued
2		to take service from HPS fixtures via email with an attached letter (Exhibit A-25
3		O3). This letter highlighted why the change was occurring, the transition period
4		mentioned above, the benefits of LEDs, and lastly, the new labor credit being
5		offered for HPS to LED conversions.
6		
7	Q20.	Are you proposing any changes to the E1 Option I and D9 tariff language?
8	A20.	Yes. We are proposing to include the following language for both E1 Option I and
9		D9 tariff options: "Effective January 1st, 2025, new high pressure sodium (HPS)
10		fixtures will no longer be available. Customers with existing HPS fixtures will
11		continue to receive service until those fixtures fail. At that time, the fixture will be
12		converted to an LED luminaire."
13		
14	<u>Comr</u>	nunity Lighting Sales Forecast
15	Q21.	How did you develop the Lighting sales forecast for E1 Options I & II?
16	A21.	Consistent with the methodology utilized in prior Company electric rate cases, the
17		sales forecast for the E1 Option I & II Rate Schedules were developed by first
18		preparing a forecast of light counts for each lighting type (technology and wattage
19		size) for the projected test period based upon: (1) known projects, (2) continued
20		conversions of mercury vapor lighting to LED lighting, and (3) an estimate of
21		
		increased light counts net of removals, resulting from sales growth. The system
22		increased light counts net of removals, resulting from sales growth. The system wattage (nominal lamp wattage plus ballast wattage) applicable to each lighting
22 23		increased light counts net of removals, resulting from sales growth. The system wattage (nominal lamp wattage plus ballast wattage) applicable to each lighting type was applied to the forecasted volume of lights for each lighting type. Annual
22 23 24		increased light counts net of removals, resulting from sales growth. The system wattage (nominal lamp wattage plus ballast wattage) applicable to each lighting type was applied to the forecasted volume of lights for each lighting type. Annual usage was assumed to be 4,200 hours, to reflect the hours that the lights on either
22 23 24 25		increased light counts net of removals, resulting from sales growth. The system wattage (nominal lamp wattage plus ballast wattage) applicable to each lighting type was applied to the forecasted volume of lights for each lighting type. Annual usage was assumed to be 4,200 hours, to reflect the hours that the lights on either the dusk to dawn or standard provision are illuminated. The energy forecast for

1		lights on the dusk to midnight provision was based upon 2,100 hours use and the
2		energy forecast for lights on the de-energized provision is zero. Lastly, pursuant to
3		the order in Case No. U-21297, we reduced the E1 Option I annual usage of 4,200
4		hours (dusk to dawn) and 2,100 hours (dusk to midnight) by 3.25% to account for
5		lights that are non-operational throughout the course of the year. This adjustment
6		is reflected within my workpapers titled "U-21534 Lighting Forecast" and "U-
7		21534 Lighting Rate Model."
8		
9	Q22.	How did you develop the Lighting sales forecast for E1 Option III, D9, E2, and
10		E1.1?
11	A22.	The sales forecast for the E1 Option III Rate Schedule was developed by first
12		preparing a forecast of light counts for each of the lighting types for the projected
13		test period based upon known municipal-owned streetlighting projects and an
14		estimate of light count changes. The system wattage value applicable to each
15		lighting type was applied to the forecasted volume of lights for each lighting type
16		for the 4,200 hours for which all the lights are illuminated on an annual basis.
17		
18		The total sales forecast for the OPL D9 Rate Schedule was developed by preparing
19		a forecast of light counts for each of the lighting types for the projected test period
20		based upon existing light counts, an estimate of increased light counts resulting
21		from sales growth net of removals, and continued conversions of mercury vapor
22		lighting to LED lighting. The system wattage value applicable to each lighting type
23		was applied to the forecasted volume of lights for each lighting type for the 4,200
24		hours for which the lights are illuminated on an annual basis.
25		

1		The sales forecast for the E2 ATS Rate Schedule was determined by using the total
2		connected wattage, as of November 2023, for the rate schedule and determining the
3		annual usage based upon that determinant. In other words, it is simply the product
4		of the total reported wattage and the total number of hours in the projected test
5		period.
6		
7		The total sales forecast for the E1.1 Rate Schedule was based upon annualized
8		usage data for the 12-month period that ended June 2023.
9		
10	<u>Comp</u>	oany Preventative Maintenance Programs
11	Q23.	What preventative maintenance programs does the Company manage and
12		how are the related expenses classified?
13	A23.	The Company manages the following preventative maintenance programs: 1) Post
14		Inspections, 2) Post Painting, 3) Night Patrol, 4) Post Replacement, and 5) Cable
15		Replacement. The Post and Cable Replacement programs are considered capital
16		expenditures while the remaining programs are booked as O&M.
17		
18	Q24.	Please describe the Company's Post Inspection program and its relationship
19		to the Post Painting and Post Replacement programs.
20	A24.	DTE Electric owns more than 60,000 decorative metal posts and has established
21		detailed post inspection criteria to inspect its posts every three years to both identify
22		posts whose structural integrity dictates their replacement (condemnation), and
23		posts that require painting. At the time posts are inspected, minor post maintenance
24		work such as adding or replacing post asset tags, post hand-hole covers, and T-box
25		door covers may also be completed. Over the past three years, DTE Electric's

Line No. 1 decorative post inspection process has resulted in the annual replacement of 2 condemned posts at a rate of approximately 3% and post painting at a rate of 3 approximately 2% relative to the total population of posts. 4 5 Q25. Does the Company also inspect its streetlight-only wood poles? 6 A25. Yes. Our streetlight-only wood poles are inspected as part of DTE's pole top 7 maintenance (PTM) program managed by Distribution Operations. As wood poles 8 are inspected through this program, streetlight-only wood poles identified as 9 condemned or near end-of-life, are sent to DTE - Community Lighting for 10 replacement by its' contractor(s) responsible for replacing our decorative metal 11 posts. 12 13 Q26. 14 A26. 15 16

Please describe the Company's Night Patrol program and its purpose.

To further bolster customer service and reliability, the Company implemented a Night Patrol program in 2019 with the intent to proactively identify municipal-wide outages which would then be routed to a DTE authorized construction crew for 17 repair. All of DTE's E1 Option I streetlights are within the scope of this program, 18 and depending on prior patrol results and repair detail (i.e. large percentage of 19 outages noted in a single municipality or high concentration of outages in a specific 20 area), the Company may adjust the timing of the next scheduled night patrol.

21 In 2022, DTE developed a night patrol database to record details by light and by 22 circuit as to the nature and recurrence of outages. The purpose of cataloging this 23 data is to allow the Company to utilize analytics to identify repeat visits to the same 24 luminaire or problematic circuits because of underground cable failures.

1 Q27. Why did the Company launch the Cable Replacement program which targets 2 underground cable replacements? 3 A27. As more outage data continues to be collected from the Night Patrol program, we 4 are beginning to identify root cause issues through direct feedback from our 5 contractors tasked with restoring service, and data on specific lights and circuits 6 that indicate recurring outages. In general, outages are the result of 1) a failed 7 luminaire, 2) failed wiring or components such as a photocell, or 3) failed 8 underground cable. 9 10 This program specifically targets underground cable replacement work as this tends 11 to be the costliest type of repair to perform on a reactive basis and has a higher 12 likelihood to impact multiple lights when the cable begins to fail. Repairing larger 13 stretches of cable using a data driven approach on a planned basis through this 14 program is not only more cost effective, but is also anticipated to reduce the 15 likelihood of one or more lights failing due to an underground fault once replaced, 16 thereby increasing reliability. 17 18 You mentioned that proactive underground cable replacement work is more **O28**. 19 cost effective than reactive repairs. Can you elaborate? 20 A28. When responding to outage events that involve underground cable failures as the 21 root cause, our repair crew's primary objective is to address the immediate issue 22 and restore service as quickly as possible. This increases the number of "locate and 23 repairs" which result in sections of failed cable being isolated and replaced. Though 24 this addresses the immediate root cause, it doesn't necessarily increase the

		R. A. BELLINI
Line <u>No.</u>		U-21534
1		longevity of the stretch of cable supporting that circuit, in a manner that replacing
2		failed or end-of-life underground cable would.
3		
4	Q29.	Are there any other long-term benefits expected to be realized from the Cable
5		Replacement program?
6	A29.	Yes. First, most of the underground system cable that is currently in service is direct
7		buried, meaning that the cable is unsleeved and buried at a depth which makes it
8		more susceptible to freezing and thawing impacts as well as 3 rd party strikes during
9		excavation work (i.e. other utility work or municipal driven projects such as road
10		widening). Cable that is replaced under this program is now installed within a
11		protective sleeve which increases the likelihood that it can survive a 3 rd party strike
12		or become exposed through excavation. Second, as damaged and end-of-life cable
13		is replaced with newly installed and protected cable, we expect to see a reduction
14		in outages whose root cause is determined to be an underground cable failure. Over
15		time, this will reduce the number of reactive underground cable events and increase
16		lighting system reliability.
17		
18	<u>Outa</u>	ge Restoration Activities
19	Q30.	What was DTE Electric's performance with respect to outage duration for its
20		lighting customers?
21	A30.	DTE Electric's 2022 performance was 4.2 calendar days. These historical metrics
22		for outage duration and defects are displayed on Exhibit A-25, Schedule O1.
23		In addition to weather-related events, "long duration" and "follow-up" outage
24		events include extended repair time for underground faults (i.e. Miss Dig permits),
25		repairs resulting from third party damage, and lack of special order material (SOM)

1 maintained by a city or municipality. The performance metrics only include 2 reactive street light outage repairs; they do not include any outage repair resulting 3 from patrol and fix activities. However, Exhibit A-25, Schedule O1 does reflect 4 the total number of lights canvassed from the night patrol program as well as the 5 number of outages identified from these patrols. Street light outage events reported 6 on weekends and after normal week-day business hours are analyzed and 7 dispatched to crews on the following business day. DTE Electric measures both 8 total and crew duration cycle repair periods. Crews authorized by DTE Electric 9 work to complete reactive outage repairs of reported street light outage events.

10

Line

No.

Q31. What other measures does DTE Electric have in place to improve its restoration time and to maintain a high level of customer service?

13 A31. Restoration performance, among other metrics, are reviewed with our contractors 14 at monthly performance meetings and, to the extent that restoration performance is 15 not meeting expectations, DTE Electric can shift restoration work as needed to 16 alternate contractors to achieve the desired restoration performance. Internally, the 17 Company evaluates contractor performance metrics on a weekly basis to identify 18 potential performance issues or problem-solving opportunities. In addition to these 19 efforts, the Company continues to improve the arrangements for the provision of 20 special-order materials on behalf of municipalities that choose streetlight materials 21 that are not included in DTE Electric's standard streetlight offerings.

22

Q32. Could you please summarize DTE's Outage Performance over the past six years?

Line <u>No.</u>

1	A32.	While any individual year will be impacted by external factors such as changing
2		weather patterns (i.e. more freezing and thawing leads to increased cable faults) and
3		number of catastrophic storms (i.e. construction crews being diverted to assist in
4		power restoration activities), key outage metrics continue to trend in a positive
5		direction when evaluating performance collectively, over the past six years.
6		Specifically, the outage data summarized in Exhibit A-25, Schedule O1 indicates
7		a positive impact in terms of the correlation between our proactive efforts resulting
8		from the night patrol & underground cable replacement programs to reduce
9		customer reported outage events (when adjusting for the removal of "ok on
10		arrivals" and "streetlight knockdowns" and adding "follow-up events completed)
11		from approximately 19,500 in 2019 to approximately 14,000 in 2023 as Chart 1
12		below illustrates:





3

4

5

Line

No.

1

2

As we collect more night patrol data, we will continue to use this data to strategically target municipalities based on historical results.

6

Q33. Were there any requirements as part of the order in Case No. U-21297
 pertaining to DTE making streetlighting outage reports available to
 municipalities that request them?

A33. Yes. Specifically, the Order on page 373 states "...DTE Electric Company shall
 work with interested stakeholders to develop a streamlined streetlight outage report
 request process, a standard report request process, a standardized report format,
 data protocols, and delivery method and shall update its E1 tariff to reflect the
 following:

15 Any E1 streetlight customer may request to receive from the company a 16 calendar-year report, to be delivered by the company on or before 17 February 28 of the following year, providing, at a minimum, streetlight 18 outage occurrence counts, average outage durations and counts of 19 outages lasting longer than 14 days, covering all E1 streetlights served 20 under all of the customer's accounts. Customers with more than 5,000 21 E1 streetlights, may request to receive quarterly reports containing the 22 same information, to be delivered by the company within two months of 23 the end of each calendar quarter."

1	Q34.	What modifications are you proposing to the tariff language as provided in the
2		Order?
3	A34.	We propose clarifying that outage reporting will only be available for E1 Option I
4		customers, as these are the only streetlights within E1 that the Company owns,
5		operates, and maintains.
6		
7	Q35.	When do you anticipate implementing this new process and making this
8		outage report available to requesting municipalities?
9	A35.	We have been working toward developing an outage report for municipalities that
10		includes 1) streetlight outage occurrence counts, 2) average outage durations, and
11		3) counts of outages lasting longer than 14 days. A meeting with MPSC Staff,
12		MAUI, and other interested stakeholders is scheduled end-March 2024 to share our
13		proposed reporting template which provides the outage data required by the order
14		in Case No. U-21297. Our goal is to collectively agree upon the reporting
15		framework, content, delivery, and effective date for implementation. Our new
16		reporting system discussed below, will help to streamline the process of preparing
17		the outage reports once the system has been tested and debugged.
18		
19	Q36.	Can you provide an overview of the Company's new outage management
20		system?
21	A36.	In late 2023, Community Lighting began its transition to a standalone outage
22		management system (OMS), KloudGin. Initially part of the Advanced Distribution
23		Management System (ADMS) solution, this standalone OMS system will enable
24		us to issue outage work to our contractors more efficiently, increase our ability to
25		remove duplicate events (i.e. same outage reported by multiple parties), and when

Line No		R. A. BELLINI U-21534
<u>1 1</u>		fully functional allow for enhanced automation for outage reporting by
2		municipality
2		manopanty.
5	037	What is the status of the new OMS system and when do you expect it to be
4	Q37.	what is the status of the new Owis system and when do you expect it to be
5		
6	A37.	The remaining work of integrating this OMS system into our operations is expected
7		to be completed by the end of Q1 2024. Once completed, our group will need to
8		work with our IT group and the software vendor to stress test this software to
9		identify and correct errors and issues. We are tentatively aiming to have the
10		software being fully functional by Q2 or Q3 2024. Once fully operational, our goal
11		for this system to be able to automate the outage reporting by municipality in
12		compliance with the Case No. U-21297 order.
13		
14	Q38.	What was Community Lighting's spend with respect to outage restoration
15		activity?
16	A38.	In 2022, DTE Electric's Community Lighting team spent approximately \$8.1
17		million on outage restoration expense with approximately 76% of this cost being
18		capitalized, and the balance being recorded as O&M. The outage restoration
19		expense was approximately \$7.6 million in 2021. Exhibit A-25, Schedule O2
20		reflects DTE Electric's historical performance for outage restoration cost per event.
21		
22	Q39.	Please explain the difference between capitalized outage expenses and non-
23		capitalized, or O&M outage expenses.
24	A39.	Outage restoration activities include remediating identified lighting outages that
25		could range from replacement of small wiring or lighting components to
replacement of system cable, posts, and luminaires. Any repair (inclusive of both
 materials and labor) that does not extend the useful life of the lighting asset (small
 wiring or lighting components such as a replacement of a fuse) is considered an
 O&M expense. All other repairs (both materials and labor) are considered capital
 expenditures.

6

7 Community Lighting Operations & Maintenance and Capital Expenditures

Q40. What is included in the Operations & Maintenance of Street Lighting and Signal Systems account on line 23 of Exhibit A-13, Schedule C5.6, page 1?

Line 23 on this exhibit shows the projected O&M expenses which are directly 10 A40. 11 assigned to Account 596, Maintenance of Street Lighting and Signal Systems. This 12 account represents preventive maintenance expense, labor expense and non-13 capitalized outage restoration expense. The preventive maintenance work includes 14 post inspection, post painting, and night patrols for DTE owned municipal 15 streetlights. The labor expense primarily reflects the labor of the Community 16 Lighting team including sales, planning, asset maintenance, construction, and asset 17 engineering. As reflected on Exhibit A-13, Schedule C5.6, the historical period 18 O&M expense of \$4.0 million is adjusted first for normalization attributable to an 19 anticipated reduction in O&M related outage spend of \$0.25 million, and then for 20 inflation of 3.20% for 2023, 2.90% for 2024, and 2.90% for 2025. This results in 21 a forecasted O&M expense of \$4.1 million in the projected test period.

22

Q41. What are the Community Lighting capital expenditures on Exhibit A-12, Schedule B5.5, "Projected Capital Expenditures – Community Lighting"?

1	A41.	Capital expenditures for Community Lighting for 2022 were \$17.8 million. The
2		2022 expenditures included approximately \$6.3 million for new installations and
3		replacements, \$7.4 million for outage restoration, \$1.7 million for cable
4		replacements, \$1.5 million for post replacements, and \$0.9 million for planned HID
5		to LED conversions.
6		
7		The projected capital expenditures for Community Lighting are \$16.7 million for
8		2023, \$16.7 million for 12 months ending December 31, 2024, and \$17.3 million
9		for 12 months ending December 31, 2025. Similar to the 2022 actual expenditures,
10		these projections include outage restoration, including conversion of failed mercury
11		vapor luminaires to LED for both streetlight and OPLs, post replacement, new
12		business, and capital support staff. As previously discussed, Community Lighting
13		launched its underground cable replacement program in 2022 which is also
14		included in Exhibit A-12, Schedule B5.5 line 4 with projected spend of \$1.5 million
15		for 2023, \$1.1 million for 12 months ending December 31, 2024, and \$1.7 million
16		for 12 months ending December 31, 2025.
17		
18	LED	Luminaire Selection Methodology Specific to HID to LED Conversions
19	Q42.	Can you provide an overview on HID to LED conversions and DTE's LED
20		selection methodology for such conversions?
21	A42.	In Case No. U-21297, we described two distinct scenarios in which the Company
22		recommends installation of specific LED luminaires, and our LED selection
23		methodology for both. The first scenario pertains to new lighting installations. A
24		new installation for purpose of this discussion, is generally defined as installing
25		poles, wiring, and luminaires where they did not exist previously (i.e., a

Line <u>No.</u>

24		Company's LED selection methodology?
23	Q43.	Could you please summarize the order in Case No. U-21297 with respect to the
22		
21		recommended lighting design.
20		Under either scenario, the customer has the choice to deviate from the Company's
19		
18		of the HID luminaire with an LED luminaire.
17		during conversion work is to restore the equivalent "out of the box" initial output
16		rewiring of the overhead and underground system cable. Therefore, our objective
15		need extensive reconfiguration inclusive of work such as pole relocations and
14		pre-existing lighting systems is that these older municipal lighting systems would
13		impractical and costly to conform to current ANSI/IES RP8 lighting standards for
12		impractical and costly for municipalities to do so."3 The reason it would be
11		infrastructure may not meet ANSI/IES RP-8 standards, and that it would be
10		in Case No. U-21297, "[t]he Company understands that pre-existing streetlighting
9		recommendations for new lighting installations. As stated in my rebuttal testimony
8		pre-date current lighting standards that the Company adheres to today when making
7		that the Company owns, operates, and maintains, were installed decades ago, and
6		to HID to LED conversions on pre-existing lighting systems. Most lighting systems
5		The second scenario, which results in the majority of LEDs being installed, pertains
4		
3		be evaluated in accordance with ANSI/IES RP-8 standards.
2		design for the new roundabout). In this scenario, all new lighting installations will
<u>1</u>		municipality has constructed a roundabout and engaged DTE to provide a lighting
No.		

³ Bellini Rebuttal Testimony, Case No. U-21297, pg. 12, lines 21-23

1	A43.	The MPSC Commission in their order in Case No. U-21297 disallowed
2		approximately \$5.8M of LED plant from the Company's historical books,
3		determining that the Company had overspent on LED conversions, in part based on
4		the wattage of the luminaires it selected as compared to a crossover chart from the
5		Company's primary LED lighting vendor, Leotek.
6		
7		Specifically, on page 137 of the order, the Commission states "DTE Electric does
8		not deny that its lamp choices exceed what Leotek recommends as a high-level
9		choice. The ALJ further found that "DTE has not established that it has any
10		meaningful discussion ⁴ with customers currently regarding the choice of lighting"
11		and that "since DTE does not conduct any analysis of the appropriate lighting for
12		the roadway at issue, it is difficult to credit that DTE meaningfully consults with its
13		municipal customers." Absent convincing evidence to the contrary, the ALJ found
14		that the crossover recommendations are reasonable."
15		
16	Q44.	What significant developments have occurred since the order in Case No. U-
17		21297?
18	A44.	Specifically, Leotek no longer supports their crossover chart and has removed them
19		from their Company's website. This Leotek crossover chart was one of the primary
20		reasons for the MAUI adopted proposal of DTE's historical LED plant reductions
21		as reflected in witness Bunch's workpaper prepared in Case No. U-21297, included
22		here as Exhibit A-25 Schedule O4 titled "WP Calculation of \$5.8M Disallowance
23		by MI-MAUI in U-21297."

⁴ U-21297 Proposal For Decision, p. 340.

Line
No.

1	Q45.	Are you recommending that the MPSC Commission revisit the reasoning that
2		resulted in the disallowance of the LED plant-in-service in Case No. U-21297?
3	A45.	Yes. Both DTE and MAUI drew distinctly different conclusions from the Leotek
4		crossover chart presented in Case No. U-21297. Given that the crossover chart is
5		no longer supported by Leotek, which was the primary evidence used to determine
6		the excessive spend in LEDs during conversions, it would be prudent to revisit the
7		methodology employed by DTE in its HID to LED conversions on pre-existing
8		streetlighting systems.
9		
10		In the instant case, DTE sought the opinions of two lighting industry experts
11		(discussed later in my testimony) to review and provide independent opinions as to
12		the reasonableness and prudency of DTE's LED selection methodology as it relates
13		to conversions. Given the technical complexity of this topic and the limited time
14		available to discuss this issue in the context of a rate case, the Company would be
15		amenable to a Staff facilitated technical workshop inclusive of Leotek's
16		engineering team, DTE, expert consultants, and MI-MAUI with the intent of
17		evaluating appropriate HID to LED equivalent conversions employed by DTE and
18		determine whether or not DTE unnecessarily installed more expensive LEDs during
19		conversions. It would also be prudent to directly engage with Leotek and the
20		preparer of this chart in order to assess whether or not DTE erred in selecting
21		luminaires that deviated from this chart which is no longer supported by Leotek.
22		
23	Q46.	Is DTE presenting additional evidence supporting its' selection methodology
24		specific to HID to LED conversion projects on pre-existing lighting systems?

<u></u>		
1	A46.	DTE has sought the independent review and opinions of two lighting industry
2		experts, Dr. Ronald Gibbons, PH.D., FIES, currently the Director of the Center for
3		Infrastructure Based Safety Systems (CIBSS) at the Virginia Tech Transportation
4		Institute (VTTI) ⁵ , and Donald McLean, PLEng (Founder and Senior Partner, DMD
5		Consulting Engineers, $Ltd)^6$ as to the appropriateness of DTE's LED selection
6		methodologies pertaining to HID to LED conversions. Both experts were asked to
7		review and opine on DTE's lighting study which recommended 58W and 136W
8		LED selections when converting 100W HPS and 250W HPS fixtures, respectively,
9		as these HPS fixture types are the most commonly converted municipal fixtures.
10		
11	Q47.	Please summarize <u>Don McLean's</u> findings and overall conclusion with respect
12		to DTE's LED selection process when converting HID's.
13	A47.	Mr. McLean's key points from his conclusion detailed in his report (Exhibit A-25,
14		Schedule O5, page 15) are quoted below:
15		• "From a comparison standpoint, matching published lumens from luminaire
16		to luminaire is not always the best method. It is more important to assess
17		lighting levels on the roadway, which was undertaken by DTE."
18		• "DTE reviewed both roadway lighting levels on and off the roadway

19defining lighting Luminance and Illuminance metrics in the analysis,20including spill lighting. In our opinion, what DTE have provided is21reasonable for an HPS to LED conversion given they have focused on22calculated lighting levels on the roadway vs simply using lumen values."

⁵ U-21534 Exhibit A-25 Schedule O9_Gibbons – DTE Energy Response Document & CV, p12 - 28

⁶ U-21534 Exhibit A-25 Schedule O8 Don McLean Curriculum Vitae

Line <u>No.</u>		U-21534
1		• "DTE's use of multiple roadway types and averaging the results of these
2		roadways is a reasonable methodology to use in comparing luminaires and
3		as a luminaire selection guide in large scale retrofit HPS-LED conversions."
4		• "Based on the criteria and approach defined by DTE, DMD is in agreement
5		with the conversion methods and LED luminaires chosen to replace the
6		incumbent 100W and 250W HPS luminaires."
7		
8	Q48.	Please also summarize Dr. Gibbons' findings and overall conclusion with
9		respect to DTE's LED selection process when converting HID's.
10	A48.	Dr. Gibbons' key points from his conclusion detailed in his report (Exhibit A-25,
11		Schedule O9, page 11) are quoted below:
12		• "The approach DTE Energy used for the selection of luminaires is valid and
13		aligns with the state of the art in the industry."
14		• "The luminaires selected by DTE energy were appropriate for the template
15		roadways considered in their analysis."
16		• "The appropriate luminaires for intersection evaluations selected through
17		analysis are Leotek 136W and the Leotek 58W for the 250Watt HPS and
18		for the 100 Watt HPS respectively."
19		
20	Q49.	Please identify and define the primary LED lighting criteria evaluated by
21		DTE when selecting an appropriate LED replacement of an HID light.
22	A49.	Though there are several criteria used in evaluating lighting options, roadway
23		illuminance and luminance are weighted more heavily than other criteria such as
24		glare, light trespass, etc.

	R. A. BELLINI U-21534
	The Texas Department of Transportation (TxDOT) provides the following simple
	definitions for roadway illuminance and luminance: ⁷
	• <u>Roadway Illuminance</u> : Measurement of the amount of light that hits the
	pavement surface.
	• <u>Roadway Luminance</u> : Measurement of the reflected light from the
	pavement surface that is visible to the motorist's eye.
	TxDOT states that "[t]he level and uniformity of illuminance or luminance along a
	highway depends on several factors, including the lumen output of the light source,
	luminaire distribution, mounting height, luminaire position, pavement reflectance,
	and pole spacing and arrangement."
	This weighting criteria is consistent in both the manner in which DTE assessed
	proper LED selections when converting municipal HID lighting projects and also
	as evaluated by both industry experts discussed in their detailed findings below.
50.	Please briefly explain the parameters of the reviews conducted by both
	experts.
50.	Both Don McLean and Dr. Gibbons conducted an independent review based on
	information sourced and used by DTE in its' own analysis ("WP-RAB - Work

Line <u>No.</u>

Q5

A5 Paper A – Agi 32 Simulation Files_100W HPS" through "WP-RAB – Work Paper Q - IES Photometric Files_LED") in selecting LEDs used in HID to LED conversion projects.

⁷ <u>Highway Illumination Manual: Illumination Levels (txdot.gov) available at</u> <u>https://onlinemanuals.txdot.gov/TxDOTOnlineManuals/TxDOTManuals/hwi/illumination_levels.htm#i102</u> <u>4407</u>

Line <u>No.</u>		R. A. BELLINI U-21534
1		Both reviews were specific to DTE's most commonly converted fixtures, the 100W
2		and 250W HPS fixtures. Both compared new (or "out of the box") LED luminaires
3		to new HPS luminaires.
4		
5	Q51.	Please highlight Mr. McLean's review process and specific conclusions from
6		his report (Exhibit A-25, Schedule O8) on DTE's selections of the 58W and
7		136W to replace 100W and 250W HPS fixtures, respectively.
8	A51.	The key findings are noted below in various quoted excerpts from Mr. McLean's
9		report (Exhibit A-25 O5 "Don McLean DTE HID-LED Selection Methodology
10		Opinion Letter"):
11		
12		100W HPS Replacement Evaluation
13		"Revised Rdwy Performance Summary.xlsx (Exhibit A-25 O7_DMD_Rdwy
14		Performance Summary) contains Target Roadway lighting calculation summaries
15		for Roadways 100A through 100G as provided in "Workpaper G - Roadway
16		Typicals Master Table 02 01 18." These 7 roadways pertain to 100W HPS
17		replacements only. The calculation summaries contain roadway Luminance and
18		Illuminance metrics for the existing 100W HPS and the 4 LED luminaires DTE
19		used in the conversion analysis."
20		
21		"Revised Rdwy Performance Summary.xlsx" then takes the calculation summaries
22		for each of the 4 LED models considered in the analysis and compares the average
23		values for Luminance and Illuminance to the average values for the HPS luminaire
24		as HPS is taken as the baseline."

1	250W HPS Replacement Evaluation
2	"Revised Rdwy Performance Summary.xlsx" contains Roadway lighting
3	calculation summaries for Roadways 250A, 250B, 250C AND 250F as they are
4	described in the Exhibit G - Roadway Typicals Master Table 02 01 18 (Rate Case)
5	(Master Tables). These roadways pertain to 250W HPS replacements only. The
6	calculation summaries contain roadway Luminance and Illuminance metrics for the
7	existing 250W HPS and the 4 LED luminaires used in the analysis."
8	
9	"Revised Rdwy Performance Summary.xlsx" then takes the calculation summaries
10	for each of the 4 LED models considered in the analysis and compares the average
11	values for Luminance and Illuminance to the Average values for the HPS luminaire
12	as HPS is taken as the baseline."
13	
14	58W LED Results Summary
15	"The light levels produced by the 58W LED Luminaire showed an increase in
16	Average Illuminance. The 58W fixture failed to meet spill light targets at
17	surrounding property lines with a 51.2% increase compared to the 100W HPS
18	baseline. While the 37W, 30W and 27W fixtures meet spill lighting targets within
19	a reasonable tolerance, the 58W luminaire is the only fixture that was able to
20	maintain the minimum Average Illuminance of the HPS baseline."
21	
22	136W LED Results Summary
23	"The 136W luminaire had the highest Average Illuminance out of the 4 LEDs at
24	only 3.5% below the target HPS baseline levels, which we would deem to be within
25	a reasonable level of tolerance. The 136W LED luminaire was also the only

Line <u>No.</u>

Line		R. A. BELLINI U-21534
<u>No.</u> 1		luminaire to maintain baseline spill light levels, with a 27.3% reduction in max spill
2		light levels at property frontages compared to the 250W HPS baseline "
2		nght levels at property nontages compared to the 250 w 1115 baseline.
1	052	Plags highlight Dr. Cibbons' raview process and specific conclusions from his
4	Q32.	Trease inginight <u>Dr. Gibbons</u> review process and specific conclusions from his
5		report (Exhibit A-25, Schedule O9) on DTE's selections of the 58W and 136W
6		to replace 100W and 250W HPS fixtures.
7	A52.	In Dr. Gibbons review of various simulations, he "verified the parameters placed
8		in the simulation including luminaire type, location, and tilt angle" and then
9		"calculated the lighting levels within each model." Using this data, Dr. Gibbons
10		then "compared the calculated results to the incumbent HPS technology where the
11		roadway illuminance, luminance, glare, sidewalk illuminance and light trespass
12		values were reviewed. In the analysis, the result criteria were established that the
13		luminaire had to increase the luminance and illuminance on the roadway with the
14		desire to increase the sidewalk illuminance, while reducing glare and light
15		trespass."8 The key findings are noted below in various quoted excerpts from Dr.
16		Gibbons report ("Exhibit A-25 Schedule O9_Gibbons - DTE Energy Response
17		Document & CV):"
18		
19		100W HPS & 250W HPS Replacement Evaluation
20		"In the review of the DTE methodology, I [Dr. Gibbons] opened the AGI32 Simulation
21		packages for the 100 Watt HPS replacement comparisons and the 250 Watt HPS
22		comparisons. In all there were 8 comparison templates for 100 Watt selection process
23		and 4 templates for the 250 Watt comparisons. In each of the simulations, I verified the
24		parameters placed in the simulation including luminaire type, location, and tilt angle. I

⁸ U-21534 Exhibit A-25 Schedule O9_Gibbons – DTE Energy Response Document & CV, p3-4

1	then calculated the lighting levels within each model. Using this data, I compared the
2	calculated results to the incumbent HPS technology where the roadway illuminance,
3	luminance, glare, sidewalk illuminance and light trespass values were reviewed. In the
4	analysis, the result criteria were established that the luminaire had to increase the
5	luminance and the illuminance on the roadway with the desire to increase the sidewalk
6	illuminance while reducing glare and the light trespass."
7	
8	58W & 136W LED Results Summary
9	"Based on this analysis, I [Dr. Gibbons] would recommend the Leotek 58W to replace
10	the 100W HPS and the Leotek 136W to replace the 250W HPS."
11	
12	LED Comparison Matrices Summarizing Dr. Gibbons findings ²
13	

Table 4: Study Results of 100W HPS to LEDConversion for Continuous Lighting on Straight Roadway

	LED 58W	LED 37W	LED 30W	LED 27W
Roadway Template A	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template B	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template C	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template D	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template E	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template F	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Roadway Template G	Fully Meets	Fully Meets	Fully Meets	Does not Meet
Roadway Template A Roadway Template B Roadway Template C Roadway Template D Roadway Template E Roadway Template E	Ro: 2013 Application Sp MH, 2' setback, 150' Greenbush Rd, Way Same as Roadway T 15899 E. Eleven Mild 16461 E. Eleven Mild 321 E. Granet Ave	adway Descriptions ecification (one row ' pole-to-pole spacin 'ne 'emplate B with shor e Rd, Roseville e Rd, Roseville Hazel Park	, near side, 2-lanes, 2 g) t arm application ch	24' road width, 28.5' ange
Roadway Template F	SZIE. Granet Ave, F	azei rark Complete E with cher	tarm application ch	2000
Roadway Template G	Same as Roduway I	emplate r with shor	t ann application ch	ange

14

⁹ Summary of results prepared by DTE based on Dr. Gibbons analysis from tables presented in U-21534 Exhibit A-25 Schedule O9_Gibbons – DTE Energy Response Document & CV, pp 4-5, 11

Line <u>No.</u> 1

Table 5: Study Results of 100W HPS to LEDConversion for Local/Local Intersection

	LED 58W	LED 37W	LED 30W	LED 27W
Local/Local A	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Local/Local B	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Local/Local C	Fully Meets	Fully Meets Does not Meet Doe		Does not Meet
Local/Local A	S. Linville Ave and	Hazelwood St, West	land	
Local/Local C	Pine St and 8th St,	Port Huron		

2

Table 6: Study Results of 250W HPS to LED Conversion for Continuous Lighting on Straight Roadway

	LED 136W	LED 111W	LED 89W	LED 72W	
Roadway Template A	Fully Meets	Does not Meet	Does not Meet	Does not Meet	
Roadway Template B	Does not Meet	Fully Meets	Does not Meet	Does not Meet	
Roadway Template C	Fully Meets	Does not Meet	Does not Meet	Does not Meet	
Roadway Template F	Fully Meets	Does not Meet	Does not Meet	Does not Meet	
Roadway Template A	2013 Application Specification (two rows, opposite, 4-lanes, 48' road width, 30' MH, 2' setback, 180' pole-to-pole spacing)				
Roadway Template B	Avondale St and Carlson St, Westland				
Roadway Template C	Same as Roadway T	emplate B with sho	rt arm application ch	ange	
Roadway Template F	Ryan Rd between N	Ickinley Ave and Fra	zho Rd, Warren		

3

Table 7: Study Results of 250W HPS to LEDConversion for Local/Local Intersection

	LED 136W	LED 111W	LED 89W	LED 72W
Collector/Collector A	Fully Meets	Does not Meet	Does not Meet	Does not Meet
Collector/Collector B	Fully Meets	Fully Meets Does	Does not Meet	Does not Meet
Collector/Collector C	Does not Meet	Does not Meet	Does not Meet	Does not Meet
Collector/Collector A Collector/Collector B	Sheldon Rd and Sal Avondale Rd and W	tz Rd, Canton /ildwood Ave, Westl	and	
Collector/Collector C	13th St and Court S	t, Port Huron		

4

8

5 Q53. Please summarize DTE's four recommendations to the MPSC Commission

6 **based on the new evidence provided in the instant case.**

- 7 A53. <u>Recommendation 1</u>: Based on both experts' independent analysis and conclusions
 - as to the appropriateness of our LED selections for conversions, the Company

1	believes it would prudent to continue utilizing 58W and 136W Leotek LEDs when
2	converting 100W and 250W HPS luminaires, rather than being limited to the
3	choices based solely on Leotek's crossover chart, which is no longer supported by
4	the Company.
5	
6	Recommendation 2: In addressing the ALJ's comments provided in the PFD in
7	Case No. U-21297 (PFD, p. 340) that "DTE has not established that it has any
8	meaningful discussion with customers currently regarding the choice of lighting,"
9	the Company proposes to memorialize our LED recommendations (noted in the
10	preceding paragraph) to the customer in their contract prior to signing, and
11	explicitly informing the customer in the contract and during discussions that the
12	customer has the choice to select another LED at their discretion and confirmed in
13	the municipal conversion agreement.
14	
15	Recommendation 3: If the Commission deems it necessary, the Company would
16	be amenable to a Staff facilitated technical workshop inclusive of Leotek's
17	engineering team, DTE, outside consultants, and MI-MAUI with the intent of
18	evaluating appropriate HID to LED equivalent conversions employed by DTE and
19	also determining whether or not DTE unnecessarily installed more expensive LEDs
20	during conversions.
21	
22	Recommendation 4: Based on the new evidence presented by the Company in the
23	instant case, we believe it may be appropriate to revisit the decision to disallow the
24	\$5.8M in LED gross plant as ordered in Case No. U-21297.

Line No

<u>No.</u>

1 Community Lighting Rate Design

2 Q54. What does Exhibit A-16, Schedule F3 show?

3 A54. This exhibit shows the present and proposed rate design and corresponding 4 revenues by rate schedule, based on the billing determinants for the 12 months 5 ending December 31, 2025. The exhibit details the forecasted billing determinants 6 as well as the resulting present and proposed rates and revenues. The various billing 7 components are listed in column (a), and the respective billing determinants, 8 including units of measure, are listed in column (b). The forecasted billing 9 determinants were developed based on historical data and relationships, as well as 10 known and measurable changes, and are consistent with the sales forecast as 11 presented on Company Witness Mr. Leuker's Exhibit A-15, Schedule E1, Other 12 class sales. The existing luminaire and energy rates, both non-capacity energy and 13 capacity energy, as approved in the Order dated December 1, 2023, in Case No. U-14 21297 are in columns (c), (d) and (e), and are used to calculate the present revenues 15 in column (f). The luminaire rates proposed in this proceeding based upon the 16 lighting cost of service (as discussed in detail below) are in column (g), the 17 proposed non-capacity energy rates are in column (h), the proposed capacity energy 18 rates are in column (i) and the resulting revenues from the new lighting cost of 19 service are in column (j).

20

Q55. How were DTE Electric's present Municipal Street Lighting and Outdoor Protective Lighting charges determined?

A55. The lighting rates approved in MPSC Case No. U-21297 reflect a monthly energy
 charge, both non-capacity energy and capacity energy, and a luminaire charge. The
 monthly energy charge was determined by applying the energy rates, both in

Line <u>No.</u>

1	cent/kWh, to the calculated consumption values of the various lighting technology
2	lamp sizes for both the E1 and D9 Rate Schedules. The luminaire charge is a fixed
3	monthly amount applied to each luminaire dependent on the technology utilized,
4	the lamp size or wattage, the lighting provision and whether it is served from
5	underground or overhead. The total (energy and luminaire) monthly lighting
6	charges that were calculated in Case No. U-21297 do not fully represent true cost
7	of service rates by technology type (within the lighting rate class). In Case No. U-
8	21297, the lighting rates were gradually moved towards cost of service, with the
9	total movement capped to minimize the impact on any individual customer.
10	

Q56. What is the allocation methodology for production and distribution revenue requirements to the various lighting rate schedules that you are supporting in this case?

14 A56. The functionalized production (Exhibit A-16, Schedule F1.1) and distribution 15 (Exhibit A-16, Schedule F1.2) revenue requirement amounts supported by 16 Company Witness Maroun for each of the lighting rates schedules (D9, E1, & E2) 17 were fully allocated to each of those rate schedules within the lighting rate model. 18 The proposed luminaire, distribution, and energy charges (both capacity and non-19 capacity) within each of the rate schedules were designed to meet the production 20 and distribution revenue requirement for each rate schedule shown in these exhibits. 21 Witness Maroun's Exhibit A-16, Schedule F1.5, detailing how much of the 22 production revenue requirement for each rate class is capacity and non-capacity 23 related, was used to allocate the production revenue requirement between the 24 capacity and non-capacity energy charges. The E1 and D9 Rate Schedule energy 25 charges, both capacity and non-capacity, were developed based upon the total

Line <u>No.</u>		R. A. BELLINI U-21534
1		production revenue requirement prepared by Witness Maroun for the E1 and D9
2		Rate Schedules.
3		
4	Rate S	Schedule E1
5	Q57.	How were the proposed E1 Rate Schedule luminaire charges determined?
6	A57.	The Company determined the new luminaire service cost structures listed in the E1
7		Rate Schedule tariff schedules as shown on Exhibit A-16, Schedule F3 by
8		reviewing and allocating the specific cost of service components to the type of
9		service, underground or overhead, and then further allocating them to the individual
10		lighting technologies. There were no changes in the methodology for the allocation
11		of non-production O&M costs or capital-related costs to luminaire charges
12		proposed in this proceeding.
13		
14	Q58.	How was O&M allocated to the proposed E1 Rate Schedule luminaire charges
15		in the lighting model?
16	A58.	Total Distribution O&M expense reflected in the E1 Rate Schedule luminaire
17		charge is \$9.5 million, based upon the Company's cost of service model sponsored
18		by Witness Maroun. This distribution O&M expense is comprised \$3.2 million
19		directly assigned to lighting and recorded in account 596 (Street Lights & OPL),
20		\$3.5 million allocated to lighting from various distribution operation and
21		distribution maintenance accounts, \$1.3 million from various customer
22		service/sales accounts allocated to E1 Rate Schedule lighting and \$1.5 million of
23		total A&G expense. Based upon the underlying labor costs within account 596 and
24		the various distribution operation, distribution maintenance and customer service
25		accounts allocated to E1 Rate Schedule lighting, approximately 41%, or \$0.6

Line <u>No.</u>		K. A. BELLINI U-21534
1		million, of A&G expense was directly allocated to E1 Option I Rate Schedule
2		lighting and the balance was allocated to the various distribution O&M accounts
3		within the E1 Rate Schedule.
4		
5		The total customer service and distribution O&M expense allocated to lighting,
6		including A&G allocated to these accounts, was further allocated to the various E1
7		Rate Schedule luminaire/distribution charges based upon the system wattage of the
8		luminaires and lamps. With the exception of post inspection, night patrols and post
9		painting, all O&M (\$3.2 million) and A&G (\$0.6 million) directly assigned to
10		lighting was spread equally across all luminaires. The O&M associated with post
11		inspection and post painting was spread equally to all underground fed luminaires.
12		
13	Q59.	How was depreciation expense allocated to the proposed E1 Option I Rate
13 14	Q59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model?
13 14 15	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire
13 14 15 16	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by
13 14 15 16 17	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the
13 14 15 16 17 18	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset
13 14 15 16 17 18 19	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and
13 14 15 16 17 18 19 20	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and intangible plant accounts allocated to lighting.
 13 14 15 16 17 18 19 20 21 	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and intangible plant accounts allocated to lighting.
 13 14 15 16 17 18 19 20 21 22 	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and intangible plant accounts allocated to lighting. The depreciation expense for overhead subaccount 373.01 (street lighting and
 13 14 15 16 17 18 19 20 21 22 23 	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and intangible plant accounts allocated to lighting. The depreciation expense for overhead subaccount 373.01 (street lighting and signal systems - overhead) was allocated directly to overhead fed luminaires, and
 13 14 15 16 17 18 19 20 21 22 23 24 	Q59. A59.	How was depreciation expense allocated to the proposed E1 Option I Rate Schedule luminaire charges in the lighting model? The total depreciation expense reflected in the E1 Option I Rate Schedule luminaire charges, as established in the Company's cost of service model supported by Witness Maroun, is \$27.6 million. This reflects \$20.3 million depreciation for the directly assigned lighting asset accounts, \$3.1 million for the distribution asset accounts allocated to lighting, and the balance associated with general and intangible plant accounts allocated to lighting. The depreciation expense for overhead subaccount 373.01 (street lighting and signal systems - overhead) was allocated directly to overhead fed luminaires, and depreciation expense for underground subaccount 373.02 (street lighting and signal

Line
<u>No.</u>

1		depreciation expense for overhead subaccount 373.03 (Street Lighting wire - OH)
2		was allocated to all overhead luminaires equally. The depreciation expense for
3		underground subaccount 373.04 (Street Lighting Wire/Cable - Underground) was
4		allocated to all underground-fed luminaires equally.
5		
6		The depreciation expense for both the overhead and underground luminaire
7		subaccounts (LED Overhead, LED Underground, and HID Overhead, HID
8		Underground) was allocated to the respective overhead and underground
9		luminaires based upon lighting technology, wattage and underlying original
10		investment. For instance, all underground-fed mercury vapor luminaires received
11		an allocation of depreciation expense from subaccount 373.05 (Street Lighting
12		Luminaires - HID Underground) based upon the luminaire type's investment and
13		underlying mercury vapor luminaire useful life.
14		
15		The depreciation expense that was allocated to lighting from distribution was
16		allocated to all underground and overhead lighting based upon each luminaire
17		type's system wattage the best representation of each lighting type's usage of the
18		distribution system.
19		
20	Q60.	How was the revenue requirement for other taxes, return on investment and
21		income tax allocated to the proposed E1 Option I Rate Schedule luminaire
22		charges?
23	A60.	All other components were allocated to the various luminaire types in a manner
24		similar to that employed for the related underlying depreciation expense. For the

<u>No.</u>

directly assigned street lighting asset subaccounts, other taxes, return on investment and income tax followed the allocation of net plant to each of the lighting types.

3

2

1

4 Q61. Do you believe the proposed allocation of costs reflected in the various E1 5 Option I Rate Schedule luminaire charges is reasonable?

A61. Yes. The methodology utilized in the lighting model to allocate each of the
individual cost of service components discretely, rather than in total, more
accurately reflects the cost to provide lighting service to underground and overhead
assets as well as the various lighting technologies. The use of the eight separate
asset subaccounts for allocation of the capital-related costs results in more accurate
rate setting based upon both how the lights are fed as well as the lighting
technology, wattage and luminaire investment.

13

14 Q62. How were the E1 Option II Rate Schedule charges developed?

15 A62. The E1 Option II Rate Schedule charges were developed based upon a share of the 16 production revenue requirement allocated by Witness Maroun in the Company's 17 cost of service model to the E1 Rate Schedule, a share of the distribution and 18 customer service revenue requirements allocated by Witness Maroun in the 19 Company's cost of service model to the E1 Rate Schedule and a small allocation of 20 the O&M expense directly assigned to the E1 Rate Schedule from Account 596. 21 The allocations of revenue requirement from production, distribution and customer 22 service to the E1 Option II Rate Schedule were accomplished on a per kWh basis 23 across all E1 Option II rates. The proposed rates for the E1 Option II Rate Schedule 24 are displayed in a luminaire charge, similar to that for Rate Schedule E1 Option I, 25 and energy charges, both capacity and non-capacity, in a cent/kWh format.

<u>No.</u>

1 Q63. How were the E1 Option III Rate Schedule charges developed?

2 A63. The E1 Option III Rate Schedule charges were developed based upon a share of the 3 total production revenue requirement allocated by Witness Maroun in the 4 Company's cost of service model to the E1 Rate Schedule, a share of the total 5 distribution revenue requirement allocated by Witness Maroun in the Company's 6 cost of service model to the E1 Rate Schedule and a share of the customer service 7 revenue requirement allocated by Witness Maroun in the Company's cost of service 8 model to the E1 Rate Schedule. The allocations of revenue requirement from 9 production, distribution and customer service to the E1 Option III Rate Schedule 10 were performed on an equal energy basis across all E1 Option III rates. The 11 proposed E1 Option III Rate Schedule distribution and energy charges, both 12 capacity and non-capacity, are displayed in a cent per kWh format, allowing for a 13 transparent comparison of lighting costs for the various luminaire system wattages 14 and the various lighting technologies.

15

16 Q64. How does your proposed cost allocation methodology impact the present rates 17 for the E1 Rate Schedule?

- A64. The cost allocation methodology described above and employed in the lighting
 model reflects a collective revenue deficiency for the E1 Rate Schedule options.
- 20

Q65. What is your proposal regarding rate design in this proceeding for Rate Schedule E1 Option I rates?

A65. I have proposed a continuation of the gradual move towards rates which are entirely
based upon cost of service for the lighting class. Consensus on this methodology
was reached in the lighting collaborative ordered in Case No. U-17767 and

		R. A. BELLINI
Line <u>No.</u>		U-21534
1		beginning with rate Case No. U-18014, the Rate Schedule E1 Option I lighting rates
2		are being gradually moved to rates which are entirely based upon cost of service.
3		
4	Q66.	How were the Rate Schedule E1 Option I proposed rates developed in this
5		proceeding?
6	A66.	The proposed Rate Schedule E1 Option I lighting rates were designed with two
7		goals in mind; (1) continue the gradual move to rates which are entirely cost based
8		and (2) minimize the impact of the proposed lighting rates on the monthly lighting
9		bill for any municipality. Using the lighting rate model, the first step towards
10		achievement of these goals was to limit the overall increase on any municipality
11		and/or total lighting rate to 1.5 times the proposed average increase in revenue
12		requirement. The second step of the process was to allocate the remaining revenue
13		deficiency for the Rate Schedule E1 Option I class, on a percentage basis, to all the
14		remaining lights.
15		
16	Rate S	Schedule D9
17	Q67.	How were the proposed rates for the D9 Rate Schedule determined?
18	A67.	The proposed luminaire rates for the D9 Rate Schedule for both commercial and
19		residential OPL service were developed based upon the allocated and directly
20		assigned distribution costs supported by Witness Maroun in the Company's cost of
21		service model. The luminaire rate design methodology employed in the lighting
22		model for the D9 Rate Schedule mirrors the methodology employed for the E1 Rate
23		Schedule with all allocated distribution costs assigned to luminaire charges based

upon energy consumption and the directly assigned costs allocated based upon theunderlying individual cost of service components. As I discussed earlier, the

Line No.		R. A. BELLINI U-21534
1		proposed energy charges, both capacity and non-capacity, for the D9 Rate Schedule
2		for both commercial and residential OPL service were developed collectively with
3		the E1 Rate Schedule energy charges.
4		
5	Q68.	Are all of the proposed luminaire rates for the D9 Rate Schedule entirely cost-
6		based?
7	A68.	No. The proposed rates for Rate Schedule D9 required the use of the same two-
8		step methodology to gradually achieve cost-based intra-class rates that was
9		employed for the E1 Option I Rate Schedule.
10		
11	Rate	Schedule E2
12	Q69.	How were the proposed Rate Schedule E2 charges determined?
13	A69.	The Rate Schedule E2 charges were developed based upon the production, both
14		capacity and non-capacity, and distribution revenue requirements allocated to Rate
15		Schedule E2 customers by Witness Maroun in the Company's cost of service
16		model. Each of the revenue requirement amounts were divided by the total
17		forecasted energy for the projected test period to arrive at a distribution rate, a non-
18		capacity energy rate and a capacity energy rate in cents/kWh.
19		
20	Q70.	How has Witness Maroun's presentation of the revenue deficiency for
21		production presented in this case impacted your rate design?
22	A70.	To allocate the targets to the lighting tariff energy charges, both capacity and non-
23		capacity, in the cost of service-based rate presentation, I have allocated the revenue
24		deficiency for Rate Schedule E2 to the E2 rate directly and I have allocated the total
25		D9 deficiency, and total E1 deficiency Rate Schedules to those energy rates in total.

Line <u>No.</u>		R. A. BELLINI U-21534
1	Q71.	Will you please describe Exhibit A-16, Schedule F8?
2	A71.	This exhibit contains the proposed tariff sheet changes which result from the pricing
3		changes described above.
4		
5	Q72.	Does this complete your direct testimony?
6	A72.	Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)	
DTE ELECTRIC COMPANY)	
for authority to increase its rates, amend)	
its rate schedules and rules governing the)	
distribution and supply of electric energy, and)	
for miscellaneous accounting authority.)	

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

PINA BENNETT

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF PINA BENNETT

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Pina Bennett (she/her/hers). My business address is: One Energy Plaza,
3		Detroit, Michigan 48226. I am employed by DTE Electric Company ("DTE
4		Electric" or "Company").
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	I graduated from Gujarat University (India) with a Bachelor of Science Degree in
11		Electronics. In addition, I received a master's degree in business administration
12		from Gujarat University in India. I have also completed several Company-
13		sponsored courses and attended various seminars and conferences to further my
14		professional development.
15		
16	Q4.	Do you have any professional certifications or other certifications?
17	A4.	Yes, I also hold a Lean Six Sigma Black Belt certification.
18		
19	Q5.	Please summarize your professional experience.
20	A5.	I began my career in India on the product management team at Torrel Cosmetics, a
21		division of Torrent Pharmaceuticals, where I was responsible for launching a range
22		of eleven skincare products. I worked in the business-to-business marketing
23		industry in Singapore and was a professor at S. K. Patel Institute of Management
24		& Computer Studies, teaching master's level marketing courses. While there, I
25		developed an executive marketing training program for corporate executives. I

Line <u>No.</u>	
1	joined I

1	joined DTE Electric in 2008 as the program owner for the Outdoor Protective
2	Lighting program, in the Community Lighting organization, which was part of the
3	DTE Electric Regulated Marketing organization. Between 2010 and 2018, I held a
4	number of Chief of Staff positions across DTE Electric and DTE Energy Corporate
5	Services (LLC). These positions had varying titles and supported the Vice President
6	of Marketing, Vice President of Distribution Operations, Senior Vice President of
7	Distribution Operations, Chief Administrative Officer, and Chief Nuclear Officer.
8	In these roles, I was responsible for providing strategic oversight and organizational
9	accountability for business success. I then became the Manager of Joint Use
10	Operations within DTE Electric Sales and Marketing. In this role, I was responsible
11	for managing third-party attachments to DTE Electric-owned assets. In November
12	2022, I started my current role as Director of Electric Marketing in the Electric
13	Sales and Marketing organization of DTE Electric.
14	

15 Q6. What are your current duties and responsibilities?

- A6. My responsibilities as Director of Electric Marketing span three primary focus
 areas:
- Transportation Electrification: support and accelerate EV adoption within DTE
 Electric's service territory and help the State of Michigan achieve its
 decarbonization goals;
- New Product Development: assess and provide products and services, which
 support customer satisfaction and customer affordability, under the Value Added Programs and Services ("VAPS") regulations;

Line <u>No.</u>	P. BENNETT U-21534
1	3. Customer Marketing: communicate with customers regarding DTE Electric
2	rates and tariffs for electric service and address customer inquiries or
3	complaints.

1 **Purpose of Testimony**

2	Q7.	What is th	e purpose of yo	our testimony?						
3	A7.	The purpos	e of my testimo	ny is to explain and support the programs, policies, and						
4		Company	departments, alo	ong with any associated costs, for the five following						
5		areas:								
6		1. Status o	1. Status of existing Charging Forward program components;							
7		2. The Cor	npany's proposa	al for a Transportation Electrification Plan ("TEP");						
8		3. Custome	er Collection – N	Merchant Fee expense;						
9		4. Certain	expenditures rel	ated to the 2023 full time-of-day ("TOD") roll out; and,						
10		5. Electric	Regulated Mark	ceting operations and maintenance ("O&M") expense.						
11			-							
12	Q8.	Are you sp	onsoring any e	xhibits in this proceeding?						
13	A8.	Yes. I am s	ponsoring the fo	ollowing exhibits:						
14		Exhibit	Schedule	Description						
15		A-12	B5.9	Charging Forward Cost Projections						
16		A-13	C5.7.1	Customer Service-Credit/Debit Card Merchant Fees						
17		A-13	C5.9	Regulated Marketing Projected O&M Expenses						
18		A-13	C5.9.2	TOD Regulatory Asset Deferral						
19		A-29	T1	Charging Forward 4 th Annual Status Report						
20										
21	Q9.	Were these	e exhibits prepa	ared by you or under your direction?						
22	A9.	Exhibit A-2	29, Schedule T1	was prepared under my direction pursuant to the Orders						
23		dated May	2, 2019 and	May 8, 2020 in Case Nos. U-20162 and U-20561,						
24		respectivel	y. Exhibit A-1	3, Schedule C5.9.2 is co-sponsored with Company						

PB-4

Line

		P. BENNETT
Line No.		U-21534
1		Witnesses Hatsios and Sparks. The remaining exhibits were prepared under my
2		direction in support of the instant case.
3		
4	1. <u>St</u>	atus of Existing Charging Forward Program Components
5	Q10.	What is the status of the pilots in the existing Charging Forward program?
6	A10.	In May 2019, the Commission issued an Order in Case No. U-20162 approving the
7		original Charging Forward and funding was exhausted by year-end 2023. Building
8		on the momentum of the fleet element in the original Charging Forward program,
9		the Company proposed Charging Forward eFleets ("eFleets") in Case No. U-20935
10		in December 2020 and received approval in March 2021. The third iteration of
11		funding for the Charging Forward Expansion ("Expansion") was approved in
12		November 2022 in Case No. U-20836. Most recently, in December 2023, the
13		Michigan Public Service Commission ("MPSC") approved funding in Case No. U-
14		21297 to continue Charging Forward programming through 2024.
15		
16	Q11.	What elements of Charging Forward programming are categorized as
17		permanent programs or pilots?
18	A11.	The Charging Forward programming elements are categorized as follows:
19		• Permanent program offerings ¹ : Education & Outreach, Emerging
20		Technology Fund, and Program Administration;
21		• Pilot offerings: Home Charger Rebates, Home Charger Install, EV Rebates,
22		Business Charger Rebates, Business Charger Installation, eFleet Charger
23		Rebate, eFleet Battery Support, School Bus Chargers and Charging Hubs.
24		

¹ As approved annually through 2028 with the December 1, 2023 Order in Case No. U-21297

P. BENNETT U-21534

	What is the Compan	y's tota	l expec	ted inv	estmen	t for tl	ne existi	ng Chai
2	Forward program?							
3 A12.	The total actual and est	imated f	future in	vestme	nts for t	he exist	ing Char	ging For
4	program, through the e	end of 20)24, are	summa	rized in	n Table	1 below.	
5								
6 7	Fable 1Actual &	Estima	ted Pro	gram I	nvestm	ent (in	\$ thousa	unds) by
7			Ele	ment ²				
8								1
	Program Element	2019	2020	2021	2022	2023	2024	Total
	Program	273	448	648	965	1,610	1,813	5,757
	Administration	202	202	265	1 216	1.026	1 200	5 001
	Business and eFleet	162	511	1,858	2,599	2,927	1,800	20,054
	Charger Rebates Home Charger					520		520
	Installation							
	Business Charger Install	ation				0.6	3,315	3,315
	Charging Hubs					96	1,800	1,896
	School Bus Chargers						5,000	5,000
	Residential Customer Rebates ³	48	121	290	655	1,828	2,000	2,000 4,941
		227	119	112	564			1.022
	Additional Elements		117	112	201			1,022
	Emerging Tech Fund					825	1,000	1,825

 ² Differences in totals due to rounding
 ³ Residential Customer Rebates include Home Charger Rebates and EV Rebates

2										
2		Spond Type	2010	2020	2021	2022	2022	2024	Total	
		Capital	<u>2019</u> 64	2020	196	15	994	12.509	13.778	
		O&M	01		170	10	922	2,293	3,214	
		Regulatory Asset	1,028	1,401	3,078	5,985	6,927	15,922	34,341	
		Total	1,092	1,401	3,274	6,000	8,842	30,724	51,332	
3		Exhibit A-12, Sche	dule B	5.9 show	vs the to	otal esti	mated c	alendar y	ear invest	tment
4		(lines 1 through 24)	for the	followi	ng perio	ods:				
5		January, 1 2	022 to I	Decemb	er 31, 20	022 ("hi	storical	period")	in column	(b);
6		January 1, 2	023 to I	Decemb	er 31, 20	024 ("br	idge per	riod") in c	column (e)); and
7		 Total actua 	l and e	stimate	d pilot	and per	rmanent	program	costs fo	or the
8		historical an	nd bridg	ge perio	ds are \$	56,000 ti	housand	and \$39	,566 thou	sand,
9		respectively	, as sho	wn in li	ne 24.					
10										
11	Q13.	What are the cost	s incluc	led in P	rogram	Admin	istratio	n?		
12	A13.	The December 1,	2023 O	order in	Case N	o. U-21	297 app	proved \$1	.8M in a	nnual
13		O&M costs for Ex	pansion	Program	n Admii	nistratio	n. The	Decembe	r 1, 2023 (Order
14		in Case No. U-212	97 also	continu	ied regu	latory as	sset trea	tment for	approxim	nately
15		an average of \$0.8	million	in annu	al costs	through	the proj	ected test	year for e	Fleet
16		Advisory Services	, which	was or	riginally	approv	ed in C	ase No.	U-20935. ⁴	⁵ The
17		combined Program	n Admir	nistratio	n invest	ment er	abled c	ommon e	elements f	`or all
18		permanent program	ns and p	oilots ap	proved	in the C	harging	Forward	program,	to be
19		managed by a sin	gle bud	lget and	l admin	istrative	team. '	The Com	ipany is i	n the
20		process of ramping	g up a 14	4-persor	n team to	o accom	plish the	e objectiv	es address	sed in
21		Case No. U-21297	. The ad	ministra	ative tea	m, curre	ently at t	en Full T	ime Emple	oyees

Actual & Estimated Program Investment (in thousands) by Type⁴

Line <u>No.</u>

1

Table 2

⁴ Differences in totals due to rounding
⁵ This approved plan for eFleet Advisory services spans the calendar years 2021 through 2025.

1		(FTEs), allocates 40% of its resources to eFleets (regulatory asset), 15% (capital)
2		to reflect the work on capital projects, and 45% (O&M) on all other initiatives. By
3		2025, all Program Administrative spend will move to O&M. These expenditures
4		are shown in lines 2, 12 and 15 of Exhibit A-12, Schedule B5.9 with actual
5		investments of \$1.0 million and \$3.4 million for the historical and bridge periods
6		in columns (b) and (e), respectively.
7		
8	Q14.	What are the costs for Education and Outreach (E&O)?
9	A14.	There are no modifications to the Company's combined E&O budget for the
10		Charging Forward program, as proposed and approved with the December 1, 2023
11		Order in Case No. U-21297, at a total of \$1.5 million annually in O&M and \$0.3
12		million in regulatory assets for eFleets. Lines 11 and 16 of Exhibit A-12, Schedule
13		B5.9, shows the actual investment of \$1.2 million for the historical period in
14		column (b) and \$2.8 million for the bridge period in column (e).
15		
16	Q15.	What are the costs for Business and eFleet Charger Rebates?
17	A15.	The Company was approved a total of \$24.4 million, with the December 1, 2023
18		Order in Case No. U-21297, for Business and eFleet Charger Rebates. This total
19		includes \$5.8 million to exhaust funding of the original Charging Forward pilot
20		through 2023, \$6.9 million for eFleets Business Charger Rebates through 2024, and
21		\$11.7 million for Expansion's Business Charger Rebates through 2024. The
22		Company incurred decreased levels of approved and installed DCFC sites after
23		implementing additional requirements ⁶ as ordered by the Commission that aligned

⁶ DTEE site requirements and preferred site conditions for DCFC sites are available at https://www.dteenergy.com/content/dam/dteenergy/deg/website/business/service-and-price/pev/plug-in-electric-vehicles-pev/DCFCSiteRequirements.pdf

1 with the National Electric Vehicle Infrastructure (NEVI) projects. Furthermore, 2 the Company's capital costs for public commercial DC fast chargers (DCFCs) 3 turned out to be lower than initially projected. The conservative approach taken 4 during the pilot phase contributed to this outcome and we intend to deploy these 5 funds in 2024 to support projects that have well-justified use cases to ensure prudent 6 investment. The eFleet project installations, tied to recipients of the Environmental 7 Protection Agency's Clean School Bus Rebate Program, were also more 8 conservative in terms of spend and timing. As a result of these insights, the 9 Company reduced the total budget for this component by approximately \$10 10 million. Added together, lines 3 and 18 of Exhibit A-12, Schedule B5.9, show the 11 actual and projected investment of \$2.6 million for the historical period and \$14.9 12 million for the bridge period in column (b) and (e) respectively. We intend to deploy 13 these funds in 2024 to support projects that are well-justified use cases to ensure 14 prudent investment.

15

Line

No.

16 Q16. What are the costs for Home Charger Installation?

A16. The Company was approved \$2.3 million, with the November 2022 Order in Case
No. U-20836, for Home Charger Installation. The pilot commenced in early 2023
and by the end of 2023, had provided turnkey charger installation solutions for over
600 residential customers and approved over 40 installations scheduled to be
completed in 2024, reducing financial and physical installation barriers to home
charger ownership and EVs.

23

With the initial set up of the pilot for financing home EV charger installations, there was an overestimation of the capital expenditures required for the program. While

1		the Company incurred upfront costs of \$2.4 million to purchase and install the
2		chargers and develop the necessary IT systems to set up and support the program,
3		the appropriate accounting treatment is to record \$1.9 million of these expenses as
4		Receivables from customers. Instead of recovering the Receivables through base
5		rates, the Company recovers those costs through a fee added to participating
6		customers' bills. Thus the \$1.9 million Receivable is not proposed to be included
7		as part of the Company's base rate request in the instant case and is not included in
8		Exhibit A-12, Schedule B5.9, Line 4, column (e). The remaining \$0.5M of capital
9		expenditure covers IT and program setup costs.
10		
11		Additionally, around mid-year 2023, the Company received intervenor feedback on
12		transitioning the pilot to value-added programs and services ("VAPS"), which also
13		resulted in scaling back the investment as a regulated offering. With the recent
14		December 1, 2023, Order for Case No. U-21297, the Home Charger Installation
15		pilot has been terminated and the Company anticipates transitioning it to VAPS in
16		2024. Line 4 of Exhibit A-12, Schedule B5.9 shows zero actual costs in column (b)
17		and bridge period costs of \$0.5 million in column (e).
18		
19	Q17.	What are the costs for Business Charger Installation?
20	A17.	The Company was approved \$3.57 million with the December 1, 2023 Order in
21		Case No. U-21297 for Business Charger Installation. Lines 5 and 19 of Exhibit A-
22		12, Schedule B5.9 show zero actual costs in column (b) and \$3.3 million for bridge
23		period costs in column (e).
24		

⁷ Total of \$1.2 million for bridge period (\$0.5 million capital and \$0.7 million regulatory asset) and a total \$2.3 million for test period (\$1.0 million capital and approximately \$1.3 million regulatory asset)

1	Q18.	What is the status of the Business Charger Installation program?
2	A18.	Originally, the Company was meant to own the chargers. Instead, the pilot was
3		modified to have the site hosts take ownership, while DTE Electric provides full
4		support for utility infrastructure, customer readiness, and charger expenses. The
5		Company intends to deploy the bridge period funding in 2024.
6		
7	Q19.	What are the costs for Charging Hubs?
8	A19.	The Company was approved \$2.8 million, with the November 2022 Order in Case
9		No. U-20836, and \$2.7 million, with the December 2023 Order in Case No. U-
10		21297, for Charging Hubs. Line 6 of Exhibit A-12, Schedule B5.9 shows zero
11		actual costs in column (b), \$1.9 million for bridge period costs in column (e) and
12		\$3.5 million for the projected test period costs in column (f).
13		
14	Q20.	What is the status for the Charging Hubs pilot?
15	A20.	DTE Electric was approved to begin construction on up to two Charging Hubs
16		designed for medium- and heavy-duty fleet vehicles providing multiple fast
17		chargers in a single location. The Company is collaborating with federal grant
18		partners, such as the State of Michigan, and Detroit Diesel (Daimler Truck North
19		America) to fulfill grant requirements for the Department of Transportation's
20		Rebuilding American Infrastructure with Sustainability and Equity, or "RAISE"
21		program that awarded \$8.5M of funding for the buildout of the first Charging Hub
22		in Redford. The Company is focused on executing key activities in the bridge and
23		test period which include defining roles and establishing partnership agreements,
24		finalizing the scope of work through cross-coordination with partners, launching
25		an RFP for the start of site design and engineering in 2024, and start of construction
Line		P. BENNETT U-21534
------------	------	---
<u>No.</u>		
1		in 2025. Furthermore, the Company is scouting additional prospective sites to start
2		construction in 2025 while also looking for available federal and state grant
3		opportunities to maximize awards to the Southeast Michigan region in which DTE
4		Electric serves.
5		
6	Q21.	What are the costs for eFleet Battery Support?
7	A21.	The Company was approved \$2.0 million, with the November 2022 Order in Case
8		No. U-20836, and \$3.0 million, with the December 1, 2023 Order in Case No. U-
9		21297, for eFleet Battery Support. Line 7 of Exhibit A-12, Schedule B5.9 shows
10		zero actual costs in column (b) and \$5.0 million for bridge period costs in column
11		(e). The Company intends to continue to seek partners, in 2024, in support of the
12		program.
13		
14	Q22.	What are the costs for School Bus Chargers?
15	A22.	The Company received approval for \$2.0 million with the December 1, 2023 Order
16		in Case No. U-21297. Line 22 of Exhibit A-12, Schedule B5.9 shows zero actual
17		costs in column (b) and \$2.0 million for bridge period costs in column (e).Since
18		approval in December 2023, the Company has been working to establish the
19		program and intends to deploy the funding in 2024.
20		
21	Q23.	What are the costs for Residential Customer Rebates?
22	A23.	Residential Customer Rebates include Home Charger Rebates and EV Rebates. The
23		Company received approval for \$2.0 million with the November 2022 Order in
24		Case No. U-20836, proposed \$1.0 million for Home Charger Rebates and \$1.0
25		million for EV Rebates in Case No. U-21297 and was approved a total of \$2.0

PB-12

		P. BENNETT
Line <u>No.</u>		U-21534
1		million for both Residential Customer Rebates pilots. Line 17 of Exhibit A-12,
2		Schedule B5.9 shows the actual investment of \$0.7 million in column (b) and bridge
3		period costs of \$3.8 million in column (e).
4		
5	Q24.	What are the costs included in Additional Elements?
6	A24.	In the November 2022 Order for Case No. U-20836, the Company was approved
7		to exhaust the remaining funding for the \$0.6 million budget as part of the expanded
8		scope of Charging Forward based on stakeholder feedback ⁸ . The funding for the
9		three Additional Elements supported costs for an EV-Grid Impact Study, an EV-
10		Ready Builder Rebate Pilot (as proposed in Case No. U-20561), and an EV-Only
11		Off-Peak Incentive Pilot ("Bring Your Own Charger"). Line 20 of Exhibit A-12,
12		Schedule B5.9 shows the actual costs of \$0.6 million in column (b) and zero bridge
13		period costs in column (e).
14		
15	Q25.	What are the costs for the Emerging Technology Fund?
16	A25.	The Emerging Technology Fund was approved for \$0.9 million in Case No. U-
17		20836, and \$1.0 million annually for five years (through year 2028) with Case No.
18		U-21297. Line 21 of Exhibit A-12, Schedule B5.9 shows zero actual costs in
19		column (b) and \$1.8 million in bridge period costs in column (e).
20		
21	2. <u>Tł</u>	ne Company's Proposal for a Transportation Electrification Plan (TEP)
22	Q26.	What is the purpose of this section?
23	A26.	In Case No. U-20836, the MPSC requested DTE Electric "to prepare and submit,
24		with its next rate case, a full scale, well-developed, permanent Charging Forward

⁸ Detailed further in the 3rd Annual Status Report (Exhibit A-29, Schedule T1) available at https://mipsc.my.site.com/sfc/servlet.shepherd/version/download/0688y0000038iECAAY

1		proposal that includes a BCA [benefit-cost analysis]." As a result, the Company has
2		spent the last year and a half developing a comprehensive TEP with robust analyses
3		and careful evaluation of the role of the utility along with in-depth benchmarking
4		and stakeholder consultation. The purpose of this section is to discuss the full TEP
5		portfolio - approach, programs, and benefit-cost analysis - and seek approval of
6		the expense for administering the TEP in 2025.
7		
8	Q27.	How is this portion of your testimony structured?
9	A27.	This portion of my testimony is organized into the following four sub-sections:
10		I. Background and Approach
11		II. TEP Portfolio Proposal
12		III. TEP Benefit Cost Analysis
13		IV. TEP Investment
14		
15	I.	Background and Approach
16	Q28.	What is DTE Electric's overall vision for its TEP?
17	A28.	DTE Electric's goal is to power and enable a cleaner energy future for its customers
18		through transportation electrification. The Company aims to do this in a series of
19		ways:
20		 create a plan that enhances the state's charging network and provides
21		customers beneficial electric pricing options along with education and
22		advisory services to help accelerate customers' journeys to Electric Vehicle
23		("EV") adoption,
24		 amplify EV benefits for all customers and intentionally break down barriers
25		for low- and moderate-income customers and disadvantaged communities,

Line		P. BENNETT U-21534
<u>No.</u>		0 2100 1
1		 integrate EV load with the grid of the future by using advanced technologies
2		to reduce peak demand and minimize costs to all customers, and
3		 deliver reliable, cleaner energy to power EVs and reduce state-wide carbon
4		emissions.
5		
6	Q29.	What are the Company's guiding principles used to develop the TEP?
7	A29.	DTE Electric adhered to the following guiding principles in the development of the
8		TEP:
9		• Support and accelerate EV adoption by facilitating charger deployment
10		while ensuring that the portfolio maintains affordability benefits for all DTE
11		Electric customers,
12		• Consider unique reasons for utility participation such as closing charging
13		gaps and improving economics of electrification in the near-term, and
14		 Promote equity by focusing on low-income ("LI") customers and
15		disadvantaged communities ("DACs").
16		
17	Q30.	What was the Company's approach to developing the TEP?
18	A30.	The Company spent the last 15 months developing a comprehensive TEP by:
19		1. Conducting in-depth benchmarking,
20		2. Evaluating likely service requirements, including the number of chargers,
21		charging infrastructure needed, and investment required,
22		3. Creating a framework to guide utility investment based on the Company's guiding
23		principles, and,
24		4. Seeking stakeholder feedback, which was incorporated at multiple points in this
25		process.

		P. BENNETT
Line <u>No.</u>		U-21534
1		Each of these steps is discussed in more detail below.
2		
3	Q31.	What was the Company's benchmarking process?
4	A31.	The Company analyzed six utility TEPs in-depth, ⁹ chosen because of their recent
5		proposal or approval and the robustness of their included programs. The Company
6		also reviewed an industry benchmarking report in detail, ¹⁰ and has consistently
7		participated in national EV working groups. ¹¹ This work helped guide DTE
8		Electric's strategy and TEP development.
9		

- ComEd Beneficial Electrification Plan available at <u>https://icc.illinois.gov/docket/P2022-0432/documents/325766/files/567114.pdf</u>, accessed December 5, 2023
- ConEd Electric Vehicle Infrastructure Make-Ready Program Implementation Plan available at https://documents.dps.ny.gov/public/Common/ViewDoc.aspx?DocRefId=%7b181AB1C0-0F11-44F6-B652-5705D91EC1B3%7d, accessed December 5, 2023
- National Grid Direct Pre-filed Testimony of the Electric Vehicle Program Panel Exhibit NG-EVPP-1 available at <u>https://fileservice.eea.comacloud.net/FileService.Api/file/FileRoom/13758106</u>, accessed December 5, 2023
- SCE Application of Southern California Edison Company (U338E) for Approval of its Charge Ready 2 Infrastructure and Market Education Programs available at <u>https://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M346/K230/346230115.PDF</u>, accessed December 5, 2023
- SCE Decision on the Transportation Electrification Standard Review Projects, SCE's Mediumand Heavy-Duty Vehicle Charging Infrastructure Program available at <u>https://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M215/K783/215783846.PDF</u>, accessed December 5, 2023
- Xcel Colorado Transportation Electrification Plan 2021-2023 available at <u>https://www.xcelenergy.com/staticfiles/xe-</u> responsive/Company/Rates%20&%20Regulations/Regulatory%20Filings/20A-0204E-_2021-<u>2023 TEP_Updated.pdf</u>, accessed December 5, 2023
- Xcel Minnesota Petition of Northern States Power Company for Approval of a Public Charging Network, an Electric School Bus Pilot, and Program Modifications available at <u>https://www.edockets.state.mn.us/edockets/searchDocuments.do?method=showPoup&documentI</u> <u>d=%7b90B25F82-0000-C32B-B70E-1C25A3E2A491%7d&documentTitle=20228-188061-07</u>, accessed December 5, 2023

¹⁰ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023

¹¹ Alliance for Transportation Electrification, Midcontinent Transportation Electrification Collaborative, Electric Power Research Institute

⁹ The six utilities included in benchmarking include Commonwealth Edison (ComEd), Consolidated Edison (ConEd), National Grid Massachusetts (National Grid), Southern California Edison (SCE), Xcel Colorado, and Xcel Minnesota. The TEPs benchmarked are:

1 Q32. What was the Company's high-level overview from the review of the TEPs?

- 2 A32. The table below shows a high-level summary of the six TEPs at the time DTE
- 3 Electric benchmarked them.
- 4
- Table 3Overview of Six TEPs Benchmarked as of Q4 202212,13
- 5

Company	State	Electric	Program	Investment	# Charger	2030 EV
		Customers	Years	(\$ millions)	Ports	Forecasts
		(millions)			(L2 DCFC)	
ComEd	IL	4.1	'23-'25	\$270	7,730 196	700,000
ConEd	NY	3.8	'21-'25	\$290	18,500 457	500,000
National	MA	2.2	'22-'25	\$278	31,400 393	500,000
Grid						
SCE	CA	1.4	'21-'25	\$793	24,500 205	2,600,000
Xcel CO	CO	5.2	'21-'23	\$108	19,800 210	500,000
Xcel MN	MN	1.5	'23-'26	\$384	0 1,470	797,000

6

7

There are several key themes that emerged from the benchmarking:

- 8 1. Most of the TEPs outline investment and programs for a three- to five-year 9 timeframe, which is longer than a typical general rate case bridge and test period,
- 10
 2. The TEPs can accommodate programmatic changes, as needed, in a dynamic
 environment,
- The TEPs generally emphasized Level 2 charging over DCFC to improve overall
 customer affordability, due to the higher number of use cases for Level 2
 charging, lower costs of installing Level 2 chargers compared to DCFCs, and
 minimized grid impact, and

¹² Data for investment, program years, electric customers, and 2030 EV forecasts sourced from company TEP filings. Exceptions: # Charge Ports for SCE does not include the 870 sites approved for the Charge Ready Transport medium-duty and heavy-duty vehicle program; 2030 EV forecasts for ComEd and ConEd were estimated based on state EV targets and customer size

¹³ Since Q4 2022, Xcel CO has reached a settlement agreement on its TEP, Xcel MN has since withdrawn its TEP, and National Grid has since received approval for portions of its TEP

4. The TEPs often include an emphasis on compliance with statewide regulations,
 equity, multi-unit dwelling and fleet segments, supporting functions, and
 managing incremental EV load, as well as a trend towards make-ready
 incentives as opposed to utility ownership, discussed in more detail below.

5

6 Q33. What has the Company found with respect to TEP regulation?

7 From a compliance perspective, seven states have legislative or regulatory A33. 8 requirements for their investor-owned utilities to file periodic TEPs with their 9 utility commissions that describe the utilities' transportation electrification efforts 10 for the next three to five years. Utilities in Colorado, Illinois, New Mexico, Oregon, 11 and Washington are required to make such filings by state legislation while utilities 12 in Arizona and Virginia are required to do so by their utility commissions. States 13 that require TEPs generally call for updates every three to five years, reflecting the 14 need to modify programming based on experience as well as to revise plans to 15 address new transportation electrification goals or emerging state policies.¹⁴

16

Most states do not have requirements for their utilities to submit periodic comprehensive TEPs, including many states with utilities that are actively investing in transportation electrification. California and New York, together, account for most of the \$3 billion in approved utility TE investments over the last 10 years in the United States, yet neither state requires utilities to engage in a comprehensive TEP process (although it has been proposed in California). In states like these, utilities have filed TEPs to align with statewide environmental initiatives including

¹⁴ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023

> statutory EV targets.¹⁵ The most impactful of these has been California's Zero-1 2 Emission Vehicle ("ZEV") program and the related regulations that have set 3 increasingly stringent EV sales targets in California since 1990, with the most recent 4 amendment to the regulations, called the Advanced Clean Cars II regulations, 5 requiring all new passenger vehicles sold in California to be zero-emission by 2035. Fifteen other states have since adopted the program.¹⁶ These states and California 6 7 are collectively called ZEV states, and their share of national EV sales is higher than their share of the national population.¹⁷ This makes TEPs more likely to be filed in 8 9 these states compared to non-ZEV states.

10

11 Q34. What has the Company found with respect to TEP equity policies?

12 A34. An emphasis on equity, through supporting DACs and low- and moderate- income 13 ("LMI") residential customers, is a key theme in most TEPs. The TEPs 14 benchmarked incorporated an equity focus in 20 to 40 percent of total plan investments. The most common way in which these utilities are focusing on equity 15 is through enhanced program offerings for commercial customers located in DACs 16 (the definition varying by utility and state) and for residential customers that are 17 18 either located in DACs or that meet an income threshold set by the utility. For 19 example, National Grid proposed \$1,700 in make-ready and charger rebates for 20 customers that are in designated Environmental Justice Communities or that meet

¹⁵ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023

¹⁶ Colorado, Connecticut, Delaware, Maine, Maryland, Massachusetts, Minnesota, New York, New Jersey, Nevada, Oregon, Rhode Island, Washington, Vermont, and Virginia

¹⁷ Evaluating Electric Vehicle Market Growth Across U.S. Cities available at <u>https://theicct.org/wp-content/uploads/2021/12/ev-us-market-growth-cities-sept21_0.pdf</u>, accessed December 5, 2023

т:		P. BENNETT
Line <u>No.</u>		0-21534
1		the low-income threshold and only up to \$1,000 for single-family homes ("SFHs")
2		that do not meet these criteria. ¹⁸
3		
4	Q35.	What has the Company found with respect to MUD and fleet policies?
5	A35.	MUDS and fleets receive unique attention in most TEPs. MUDs do, mainly because
6		of the coordination issues between residents and those who own the property or
7		have a say in how it is managed, such as landlords or Homeowners Associations.
8		These coordination issues stem from the residents wanting EV charging but needing
9		these other stakeholders to approve or pursue the installation for them. Unless
10		landlords and Homeowners Associations are motivated to do this, MUD residents
11		are left without the ability to freely install chargers like single-family homeowners
12		can. There is also typically an equity focus. The TEPs benchmarked by the
13		Company feature increased incentives for, or programs limited to, MUDs located
14		in DACs, MUDs serving LMI residents, or having some other equity focus. For
15		example, Xcel Colorado has a utility-owned make-ready infrastructure program for
16		MUDs and offers a charger rebate for MUDs that meet income-qualified criteria or
17		that are in high emissions communities. ¹⁹
18		
19		Fleets, particularly medium- and heavy-duty vehicles ("MHDVs"), transit buses,
20		and school buses, are another segment that receive unique attention, especially
21		among larger utilities. Southern California Edison (SCE) has dedicated \$356 million

 ¹⁸ National Grid Direct Pre-filed Testimony of the Electric Vehicle Program Panel Exhibit NG-EVPP-1 available at <u>https://fileservice.eea.comacloud.net/FileService.Api/file/FileRoom/13758106</u>, accessed December 5, 2023; Environmental Justice Communities defined by the State of Massachusetts
 ¹⁹ Xcel Colorado Transportation Electrification Plan 2021-2023 available at https://www.xcelenergy.com/staticfiles/xe-responsive/Company/Rates%20&%20Regulations/Regulatory%20Filings/20A-0204E-_2021-2023_TEP_Updated.pdf, accessed December 5, 2023

	through its Charge Ready Transport TEP to support the electrification of MHDVs
	by providing low- or no-cost charging infrastructure. ^{20, 21} As observed with MUDs,
	some TEPs also have equity-focused programs or enhanced incentives within their
	fleet programming. For example, Commonwealth Edison's (ComEd's) TEP
	proposal included a \$120,000 rebate for electric school bus purchases while the
	rebate for the buses serving DACs is 50% higher at \$180,000. ²²
Q36.	What has the Company found with respect to the nature of TEP incentives?
A36.	Make-ready infrastructure programs are the most commonly offered type of
	incentive program in the TEPs. A greater share of TEP capital budgets is allocated
	to make-ready infrastructure programs versus own-and-operate programs. ²³ In an
	analysis of all United States utility TE filings from 2012 through Q3 2022,
	conducted by the Midcontinent Transportation Electrification Collaborative in
	2022, nearly \$2 billion had been allocated for make-ready infrastructure programs,
	whereas in that same period, less than \$1 billion had been allocated for utility own-
	and-operate programs. ²⁴ DTE Electric's benchmarking found this trend to be
	consistent in the three TEPs with significant capital budgets (excluding Xcel
	Minnesota's withdrawn proposal), with 90% of their capital budgets being
	Q36. A36.

²⁰ SCE Decision on the Transportation Electrification Standard Review Projects, SCE's Medium- and Heavy-Duty Vehicle Charging Infrastructure Program available at <u>https://docs.cpuc.ca.gov/PublishedDocs/Published/G000/M215/K783/215783846.PDF</u>, accessed December

5, 2023

²¹ Charge Ready Transport Advances Despite Pandemic-Related Challenges available at <u>Charge Ready</u> <u>Transport Advances Despite Pandemic-Related Challenges | Energized by Edison</u>, accessed December 15, 2023

²² ComEd Beneficial Electrification Plan available at <u>https://icc.illinois.gov/docket/P2022-0432/documents/325766/files/567114.pdf</u>, accessed December 5, 2023

²³ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023

²⁴ Midcontinent Transportation Electrification Collaborative 2022 meeting; analysis only includes those filings listed on Atlas Public Policy EV Hub

Q37. What did the Company find with respect to the handling of supporting functions in the benchmarked TEPs?

3 A37. The benchmarked TEPs dedicate between 10% and 25% of their total TE spend on 4 other portfolio costs that include marketing, education, outreach, and program 5 support such as IT and program administration. Utilities recognize the need to 6 increase education on the benefits of EVs and spread awareness about their 7 programs. Proposals include expanding their websites and working with local car 8 dealerships. An extension of these programs, seen more commonly in the fleet 9 segment, includes advisory services such as call centers or dedicated staff to advise 10 customers. Per the ACEEE report, more than half the utility TEPs offer detailed 11 fleet advisory services, including fleet assessments, which give fleet operators 12 information on what electrification would cost them in terms of infrastructure investments and ongoing vehicle charging.²⁵ 13

14

15 Q38. What else did the Company learn?

16 All benchmarked utilities emphasize the importance of strategically managing the A38. incremental load from EV charging to mitigate grid impacts. Most utilities have 17 18 participant requirements or incentives that support managed charging or Time of 19 Day rates. Both can influence customer charging behavior by encouraging or 20 requiring charging during off-peak hours. All utilities offer TOD rates to their 21 residential program participants and use their educational resources to encourage 22 off-peak charging. Although all utilities recognize the importance of strategically 23 managing the transition of additional load from EVs, especially as adoption 24 increases, managed charging is still in a relatively nascent stage. Only two utility

²⁵ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023

Line No		P. BENNETT U-21534
1		TEPs, those of National Grid and Xcel Colorado, offer an additional incentive for
2		participants to enroll in managed charging programs, similar to the DTE Electric
3		Smart Charge program today. ^{26,27}
4		
5	Q39.	What is the forecasted market size for EV registrations in DTE Electric's
6		service territory?
7	A39.	In DTE Electric's service territory of Southeast Michigan, EV sales have grown at
8		a compound annual growth rate (CAGR) of 90% from 2019 to 2022, with
9		approximately 13,100 EVs sold in 2022, compared to about 1,900 EVs in 2019.
10		Year to date, 77% of the newly sold EVs in Michigan are registered in DTE
11		Electric's service territory and 74% of these are all-electric. ²⁸ There are currently
12		almost 46,000 EVs registered in Southeast Michigan, and, as shown in the Figure
13		below, the Company forecasts this number increasing to an estimated 326,000,
14		including MHDVs, by 2028, which is the timeframe of the Company's TEP. ²⁹
15		

²⁶ Utility Transportation Electrification Planning—Emerging Practices to Support EV Deployment available at <u>https://www.aceee.org/research-report/t2201</u>, accessed December 5, 2023 ²⁷ DTE Electric Smart Charge brochure available at

https://www.dteenergy.com/content/dam/dteenergy/deg/website/residential/Service-Request/pev/plug-in-electric-vehicles-pev/SmartChargeBrochure.pdf, accessed December 11, 2023 ²⁸ The balance are plug-in hybrid EVs; regenerative hybrids and hydrogen fuel cell vehicles are not

considered EVs ²⁹ Data for 2023 from S&P Global as of September 30, 2023; registration volumes (both actual and forecasted) include medium-duty and heavy-duty vehicles

1Figure 1DTEE Forecast of Annual New EV Registrations and2Cumulative Registered EVs 30



3

Line

No.

4 Q40. How did the Company arrive at this EV registration forecast?

5 A40. This EV registration forecast, shown in the figure above, was derived from a 6 combination of a short-term forecast developed using recent registration data from 7 S&P Global and a long-term forecast derived from forecasts published by industry 8 experts. For the short-term forecast in 2024 and 2025, EV registrations were 9 determined using an exponential regression based on EV registrations in DTE 10 Electric service territory from 2018 through 2023. For 2027 and 2028, DTE Electric EV registrations were derived from forecasts published in 2022 and 2023.³¹ To get 11 12 a Michigan EV forecast in the near term, a marginally lower forecast was factored 13 in to account for the lower growth rate in the near term for a non-ZEV state. The 14 fraction applied to the forecast to achieve this grows over time as, in the long term, 15 the Michigan EV sales rate is expected to be closer to the national EV sales rates. 16 2026 is the average of the forecast in 2025 and 2027, as it is the transitionary year

³⁰ Data for 2023 from S&P Global as of September 30, 2023; registration volumes (both actual and forecasted) include medium-duty and heavy-duty vehicles

³¹ Including those from Bloomberg New Energy Finance, Goldman Sachs, Electric Power Research Institute, International Council on Clean Transportation, Boston Consulting Group, and the U.S. Energy Information Administration

1 between the short- and long-term forecasts. The Michigan EV forecast is then 2 converted to a DTE Electric EV forecast by applying another factor representing 3 the percentage of new EVs registered in the DTE Electric service territory 4 compared to the total registered in the state. 5 6 Q41. What is the charging infrastructure required to support the forecasted EV 7 adoption? 8 A41. The forecast shows an estimated increase to 326,000 EV registrations in 2028 from 9 the approximately 46,000 EVs registered in DTE Electric's service territory in 10 Southeast Michigan today. This increase in forecasted EV registration equates to 11 approximately 238,000 chargers being needed in DTE Electric's service territory 12 over the four-year TEP time horizon, increasing from approximately 35,000 13 chargers annually in 2025 to 78,000 annually in 2028, as shown in the figure below. 14

15

Figure 2

Line

No.

Forecast of Incremental Chargers Needed in DTEE

16

Service Territory (thousands)



More than 80% of the estimated chargers needed to support the forecasted EV adoption from 2025 through 2028 are projected to be at single-family homes. The majority of the incremental chargers needed are Level 2 chargers, driven by the residential segment that includes both single-family homes and MUDs.

5

6 Q42. How was this charging infrastructure requirement evaluated?

A42. First, the Company developed an overview of the needs of the five primary
customer segments. The five primary customer segments are consistent with the
TEPs benchmarked and are described in the table below.

10

11

Table 4Overview of Primary Customer Segments and Needs

Segment	Customer Description	Market Needs
SFHs	Residential customers in detached homes which generally have a single electrical panel (includes buildings with three or fewer housing units)	 Longer duration charging is possible, so it can be served by Level 2 chargers (Level 1 charging was not considered for this analysis) Cost of installation, which can be as much as \$8,000, can be barrier for low- income customers
MUDs	Commercial customers with buildings that have four or more housing units. Parking may be in shared lots or designated parking spots	 Longer duration charging is possible, so it can be served by Level 2 chargers except in unique situations (e.g., no parking) If landlords lack motivation to install chargers, it deters EV adoption for residents
Public	Commercial customers owning chargers for public use, either at a destination (e.g., stores and restaurants) or on- route near a major throughway	 In some areas, Level 2 chargers are sufficient, but majority of charging needs, in the future, will be fulfilled by DCFCs that have a shorter charging time In 2023, there was a lack of public charging infrastructure in disadvantaged and rural communities

		identified within DTE Electric service territory
Fleet	Commercial customers owning chargers for business use. Fleets can be one or more light- duty vehicles and/or MHDVs	 Type of charger needed varies depending on type of EV, vehicle miles traveled, and parking duration(s) Large fleet depots, particularly for MHDVs, can have high installation costs
Workplace	Commercial customers owning chargers for employee use with their personally owned vehicles	• Longer duration charging is possible, so it can be served exclusively by Level 2 chargers. Over time, workplaces may be served by DCFCs, as well
Once the cu	stomer segments were det	fined, DTE Electric's EV registration forecast
was proport	ioned into each customer	segment.
The formul	a shown in the figure be	alow was used to calculate the incremental
	8	elow was used to calculate the incremental
number of c	hargers by customer segm	ent and charger type (Level 2 or DCFC) for a
number of c given year:	hargers by customer segment	nent and charger type (Level 2 or DCFC) for a
number of c given year: `igure 3	hargers by customer segment Formula for Incre	emental Number of Chargers, by
number of c given year: ` igure 3	hargers by customer segm Formula for Incre Customer Segmen	ent and charger type (Level 2 or DCFC) for a emental Number of Chargers, by at and Charger Type
number of c given year: 'igure 3	whargers by customer segmed Formula for Increa Customer Segmen Chargers = $\frac{Numb}{EVs \ per C}$	ent and charger type (Level 2 or DCFC) for a emental Number of Chargers, by at and Charger Type $\frac{er \ of \ EVs}{Charger \ Port} \times Charger \ Mix}{Ports \ per \ Charger}$
number of c given year: Tigure 3 The increme	The second seco	enow was used to calculate the incremental ment and charger type (Level 2 or DCFC) for a mental Number of Chargers, by at and Charger Type $\frac{er \ of \ EVs}{Charger \ Port} \times Charger \ Mix}{Ports \ per \ Charger}$ asted each year was divided by the number of
number of c given year: `igure 3 The increme EVs served	The second seco	enow was used to calculate the incremental ment and charger type (Level 2 or DCFC) for a mental Number of Chargers, by at and Charger Type $\frac{er \ of \ EVs}{Charger \ Port} \times Charger \ Mix}{Ports \ per \ Charger}$ asted each year was divided by the number of at the number of ports. EVs per charger port
number of c given year: 'igure 3 The increme EVs served is assumed t	The second state of the s	enow was used to calculate the incremental ment and charger type (Level 2 or DCFC) for a emental Number of Chargers, by at and Charger Type $\frac{er \ of \ EVs}{Charger \ Port} \times Charger \ Mix}{Ports \ per \ Charger}$ asted each year was divided by the number of at the number of ports. EVs per charger port the family homes and as high as approximately

Line <u>No.</u>		P. BENNETT U-21534
1		per charger port increases over time, as adoption of EVs increases and chargers are
2		utilized more efficiently.
3		
4		The number of ports calculated above was then segmented into charger type by
5		multiplying the number by the charger mix, which is a percentage representing the
6		assumed share of Level 2 or DCFC ports for that segment. The charger type for
7		single-family homes and MUDs was assumed to be 100% Level 2 chargers since
8		longer duration parking is expected. Public charging was assumed to be primarily
9		DCFCs. For fleet charging, the charger mix varies by use case and vehicle type; the
10		Company assumed 80% Level 2 charging for light-duty vehicles, 80% DCFCs for
11		larger vehicles and 100% DCFCs for buses.
12		
13		Finally, the number of ports for each charger type was divided by the number of
14		ports per charger to arrive at the number of chargers by customer segment. The
15		number of ports per charger ranges from one to 1.3, depending on the segment and
16		the year. For example, one port per charger is assumed for single-family homes and
17		school buses, while the need for public charging increases to 1.3 ports per charger
18		in 2028.
19		
20	Q43.	What is the estimated investment required to support the number of chargers
21		needed?
22	A43.	The approximately 238,000 incremental chargers needed over the four-year TEP
23		time horizon will require nearly \$1.9 billion of infrastructure investment, funded
24		by a mix of public, private, government, and utility sources, increasing from





7

8 Even though the public charging segment represents just 3% of the chargers needed, 9 as shown in the figure above, it is the largest driver of investment required in the 10 near term at nearly 40% due to the high costs of DCFCs and the associated 11 installation. Conversely, although the single-family home charging segment 12 represents over 80% of the total projected chargers, they only require about 25% of 13 the total investment since they are much less expensive.

2

4

5

6

1 Q44. What assumptions were made in order to calculate the estimated investment

- needed?
- 3 A44. DTE Electric data were used to define cost assumptions by charger segment and
 - type, as shown in the table below:

Table 5Average Approximate Installation Costs by Charger Type and

Segment, 2025-2028³²

7

8

True	Sameant	Utility Customer		EV	Total
гуре	Segment	Make-Ready	Make-Ready	Charger	Cost
	SFH	\$230	\$1,580	\$590	\$2,400
	MUD	\$1,360	\$13,600	\$590	\$15,550
Laval 2	Workplace	\$330	\$13,310	\$1,460	\$15,100
Level 2	Fleet	\$1,040	\$12,960	\$1,440	\$15,440
	Other Public	\$1,250	\$12,520	\$1,450	\$15,220
	School bus	\$16,510	\$61,900	\$32,750	\$111,160
	Transit bus	\$16,510	\$61,890	\$79,010	\$157,410
DCFC	Workplace	\$5,480	\$65,770	\$78,210	\$149,460
	Fleet	\$16,500	\$61,870	\$78,680	\$157,050
	On-route	\$20,630	\$61,890	\$78,790	\$161,310
	Destination	\$17,710	\$53,130	\$76,320	\$147,160

9

13

10 The Company also considered the following factors in developing its cost

- 11 assumptions:
- 12 Inflation,
 - Charger costs decreasing by 3% each year due to expected technological
- 14 advancements, and

³² Rounded to the nearest 10. Definitions and specific examples for utility make-ready, customer makeready, and EV charger equipment are provided in Table 7 below. Utility make-ready includes customerowed CIAC (typically 15% of total utility make-ready on average) and non-CIAC utility make-ready for which DTE Electric is responsible

1		• For every increase in project size by two chargers, charger costs were
2		reduced by 2% and installation costs were reduced by 5% for Level 2
3		chargers and 10% for DCFCs, on a per-charger basis. No further per-charger
4		cost savings were assumed for project sizes over ten chargers.
5		
6		The impact of these factors on the cost assumptions is that charger and installation
7		costs decline as the number of chargers per location increases, and for a fixed
8		number of chargers per location, charger costs decline and installation costs increase
9		over time.
10		
11		DTE Electric also reviewed internal project data that indicated that 20% of fleet
12		installations and 75% of workplace installations did not require any service
13		upgrades, so the utility make-ready ("UMR") costs for these segments were reduced
14		accordingly. For single-family homes, the internal project data revealed that the
15		average customer make-ready ("CMR") cost for "newer" buildings (built in 1980 or
16		after) is about half the average CMR cost for "older" buildings (built before 1980).
17		Similarly, it is estimated that newer single-family homes would experience about a
18		five-year delay on the kinds of UMR costs that older SFHs typically incur today.
19		
20		The investment required does not include transmission or power supply costs.
21		
22	Q45.	What was the Company's approach to engaging stakeholders in the TEP
23		design?
24	A45.	DTE Electric engages stakeholders in its current Charging Forward programs by,
25		among other things, hosting annual stakeholder discussions and submitting

Line

<u>No.</u>

1	quarterly and annual status reports in the Case No. U-20162 docket. Listening to
2	stakeholders during the TEP development helped DTE Electric produce a well-
3	balanced and well-aligned plan to serve customers. The Company implemented a
4	stakeholder engagement process aimed at providing transparency and obtaining
5	feedback on the overall approach and development phases of the planning to ensure
6	that its TEP balances the diverse interests of its stakeholders. This was achieved
7	through a series of webinars and surveys and included:
8	 Focused discussions with the MPSC,
9	• A kick-off webinar with stakeholders to explain the TEP approach, discuss
10	the guiding principles, and request their engagement,
11	• Three separate webinars for the three key stakeholder groups (defined
12	below) to share our need assessment, customer segmentation, and charger
13	installation cost categories and to seek insights into stakeholder positions on
14	key things like which needs that DTE Electric should support, and whether
15	the Company should consider waiving Contribution in Aid of Construction
16	("CIAC") for residential or business customers,
17	• Three surveys following each stakeholder webinar to allow the stakeholders
18	to provide additional feedback, and
19	 Individual follow-up meetings with organizations, if requested.
20	DTE Electric invited 110 organizations to engage in this process and about half of
21	the organizations invited participated, of which half belonged to the EV Industry
22	stakeholder group.
23	
24	Q46. What were the three key stakeholder groups?

1	A46.	DTE Electric included more than 100 organizations that could be impacted by the
2		TEP and organized these into three key stakeholder groups: EV industry, customer-
3		facing, and policy & advocacy groups. The types of organizations in those key
4		stakeholder groupings are shown in the table below:
5		

6

7

Table 6Types of Organizations in the Three Key Stakeholder Groups

EV Industry	Customer-Facing	Policy & Advocacy	
 EV Industry Auto manufacturers Charger manufacturers Network providers Charger installation companies 	 Customer-Facing Municipalities Regional planning organizations Transit agencies Businesses Gas and convenience store owners 	 Policy & Advocacy MPSC Regional advocacy groups National advocacy groups 	
	 Rental car companies Transportation Network Companies 		

8

9 Q47. What insights were garnered from stakeholders?

A47. Stakeholders provided feedback through the stakeholder engagement process, most
of which was fairly aligned. There were some areas where stakeholders had
divergent opinions. The feedback that most stakeholders were aligned on included:

- There is a need to provide charger rebates to facilitate EV adoption in the near term,
- Utility TEPs should have a strong focus on multi-unit dwellings, low-income
 customers, and disadvantaged communities,
- 17 The resulting portfolio should provide net affordability benefits to all DTE
- 18 Electric customers using a robust BCA, and

<u>No.</u>		
1		 DTE Electric should also focus on grid modernization to help improve
2		reliability and on streamlining interconnection timelines to improve the
3		customer experience.
4		The process also identified the following differing positions:
5		 Utilities should own chargers for specific use cases, such as curbside Level
6		2 charging and rural fast charging versus utility ownership should be
7		minimal and encouraged as a last resort,
8		• There are clear failures in the EV charger market today <i>versus</i> it is premature
9		to assume failures in the nascent EV market in Michigan,
10		 Utilities should waive CIAC from customers versus cost causation principles
11		of rate design (and appropriate credits based on expected load and revenue)
12		should remain in place for EV requests, similar to new service requests and
13		upgrades, and
14		 Charging infrastructure needs and corresponding investment identified in the
15		need assessment for DTE Electric's TEP should be based on the aspirational
16		EV goal of two million EVs by 2030 in the MI Healthy Climate Plan versus
17		basing them on DTE Electric's EV forecast. ³³
18		
19	Q48.	How was the TEP informed by stakeholder feedback?
20	A48.	In accordance with the Company's guiding principles, DTE Electric had already
21		envisioned supporting and accelerating EV adoption by facilitating charger
22		deployment while ensuring affordability benefits for all DTE Electric customers
23		and promoting equity by focusing on low-income customers and disadvantaged

Line

³³ MI Healthy Climate Plan available at <u>https://www.michigan.gov/egle/about/organization/climate-and-energy/mi-healthy-climate-plan</u>, accessed December 18, 2023

Line <u>No.</u>		U-21534
1		communities, which are things that TEP stakeholders valued as well. After
2		receiving insights from stakeholders, DTE Electric also decided:
3		 not to waive CIAC beyond revenue credits from existing line extension
4		policy,
5		• to use its own EV forecasting methodology to determine charging
6		infrastructure needs, and
7		 not to include utility-owned pole-mounted chargers with this initial TEP.
8		The Company believes that there is merit in the utility owning and operating pole-
9		mounted chargers due to the lower costs along with the opportunity to seek federal
10		funding at scale, and the ability to provide more affordable overnight charging
11		solutions for DACs and MUDs. However, in order to achieve consensus where
12		possible, the Company has opted not to include any utility-owned charging with its
13		initial TEP.
14		
15	Q49.	What framework did DTE Electric use to develop the TEP?
16	A49.	DTE Electric evaluated the participation models for each of the customer segments,
17		leveraging the guiding principles and stakeholder feedback.
18		
19		First, DTE Electric defined the three primary cost categories for charger installation
20		and refined the five primary customer segments.
21		
22		The three primary cost categories for charger installation help provide
23		considerations for utility support for EV charging. Definitions and specific examples
24		for these three cost categories, which include utility make-ready, customer make-
25		ready, and EV chargers are provided in the table below:

1		

Table 7 Charger Installation Cost Category Definitions and Examples

2

	Utility Make-Ready	Customer Make- Ready	EV Charger
Description	• Upgrades on the utility side of the meter, from the line transformer to the meter	• Upgrades on the customer side of the meter, from after the meter to the EV charger stub out	Hardware required to charge the EV
Examples	 Grid edge infrastructure (e.g., pole top transformer) needs to be upgraded to support residential EV load Another service line needs to be added to support EV chargers in a parking lot 	 A residential customer upgrades the panel to support an EV Charger A commercial customer installs conduit and cable from the panel to the charger stub out 	 Level 2 chargers DCFCs

3

The five primary customer segments were further divided into sub-segments to allow DTE Electric to examine specific needs and dynamics at a more granular level to appropriately determine the degree to which the Company should participate. These sub-segments are defined in the table below:

1
2

Segment Customer Sul Segments		Description of Location or Use Case
Single-Family Low-Income		Level 2 chargers for SFH residents within
Homes		200% of federal poverty limit
	Non-Low	All other Level 2 chargers at SFHs
	Income	
Multi-Unit	Low-Income	Level 2 chargers at affordable MUD housing
Dwellings		(e.g., public housing, government-subsidized
		private housing, etc.)
	Non-Low	All other Level 2 chargers for MUDs
	Income	
Public	DAC/rural on-	DCFCs within one mile of a major
	route DCFC	throughway and in DACs and/or rural areas
	All other on-	All other DCFCs within one mile of a major
	route DCFC	throughway
	Destination	All DCFCs further than one mile from a
	DCFCs	major throughway
	Destination	All Level 2 public charging, including pole-
	Level 2	mounted charging
Fleet	Transit agencies	DCFCs serving transit buses
	Schools	DCFCs serving school buses
	Level 2	Level 2 charging for fleet EVs, typically
		light-duty vehicles
	All other	All other DCFCs for fleet EVs
	DCFCs	
Workplace	-	Chargers for employee use with personally
_		owned vehicles

3

The ways in which DTE Electric ultimately decided to support the above customer
sub-segments, including justification for its proposal are included in the following
TEP Portfolio Proposal section.

7

8

II. <u>TEP Portfolio Proposal</u>

9 Q50. What are the Company's proposed TEP programs?

Line <u>No.</u>

A50. DTE Electric's proposed TEP programs achieve its guiding principles by
facilitating charger deployment while maintaining overall affordability benefits for
all DTE Electric customers, improving economics of electrification in the nearterm, and promoting equity with a focus on low-income customers and
disadvantaged communities. The portfolio is summarized in the table below:

6

7

Table 9Proposed TEP Rebate Programs, 2025-2028

8

Customer Segment	Customer Sub- Segments	Rebate ³⁴	Segment Availability	Total Investment (\$ millions)
SFHs	LI Level 2	\$2,200	100%	24.0
	LI Level 2	\$14,400	90%	7.0
MUDS	Non-LI Level 2	\$5,000	45%	20.7
Public	DAC/rural on-route DCFC	\$70,000	35%	21.6
	All other on- route DCFC	\$50,000	35%	15.4
	Transit bus DCFC	\$70,000	100%	2.3
Fleet	School bus DCFC	\$70,000	30%	7.0
	Other DCFC	\$70,000	30%	20.0
	Other Level 2	\$2,500	90%	6.8
Total	-	-	-	124.8

9

10 The on-route charging segment makes up the biggest category of investment at 30%,

11 followed closely by fleet at 29%, MUDs at 22% and single-family homes at 19%.

12 A benefit cost analysis is provided in the next section.

³⁴ LI SFH and LI MUD are average estimates based on total installation costs and would not exceed actual costs



How was the final portfolio informed by stakeholder feedback?

20

21

as such is not included in the survey questions shown in the previous figure. In

Council of Governments (SEMCOG), Tesla, and University of Michigan.

Line

1

Q51.

³⁵ The 12 survey respondents included representatives from BorgWarner, BP Pulse, ChargerHelp, EV Connect, Flo EV Charging, General Motors, Michigan Auto Dealers Association, Michigan Energy Innovation Business Council (MEIBC), Michigan Public Service Commission, Southeast Michigan

³⁶ Note that non-DAC/Rural on-route DCFC is missing from this survey, because this customer segment was not included in the TEP preview this survey was designed to complement, but in response to stakeholder feedback it was added to the final proposed TEP.

	response to stakeholder feedback at this and other webinars (for example,
	stakeholders ranked this customer segment the third-most important for utility
	action), the Company decided to add the non-DAC/Rural on-route DCFC customer
	sub-segment to the final portfolio of proposed TEP programs.
Q52.	What is the justification behind the Company's support of the Single-Family
	Home segment?
A52.	The Company is proposing support for Home Charger Rebates for low-income
	residential customers in single family homes over the TEP timeframe at 100% of
	the forecasted charger deployments for this subsegment in the DTE Electric service
	territory, for a total investment of approximately \$24 million. The proposed rebate
	would cover the cost of the Level 2 charger and the full cost of the customer's
	installation and is calculated at an average of \$2,200 per rebate.
	The Company has focused its support on the low-income single-family home
	subsegment for these reasons:
	• While over 80% of the chargers needed between 2025 and 2028 are expected
	to be in the single-family home segment, per Figure 2 above, the Company
	and stakeholders believe that EV adoption in the non-low-income sub-
	segment is unlikely to be solely determined by the cost to install a home
	charger. However, this can be a significant barrier for low-income residential
	customers,
	• Customers need to install a charger at home to unlock the fuel pricing of
	approximately \$1 eGallon equivalent and experience the benefits and
	features of a dedicated EV charger,
	Q52. A52.

1	•	Customers can face high installation costs due to outdated electrical wiring
2		and/or breaker panels. While the average total cost of installation is \$2,400, ³⁷
3		the range can vary from as low as \$750 to as high as \$7,850, based on a
4		review of more than 500 installations completed through the Company's
5		Home Charger Installation pilot program,
6	•	The Company received strong stakeholder support for this approach with
7		one key stakeholder stating, in a feedback webinar, that "[the low-income]
8		community needs resources to move to EV adoption. This segment cannot
9		be left behind."
10		
11	Q53. Wha	t participation criteria will the Company require for the income-qualified
12	Hom	e Charger Rebates?
12 13	Hom A53. Initia	e Charger Rebates? lly, the Company envisioned a low- and moderate-income customer eligibility
12 13 14	Hom A53. Initia thres	e Charger Rebates? Ily, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us
12 13 14 15	Hom A53. Initia threst feedb	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us pack that this was too high. Consequently, DTE Electric lowered the income
 12 13 14 15 16 	Hom A53. Initia thres feedb eligit	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us pack that this was too high. Consequently, DTE Electric lowered the income pility threshold to 200% of the federal poverty limit, which aligns with the
12 13 14 15 16 17	Hom A53. Initia thres feedb eligib thres	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us back that this was too high. Consequently, DTE Electric lowered the income bility threshold to 200% of the federal poverty limit, which aligns with the hold for other DTE low-income programs ³⁸ and would be approximately
12 13 14 15 16 17 18	Hom A53. Initia thres feedb eligib thres \$60,0	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us back that this was too high. Consequently, DTE Electric lowered the income bility threshold to 200% of the federal poverty limit, which aligns with the hold for other DTE low-income programs ³⁸ and would be approximately 000 for a four-person household.
 12 13 14 15 16 17 18 19 	Hom A53. Initia thres feedt eligit thres \$60,0 Other	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us back that this was too high. Consequently, DTE Electric lowered the income bility threshold to 200% of the federal poverty limit, which aligns with the hold for other DTE low-income programs ³⁸ and would be approximately 000 for a four-person household. qualification requirements are:
 12 13 14 15 16 17 18 19 20 	Hom A53. Initia thres feedb eligib thres \$60,0 Other	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us back that this was too high. Consequently, DTE Electric lowered the income bility threshold to 200% of the federal poverty limit, which aligns with the hold for other DTE low-income programs ³⁸ and would be approximately 000 for a four-person household. qualification requirements are: Proof of EV purchase or lease,
 12 13 14 15 16 17 18 19 20 21 	Hom A53. Initia thres feedb eligit thres \$60,0 Other	e Charger Rebates? Illy, the Company envisioned a low- and moderate-income customer eligibility hold of 400% of the federal poverty limit. Some key stakeholders gave us back that this was too high. Consequently, DTE Electric lowered the income bility threshold to 200% of the federal poverty limit, which aligns with the hold for other DTE low-income programs ³⁸ and would be approximately 000 for a four-person household. qualification requirements are: Proof of EV purchase or lease, Installation of an ENERGY-STAR certified or vehicle manufacturer charger

Line

<u>No.</u>

 ³⁷ Total cost of installation includes DTE Electric costs of about \$200 for non-CIAC utility make-ready
 ³⁸ The Energy Efficiency Assistance program and Shutoff Protection Plan are two such DTE programs

Line <u>No.</u>		P. BENNETT U-21534
1		• Enrollment in a Time of Day ("TOD") rate, such as Whole-Home TOD
2		(D1.2), Dynamic Peak Pricing (D1.8), EV-only TOD (D1.9), or the recently
3		approved Overnight Savers (D1.13).
4		
5	Q54.	Are there additional considerations for the income-qualified Home Charger
6		Rebates proposal?
7	A54.	Yes. It will be critical to monitor and adjust the income eligibility threshold based
8		on market dynamics of EV adoption. For example, if the upfront premium for EVs
9		continues to remain out of reach for low-income customers, DTE Electric may need
10		to adjust the income threshold of the Home Charger Rebate program upwards to
11		meaningfully support this segment and encourage EV adoption in Southeast
12		Michigan.
13		
14	Q55.	What is the justification behind the Company's support of the Multi-Unit
15		Dwelling segment?
16	A55.	The Company is proposing to support the multi-unit dwelling ("MUD") segment
17		for both low-income MUD housing and for all other MUDs with two separate
18		programs.
19		The Company is proposing support for rebates for qualified low-income MUDs at
20		about 90% of the forecasted MUD charger deployments in this subsegment over the
21		TEP timeframe, for a total investment of approximately \$7 million. The proposed
22		income-qualified Business Charger Rebate would cover the cost of the Level 2
23		charger and the full cost of the installation that the customer is responsible for
24		paying, including the CIAC portion of the utility make-ready and the customer
25		make-ready. The average rebate is calculated at \$14,400 per charger.

1	
2	The Company is also proposing support for all other MUDs at about 45% of the
3	forecasted MUD charger deployments in this subsegment over the TEP timeframe,
4	for a total investment of approximately \$20.7 million, to cover the cost of the charger
5	and a portion of the installation. The proposed revised Business Charger Rebate
6	would be \$5,000 and would cover the cost of the Level 2 charger.
7	
8	The Company proposes supporting this segment in this manner for the following
9	reasons:
10	• As discussed in the single-family home segment above, access to overnight
11	charging is critical to unlock fuel savings and this can be a purchase barrier
12	for EVs,
13	• The average total cost of installation (less utility-owned non-CIAC utility
14	make-ready) is approximately \$14,400 over the TEP timeframe, as shown in
15	Table 9, driven primarily by customer make-ready, which often requires
16	trenching and extending electrical wiring to parking areas,
17	• The cost of installation can make it a challenge for landlords, especially in
18	the low-income or affordable housing subsegment, to install EV chargers,
19	• While landlords in segments other than the low-income subsegment may
20	have some incentive to install chargers as an amenity to attract tenants and
21	retain occupancy, landlords in the low-income subsegment may not have the
22	same motivation or resources to install EV chargers,
23	 As discussed above, benchmarking shows that MUDs are receiving unique
24	attention in other utility TEPs due to some of the same reasons outlined
25	above, and

Line <u>No.</u>		U-21534
1		• Stakeholders surveyed by DTE Electric ranked the low-income MUD
2		housing segment as the fourth most important subsegment for utility action.
3		
4	Q56.	What participation criteria will the Company require for the rebates in the
5		MUD segment?
6	A56.	To qualify for the income-qualified Business Charger Rebate, the MUD must meet
7		at least one of the following criteria:
8		• MUD is owned and managed by a public entity such as the Housing
9		Commission,
10		• MUD receives government subsidization that requires at least 40% of the
11		units to be for residents whose household incomes do not exceed 60% of the
12		area median income (such as the LI Housing Tax Credit),
13		• MUD has at least 40% of their residents participating in the Housing
14		Voucher Program, or
15		 Other criteria deemed equivalent to those above.
16		
17		Qualification requirements proposed for both income-qualified and non-income
18		qualified Business Charger Rebates include:
19		 Installation of a qualified, networked charger (similar to the Business
20		Charger Rebates program today),
21		 Authorizing network provider to share charger data with DTE Electric,³⁹
22		 Commitment to 97% charger uptime, and

³⁹ Data shared with DTE Electric would be used to derive utilization rates for each charger, determine if charger is meeting uptime requirements, discern charging trends, and other purposes. Data shared with DTE Electric will not include any personally identifiable information for the EV drivers who charge on that charger.

Line <u>No.</u>		P. BENNETT U-21534
1		• Demonstrated tenant interest in installing EV chargers; this helps protect
2		utility investment through greater likelihood of utilization of charging-
3		related assets and investment.
4		
5	Q57.	Are there additional considerations for the Business Charger Rebates for
6		multi-unit dwellings?
7	A57.	Yes. There are two additional considerations for the Business Charger Rebates in
8		the multi-unit dwelling segment:
9		1. The Company believes that Level 2 charging is appropriate for the longer
10		parking duration at MUDs. This enables fuel savings for tenants while
11		minimizing impacts to the DTE Electric grid. However, the Company is
12		proposing that an exception could be made to allow rebates for DCFCs at MUDs
13		in special cases, for example, if there is extremely limited parking space for
14		residents.
15		2. One quarter (25%) of the stakeholder survey respondents indicated that DTE
16		Electric's proposed support of the low-income MUD market was too much and
17		one quarter (25%) of the survey respondents indicated that DTE Electric's
18		support of the non-low-income MUD market was not enough. These results
19		warrant the flexibility for DTE Electric to adjust the low-income MUD housing
20		qualification requirements and the rebate amounts in this segment based on
21		market demand to help appropriately enable MUD resident EV adoption during
22		the TEP timeframe.
23		
24	Q58.	Can you explain the reasons for the Company's support of the Public
25		Charging segment?

1	A58.	Stakeholders ranked all the public charging subsegments, including on-route and
2		destination charging, as the most important for utility action because the availability
3		of public charging is critical to reducing range anxiety, which is a key barrier to EV
4		adoption. Reliable, on-route fast charging, defined as fast charging within one mile
5		of a major throughway exit, can increase customer's confidence in the refueling
6		infrastructure and so, the Company is proposing to provide support for on-route
7		public fast charging by offering a rebate of \$70,000 per on-route DCFC in
8		disadvantaged communities and rural areas and \$50,000 per on-route DCFC in
9		other areas. To manage affordability impacts to its customers, DTE Electric
10		proposes to support 35% of the forecasted on-route public charger deployment for
11		an investment of \$21.6 million in the DAC and rural on-route subsegment and \$15.4
12		million in other on-route areas.

13

As noted above, public charging represents the highest category of investment required over the TEP timeframe because of the expensive hardware and the high cost of installation of DCFCs driven by high-voltage wiring. Site hosts seek higher utilization rates to recoup their investments which tends to concentrate private sector investment in higher-income areas that have high EV adoption rates. This is reflected in DTE Electric's increased support for the DAC and rural on-route subsegment as compared to the other on-route areas.

21

The Company expanded its support to on-route DCFCs not in DAC or rural areas based on stakeholder feedback in the development phase. Stakeholders consider utility support in this area critical in the near-term to decrease range anxiety and to complement available federal funding opportunities, such as the NEVI program.

1		DTE Electric does not, however, propose rebates for the destination charging
2		segments as the economics of Level 2 charger deployment are not as challenging,
3		and businesses have other motivation for installation such as increased foot traffic.
4		For site hosts installing a destination DCFC, DTE Electric will continue to offer a
5		commercially available rate without demand charges for sites less than one
6		megawatt. ⁴⁰
7		
8	Q59.	What participation criteria will the Company require for its on-route Business
9		Charger Rebates program?
10	A59.	Participating customers will need to install a qualified, networked charger (similar
11		to the Business Charger Rebate program today), authorize the network provider to
12		share charger data with DTE Electric, and commit to 97% charger uptime. ⁴¹
13		
14		To qualify for the DAC on-route rebate, a community will need to be identified as
15		disadvantaged by the Michigan State Plan for EV Infrastructure Deployment. ⁴²
16		To qualify for the rural on-route rebate, a community will need to be identified as
17		rural as viewed on the U.S. Department of Transportation Rural Eligibility Map. ⁴³
18		

⁴⁰ General Service Rate D3 as described in DTE Electric Company Rate Book for Electric Service available at https://www.michigan.gov/mpsc/-/media/Project/Websites/mpsc/consumer/rate-books/electric/dtee1cur.pdf?rev=e0168ab41b8245bba5f3ca7631c29614&hash=D16249E421EC5AB0F5C3A2304B0FB0F7, accessed December 18, 2023. Sites over one megawatt also qualify through June 2026

⁴² Michigan State Plan for EV Infrastructure Deployment available at

https://www.michigan.gov/mdot/travel/mobility/initiatives/nevi, accessed December 18, 2023 ⁴³ Rural defined as, "located outside of a U.S. Census-designated urban area with a population of 50,000 or more." Rural Eligibility available at <u>https://www.transportation.gov/rural/eligibility</u>, accessed December 11, 2023

⁴¹ Data shared with DTE Electric would be used to derive utilization rates for each charger, determine if charger is meeting uptime requirements, discern charging trends, and other purposes. Data shared with DTE Electric will not include any personally identifiable information for the EV drivers who charge on that charger.
Q60. How does the Company propose continuing its support of the Fleet Charging segment?

3 A60. Transit and school bus electrification have received unique attention in 4 governmental policy and funding programs due to the expected community 5 benefits. Due to the high upfront premium of electric buses, additional support is 6 often needed to improve economics even with the available funding. Although 7 school bus chargers are lower cost, on average, than transit bus chargers, schools 8 require more incentives to convert since the buses drive fewer miles than transit 9 buses and so do not achieve the same level of fuel savings to offset the upfront 10 premium. DTE Electric stakeholders ranked this subsegment high in terms of 11 importance for utility action, following public charging and low-income MUDs 12 (see Figure 5).

13

Therefore, the Company is proposing to continue its eFleet Charger Rebate program for both school and transit buses with a rebate of \$70,000 per DCFC, assuming 60 kW and 150 kW DCFCs for those subsegments respectively. DTE Electric proposes supporting 100% of the transit bus charger subsegment over the TEP timeframe for a total investment of approximately \$2.3 million. The Company proposes a total investment of approximately \$7 million to support 30% of the forecasted school bus chargers needed while interest and affordability evolves.

21

DTE Electric also proposes to continue offering a \$2,500 eFleet Charger Rebate for all fleet owners installing a Level 2 charger. The Company proposes supporting 90% of the forecasted charger deployments in this subsegment for a total investment of \$6.8 million. Encouraging Level 2 charging for fleets improves the total cost of

Line <u>No.</u>		U-21534
1		ownership economics, which is a key driver for fleet conversion, while also reducing
2		grid impacts and supporting DTE Electric customer affordability.
3		
4		The Company also proposes continuing offering up to a \$70,000 eFleet Charger
5		Rebate for DCFCs for approximately 30% of the forecasted charger deployments
6		for a total investment of \$20 million.
7		
8	Q61.	What participation criteria will DTE Electric require for the Fleet Charging
9		segment?
10	A61.	Participating fleet customers will need to install a qualified, networked charger
11		(similar to the eFleet Charger Rebate program today), authorize the network
12		provider to share charger data with DTE Electric, agree to load commitments, and
13		commit to demand ceilings in constrained areas or for large depots to help manage
14		grid impacts.44 Additionally, schools will need to install vehicle-to-grid chargers to
15		be eligible for the full \$70,000 rebate.
16		
17	Q62.	Are there additional considerations for the TEP portfolio proposal?
18	A62.	Yes. There are four additional considerations:
19		1. DTE Electric investment is designed, at the portfolio level, to:
20		a. Maintain affordability benefits for all DTE Electric customers, as
21		calculated using the BCA methodology discussed in the next section, and

⁴⁴ Data shared with DTE Electric would be used to derive utilization rates for each charger, determine if the charger is meeting uptime requirements, discern charging trends, and other purposes. Data shared with DTE Electric will not include any personally identifiable information for the EV drivers who charge on that charger.

Line
<u>No.</u>

2.	 b. Remain within the total MPSC-approved level of investment, which is being proposed at \$125 million for rebates and \$20 million for supporting functions over the TEP timeframe from 2025 to 2028. As indicated in the explanation of multiple segments in this section, maintaining flexibility to adjust TEP programming within the approved investment limits and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
2.	 being proposed at \$125 million for rebates and \$20 million for supporting functions over the TEP timeframe from 2025 to 2028. As indicated in the explanation of multiple segments in this section, maintaining flexibility to adjust TEP programming within the approved investment limits and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
2.	supporting functions over the TEP timeframe from 2025 to 2028. As indicated in the explanation of multiple segments in this section, maintaining flexibility to adjust TEP programming within the approved investment limits and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
2.	As indicated in the explanation of multiple segments in this section, maintaining flexibility to adjust TEP programming within the approved investment limits and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	flexibility to adjust TEP programming within the approved investment limits and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	and while maintaining affordability at the portfolio level, will be critical to successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	successfully enable overall EV adoption during the TEP timeframe. EV's are still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	still relatively new and evolving and DTE Electric can envision several developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	developments like EV pricing challenges, charger technology advancement, supply chain constraints, federal incentive changes, private investment changes,
	supply chain constraints, federal incentive changes, private investment changes,
	and EV sales not occurring as forecasted, requiring complementary modification
	in TEP programming. Examples of adjustments the Company may need to make
	to further TEP success in achieving its goals include changing rebate dollar
	amounts, customer eligibility criteria, terms and conditions, and rebate volume
	by subsegment.
3.	DTE Electric is not proposing to support the workplace charging subsegment as
	it is believed that there is sufficient incentive for workplaces to install chargers
	as an amenity to attract employees, and
4.	Electric Choice customers, if they request a rebate, will receive a discounted
	rebate of about 35% (for example, up to \$25,000 instead of \$70,000 per charger)
	to maintain affordability benefits for all DTE Electric customers by accounting
	for the lower amount of rate revenue received from Electric Choice customers.
Q63. V	What rate book modifications is the Company proposing as part of its TEP?
	4. Q63. V

1	A63.	The Company is proposing the following modification in rate book language as
2		sponsored by Company Witness Willis:
3		 Deletion of the Charging Forward CIAC waiver in section C6.1(16) of
4		Section C – Part I, Company Rules and Regulations.
5		
6	Q64.	Why is the Company requesting the deletion of the Charging Forward CIAC
7		waiver?
8	A64.	Consistent with providing positive rate impacts and affordability benefits accruing
9		to all customers, DTE Electric decided, as part of its TEP, to no longer waive CIAC
10		beyond revenue credits from the existing line extension policy. This is also in
11		alignment with feedback received from key stakeholders. Making the rate book
12		modification as described above will align the rate book and the TEP.
13		
14	Q65.	How did you support the design of the Company's EV Fast Charger Rate?
15	A65.	Under my direction, a list of 68 known DTE Electric DCFC customers was
16		generated and provided to Company Witness Willis. This list was initially compiled
17		using data from the Alternative Fuels Data Center,45 and supplemented using
18		Charging Forward participant data.
19		
20	Q66.	How will DTE Electric engage key stakeholders during the TEP timeframe?
21	A66.	DTE Electric proposes to continue providing Annual Status Reports for its TEP
22		programs.
23		

⁴⁵ Alternative Fuels Data Center, available at <u>Alternative Fuels Data Center: Alternative Fueling Station</u> <u>Locator (energy.gov)</u>, <u>https://afdc.energy.gov/stations/#/analyze?region=US-</u> <u>MI&fuel=ELEC&ev_levels=dc_fast</u>, and accessed December 6, 2023. Advanced filter choices included Location: Michigan, Fuel: Electric and DCFC, Station: Public and Available

P. BENNETT U-21534

Line

<u>No.</u>

1	Q67.	What metrics does the Company propose to track?
2	A67.	The Company proposes to track the following metrics, by segment:
3		 Rebate applications filed,
4		 Rebate applications approved,
5		 Charger uptime,
6		 Charger utilization rate,
7		 On-peak and off-peak charging,
8		 Customer satisfaction,
9		 Total investment including equity-focused programs, and
10		 Installation cost per port, including utility make-ready investment, customer-
11		owed contribution in aid of construction, customer make-ready, and charger
12		costs.
13		These metrics will be tracked to guide necessary adjustments to program parameters
14		to further customer affordability and overall effectiveness of the TEP. The Company
15		will also monitor program activity and feedback to remain agile and scale its
16		programs in accordance with its guiding principles and to successfully influence
17		EV adoption.
18		
19	III	. <u>Benefit Cost Analysis ("BCA")</u>
20	Q68.	What methodology was used to evaluate the TEP BCA?
21	A68.	In the November 2022 Order in Case Number U-20836, the Michigan Public
22		Service Commission requested that DTE Electric "submit a full scale, well-
23		developed, permanent Charging Forward proposal that includes a BCA." The
24		Commission additionally stated that "the requirement of a BCA should not be

25 *interpreted as a requirement that all pilots be financially solvent at the time they*

1		are proposed (although that is preferable) but that when weighing costs versus
2		benefits for a full-scale program, benefits outweigh costs over the duration of the
3		program." As such, DTE Electric developed a robust BCA for the TEP that can be
4		evaluated by segment and for the whole TEP portfolio. This BCA shows that the
5		TEP portfolio provides net benefits to customers over its duration.
6		
7		DTE Electric used the net present value ("NPV") of the revenue requirement
8		assessed for the TEP programs as the BCA test for the TEP. Revenue requirement
9		is the required additional revenue that DTE Electric needs to collect from customers
10		to recover the cost of administering the TEP programs. When the TEP programs
11		produce positive revenue requirement NPV, customers will end up, all things equal,
12		paying higher electric rates. Conversely, when the TEP programs produce negative
13		revenue requirement NPV, the TEP provides an offset to electric rates.
14		
15	Q69.	What are the key assumptions incorporated in the BCA analysis?
16	A69.	The revenue requirement analysis takes the following elements into consideration,
17		segmented by their effects, where (+) means they are adding rate pressure, whereas
18		(-) means they are providing rate relief:
19		• (+) utility-owned UMR investment for rebated chargers,
20		 (+) rebates for chargers,
21		 (+) supporting function costs (for portfolio-level BCA only),
22		 (+) energy cost of serving "qualified" additional EV load, and
23		• (-) electric revenue from "qualified" additional EV load.
24		

Line <u>No.</u>	P. BENNETT U-21534
1	It is important to note that the BCA only considers incremental load from rebated
2	chargers (i.e., "qualified" additional EV load). The "qualified" additional EV load
3	occurring on TEP-supported chargers – and accounted for in the BCA – is only about
4	10% of the total expected EV load through 2030.
5	
6	The rebated charger utilization rates used for the BCA are listed by charger type and
7 8	customer segment in the table below:

9	Table 10	Charger Power and Utilization Rate by Customer Sub-segment and

Charger Type

10

11

Charger Type	Customer Sub-Segment	Utilization Rates ⁴⁶
Level 2 12kW	SFH	2%
	MUD (LI / all other)	6% /9%
Level 2 19kW	Workplace	1%
	Other fleet	7%
	Destination	8%
DCFC 60kW	School bus	4%
DCFC 150kW	Transit bus	14%
	Workplace	<1%
	Other fleet	5%
	On-route (disadvantaged	2% /4%
	community & rural / all other)	
	Destination	1%

12

For additional conservatism, the BCA assumes a constant utilization rate, despite the utilization rate likely increasing over time, especially in segments where chargers serve multiple vehicles, such as on-route DCFCs. For most segments, the utilization rate used in the BCA is the average across the four TEP program years as output from the segment assessment model, discussed above. For a few other

⁴⁶ Utilization rates used in the BCA are outputs from the market assessment process

The energy cost of serving "qualified" additional EV load was calculated for each 9 customer segment as an annual weighted average derived from hourly wholesale 10 power price forecasts, consistent with the Company's 2022 Integrated Resource 11 Plan filing (Case No. U-21193 Order dated July 26, 2023). Electric revenue from 12 "qualified" additional EV load was calculated based on electric tariff rates for EV 13 customers in their applicable rate classes. The 2024 values for electric tariff rates 14 and the cost of energy values by customer segments are listed in the tables below:

15

Line

No.

- 16
- 17

Table 11	2024 V	alues	for	Electric '	Tariff Rates	

Input	\$/kWh	Source
SFH charger revenue	0.1502	Weighted average of residential rates D1.11, D1.2, and D1.9 ⁴⁷
All other charger revenue	0.1340	General service rate D3 (no demand charges) ⁴⁸

18

⁴⁷ Using EV Data Sharing pilot data (participant tariffs and split of on-peak vs. off-peak charging for the corresponding tariffs).

⁴⁸ The Company does not anticipate the 1 MW threshold waiver sunset of June 2026 to affect the BCA as the vast majority of DCFC installations will remain below the acceptable threshold. However, DTEE will address this if needed after June 2026.

1

Table 122024 Cost of Energy Values by Customer Segment49

2

Customer Segment	Cost of Energy (\$/kWh)
Single-Family Homes	0.0411
Multi-Unit Dwellings	0.0412
Public	0.0414
Fleet	0.0385
Workplace	0.0408

3

4

5

6

7

8

The revenue requirement is calculated using standard utility financing costs and accounting treatment:

- Rebates are treated as a regulatory asset (amortized over a five-year period),
- Utility-owned UMR investments are capitalized (depreciated over a 40-year period, the expected life of the UMR equipment),
- 9 50/50 debt-to-equity ratio with 9.9% return on equity and 4.1% weighted
 10 average cost of debt,
- 11 26% income tax,
- 12 2% property tax, and
- Discount rate of 6.92% for NPV calculation, based on DTE Electric's
 currently approved pre-tax weighted average cost of capital of its total
 capital structure.
- 16

17 **Q70.** What are the results of the BCA analysis?

- 18 A70. The NPV of revenue requirements for all customer segments supported by the TEP
- 19 are shown in the table below:

⁴⁹ Cost of energy is an annual weighted average for each customer segment. This is determined by multiplying the hourly load forecast for each customer segment by the corresponding hourly market locational marginal pricing forecast (aligned with 2022 IRP through 2042) to determine the total annual cost for that customer segment, and then that total cost is divided by the total energy consumed by that customer segment. Starting in 2043, cost of energy for all segments is assumed to grow at 2.5%.

1	

Table 13	NPV Revenue Requirement of Proposed TEP Customer Segments
----------	---

2

Customer Segment	Customer Sub-Segments	NPV Revenue Requirement (\$ millions) ⁵⁰
SFHs	LI Level 2	-15
MUDs	LI Level 2	+2
	Non-LI Level 2	-31
Public	DAC/rural on-route DCFC	+14
	All other on-route DCFC	-3
	Transit bus DCFC	-6
Fleet	School bus DCFC	+7
	Other DCFC	-5
	Other Level 2	-37
Supporting F	unctions	+17
Total		-56

3

Overall, the TEP portfolio-level BCA results in \$56 million of rate relief for DTE 4 5 Electric customers. The segment-level revenue requirement NPVs range from \$14 6 million in rate pressure for the DAC/rural on-route DCFC subsegment to \$37 7 million in rate relief for the other fleet Level 2 segment. The portfolio-level BCA is 8 the sum of the segment-level NPVs less the NPV of increased revenue requirement 9 for supporting functions that include E&O, program administration, additional 10 elements, and the emerging technology fund (approved in Case Number U-21297 11 for five years, starting in 2024, with a projected annual investment of approximately 12 \$1 million).

13

As shown in Figure 6 below, the annual revenue requirement initially applies rate pressure, but the TEP begins providing rate relief in 2033, increasing to a maximum of \$32 million of rate relief in 2064. So, while there is rate pressure in the near-term,

⁵⁰ For net revenue requirement, + means the sub-segment or portfolio is adding rate pressure whereas - means it is providing rate relief. See above for more detail.



6

Q71. What, in addition to the above discussion, should be considered when
 reviewing the BCA results?

9 A71. DTE Electric considers the \$56 million in rate relief, calculated as a result of the 10 proposed TEP investment using the BCA methodology described above, to be a 11 conservative estimate, for several reasons:





Line No.		P. BENNETT U-21534
1		3. The BCA does not take credit for any revenue generated in the first year of any
2		rebated charger's installation, despite rebated chargers coming online
3		throughout the year that the investment occurs.
4		
5	Q72.	How will DTE Electric account for utility make-ready costs for all newly
6		installed EV chargers, regardless of participation in the TEP?
7	A72.	DTE Electric customers are expected to request new or upgraded service
8		connections to install chargers, even if they do not participate in a TEP program.
9		Based on the market assessment above, approximately \$189 million of utility make-
10		ready investment will be needed for utility make-ready work to connect the
11		chargers required to support EV adoption from 2024 through 2028. From this same
12		analysis, DTE Electric estimates that it will be responsible for approximately 85%
13		of this investment, following DTE Electric tariff and line extension policy, with the
14		balance coming from customers' CIAC. Therefore, the total non-CIAC UMR
15		investment of \$161 million has been included in the new customer connection
16		portion of the budget of DTE Electric's 2023 Distribution Grid Plan (DGP) for the
17		DGP investment timeframe of 2024 through 2028 (filed September 29, 2023, in the
18		Case No. U-20147 docket). Non-CIAC UMR costs, for all new or upgraded service
19		connections to install chargers, for the bridge year of 2024 (\$4.7 million) and the
20		test year of 2025 (\$11.4 million) are included on page 5 , line 29 of Schedule B5.4
21		of Exhibit A-12.
22		
23	IV	TEP Expense
24	Q73.	What costs and accounting treatment is DTE Electric requesting for rate
25		recovery in this proceeding associated with the TEP?

Line <u>No.</u>					P. BE	CNNETT U-21534
1	A73.	TEP costs and accounting treatment	nent the Compan	y reque	sts in this pr	roceeding
2		associated with the TEP are summ	narized in the table	e below:		
3						
4	Table	e 14 Projected TEP Program	n Spend in 2025 b	у Ассон	inting Treati	ment (\$,
5		ir	n thousands)			
6						
			Acco	unting T	reatment	
		Program Component	Capital	O&M	Regulatory	Totals
					Asset	
		Program Administration		1,752		1,752
		Education & Outreach		1,500		1,500
		Business and eFleet Charger Reb (public, fleet and MUD segments	ates		16,002	16,002

3,126

1,000

20,128

3,126

1,000

1,600

24,980

		Total Program Spend	1,600	3,252
7				
8	Q74.	What are the costs for Education & Out	reach?	

Residential Customer Rebates

Emerging Tech Fund

TEP IT Capabilities

(low-income single family homes only)

A74. As the new fuel provider for EVs and to build off early success, the Company
proposed EV E&O as a permanent offering in Case Number U-21297, and the
Commission approved \$1.5 million, as shown in Exhibit A-12, Schedule B5.9, line
11, column (f), on an ongoing basis for these efforts. Over 90% of surveyed
stakeholders agreed that continued E&O as part of the TEP was either "important"
or "extremely important" and nearly 60% responded the same for the eFleet
Advisory Service, with the balance remaining "neutral" in both cases.

1,600

16

As its E&O efforts mature with the TEP in 2025, DTE Electric intends to roll eFleet
Advisory Services under the ongoing E&O umbrella. The Company will also

> 1 explore a similar service for MUDs, to ease the charger installation process for 2 landlords. This service would partially address coordination issues stemming from 3 landlords and Homeowners Associations not pursuing or allowing charger 4 installations because they do not understand the incentives available or the 5 installation process. 6 7 Q75. What are the costs for program administration? 8 A75. Similar to E&O, the Company proposed a permanent EV team in Case No. U-21297 9 and received approval in the December 1, 2023 Order. A permanent DTE Electric 10 EV team will provide continuous, stable, and high-quality TEP administration and 11 execution. Annual program administration costs for the TEP time frame are 12 estimated to be about \$1.8 million, as shown in Exhibit A-12, Schedule B5.9, line 13 12, column (f), to support labor costs for the EV team and program costs, such as 14 EV industry knowledge sharing and the web-based rebate application subscription 15 from PowerClerk[®]. The team will be responsible for everything from strategy to 16 program execution, including facilitating EV-related federal funding opportunities 17 for Southeast Michigan, as applicable. 18 19 **Q76**. What are the costs for the Emerging Technology Fund? 20 A76. As approved in Case No. U-21297, the \$1 million annual Emerging Technology

> Fund allows the Company to efficiently test new technologies and prepare for widespread EV adoption in the future. The Company launched an annual grant program to enable timely funding of prudent pilots in a rapidly evolving technology environment. Organizations seeking funding are vetted via three stages of review: initial screening by the EV team, cross-functional review by other business units

1		within DTE Electric, and the final review by the Emerging Technology Fund
2		Advisory Committee that was established in March 2023. ⁵¹ Each year, the Advisory
3		Committee convenes multiple times a year for rounds of reviews until the \$1
4		million funding is exhausted for deserving proposals. Line 21 of Exhibit A-12,
5		Schedule B5.9 shows \$1.0 million in test period costs in column (f).
6		
7	Q77.	What are the costs for TEP IT capabilities?
8	A77.	The Company is proposing an information technology investment of approximately
9		\$1.6 million, as shown in Exhibit A-12, Schedule B5.9, line 8, column (f), to build
10		data capabilities and dashboards for the purpose of tracking and reporting. This is
11		the majority of the approximate \$2.5 million that DTE Electric estimates will be
12		necessary to fully support the TEP programs during their four-year timeframe. This
13		is approximately 2% of the total proposed rebates, which is in alignment with, and
14		in some cases, even below, the benchmarked TEPs. Please see above for details on
15		metrics proposed to be tracked.
16		
17	3. <u>Cı</u>	<u> istomer Collection – Merchant Fees</u>
18	Q78.	What is the purpose of your testimony regarding merchant fees?
19	A78.	The purpose of my testimony regarding merchant fees is to support the recovery of
20		debit and credit card payment transaction fee expenses in the Company's rates.
21		

22 Q79. What are merchant fees?

⁵¹ Members include Ecology Center, EPRI, Ford, GM, the MPSC, and Next Energy

1	A79.	Merchant fees are the transactional costs associated with the processing of debit						
2		and credit card payments. These costs, or fees, are expenses borne by the Company						
3		and levied by the c	customer's de	bit and credi	t card issuer	and payment	processor.	
4								
5	Q80.	What type of debi	t and credit	cards does tl	ne Company	allow custo	mers to use?	
6	A80.	DTE Electric allo	ws the use o	f all debit ca	ards for bill	payments. Ir	n addition, it	
7		allows customers t	to use Visa, I	Discover, or I	MasterCard c	redit cards. I	OTE Electric	
8		has restricted the ty	pe of credit o	cards that are	allowed for b	oill payment t	to these three	
9		card issuers as the	y offer a low	er negotiated	l utility trans	action rate for	or customers	
10		using consumer cro	edit cards.	C	•			
11		6						
12	081	How many DTF	Flootric ous	tomore used	aradit or d	abit cards a	s a form of	
12	Q01.		Littli tus	comers used	u cicuit or u	con carus a		
13		payment over the	last five yea	rs?				
14	A81.	The number of cu	stomers usin	g the debit o	or credit pays	ment option	one or more	
15		times in a given ye	ar is shown i	n the table be	elow. It has in	ncreased by 1	3% over the	
16		last five years, from	m less than 1.	0 million in 2	2018 to over	1.1 million i	n 2022.	
17								
18	Table	15 Number o	of DTE Elect	tric Custome	ers paying w	ith a Credit	/Debit Card	
19				2018-2022	2			
20								
20			2018	2019	2020	2021	2022	
		Residential	985,417	1,047,404	1,060,122	1,092,245	1,112,592	
		Non-Residential	34,707	37,480	38,518	39,863	41,173	
		Total	1,020,124	1,084,884	1,098,640	1,132,108	1,153,765	
21								
22	O82 .	What is the avera	ge monthly	merchant fe	e paid by the	e Company?	,	
	£°-1		8 J			j·		

Line <u>No.</u>		P. BENNETT U-21534
1	A82.	The average monthly customer merchant fee paid by the Company for residential
2		and non-residential customers in 2022 was \$0.94 and \$4.72, respectively.
3		
4	Q83.	What measures has the Company taken to minimize merchant fees?
5	A83.	DTE Electric continues to restrict the use of debit and credit cards for business
6		customers with two mitigation policies that were proposed and approved by the
7		Commission in prior rate cases:
8		1. In Case No. U-20162, the Company proposed excluding industrial customers on
9		rate schedules D6.2, D8, D10, and D11 from using debit or credit cards ("Rate
10		Blocking", implemented August 2019), and
11		2. In Case No. U-20561, the Company proposed limiting the use of debit and credit
12		card payments to commercial and industrial ("C&I") customers whose aggregate
13		annual energy bill in the preceding calendar year was less than \$75,000 ("Annual
14		\$75K Blocking", implemented January 2021.)
15	Q84.	How many DTE Energy customers were restricted from using a debit or credit
16		card over the last five years?
17	A84.	All customers are provided the opportunity to use a debit or credit card as a form
18		or payment, with the exception of those customers associated with the two cost
19		mitigation strategies described above. The number of customers restricted based on
20		those two cost mitigation strategies over the last five years is shown in the table
21		below:

Line <u>No.</u>

1 Table 16 Total DTE Customers Restricted from Credit/Debit Card Payments⁵²

2

	2019	2020	2021	2022	2023
Rate Blocking	271	243	191	164	116
\$75K Blocking	-	-	5,328	5,238	5,882
Total	271	243	5,519	5,402	5,998

3

4 Q85. How have the non-residential cost mitigation strategies curtailed merchant fee 5 expense?

A85. From 2016 to 2018, non-residential merchant fee expenses grew 50%, increasing
from \$2.1 million in 2016 to \$4.7 million in 2018. From 2019 to 2022, nonresidential merchant fee expense decreased by 22%, from \$5.4 million in 2019 to
\$4.2 million in 2022, as shown in line 3 of Exhibit A-13, Schedule 5.7.1, page 2,
columns (b) and (e), respectively. The reduction in non-residential merchant fees
since 2019 is attributed to the implementation of the two cost mitigation strategies
described above.

13

Q86. What does the Company forecast for merchant fees in the projected test period?

A86. The Company forecasts and seeks recovery of \$12.29 million for merchant fees in
the projected test period, as shown in line 5 of Exhibit A-13, Schedule C.5.7.1, page
1, column (g).

19

20 **Q87.** How did the Company develop the merchant fee forecast?

⁵² The blocked customers include DTE Gas customers in the totals since this is not separated in the reporting system.

Line
<u>No.</u>

1	A87.	The Company calculated a 2023 forecast, as shown in Exhibit A-13, Schedule						
2		C5.7.1, page 2, column (g), line 4, from September 2023 year-to-date actuals and						
3		three months forec	ast. As descri	ibed above, 1	total merchai	nt fees have o	decreased in	
4		recent years due to	o the non-resid	dential cost	mitigation st	trategies imp	lemented in	
5		2019 and 2021. Ho	owever, now th	nat both strat	egies have b	een in effect	for over one	
6		year, the Company	y anticipates n	nerchant fee	s to level off	f in 2023 and	l not further	
7		decrease. The two	o-year custom	er count gro	wth of 0.5%	was applied	to the total	
8		2023 merchant fee	e expense in co	olumn (g) to	develop the	2024 and 20	25 forecast,	
9		as shown in colum	ns (h) and (i),	line 4 of the	same exhibi	t.		
10								
11	Q88.	How did the Com	pany calculat	te the custor	ner count gi	rowth rate?		
12	A88.	The company use	d the 2023, 20	024 and 202	25 customer	counts in Ex	khibit A-15,	
13		Schedule E6, page	e 1, as detailed	d in the table	e below, to a	calculate the	growth rate	
14		used to forecast 20	24 and 2025 n	nerchant fee	S.		2	
15								
16	Т	able 17 Custor	ner Count Gr	owth Perce	ntage Calcu	lation		
17								
1,		Customer Type	Column (s)	2023 (Line 6)	2024 (Line 7)	2025 (Line 8)	2 Year Growth	
		Residential Non-Residential	(b) (c) to (e)	2,055,641 215,031	2,064,797 216,100	2,074,827 217,086	0.5% 0.5%	
18								
19	<u>4. Adv</u>	vanced Customer P	Pricing Pilot a	nd Full Tim	e of Day Ro	<u>ollout</u>		

20	Q89.	What is the role of evaluation, monitoring and verification (EM&V) in the
21		Advanced Customer Pricing Pilot Program (ACPP) for 2022 and the amount
22		sought for recovery?

<u>lo.</u>					
1	A89.	The role of EM&V during the ACPP pilot supported administering participant			
2		surveys and ensuring that evaluation and analysis of this data to provide			
3		compelling, comprehensive and insightful information as the Company progressed			
4		toward a full TOD rollout. Information included optimal communication channels			
5		to reach customers, the most useful tools to provide (such as on-peak/off-peak			
6		usage graphs on the website), and content most impactful for the welcome kit (such			
7		as tips to save energy on the new rate). As shown in line 5 of Exhibit A-13, Schedule			
8		C5.9.2, column (e), DTE Electric is seeking to recover \$0.172 million of O&M			
9		expenses related to EM&V. Authorization to defer ACPP project costs to a			
10		regulatory asset was provided in Case No U-20162.			
11					
12	Q90.	What is the role of Customer Outreach in the full TOD rollout?			
13	A90.	Customer Outreach communicated the transition to full TOD rollout to ensure that			
14		all residential electric customers were informed that their base rate would be			
15		changed to a new TOD rate in March 2023.			

16

17 Q91. What is the total O&M expense for Customer Outreach that DTE Electric is 18 seeking to recover?

19 A91. DTE Electric is seeking to recover \$2.497 million of O&M expenses related to 20 Customer Outreach for the full TOD rollout. The calendar year 2022 expenses are 21 \$2.044 million and 2023 expenses are \$0.453 million. As explained further by 22 Witness Uzenski, these expenses have been approved by the Commission for 23 deferral and amortization over a period that includes the projected periods in this 24 proceeding, as detailed on Exhibit A-13, Schedule C5.9.2, line 10. 25

Line N

1	Q92.	Why is \$2.497 million of O&M expense needed for Customer Outreach?			
2	A92.	Based on lessons learned from the Advanced Customer Pricing Pilot, DTE Electric			
3		prepared customers for the upcoming change in their rate by sending a series of			
4		communications via multiple channels. The majority of communications were sent			
5		prior to the full TOD rollout in March 2023 and informed and educated customers			
6		about their new rate and provided tips for savings on a TOD rate. The Company			
7		conducted message testing with research and focus groups to ensure that all			
8		communications developed were both easy to understand and engaging. The			
9		Company also produced the following two videos as part of its outreach strategy:			
10		• What a customer needs to understand about the new rate; and			
11		• How to save money on the new rate by shifting usage to non-peak times and			
12		tools to help manage usage. ⁵³			
13					
14	<u>5. Ele</u>	ctric Regulated Marketing Operations & Maintenance Expense			
15	Q93.	What does Electric Regulated Marketing O&M expense include?			
16	A93.	Electric Regulated Marketing O&M expense includes the following areas:			
17		 Major Account Services, which manages new and existing customer 			
18		relationships for C&I customer classes,			
19		 Electric Marketing, which manages marketing campaigns to educate 			
20		customers, develops new product and service offerings, and performs project			
21		management,			
22		• Economic Development, which seeks to stimulate local economic growth			
23		and activity, including job growth through business attraction and expansion,			

⁵³ Video on how to save money on the new rate - Time of Day 3 p.m. - 7 p.m. | Products | DTE Energy, available at <u>https://solutions.dteenergy.com/dte/en/Products/Time-of-Day-3-p-m--7-p-m-/p/TOD-3-7</u>, accessed on January 5, 2024

Line		P. BENNETT U-21534
<u>No.</u>		
1		 The Demand Response Portfolio costs, supported by Company Witness
2		Farrell
3		 Charging Forward O&M expense, explained above, and
4		 Amortization of the Charging Forward regulatory assets, supported by
5		Company Witness Uzenski.
6		
7	Q94.	What are the Electric Regulated Marketing O&M expenses for the historical
8		period?
9	A94.	As shown in line 15 of Exhibit A-13, Schedule C5.9, column (e), Electric Regulated
10		Marketing total O&M expense for the adjusted 2022 historical test period was \$20.5
11		million.
12		
13	Q95.	What is the total Electric Regulated Marketing O&M expense for the
14		projected test period that DTE Electric is seeking to recover?
15	A95.	As shown in line 15 of Exhibit A-13, Schedule C5.9, column (k), DTE Electric is
16		seeking to recover \$32.2 million of Electric Regulated Marketing O&M expense in
17		the projected test period.
18		
19	Q96.	What is driving the change between the historical period and the projected test
20		period?
21	A96.	DTE Electric is proposing an increase of \$11.62 million based on the following
22		changes to the historical 2022 Electric Marketing O&M expense.
23		1. EV Program O&M expense of \$3.25 million, as shown in column (i), line 10 of
24		Exhibit A-13, Schedule 5.9;

Line		P. BENNETT U-21534
<u>No.</u>		
1		2. \$2.96 million related to Demand Response ("DR") programs, as supported by
2		Company Witness Farrell and shown in line 9 of the same exhibit;
3		3. Charging Forward regulatory asset amortization of \$3.51 million, as supported
4		by Company Witness Uzenski and shown in line 11 of the same exhibit; and,
5		4. Inflation for 2023, 2024 and 2025 in the amount of \$1.9 million, as shown in
6		columns (f) through (h), line 15 of the same exhibit.
7		
8		The majority of the increase (\$6.8 million) is driven by the Company's EV
9		programs, which are either proposed in this case and justified above (\$3.25 million)
10		or already approved in prior cases and seeking regulatory asset amortization (\$3.51
11		million). Another \$2.96 million of the increase is due to demand response programs
12		and justified in the instant case by Company Witness Farrell.
13		
14		The remaining \$1.89 million is based on assumed labor and material annual inflation
15		adjustment factors of 3.20% for 2023, 2.90% for 2024, and 2.90% for 2025, as
16		supported by Company Witness Uzenski.
17		
18	Q97.	What are your conclusions regarding the level of Electric Regulated
19		Marketing O&M expense for the projected test period?
20	A97.	The Electric Regulated Marketing O&M expense is reasonable, prudent, and
21		necessary to support the programs proposed by the Company in the instant case, to
22		maintain the existing level of customer support to C&I Major Account Services
23		customers, to support the Company's economic development activities, and to
24		educate all customers on Company offerings.
25		

т.		P. BENNETT
Line <u>No.</u>		0-21534
1	Q98.	What are your thoughts on the level of DTE Electric's historical and projected
2		capital, regulatory asset, and O&M expenses contained in your testimony,
3		overall?
4	A98.	DTE Electric has been reasonable and prudent in past capital and O&M expenses,
5		and I anticipate this to continue through the projected test period and beyond. I
6		believe that DTE Electric has fully justified, as reasonable and prudent, its request
7		for capital, regulatory asset, and O&M expenses that are set forth in my testimony
8		and associated exhibits.
9		
10	Q99.	Does this complete your direct testimony?

11 A99. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

SHAWN D. BURGDORF

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF SHAWN D. BURGDORF

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Shawn D. Burgdorf. My business address is 8001 Haggerty Road,
3		Suite 109, Belleville, Michigan 48111. I am employed by DTE Electric Company
4		(DTE Electric or Company) as the Manager of the Power Supply Strategy &
5		Modeling team within the Generation Optimization department.
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric.
9		
10	Q3.	What is your educational background?
11	A3.	I received a Bachelor of Science Degree in Mechanical Engineering from
12		University of Michigan in 2005. I also received a Master of Business
13		Administration Degree from Eastern Michigan University in 2016.
14		
15	Q4.	What is your work experience?
16	A4.	After receiving my Bachelor's degree from the University of Michigan in 2005, I
17		was employed by Consumers Energy Company (Consumers Energy). During my
18		initial employment at Consumers Energy, I worked in their production cost
19		modeling group where I supported the development of power supply forecasts using
20		the PROMOD® model as the basis. In 2009, I transferred positions into the
21		Transmission and Regulatory Strategies Department. In this role, I was responsible
22		for monitoring and analyzing filings by the Midcontinent Independent System
23		Operator, Inc. (MISO) at the Federal Energy Regulatory Commission (FERC). I
24		was also responsible for forecasting future transmission and certain energy market-

<u>No.</u>		
1		related costs in Power Supply Cost Recovery (PSCR) proceedings before the
2		Michigan Public Service Commission (Commission or MPSC).
3		
4		In 2012, I began my employment at DTE Electric within the Generation
5		Optimization Department. In 2015, I was promoted to a Supervisor position and
6		subsequently in October 2018, I was promoted to my current Manager position
7		within Generation Optimization.
8		
9	Q5.	Do you hold any certifications or are you a member of any professional
10		organizations?
11	A5.	Yes. I have attended Utility Rate School and the Advanced Regulatory Studies
12		Program, both hosted by the National Association of Regulatory Utility
13		Commissioners (NARUC) and The Institute of Public Utilities Michigan State
14		University.
15		
16	Q6.	What are your current duties and responsibilities?
17	A6.	My current responsibilities include acquisition of wholesale electric power supply
18		to reliably and economically serve the energy requirements of the Company's
19		customers including: optimization of the Company's generation assets, including
20		renewable energy facilities, within the wholesale power market; management of
21		emission allowance procurement; management of resource adequacy processes;
22		modeling the DTE Electric generation fleet; optimizing financial transmission
23		rights; and review and advocacy of Company recommendations regarding proposed
24		MISO rules, regulations, and business practices.

Line
No.

1	Q7.	Have you previously sponsored testimony before the Michigan Public Service			
2		Commission	Commission (MPSC or Commission)?		
3	A7.	Yes. I have s	sponsored testimony in the following MPSC cases:		
4		U-16149	Consumers Energy's 2010-2011 Gas Cost Recovery (GCR) Plan		
5		U-16485	Consumers Energy's 2011-2012 GCR Plan		
6		U-16924	Consumers Energy's 2012-2013 GCR Plan		
7		U-16890	Consumers Energy's 2012 PSCR Plan		
8		U-17097-R	DTE Electric's 2013 PSCR Reconciliation		
9		U-17319-R	DTE Electric's 2014 PSCR Reconciliation		
10		U-17632	DTE Electric's 2013 Renewable Energy Plan Reconciliation		
11		U-17680	DTE Electric's 2015 PSCR Plan		
12		U-17793	DTE Electric's 2015 Amended Renewable Energy Plan		
13		U-17804	DTE Electric's 2014 Renewable Energy Plan Reconciliation		
14		U-17920	DTE Electric's 2016 PSCR Plan		
15		U-17680-R	DTE Electric's 2015 PSCR Reconciliation		
16		U-18111	DTE Electric's 2016 Amended Renewable Energy Plan		
17		U-18082	DTE Electric's 2015 Renewable Energy Plan Reconciliation		
18		U-18143	DTE Electric's 2017 PSCR Plan		
19		U-17920-R	DTE Electric's 2016 PSCR Reconciliation		
20		U-20069	DTE Electric's 2017 PSCR Reconciliation		
21		U-20221	DTE Electric's 2019 PSCR Plan		
22		U-20471	DTE Electric's 2019 Integrated Resource Plan (IRP)		
23		U-20561	DTE Electric's 2019 Main Rate Case		
24		U-20528	DTE Electric's 2020 PSCR Reconciliation		
25		U-18091	DTE Electric's 2021 PURPA Avoided Cost		

Line <u>No.</u>

1	U-20836	DTE Electric's 2022 Main Rate Case
2	U-21193	DTE Electric's 2022 IRP
3	U-21297	DTE Electric's 2023 Main Rate Case

Line
No.

1 **Purpose of Testimony**

2	Q8.	What is the	purpose of you	ir testimony in this proceeding?
3	A8.	The purpose	of my testimor	ny is to calculate projected capacity related generation
4		costs that are	part of the Cor	npany's power supply costs and establish the projected
5		wholesale ma	arket energy sa	lles revenue net of fuel. To do this, I projected 2025
6		capacity-rela	ted generation	costs used in the 2024 PSCR Plan (Case No. U-21425).
7		Also, from th	ne 2024 PSCR I	Plan, I projected 2025 wholesale market revenues from
8		energy and a	ncillary service	s sales from the Company's capacity resources, and the
9		fuel cost asso	ociated with the	e Company's capacity resources to calculate projected
10		wholesale m	arket energy sa	ales revenue net of fuel. This information is used by
11		Company Wi	itness Maroun i	in his calculation of cost of service.
12				
13		I also discuss	s removing the	wording "making an emergency purchase" from tariff
14		rates D1.1, D	01.8, D3.3 and 1	D5.
15				
16	Q9.	Are you spor	nsoring any ex	chibits in this proceeding?
17	A9.	Yes. I am spo	onsoring the fol	llowing exhibits:
18		<u>Exhibit</u>	<u>Schedule</u>	Description
19		A-26	P1	Projected 2025 PURPA Capacity-Related
20				Generation Cost
21		A-26	P2	Projected 2025 PA295/PA342 Capacity-Related
22				Generation Cost
23		A-26	P3	Projected 2025 Capacity-Related Generation Cost &
24				Energy Sales Revenue Net of Fuel Cost
25				

Line	
No	

<u>No.</u>		
1	Q10.	Were these exhibits prepared by you or under your direction?
2	A10.	Yes, they were.
3		
4	Q11.	Section 6w(3)(a) of Act 341 requires that for rate design purposes the capacity
5		charge include capacity-related generation costs in the Company's PSCR
6		mechanism. What are the capacity-related generation costs included in the
7		Company's PSCR mechanism?
8	A11.	The Company's PSCR mechanism includes capacity-related generation costs
9		associated with Public Utility Regulatory Policies Act of 1978 (PURPA) power
10		purchase agreements, PA295/PA342 Company-owned renewable energy systems,
11		PA295/PA342 renewable energy contracts, and capacity purchases.
12		
13	Q12.	How did the Company project the 2025 capacity-related generation costs for
14		PURPA power purchase agreements as included in its PSCR plan filing in
15		Case No. U-21425?
16	A12.	Most of the Company's PURPA contracts have three rate components: fixed,
17		operation and maintenance (O&M), and variable. Two of the Company's PURPA
18		contracts only have a capacity component. The projections for the fixed, O&M,
19		and capacity components were included in the capacity-related generation costs.
20		The total projected 2025 PURPA capacity-related generation cost is \$8.9 million as
21		shown on Exhibit A-26, Schedule P1, line 12.
22		
22	Q13.	What costs associated with PA295/PA342 Company-owned renewable energy

1	A13.	The portion of the cost of PA295/PA342 Company-owned renewable energy
2		systems that is passed through the PSCR Transfer Price mechanism is the approved
3		Transfer Price Schedule or the levelized cost of energy for the renewable energy
4		systems. The portion of the cost of PA295/PA342 power purchase agreements (i.e.,
5		non-Company owned) that is passed through the PSCR mechanism is the lower of
6		the Transfer Price approved for the power purchase agreement and the contract
7		price of the agreement.
8		
9		The Transfer Price is a proxy for the incremental non-renewable capacity and
10		energy expense that would be passed on to the customer if the renewable energy
11		resource was not developed. The relevant statute explains that when setting the
12		Transfer Price, the Commission shall consider factors including, but not limited to,
13		projected capacity, energy, maintenance, and operating costs, information filed
14		under Section 6j of 1939 PA 3 (MCL 460.6j), and wholesale market data including,
15		but not limited to, locational marginal pricing.
16		
17	Q14.	How did the Company project the 2025 capacity-related generation costs for
18		PA295/PA342 company-owned renewable energy systems and power purchase
19		agreements?
20	A14.	The capacity-related generation cost for PA295/PA342 Company-owned and non-
21		Company-owned renewable energy systems and power purchase agreements is the
22		approved Transfer Price fixed component for each specific renewable energy
23		system. The total projected 2025 PA295/PA342 capacity-related generation cost is
24		\$130.5 million as shown on Exhibit A-26, Schedule P2, line 39.
25		

Line	
No.	

1	Q15.	How did the Company project the 2025 cost of capacity purchases?
2	A15.	The Company included the net capacity purchase costs based on the 2024 PSCR
3		Plan (Case No. U-21425) forecasted expense for the calendar year 2025. The
4		expense includes the Company's net transactions within the MISO annual Planning
5		Resource Auctions (PRA) covering the 2025 calendar year ¹ . Consistent with the
6		amount filed in Case No. U-21425, the Company is projected to sell capacity in the
7		amount of \$(1.3) million as shown on Exhibit A-26, Schedule P3, line 6.
8		
9	Q16.	How did the Company calculate the projected 2025 energy sales revenue net
10		of projected fuel costs per Section 6w(3)(b) of Act 341?
11	A16.	Section 6w(3)(b) of Act 341 requires that the revenue, net of projected fuel costs,
12		from energy market sales, off-system energy sales, ancillary services sales, and
13		energy sales under unit-specific bilateral contracts be subtracted from the
14		Company's capacity costs before calculating its capacity charge. I performed the
15		calculation using the forecasted assumptions from the Company's 2024 PSCR Plan,
16		Case No. U-21425. To calculate the energy sales revenue net of projected fuel costs,
17		first the projected wholesale energy revenue from the Company's generation
18		resources (including power purchase agreements) was determined (Exhibit A-26,
19		Schedule P3, line 11). Next, the projected wholesale revenue associated with
20		ancillary services provided by the Company's generation resources was determined
21		(Exhibit A-26, Schedule P3, line 14). Finally, all fuel expenses associated with the
22		wholesale energy and ancillary services were determined (Exhibit A-26, Schedule
23		P3, line 20) and subtracted from the projected wholesale revenues (Exhibit A-26,

 $^{^1}$ MISO annual resource adequacy auctions cover the Planning Year from June 1st – May 31st. The 2024/25 Planning Year auction covers January 1st – May 31st, 2025 and the 2025/26 Planning Year auction covers June 1st – December 31st, 2025.

	S. D. BURGDORF U-21534
	Schedule P3, line 15) resulting in the energy sales revenue net of projected fuel
	costs (Exhibit A-26, Schedule P3, line 22).
Q17.	What is the projected revenue associated with wholesale energy sales from the
	Company's generation resources in 2025?
A17.	The Company receives wholesale energy revenues from the MISO wholesale
	energy market for the electricity produced by its generation assets. The wholesale
	energy revenues forecasted for all Company assets (including PPAs) in the
	Company's 2024 PSCR Plan (U-21425) was calculated to be \$2.180 billion shown
	on Exhibit A-26, Schedule P3, line 11. This was done by summing the hourly
	generation multiplied by the corresponding hourly market price.
Q18.	Is the Company projecting any off-system energy sales or sales under unit
	specific bilateral contracts in 2025?
A18.	No. These values are shown as zero on Exhibit A-26, Schedule P3, line 12 and 13.
Q19.	What is the projected ancillary services revenue from the Company's
	generation resources in 2025?
A19.	The Company receives wholesale revenue for providing the following ancillary
	services: regulation reserves, spinning reserves, supplemental, and short-term
	reserves (all settled via MISO's energy and ancillary services market). The
	Company's 2024 PSCR Plan projected that Company's generation resources would
	generate \$4.3 million of wholesale revenue associated with regulation, spinning,

Line

<u>No.</u>

and supplemental reserves. The projected wholesale ancillary services revenues
from the Company's generation resources in 2025 are shown on Exhibit A-26,

Line <u>No.</u>		S. D. BURGDORF U-21534
1		Schedule P3, line 14. Schedule 2 Reactive Ancillary Services Revenue is no longer
2		included since FERC approved elimination of compensation for Schedule 2 in
3		2023.
4		
5	Q20.	What is the total projected wholesale energy sales revenue including ancillary
6		services in 2025?
7	A20.	The total projected wholesale energy sales revenue including ancillary services in
8		2025 is \$2.184 billion as shown on Exhibit A-26, Schedule P3, line 15.
9		
10	Q21.	What is the projected fuel cost required to generate the projected wholesale
11		energy and ancillary services sales from the Company's generation resources
12		in 2025?
13	A21.	The projected fuel cost required to make the energy and ancillary services market
14		sales is projected from the generation in the 2024 PSCR Plan and includes: fuel,
15		variable component of power purchase agreements, and the variable component of
16		renewables (based on removing the fixed component of the MPSC-approved
17		transfer prices from the overall transfer price). Total projected fuel costs for the
18		Company's generation fleet are \$1,201 million as shown on Exhibit A-26, Schedule
19		P3, line 20.
20		
21	Q22.	How did you address the MISO market administrative costs associated with
22		Schedule 17 as well as chemical and emission expenses?
23	A22.	I removed the Schedule 17 costs from being included in the fuel costs in accordance
24		with the Commission Order in Case No. U-20836. However, I believe that these
25		costs should be included in fuel costs under Section 6w(3)(b) of Act 341, because

1 they are directly attributable to "injections" of energy into MISO and must be 2 incurred to effectuate the generation sales. I also removed the chemical and 3 emission costs which amount to \$28.4 million in accordance with the Commission 4 Order in Case No. U-21297, while I disagree with this direction. Chemical and 5 emission costs are required to produce the energy from a significant amount of the 6 Company's generation assets and the revenues associated with the energy sales 7 would not be possible without these expenses. To give the "benefit" of the energy 8 sales to customers being assessed a capacity charge per the State Reliability 9 Mechanism (SRM) without including all the attributable costs required to produce 10 the energy and make the sales is not fair to the Company's PSCR customers who 11 end up paying those extra costs, thus subsidizing customers on the SRM Capacity 12 Charge. The SRM was put in place to ensure that all electric suppliers were 13 planning for reliable energy supply, and it also allows for electric choice customers 14 to obtain temporary capacity from the incumbent utility while continuing to receive 15 energy from their alternative electric supplier. This flexibility already allows 16 electric choice customers to have the benefit of short-term market trends without 17 committing to the long-term investments needed for reliability, it should not 18 inappropriately burden the Company's full-time customers by providing additional 19 subsidies to electric choice customers.

20

21 22

Q23. How does the Company intend to handle any reconciliation of previous year variance of wholesale energy sales revenue net of fuel costs?

A23. The Company currently has no electric choice customers being assessed a capacity
 charge, thus no reconciliation with any customers has been previously done. The
 Company files a reconciliation exhibit in the annual PSCR Reconciliation case that
Line No.		S. D. BURGDORF U-21534
1		would be used for any reconciliation adjustment if a customer were to be charged
2		the SRM.
3		
4	Q24.	What is the Company's projected wholesale energy sales revenue net of
5		projected fuel costs per Section 6w(3)(b) of Act 341 for 2025?
6	A24.	The total projected 2025 wholesale energy sales revenue of \$2.184 billion, net of
7		\$1.201 billion in fuel costs equates to \$0.983 billion wholesale energy sales revenue
8		net of fuel costs as shown on Exhibit A-26, Schedule P3, line 22. This amount was
9		provided to Company Witness Maroun to develop his capacity related cost of
10		service.
11		
12	Q25.	Why are you proposing to remove "making an emergency purchase" from
13		rates D1.1, D1.8, D3.3, and D5?
14	A25.	This language is not needed as any emergency interruptions are covered under other
15		language within these rates, specifically, "maintaining system integrity" and "when
16		available system generation is insufficient to meet anticipated load." The Company
17		does not make any specific emergency purchases as energy transactions are handled
18		through MISO during emergency declarations.
19		
20	Q26.	Does this complete your direct testimony?
21	A26.	Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

MICHAEL S. COOPER

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF MICHAEL S. COOPER

Line <u>No.</u>

101		
1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Michael S. Cooper (he/him/his). My business address is DTE Energy
3		Company, One Energy Plaza, Detroit, Michigan 48226. I am employed by DTE
4		Energy Corporate Services, LLC (DTE LLC), a subsidiary of DTE Energy
5		Company (DTE Energy).
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric or Company).
9		
10	Q3.	What is your educational background?
11	A3.	I received a Bachelor of Business Administration Degree with a major in
12		accounting and finance from the University of Toledo in 1994. I received a Master
13		of Arts Degree in educational administration from Michigan State University in
14		1997.
15		
16	Q4.	What is your current position and work experience?
17	A4.	My current position is Director of Compensation, Benefits & Wellness. I joined
18		DTE LLC full time in 2008 and held positions with increasing responsibility in
19		Human Resources. In 2012, I became the Manager of Compensation and assumed
20		my current position in 2017. Prior to joining DTE LLC, I was employed by
21		Manpower as an on-site Staffing Program Manager and in other related positions
22		for Visteon Corporation. I was previously employed at Robert William James &
23		Associates as a recruiter with an emphasis in accounting and finance related
24		positions.

1	Q5.	What are y	our current responsibilities as Director of Compensation, Benefits
2		& Wellness	?
3	A5.	As Director	of Compensation, Benefits & Wellness, I have overall responsibility
4		for the desig	gn, implementation, and administration of DTE Energy's compensation
5		and employ	ee benefits related policies and practices.
6			
7	Q6.	Have you p	reviously sponsored testimony before the Michigan Public Service
8		Commissio	n (MPSC or Commission)?
9	A6.	Yes. I have	sponsored testimony in the following cases:
10		U-18255	2017 DTE Electric General Rate Case
11		U-18999	2017 DTE Gas General Rate Case
12		U-20162	2018 DTE Electric General Rate Case
13		U-20561	2019 DTE Electric General Rate Case
14		U-20642	2019 DTE Gas General Rate Case
15		U-20836	2022 DTE Electric General Rate Case
16		U-20940	2021 DTE Gas General Rate Case
17		U-21291	2024 DTE Gas General Rate Case
18		U-21297	2023 DTE Electric General Rate Case

1 **Purpose of Testimony**

2	Q7.	What is the purpose of your testimony?
3	A7.	My testimony will present an overview of employee compensation practices and
4		benefit expense for DTE Electric for the 2022 historical test period and the 12
5		months ended December 31, 2025, projected test period. Specifically, I will:
6		1. Provide support for the Company's projected pension costs, other post-
7		employment benefits costs (OPEB), active employee health care costs and the
8		costs of other employee benefits;
9		2. Support the Company's labor cost escalation assumptions used in Company
10		Witness Uzenski's development of the composite inflation factors for the
11		projected test period;
12		3. Provide an overview of the Company's compensation philosophy for non-
13		represented employees and the role that the Company's incentive plans play in
14		the overall reasonableness of its total compensation policies, including an
15		analysis of salaries for non-represented positions as of December 31, 2022,
16		relative to the market medians for comparable positions;
17		4. Describe the components of the Company's short-term and long-term incentive
18		compensation plans and support the inclusion of such cost in the Company's
19		revenue requirement, exclusive of the costs related to DTE Energy's Top Five
20		Executive Officers; and
21		5. Demonstrate that the quantifiable customer benefits of the Company's incentive
22		compensation plans exceed the corresponding expense, as required by the
23		Commission's traditionally mandated cost/benefit analysis of incentive
24		compensation expense.
25		

Line <u>No.</u>				U-21534
1		In summary	, my testimony	will support the reasonableness and validity of the
2		projected en	nployee benefit	ts and compensation expense to be incurred by DTE
3		Electric for t	the projected tes	st period.
4				
5	Q8.	Are you spo	onsoring any ex	xhibits in this proceeding?
6	A8.	Yes. I am sp	onsoring in wh	ole, or in part, the following exhibits:
7		<u>Exhibit</u>	<u>Schedule</u>	Description
8		A-13	C5.11	Projected Operation and Maintenance Expenses -
9				Employee Pension and Benefits
10		A-13	C5.11.1	Willis Towers Watson Healthcare Trend Projection
11		A-13	C5.11.2	PwC 2024 Medical Cost Trend
12		A-13	C5.11.3	Constant Dollar Active Healthcare Adjustment
13		A-13	C5.12.1	Projected Operation and Maintenance Expenses -
14				Pension Cost - Qualified
15		A-13	C5.12.2	Projected Operation and Maintenance Expenses -
16				Other Post-Employment Benefits (OPEB)
17		A-21	K1	Employee Compensation Market Analysis:
18				December 31, 2022
19		A-21	K2	2023 Annual Incentive Plan and Rewarding
20				Employees Plan Metrics: DTE Electric Company
21		A-21	K3	2023 Annual Incentive Plan and Rewarding
22				Employees Plan Metrics: Nuclear Generation
23		A-21	K4	2023 Annual Incentive Plan and Rewarding
24				Employees Plan Metrics: DTE Energy Corporate
25				Services LLC

Line No.				M. S. COOPER U-21534
1		A-21	K5	2023 Long-Term Incentive Plan Performance Shares
2				Metrics
3		A-21	K6	2023 Incentive Plans Cost/Benefit Analysis
4				
5	Q9.	Were these e	xhibits prepa	red by you or under your direction?
6	A9.	Yes, they we	ere. Portions	of Exhibit A-13, Schedule C5.11 are sponsored by
7		Witness Uzen	ıski.	
8				
9	<u>EMP</u>	LOYEE PENS	ION COSTS	
10	Q10.	What are per	nsion costs?	
11	A10.	Pension costs	are those cos	ts related to retirement benefits for the employees of
12		DTE Electric	that are eligi	ible to participate in the Company's defined benefit
13		pension plans	. The Compar	ny's defined benefit pension costs are recognized under
14		Financial Acc	counting Stand	ard Board's Accounting Standard Codification (ASC)
15		Section 715-3	30 (ASC 715-3	30). Costs for the Company's Savings Plan and other
16		defined contri	ibution benefit	s are recognized separately.
17				
18	Q11.	What are the	e components	of pension costs?
19	A11.	Pension costs	are measured	at the beginning of each fiscal year, under ASC 715-
20		30, and includ	le the followin	g four pension cost components:
21				
22		Service Cost	<u>s:</u> Service Co	sts represent the pension benefits earned by active
23		employees, or	n a present val	ue basis, during the current period. Service Costs are
24		measured bas	ed on the expe	cted benefits to be paid based on actuarial assumptions

1

2

3

including current and projected salaries, expected employee turnover, and life expectancy.

4 Interest Costs: Interest Costs are the increase in the Projected Benefit Obligation 5 (PBO) due to the passage of time during the current period. The PBO is the 6 actuarial present value of benefits attributable to the pension benefit formula and 7 service accrued to date discounted back to current dollars at a discount rate selected 8 at the prior year-end. A discount rate of 5.19% was used in determining the PBO 9 as of December 31, 2022. Measuring the PBO as a present value at the beginning 10 of each fiscal year requires the accrual of an interest cost for the current period at a 11 rate equal to the prior year's discount rate. The discount rate used in measuring 12 Interest Costs, as well as Service Costs for the 2022 historical test period, was 13 2.91%, based on the interest rate environment at the end of 2021, and projected 14 benefit payments from the pension plan matched against a yield curve of corporate 15 bond rates, rated AA or higher, provided by Aon, the Company's independent 16 actuarial firm. This was then reviewed by PriceWaterhouseCoopers (PwC), the 17 Company's independent accounting firm in connection with its audit of the 18 Company's financial statements as filed with the Securities and Exchange 19 Commission (SEC). The 5.19% discount rate used for determining Interest Costs 20 and Service Costs for the projected test year is based on the discount rate as of 21 December 31, 2022, which reflects the traditional assumption that high-quality 22 corporate bond yields at the end of 2022 will remain unchanged from the rates 23 prevailing at the end of the historical test year.

1 Expected Return on Assets: The Expected Return on Assets (ERoA), which is an 2 offset to pension costs, is an estimate of the expected investment return during the 3 current period, on the Market Related Value of the assets invested in the pension 4 trust at the beginning of the year adjusted for any expected funding activity and 5 projected benefit payments for the year. While actual year-to-year investment 6 returns can vary significantly, the ERoA is determined based on forward-looking 7 long-term financial market expectations to avoid large swings in pension costs 8 based on short-term investment performance. DTE Electric's expected annual 9 return was 6.80% during the 2022 historical test year, as developed by NEPC LLC, 10 the Company's independent investment consulting firm, and reviewed by PwC in 11 connection with its audit of the Company's financial statements as filed with the 12 SEC. The ERoA is 7.60%, 7.90% and 7.80% in 2023, 2024 and 2025, respectively. 13 The increase in the ERoA is due primarily to an increase in the forward-looking 14 long-term capital market assumptions that reflects the impact of the negative market 15 performance in 2022. These ERoAs are based on market conditions and pension 16 funding status as of late 2022.

17

Line

No.

18 Amortizations: In addition to current period costs described above, pension costs 19 also include the effect of the delayed recognition of prior period costs. This 20 includes Unrecognized Gains and Losses and Prior Service Costs. Unrecognized 21 Gains and Losses are changes in the amount of either the PBO or the plan's assets 22 resulting from experience different from that assumed in actuarial assumptions. 23 Most notably, since discount rates and return on assets assumptions are based on 24 either point in time measurements or long-term estimates of expected returns, 25 differences arise whenever a change is made in the discount rates or when the actual 1 asset returns differ from long-term expectations. These gains and losses are 2 deferred and the amount of the unrecognized balance in excess of a corridor equal 3 to 10% of the greater of the PBO or the Market Related Value of assets is amortized 4 based on a period equal to the average remaining service life of employees covered 5 by the plans. Prior Service Costs arise from pension plan amendments that affect 6 future benefits. When a plan provision is changed that will affect future benefit 7 payments for existing employees or retirees, the resulting change in the PBO 8 liability is amortized over the average remaining years of service life of the active 9 employees.

10

11 Q12. What is the level of pension funding reflected in the projected pension costs?

A12 A12. Based on the pension funding status on December 31, 2022, the Company is not expected to fund pension plans in 2023, 2024 or 2025. While there is no planned funding of DTE Electric's pension trust, \$50 million of pension assets related to the DTE Gas Non-Union pension trust were transferred to DTE Electric's pension trust assets in November 2023 in exchange for cash consideration. The reasons for these transfers are explained by Witness Uzenski.

18

19 Q13. How are pension costs expected to change between the historical test year and 20 the projected year?

A13. As summarized on Exhibit A-13, Schedule C5.12.1, the Company's pension costs
 are projected to decrease from \$90.987 million during the historical test year, which
 includes the one-time cost of \$64.798 million related to settlement charges
 recognized in 2022, to \$53.993 million for the projected test year. After adjustments
 for the portion of pension costs capitalized and transferred, the Company's projected

Line <u>No.</u>		M. S. COOPER U-21534
1		pension expense is \$32.273 million, as reflected on Exhibit A-13, Schedule C5.12.1,
2		line 19.
3		
4	Q14.	Is the pension expense included in the Company's proposed revenue
5		requirement?
6	A14.	No. Witness Uzenski sponsors the Company's proposal to continue to defer the
7		projected pension expense to the accumulated regulatory liability as initially
8		authorized by the Commission in its Order in Case No. U-20836. Thus, the
9		projected pension expense is not reflected in the Company's proposed revenue
10		requirement and the pension expense is eliminated on line 20 of Exhibit A-13,
11		Schedule C5.12.1.
12		
13	<u>OTH</u>	ER POST-EMPLOYMENT BENEFITS (OPEB) COSTS
14	Q15.	What are OPEB Costs?
15	A15.	OPEB costs relate to the provision of retiree medical, dental, prescription drug and
16		life insurance benefits. OPEB is a cost recognized under U.S. GAAP Accounting
17		Standard Codification (ASC) section 715-60. Similar to ASC 715-30, OPEB costs
18		are determined under ASC 715-60 at the beginning of each fiscal year.
19		
20	Q16.	What are the cost components of OPEB?
21	A16.	OPEB has the same basic cost components as pension costs. They are:
22		
23		Service Costs: Service Costs are the portion of the expected post-retirement benefit
24		obligation, on a present value basis, attributable to employee participation service
25		during the current period. Service Costs reflect actuarial assumptions of employee

Line No.

5

turnover, age at retirement, and expected longevity. Service Costs also depends on
 the estimated costs of providing these benefits after the employee's retirement and,
 therefore, is impacted by both current medical cost levels and expected medical
 cost inflation.

6 Interest Costs: Interest Costs are the costs arising from the current period interest 7 on the discounted Accumulated Post-Retirement Benefit Obligation (APBO). The 8 APBO was discounted to today's dollars based on a discount rate of 2.91% as of 9 December 31, 2021, which was also used to determine Interest Costs in 2022. The 10 discount rate used to measure the APBO as of December 31, 2022, was 5.19%, 11 which was also used to determine the Interest Costs on the APBO during the 12 projected test year. The discount rate of 5.19% was determined based on the 13 interest rate environment at the end of 2022, as determined in a similar manner to 14 the measurement of the Company's pension costs, as described above.

15

16 Expected Return on Assets: The Expected Return on Assets (ERoA), which is an 17 offset to OPEB costs, based on the forward-looking long-term financial market 18 expectations to avoid large swings in OPEB costs based on short-term investment 19 performance. The ERoA was 6.40% during the historical test year and is 7.20%, 20 7.30% and 7.30% in 2023, 2024 and 2025, respectively. The increase in the ERoA 21 is primarily due to an increase in the forward-looking long-term capital market 22 assumptions that reflects the impact of negative capital market performance in 23 2022. These assumptions are based on market conditions and funded status at the 24 end of 2022.

1		Amortizations: This cost component includes the amortizations related to deferred
2		Gains and Losses as well as Prior Service Costs. Accumulated gains and losses,
3		outside the 10% corridor, as described for pension costs, are amortized over the
4		current estimated remaining service life of active participants. Prior Service Costs
5		are amortized over the estimated remaining service life of active participants, at the
6		time of the last plan change, to the age at which these employees are fully eligible
7		for the benefits.
8		
9	Q17.	How are these OPEB costs expected to change between the historical test year
10		and the projected test year?
11	A17.	As reflected on Exhibit A-13, Schedule C5.12.2, the Company's OPEB costs are
12		projected to increase from negative \$36.661 million in the historical test year to
13		negative \$14.459 million during the projected test year. After adjustments for the
14		portion of OPEB costs transferred and capitalized, the net OPEB expense is
15		projected to be negative \$8.395 million, as shown on Exhibit A-13, Schedule
16		C5.12.2, line 17.
17		
18	Q18.	Is the negative OPEB expense included in the Company's proposed revenue
19		requirement?
20	A18.	No. Witness Uzenski sponsors the Company's proposal to continue to defer to the
21	pr	ojected negative OPEB expense to the accumulated regulatory liability. Thus, the
22	pr	ojected OPEB expense is not reflected in the Company's proposed revenue
23	ree	quirement and the negative OPEB expense is eliminated on line 18 of Exhibit A-13,
24	Sc	hedule C5.12.2.
25		

1 Q19. Did the Commission address the OPEB regulatory liability in its Order in Case 2 No. U-21297? 3 A19. Yes. In its Order in Case No. U-21297, the Company's most recent rate case, the 4 Commission adopted a seven-year amortization of the Company's OPEB 5 regulatory liability as of December 31, 2022, which resulted in an annual 6 amortization of \$18.300 million that reduced the Company's revenue requirement 7 (Case No. U-21297, Order, pp 223-224). This annual amortization of \$18.300 8 million is reflected on Exhibit A-13, Schedule C5.12.2, line 19, as a reduction to 9 OPEB expense and is also reflected on Exhibit A-13, Schedule C5.11, line 3. 10 11 Has DTE Electric previously externally funded its OPEB costs? **Q20**. 12 Yes. DTE Electric has generally funded the OPEB costs included in the Company's A20. 13 revenue requirement adopted by the Commission in previous orders through a 14 Voluntary Employees' Beneficiary Association (VEBA) trust and an Internal 15 Revenue Code Section 401(h) trust. 16 17 Q21. Will the Company externally fund its OPEB liability in the future? 18 No. Since the Commission approved the Company's proposal in Case No. U-20836 A21. 19 to continue the deferral of the projected negative OPEB expense, initially approved 20 by the Commission in Case No. U-17767, the Company's current and projected 21 revenue requirements do not include any OPEB expense and thus there is no 22 obligation for the Company to externally fund its OPEB liability. 23 24 NEW HIRE VEBA AND EMPLOYEE SAVINGS PLAN COSTS 25 **Q22.** What is the New Hire VEBA?

Line
<u>No.</u>

1	A22.	The New Hire VEBA expense on Exhibit A-13, Schedule C5.11, line 4 reflect the
2		costs of the plans that are offered in lieu of the traditional retiree healthcare plan
3		for eligible employees, as adjusted for the portion of those costs that are capitalized.
4		Because the New Hire VEBA is generally offered in lieu of the Company's
5		traditional retiree healthcare plan, which is closed to most new participants, this
6		increase in costs is offset by avoided OPEB costs.
7		
8	Q23.	What are the components of the Company's New Hire VEBA costs?
9	A23.	The Company's New Hire VEBA costs consist of contributions generally made for
10		newly hired employees after 2012. Specifically, the Company contributes \$4,000
11		on behalf of non-represented and certain Local 17 employees in their year of hire,
12		as prorated for month of hire, and \$4,000 every year thereafter. For employees
13		represented by Local 223, the Company makes a payment of \$1,650 on their first
14		service anniversary and contributes \$40 per week thereafter. In 2022 the average
15		Company contribution for Local 223 employees was \$2,177.
16		
17		In addition, the Company recognizes a true-up of the estimate of the Company's
18		liability for contributions for non-represented and Local 17 employees that reflects
19		final determinations of plan eligibility and any forfeitures by employees that leave
20		the Company before the end of the 10-year vesting period. No such true up is
21		required for Local 223 employees because payments are made through the bi-
22		weekly payroll process and the Company doesn't receive any benefit from
23		employee departures.
24		

Line No.

1 Q24. What adjustments are you proposing to the Company's New Hire VEBA 2 expense? 3 A24. As reflected on page 2 of Exhibit A-13, Schedule C5.11, line 4, I am proposing two 4 adjustments to New Hire VEBA expense. The first, which is reflected on column 5 (c) represents a normalization of the Company's recorded 2022 New Hire VEBA 6 expense and the second, which is reflected in column (h) represents the projection 7 of this expense through the end of the projected test year. 8 9 Q25. Why is a normalization adjustment required for the Company's recorded 2022 10 New Hire VEBA expense reflected on Exhibit A-13, Schedule C5.11, page 2, 11 line 4, column (c)? 12 A25. In 2022, the Company recognized an unusually high true-up adjustment related to 13 the New Hire VEBA costs recognized in 2021 compared to the actual funding 14 requirement for 2021. Specifically, the 2021 true-up reflected as a reduction to the 15 Company's New Hire VEBA expense, which after reduction for the portion 16 capitalized, was \$1.336 million, whereas the average of the five prior years true-up 17 adjustments on a similar basis was only \$0.310 million. There were two primary 18 drivers of the large increase in the true-up recognized in 2022 related to 2021. First, 19 due to historically low levels of employee turnover during the COVID-19 pandemic 20 in 2020 there was a reduction in the number of new hires eligible to participate in 21 the plan in 2021. Second, as the economy transitioned out of the pandemic in 2021 22 and employee turnover increased, there was a substantial increase in the forfeitures 23 of accumulated balances by employees that left the Company before they were 24 vested in the plan. These two factors resulted in an unusually large true-up in 2022 25 that is non-recurring. Accordingly, the Company's 2022 recorded New Hire VEBA

Line <u>No.</u>		M. S. COOPER U-21534
1		expense should be increased by \$1.027 million, which represents the excess of the
2		2021 true-up over the average of true-ups recognized in the prior five-years.
3		
4	Q26.	What is the basis for the projected increase in the New Hire VEBA expense?
5	A26.	The New Hire VEBA expense is projected to increase from the normalized 2022
6		expense of \$7.707 million to \$9.847 million in the projected test year. This increase
7		reflects the growth in the number of plan participants due to new hires.
8		
9	Q27.	How was the projected New Hire VEBA expense developed?
10	A27.	The projected New Hire VEBA expense was developed based on the number of
11		active participants in the plans as of December 31, 2022, which was increased by
12		the number of expected new participants based on the most recent five-year average
13		of actual new plan participants prorated for the assumption that the new participants
14		would be added evenly throughout the year (i.e., divided by two). The average plan
15		participants for each year were costed-out based on the Company's required
16		contributions for each plan, as described above, to determine the projected gross
17		cost for each plan. The amount for the non-represented employees and employees
18		represented by Local 17 was then reduced by the five-year average of employee
19		forfeitures for those plan participants that left the Company before they were vested
20		in the plan. Total costs for the projected test year are projected to be \$15.320
21		million, which is reduced by 35.7% to recognize the portion of costs to be
22		capitalized, resulting in net New Hire VEBA expense of \$9.847 million. This
23		represents an average annual increase of 13.8%.

1	Q28.	What is included in Employee Savings Plan expense reflected on Exhibit A-13,
2		Schedule C5.11, line 5?
3	A28.	The Company's Employee Savings Plan is an employee benefit plan that allows
4		eligible employees the opportunity to contribute a certain percentage of their annual
5		earnings that the Company matches, generally up to 6% of annual salaries and
6		wages for non-represented employees and for most represented groups. In addition,
7		employees hired after the Company's defined benefit pension plans were closed to
8		new hires receive an additional Company contribution of 4.0% of their pay,
9		although certain represented employees receive a Company contribution of 8.0%
10		of their pay.
11		
12	Q29.	What adjustments are you proposing to the Company's Employee Savings
13		Plan expense?
14	A29.	As reflected on page 2 of Exhibit A-13, Schedule C5.11, line 5, I am proposing two
15		adjustments to Employee Savings Plan expense. The first, which is reflected on
16		column (c), represents a normalization of the Company's recorded 2022 Employee
17		Savings Plan expense and the second, which is reflected in column (h), represents
18		the projection of this expense through the end of the projected test year.
19		
20	Q30.	Why is a normalization adjustment required for the Company's recorded 2022
21		Employee Savings Plan expense as reflected on Exhibit A-13, Schedule C5.11,
22		page 2, line 5, column (c)?
23	A30.	The Company experienced an abnormally high level of employee resignations in
24		2021, which were likely driven by the transition out of the COVID-19 pandemic,
25		that resulted in an abnormally high level of forfeitures recognized in 2022.

Line
<u>No.</u>

1		Specifically, the Company recognized a reduction in its Employee Savings Plan
2		expense arising from forfeitures, predominately due to the departure of non-vested
3		employees in 2021 of \$0.837 million, whereas the five-year average of forfeitures
4		prior to 2022 was \$0.459 million, resulting in excess forfeitures of \$0.378 million.
5		Because the elevated level of forfeitures in 2021 was the result of a once in a
6		century pandemic, it is proper to normalize 2022 for the impact of forfeitures in
7		excess of a normal level. The elimination of excess forfeitures results in a
8		normalized 2022 Employee Savings Plan expense of \$30.077 million as shown on
9		page 2 of Exhibit A-13, Schedule C5.11, page 2, line 5, column (d).
10		
11	Q31.	How was the projected Employee Savings Plan expense developed?
12	A31.	The projected Employee Savings Plan expense was developed based on the
13		normalized 2022 expense escalated by the four-year average of the annual increase
14		in the Company's Employee Savings Plan costs for the years 2017 through 2020 of
15		7.50%. This results in Employee Savings Plan expense for the projected test year
16		of \$37.406 million.
17		
18	Q32.	Why have you not included the annual percentage increase in the Company's
19		Employee Savings Plan costs for 2021 and 2022 in the historical average
20		annual increase?
21	A32.	In 2021, the Company's Employee Savings Plan costs were impacted by the low
22		level of new employees during the COVID-19 pandemic. Plus, in 2022 the
23		Company recognized an abnormally high level of forfeitures arising from
24		employee resignations in 2021, as the economy transitioned out of the pandemic.
25		Accordingly, the Company's experience in both 2021 and 2022 were impacted by

1		the same non-recurring item, to-wit, the once in a century worldwide pandemic.
2		Since both years were impacted, both the 2021 and 2022 annual increase should
3		be excluded from the historical annual rate of change in the Employee Savings
4		Plan costs. This is consistent with the methodology adopted by the Commission
5		in its Order in the Company's most recent rate case which adopted the
6		recommendation of the Administrative Law Judge (Case No. U-21297, Order
7		December 1, 2023, p. 191).
8		
9	Q33.	Why did you escalate the adjusted historical test year Employee Savings Plan
10		expense by the average annual increase in the Company's Savings Plan costs
11		rather than the annual increase in the Company's Savings Plan expense?
12	A33.	Since the Company's Employee Savings Plan expense is impacted by the
13		proportion of the costs that are capitalized, the annual changes in the Company's
14		Employee Savings Plan expense reflects both the effect of the changes in costs and
15		changes in the proportion of the costs capitalized. For example, the five-year
16		average of the annual increase Employee Savings Plan expense was 6.20% for the
17		years 2018 through 2022, but this reflects an increase in the proportion of costs
18		capitalized from 31.3% in 2017 to 39.6% in 2022. This increase in the proportion
19		of costs capitalized reflects the significant increase in the Company's capital
20		expenditures over this time frame, which is assumed to remain constant through the
21		projected test year. Therefore, under the assumption that the proportion of costs
22		capitalized will not increase in the future, the historical average annual increase in
23		the Company's Employee Savings Plan costs of 7.50% for the years 2017 through
24		2020, as described in Q32, is a more accurate measurement of the projected increase
25		in the Company's Employee Savings Plan expense.

2 <u>ACTIVE HEALTHCARE EXPENSE</u>

3 Q34. What are the healthcare benefit programs offered to active employees?

4 A34. The Company offers a competitive active healthcare benefits package for the 5 attraction and retention of a skilled workforce. The components of these benefits 6 are summarized on Exhibit A-13, Schedule C5.11 (lines 8 through 10) and consists 7 of medical, dental, and vision benefits for active employees that are projected to 8 increase from \$50.126 million in the historic test year to \$56.083 million. This 9 increase includes the normalization of the historical Active Healthcare costs to 10 reflect a historical average of constant dollar costs, as developed on Exhibit A-13, 11 Schedule C5.11.3, and annual escalations for the adjusted medical plan trend of 12 5.1% in 2023, 5.0% in 2024, and 4.0% in 2025, as more fully described below in 13 Q47 through Q54.

14

Q35. What is the Normalization Adjustment to 2022 Active Healthcare costs as reflected on Exhibit A-13, Schedule C5.11?

17 A35. The year-to-year volatility of actual Active Healthcare costs makes the use of any 18 one historical period's cost a potentially unreliable starting point in the 19 determination of projected Active Healthcare costs. Accordingly, the adjustment 20 of negative \$1.260 million reflected on Exhibit A-13, Schedule C5.11, page 2 on 21 line 11 of column (c), represents a normalization of the Company's actual 2022 22 Active Healthcare costs that is designed to eliminate the volatility of the Company's 23 Active Healthcare costs through the quantification of the Company's historical 24 Active Healthcare costs per employee, as adjusted for national historical healthcare 25 cost trends. This results in an average of the Company's actual Active Healthcare costs per employee that eliminates the impact of historical healthcare cost inflation
 and, therefore, reflects the cost volatility due to changes in the usage of healthcare
 services.

4

Line

No.

Q36. What is the basis for your conclusion that year-to-year Active Healthcare costs are volatile?

7 A36. The primary reason the Company's Active Healthcare costs reflect substantial 8 volatility among years is that the Company is self-insured for about 70% of its 9 total Active Healthcare costs. Self-insurance results in the level of Active 10 Healthcare costs incurred by the Company being highly impacted by the mix and 11 severity of medical treatments administered to employees and their eligible 12 dependents in any given year. For example, in 2020 DTE Electric's medical claims 13 related to outpatient specialty drugs decreased by almost \$0.6 million, or over 14 25%, compared to 2019 while in 2021 claims for the same category increased by 15 over \$1.4 million or almost 90%. In addition, in 2021, inpatient care related to the 16 treatment of COVID-19 infections increased by over \$1.0 million and then 17 declined by almost \$1.2 million in 2022. Also in 2022, the Company reinstituted 18 its healthy living requirements for employee contributions for healthcare services 19 that were suspended during the pandemic. As a result, total employee contributions 20 increased in 2022 by \$2.3 million, which is an offset to the Company's Active 21 Healthcare costs. This single non-recurring increase in employee contributions 22 reduced the Company's Active Healthcare costs in 2022 by over 2.5%.

23

Q37. Have you quantified the degree of volatility in the Company's Active Healthcare Costs?

Line <u>No.</u>		M. S. COOPER U-21534
1	A37.	Yes. The actual annual percentage change in the Company's Active Healthcare
2		costs on a per employee basis, as adjusted for a one-time credit in 2018, is reflected
3		in Table 1 below.
4		Table 1



This chart shows that the Company's actual Active Healthcare costs have changed relative to the prior year by as much as 27.2% in 2021 to a decrease of 4.5% in 2018, demonstrating that Active Healthcare costs can vary significantly from year-to-year. While the average percent change in the Company's Active Healthcare costs for the years 2013 through 2022 was 2.7%, the standard deviation of this average is 9.4%.

1	Q38.	What is the significance of this high degree of variability in the percentage
2		change in the Company's actual Active Healthcare costs?
3	A38.	Since the Company's actual Active Healthcare costs can be impacted by variations
4		in usage, the effect of benefit plan design, and changes in pricing, any given year's
5		Active Healthcare costs will likely be an unreliable basis to establish a starting point
6		for future Active Healthcare costs. Moreover, the small sample size of the
7		experience of the Company makes it a poor predictor of future experience. In 2022,
8		the Company had about 3,400 employees enrolled in its self-insured medical plans,
9		which inclusive of dependents, represented about 9,800 total participants. The total
10		number of participants represents too small of a sample to infer that the experience
11		over a few years will reflect the long-term trends in the Company's Active
12		Healthcare costs. This small sample size is a key contributor to the year-to-year
13		variability as reflected in the high Standard Deviation relative to the average.
14		
15	Q39.	Is there a method of normalizing the Company's historical Active Healthcare
16		costs to determine a more reliable starting point in determining Active
17		Healthcare costs for the projected test year?
18	A39.	Yes. The variability in the Company's actual Active Healthcare costs can be
19		normalized using constant dollar Active Healthcare costs on a per employee basis.
20		This allows for the normalization of the inherent volatility in historical Active
21		Healthcare costs through the elimination of both the impact of healthcare price level
22		changes and changes in the level of employees.
23		
24	Q40.	How did you determine a constant dollar average of the Company's Active
25		Healthcare costs on a per employee basis?

Line <u>No.</u>

1 A40. Exhibit A-13, Schedule C5.11.3 reflects the Company's actual Medical, Dental, and 2 Vision components of the actual Active Healthcare costs for the years 2018 through 3 2022, before the impact of the costs capitalized and transferred. These costs are 4 divided by the simple average of employees at the beginning and end of each year 5 to develop the Active Healthcare costs per employee. The Active Healthcare costs 6 per employee for each year is then adjusted for the actual percent increase in medical 7 trends, as reported by PwC on page 2 of Exhibit A-13, Schedule C5.11.2. Adjusting 8 the Company's actual Active Healthcare costs for the overall increases in medical 9 costs experienced by a broad universe of employers and insurance providers, as 10 reflected in the PwC study, enables the separation of the Company's year-to-year 11 variability that is driven by changes in utilization by the Company's employees and 12 their dependents from changes to overall healthcare cost trends.

13

14 The adjustment of each year's Active Healthcare costs per employee produces a 15 five-year average cost per employee on a constant dollar basis of \$12,081. By 16 multiplying this amount by the 2022 average number of employees of 6,697, a total 17 constant dollar Active Healthcare cost of \$80.911 million is generated. This 18 represents a \$2.087 million decrease relative to the Company's incurred Active Healthcare costs in 2022. This amount is adjusted for the portion of Active 19 20 Healthcare costs charged to expense and results in a constant dollar normalization 21 adjustment of negative \$1.260 million, as reflected on Exhibit A-13, Schedule 22 C5.11.3, column (m), line 16.

23

Q41. How has the Commission traditionally addressed cost elements that are subject to volatility?

MSC-23

Line No.

Line
<u>No.</u>

1	A41.	The Commission has routinely adopted prior year's average of the ratio of
2		uncollectibles to revenues to project the Company's future uncollectibles expense,
3		and for DTE Gas, has used an average of historical Lost and Unaccounted for Gas
4		volumes to project future Lost and Unaccounted for Gas expense. The difference
5		is that in those instances the pricing is separated from the level of activity because
6		the ratios of uncollectibles and the volumes of Lost and Unaccounted for Gas were
7		determined first, and then those ratios are priced by applying the percentage of
8		historical uncollectibles for projected revenue or the average Lost and Unaccounted
9		for Gas volumes are multiplied by the projected cost of gas rate.
10		
11		In contrast, for Active Healthcare costs there is no available segregation of the
12		impact of changes in activity, as reflected in usage of health services, and the
13		pricing of those services. Because the price of healthcare services increases each
14		year, it would be unreasonable to predict future Active Healthcare costs based on
15		an average of the historical Active Healthcare costs. As a result, the only means of
16		producing a starting point for Active Healthcare costs that is normalized for
17		changes in utilization is to develop an historical average of costs that neutralizes
18		the impact of changes in price levels. This is what the constant dollar normalization
19		adjustment achieves.
20		

Q42. Are there any useful analogies to the Company's constant dollar Active 21 Healthcare adjustment? 22

Yes. From a broad perspective, the constant dollar Active Healthcare adjustment 23 A42. should be regarded as means to neutralize the inherent volatility in the Company's 24 25 actual Active Healthcare costs by restating the historical costs in current dollars,

Line No.

1

2

3

4

much as "nominal" price levels are routinely adjusted for the effects of inflation to develop inflation adjusted "real" prices. This allows for a meaningful comparison of costs among years without the distortion of changes in price levels.

5 More specifically, DTE Electric has traditionally adjusted its actual annual 6 historical emergent replacement expenditures for inflation to develop a base 7 spending level used in developing projected costs. This approach was explicitly 8 adopted in a DTE Electric rate case where the Commission concluded "Adding 9 inflation to the historic five-year historical actual spend is appropriate for 10 calculating the starting point for normalized expenditures." (Case No. U-20561, Order issued May 8, 2020, p. 86). The continued use of a five-year inflation 11 12 adjusted average of Emergent Replacement Expenditures was adopted by the 13 Commission in other recent Company rate cases (Case No. U-20836, Order issued 14 November 18, 2022, p. 63, Case No. U-21297 Order issued December 1, 2023, p. 15 76).

16

Q43. Has the normalization of emergent replacement expenditures for historical inflation been contested in the Company's recent rate cases?

A43. Yes. The Attorney General has consistently opposed the normalization of historical
emergent replacement expenditures. In the Company's most recent rate case the
Attorney General claimed that the normalization of historical expenditures for
inflation compounds inflationary increases and amounts to inflating forecasted
capital expenditures by increasing the base used in the projections (Case No. U21297, Order, p. 74). Based on this claim, the Attorney General proposed the
elimination of the historical inflation normalization of emergent replacement

		M. S. COOPER
Line <u>No.</u>		U-21534
1		expenditures. However, the Commission properly rejected the Attorney General's
2		proposal and adopted the Company's historical inflation normalization of emergent
3		replacement expenditures.
4		
5	Q44.	Did the Commission also address the issue of the constant dollar normalization
6		of Active Healthcare costs in its Order in Case No. U-21297?
7	A44.	Yes. In that case the Attorney General opposed the Company's constant dollar
8		Active Healthcare cost adjustment. Like the Attorney General's arguments in
9		opposition to the historical inflation normalization of emergent replacement
10		expenditures, the Attorney General claimed the adjustment for historical healthcare
11		increases compounded inflationary increases (Case No. U-21297, Order, p. 229).
12		The Commission declined to adopt the constant dollar normalization in this matter,
13		stating that the Company did not sufficiently demonstrate that the "proposed
14		constant dollar normalization will not result in compounded inflationary pressures"
15		(Case No. U-21297 Order, p. 232).
16		
17	Q45.	Does the constant dollar adjustment result in compound inflationary
18		pressures?
19	A45.	No. Just like the normalization of historical emergent replacement expenditures,
20		the constant dollar Active Healthcare costs adjustment merely recasts the
21		Company's historical Active Healthcare costs for the impact of historical medical
22		cost escalations. This adjustment enables the development of a five-year average
23		Active Healthcare costs per employee on basis that excludes the impact of changes
24		in prices. The only difference between the two normalization adjustments is that
25		emergent replacement expenditures are adjusted for overall inflation as measured

Line <u>No.</u>

 16 17 18 19 20 21 22 23 	Q47.	Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c), lines 8 through 10, to determine the Adjusted Historical Test Period expenses in column (d), which is then adjusted for the projected active healthcare trend factors through the end of the projected test period. What is the basis for your future trend factor in active healthcare costs used
 16 17 18 19 20 21 22 		Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c), lines 8 through 10, to determine the Adjusted Historical Test Period expenses in column (d), which is then adjusted for the projected active healthcare trend factors through the end of the projected test period.
 16 17 18 19 20 21 		Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c), lines 8 through 10, to determine the Adjusted Historical Test Period expenses in column (d), which is then adjusted for the projected active healthcare trend factors through the end of the projected test period.
 16 17 18 19 20 		Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c), lines 8 through 10, to determine the Adjusted Historical Test Period expenses in column (d), which is then adjusted for the projected active healthcare trend factors
16 17 18 19		Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c), lines 8 through 10, to determine the Adjusted Historical Test Period expenses in
16 17 18		Expense, and Vision Expense based on the proportion of the expenses for each of these categories in 2022 on Exhibit A-13, Schedule C5.11, page 2 of 2, column (c),
16 17		Expense, and Vision Expense based on the proportion of the expenses for each of
16		· · · ·
		allocated to the Active Healthcare cost components of Medical Expense, Dental
15	A46.	The total constant dollar normalization adjustment of negative \$1.260 million is
14		13, Schedule C5.11?
13	Q46.	How is this constant dollar normalization adjustment reflected on Exhibit A-
12		
11		Healthcare costs per employee results in the compounding of inflationary pressures.
10		it is inaccurate to conclude that the normalization of the Company's Active
9		to be used to project the Company's future Active Healthcare costs. Accordingly,
8		2018 through 2022, which is used to create a five-year average as a starting point
7		establishment of a normalized Active Healthcare costs per employee for the years
6		Healthcare costs per employee for actual national medical cost increases allows the
5		medical cost escalations. The escalation of the Company's historical Active
4		escalation recognizes that overall inflation is an inappropriate measure of historical
3		by the PwC actual medical cost increases. This difference in historical bases for
		adjustment is based on actual historical national medical cost trends as measured
2		

1	A47.	The annual unadjusted medical plan trend factors of 7.10% for 2023, 7.50% for
2		2024, and 7.00% for 2025, are based on projections for healthcare trends provided
3		by the healthcare experts at Willis Towers Watson (WTW), as reflected in Exhibit
4		A-13, Schedule C5.11.1. These unadjusted trend factors are reduced by 2.00% in
5		2023, 2.50% in 2024, and 3.00% in 2025 to reflect the expected savings to be
6		realized by the Company's Wellness program. Accordingly, the active healthcare
7		expense projections are based on the Company's 2022 normalized expense as
8		escalated by the adjusted trend factors of 5.10% in 2023, 5.00% in 2024, and
9		4.00% in 2025.
10		
11	Q48.	How were these trend factors determined?
12	A48.	WTW's first step is to develop the Allowed Trend, which is based on its internal
13		guidance and represents its consensus expectation for medical and prescription drug
14		costs. WTW developed the Allowed Trend based on its internal book of business
15		and national survey as well as data from United States government offices and
16		agencies, and various third-party sources, as described on page four of Exhibit A-
17		13, Schedule C5.11.1. The Allowed Trend is adjusted for the Company's average
18		fixed plan design leveraging to develop the future Medical Plan Trend, which is the
19		basis of the Company's projected active healthcare costs.
20		
21	Q49.	What assumptions are reflected in WTW's overall trend factors?
22	A49.	WTW's key assumptions for 2023 are described on page five of Exhibit A-13,
23		Schedule C5.11.1. Specifically, WTW assumes that overall inflation will be
24		between 2.50% and 4.00%. Added to the overall inflation is the incremental
25		healthcare inflation of between 1.00% and 2.15%, which is premised on the

Line
<u>No.</u>

1		assumption that healthcare inflation will likely revert to the historical pattern of
2		healthcare inflation exceeding overall inflation. This assumption reflects the
3		expectation that labor shortages in the healthcare industry will become more acute
4		as well as the likelihood of increased pricing for long-term contracts between
5		insurance carriers and healthcare providers. Finally, WTW expects the impact of
6		higher utilization will add between 1.75% and 3.25% to the expected trend factors,
7		which recognizes traditional experience in the low end assumption and the high
8		end assumption reflects the risk that COVID-19 related disruptions in the delivery
9		of healthcare services will lead to future increases in utilization. In sum, WTW
10		expects the overall medical trend in 2023 will increase between 5.25% and 9.40%.
11		
12	Q50.	How was the 2023 trend of 7.10% developed by WTW for the escalations used
13		by Company in its projections?
14	A50.	As also reflected on page five of Exhibit A-13, Schedule C5.11.1, in the column
15		labeled DTE Energy, the assumptions used in the development of the 6.60%
17		
16		unleveraged medical trend are detailed. Specifically, WTW assumes general
16		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July
16 17 18		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed
16 17 18 19		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint
16 17 18 19 20		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint of the range of 1.00% to 2.15% identified for the overall medical trend. Finally,
16 17 18 19 20 21		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint of the range of 1.00% to 2.15% identified for the overall medical trend. Finally, 1.90% is added to reflect the expected change in the Company's utilization and
16 17 18 19 20 21 22		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint of the range of 1.00% to 2.15% identified for the overall medical trend. Finally, 1.90% is added to reflect the expected change in the Company's utilization and service mix. This 1.90% addition for the impact of expected increase related to
16 17 18 19 20 21 22 23		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint of the range of 1.00% to 2.15% identified for the overall medical trend. Finally, 1.90% is added to reflect the expected change in the Company's utilization and service mix. This 1.90% addition for the impact of expected increase related to utilization and service mix at the Company is based on relative risk scores
 16 17 18 19 20 21 22 23 24 		unleveraged medical trend are detailed. Specifically, WTW assumes general inflation of 3.20%, which is based on the actual increase in the CPI through July 2023. Added to the general inflation assumption is 1.50% for the assumed incremental medical cost related inflation, which is slightly less than the midpoint of the range of 1.00% to 2.15% identified for the overall medical trend. Finally, 1.90% is added to reflect the expected change in the Company's utilization and service mix. This 1.90% addition for the impact of expected increase related to utilization and service mix at the Company is based on relative risk scores developed by Merative, a firm specializing in healthcare analytics, that projects that

1		about 1.70% annually. An additional 0.2% is added to the 1.70% to reflect the
2		expected impact of the Company's increased utilization of higher cost specialty
3		prescription drugs, resulting in a total increase due to utilization and service mix of
4		1.90%. A description of Merative and the support for the relative risk scores is
5		reflected on page six of Exhibit A-13, Schedule C5.11.1.
6		Based on these assumptions WTW's 2023 medical trend is 6.60% before the impact
7		of the Company's fixed plan design leveraging or 7.10% inclusive of the
8		Company's fixed plan design leveraging.
9		
10	Q51.	Can you describe fixed plan design leveraging?
11	A51.	Yes. Fixed plan design leveraging is the impact on the Company's costs of fixed
12		cost-sharing plan design items, such as deductibles, coinsurance, copays and out of
13		pocket maximum.
14		
15	Q52.	Are you aware of any corroborating sources that support the reasonableness
16		of WTW's projections?
17	A52.	Yes. A study released in 2023 by PwC's Health Research Institute, as reflected in
18		Exhibit A-13, Schedule C5.11.2, projects that medical costs will increase by 6.0%
19		in 2023 and 7.0% in 2024.
20		These studies support the reasonableness of the healthcare trend projections
21		provided by WTW.
22		
23	Q53.	Have the projections of future medical trends relied upon by the Company in
24		recent years been accurate?

Line	
<u>No.</u>	

1	A53.	Yes. In recent years the Company's average projected medical trend rates were
2		5.5%, 6.1%, 5.9% and 6.7% for the years 2019, 2020, 2021 and 2022, respectively,
3		or a four-year average of 6.1%. The actual increase in national medical costs
4		compiled by PwC, as reflected on Exhibit A-13, Schedule C5.11.2, page 2, were
5		5.7%, 6.0%, 7.0% and 5.5% for the years 2019, 2020, 2021 and 2022, respectively,
6		or a four-year average of 6.1%. In summary, the Company's projected trend rates,
7		which were developed consistent with the method used by WTW in the trend rates
8		reflected on Exhibit A-13, Schedule C5.11.1, have matched the actual national
9		medical trend rates. This demonstrates that the Company's projected trend rates
10		have been accurate predictors of actual medical trend rates.
11		
12	Q54.	Is the Company's recent experience a reliable basis for predicting future
13		increases?
13 14	A54.	increases? No. The high variability of the annual percent change in the Company's actual
13 14 15	A54.	increases?No. The high variability of the annual percent change in the Company's actualActive Healthcare costs per employee, as reflected in Table 1 discussed in response
13 14 15 16	A54.	increases?No. The high variability of the annual percent change in the Company's actualActive Healthcare costs per employee, as reflected in Table 1 discussed in responseto Q37, highlights the inherent flaw in using historical annual changes in the
13 14 15 16 17	A54.	increases?No. The high variability of the annual percent change in the Company's actualActive Healthcare costs per employee, as reflected in Table 1 discussed in responseto Q37, highlights the inherent flaw in using historical annual changes in theCompany's Active Healthcare costs as basis for projecting future increases. As I
13 14 15 16 17 18	A54.	 increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's
 13 14 15 16 17 18 19 	A54.	increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's actual Active Healthcare costs for the year 2013 through 2022 was 2.7%, the
 13 14 15 16 17 18 19 20 	A54.	 increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's actual Active Healthcare costs for the year 2013 through 2022 was 2.7%, the Standard Deviation of that average is 9.4%. This means that for about 68% of the
 13 14 15 16 17 18 19 20 21 	A54.	increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's actual Active Healthcare costs for the year 2013 through 2022 was 2.7%, the Standard Deviation of that average is 9.4%. This means that for about 68% of the years, the Company's annual change in Active Healthcare costs could range from
 13 14 15 16 17 18 19 20 21 22 	A54.	increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's actual Active Healthcare costs for the year 2013 through 2022 was 2.7%, the Standard Deviation of that average is 9.4%. This means that for about 68% of the years, the Company's annual change in Active Healthcare costs could range from negative 6.7% to a positive 9.1%. This extreme level of volatility renders historical
 13 14 15 16 17 18 19 20 21 22 23 	A54.	increases? No. The high variability of the annual percent change in the Company's actual Active Healthcare costs per employee, as reflected in Table 1 discussed in response to Q37, highlights the inherent flaw in using historical annual changes in the Company's Active Healthcare costs as basis for projecting future increases. As I previously discussed, the average annual percentage increase in the Company's actual Active Healthcare costs for the year 2013 through 2022 was 2.7%, the Standard Deviation of that average is 9.4%. This means that for about 68% of the years, the Company's annual change in Active Healthcare costs could range from negative 6.7% to a positive 9.1%. This extreme level of volatility renders historical changes in Active Healthcare costs to be virtually worthless in determining future

Line

<u>No.</u>

Given the unreliability of the Company's actual annual change in Active Healthcare
 costs, it is prudent to project future increases in Active Healthcare costs based on
 the adjusted WTW medical trend rates, which have a proven record of accuracy,
 rather than the Company's historical experience.

5

6 OTHER EMPLOYEE BENEFITS COSTS

7 **Q55.** What are Other Benefits Costs?

8 A55. The costs of the Company's Other Employee Benefits are also reflected on Exhibit 9 A-13, Schedule C5.11 (lines 13 through 25). These costs include a variety of other benefits including Accrued Vacation, Executive and Supplemental Retirement 10 11 Plans, Supplemental Severance Plan, Supplemental Savings Plan (SSP), Deferred 12 Compensation, Wellness Program, Life Insurance, Long-Term Disability, 13 associated with the Affordable Care Act (ACA), General Benefits, Benefit Plan 14 Administration Fees and Retirement Administration Fees. In total, these expenses 15 are projected to increase from \$5.318 million in the historic test year to \$18.554 16 million in the projected test year, as shown on line 26 of Exhibit A-13, Schedule 17 C5.11. As described in detail below and as reflected on page 2 of Exhibit A-13, 18 Schedule C5.11, column (c), \$11.170 million of this increase relates adjustments to 19 normalize the Other Benefits expense reported in 2022 and \$2.067 million relates 20 to projected increases, as reflected on column (i).

21

22 Q56. What adjustments are you proposing to Accrued Vacation expense?

A56. As reflected on page 2 of Exhibit A-13, Schedule C5.11, line 13, I am proposing
two adjustments to Accrued Vacation expense. The first, which is reflected on
column (c), represents a normalization of the Company's recorded 2022 accrued

		M. S. COOPER
Line <u>No.</u>		U-21534
1		Vacation expense and the second, which is reflected in column (i), represents the
2		projection of this expense through the end of the projected test year.
3		
4	Q57.	What is the Normalization of the Company's Accrued Vacation expense?
5	A57.	Accrued Vacation expense can vary from year to year based on the timing of the
6		vacation earned and usage of vacation time by employees, as well as forfeitures.
7		This volatility in annual accrued vacation expense has been traditionally addressed
8		using a five-year average of the annual expense. Accordingly, the adjustment to
9		Vacation Accrual expense reflected on page 2 of Exhibit A-13, Schedule C5.11,
10		line 13, column (c), is based on the average of the recorded expense for the years
11		2018 through 2022 of negative \$0.497 million. This results in an increase to
12		Accrued Vacation expense of \$4.942 million.
13		
14	Q58.	What is the basis for your projection of the Company's Accrued Vacation
15		expense?
16	A58.	The adjusted five-year average is escalated by the projected 3.0% labor annual
17		cost increases through the end of the projected test year.
18		
19	Q59.	What is the basis for the Supplemental Severance Plan cost projections?
20	A59.	The Supplemental Severance Plan, which was implemented on July 1, 2016, is
21		designed to address the differences in full benefit eligibility retirement ages
22		between the DTE Traditional Pension Plan and the MCN Energy Group, Inc
23		(MCN) Traditional Pension Plan. As a severance plan, in accordance with the
24		regulations of the U.S. Department of Labor, it is not subject to participation,
25		vesting and funding requirements of ERISA. Eligible employees will receive a

lump sum payment equal to the present value of the difference between the DTE
 Pension Plan and the MCN Pension at the termination of employment. Aon
 developed the projected cost of this plan, which is estimated to decrease from
 \$0.734 million in 2022 to \$0.110 million for the projected test year, as reflected
 on Exhibit A-13, Schedule C5.11, line 14.

6

7 Q60. What is the Supplemental Savings Plan?

8 A60. The SSP is a non-qualified benefit plan that does not meet the requirements under 9 the Internal Revenue Code to be eligible for certain tax advantages, such as the 10 deductibility by the Company of any contributions. Each year, the Internal 11 Revenue Service (IRS) establishes limitations on employee annual eligible 12 compensation and annual contributions to tax advantaged plans. To the extent an 13 employee's annual eligible compensation or annual contributions, including the 14 Company's match, to the Company's qualified plan exceeds the IRS limitations, 15 employees that are Director level and above are eligible to participate in the SSP. 16 By participating in the SSP, employees accrue benefits that are identical to the benefits available under the qualified savings plan. As such, the SSP is a "make-17 18 whole" benefit plan that merely puts the participating employees in the same place 19 they would be in the absence of the IRS limitations.

20

21 Q61. What adjustments are you proposing to the SSP expense?

A61. I am proposing two adjustments to SSP expense. The first relates to a
 normalization of the actual 2022 SSP expense and the second relates to a
 projection of the SSP expense through the end of the projected test year.
1	Q62.	What is the normalization adjustment for 2022 SSP expense?
2	A62.	Since the Company does not separately fund the Company's matches to the
3		employees' contributions, the earnings and losses from the employees' directed
4		investments is a cost incurred by the Company. The SSP normalization adjustment
5		reflects an annual return on the investments of 6.80% in 2022, which is based on
6		the ERoA used in the determination of the Company's pension costs in the
7		historical test year. This results in a normalized SSP expense of \$2.456 million
8		compared to a negative expense of \$3.599 million recorded in 2022, which
9		represents an increase in SSP expense of \$6.055 million, as reflected on page 2 of
10		Exhibit A-13, Schedule C5.11, line 15, column (c). The increase in SSP expense
11		reflects the difference between the negative return on the investments in the SSP
12		and the ERoA of 6.80%.
13		
14	Q63.	What is the basis for projected the SSP expense for the projected test year?
15	A63.	The increase in the normalized 2022 SSP expense of \$2.456 million to \$3.207
16		million for the projected test year, as shown on Exhibit A-13, Schedule C5.11, line
17		15, reflects an increase in the Company's matching contributions based on
18		projected salary escalations and an increase in the expected earnings on designated
19		investments. The SSP projection reflects an annual return on the investments of
20		7.60% in 2023, 7.90% in 2024 and 7.80% in 2025, consistent with the ERoA used
21		in the determination of the Company's pension costs in the projected test year.
22		
23	Q64.	What adjustments are you proposing to Deferred Compensation Plan
24		expense?

Line <u>No.</u>

L	ine
N	T_

IN	0	•	

7

 A64. I am proposing two adjustments to Deferred Compensation expense. The first relates to a normalization of the actual 2022 Deferred Compensation expense and the second relates to a projection of the Deferred Compensation expense through the end of the projected test year.
 Q65. What is the normalization adjustment for 2022 Deferred Compensation

expense?

8 A65. Similar to the SSP, the Company's recorded costs are based on the return on the 9 investment directives of the participating employees since the deferrals are not 10 funded by the Company. The Deferred Compensation normalization adjustment 11 reflects an annual return on the investments of 6.80% in 2022, which is based on 12 the ERoA used in the determination of the Company's pension costs in the 13 historical test year. This results in a normalized Deferred Compensation expense 14 of \$88,000 compared to a negative expense of \$85,00 recorded in 2022, which 15 represents an increase in Deferred Compensation expense of \$173,000, as 16 reflected on page 2 of Exhibit A-13, Schedule C5.11, line 16, column (c). The 17 increase in Deferred Compensation expense reflects the difference between the 18 actual negative return on the investments in the Deferred Compensation balances 19 in 2022 and the Pension ERoA of 6.80%.

20

21 Q66. What is the basis for the projected Deferred Compensation Plan expense?

A66. The increase in the normalized 2022 Deferred Compensation Plan expense of
 \$88,000 to \$95,000 for the projected test year, as shown on Exhibit A-13, Schedule
 C5.11, page 2, line 16, column (j), reflects an increase in the expected earnings on
 designated investments. The Deferred Compensation Plan projection reflects an

Ν	A. S. COOPER U-21534
annual return on the investments of 7.60% in 2023, 7.90% in 202	24 and 7.80% in
2025, consistent with the ERoA used in the determination of	the Company's
pension costs in the projected test year.	
67. How did you project the increase in the Company's Wel	lness Program
expense?	
67. As referenced in my discussion of Active Healthcare expense, the	Company has a
Wellness Program designed to produce significant reductions	in future active
healthcare expense. Wellness Program expense is projected to	o increase from
\$4.995 million in the historical test year to \$5.560 million in the pr	ojected test year
based on the adjusted healthcare trend annual escalations of 5.10%	in 2023, 5.00%
in 2024, and 4.00% in 2025 (Exhibit A-13, Schedule C5.11, line 1	17).
68. How did you project the Company's Life Insurance Expense?	
68. The Company's Life Insurance expense relates to life insurar	nce provided to
employees that provides coverage that is generally equal to the	employees base
annual salary. Because the coverage is based on employee salaries	, I have adjusted
the 2022 expense of \$252,000 by the annual wage escalation	of 3.0%, which
produces a Life Insurance expense in the projected test year of	of \$276,000, as
reflected on line 18 of Exhibit A-13, Schedule C5.11.	
69. How have you projected the Company's Long-Term Disability	Expense?
69. Actual 2022 Long-Term Disability Expense is projected to increa	use from \$1.354
million to \$1.480 million during the projected test year based on the	assumption that
disability claims costs are primarily driven by labor costs escalat	tions, which are

		M. S. COOPER
Line <u>No.</u>		U-21534
1		assumed to be 3.0% per year between 2022 and the end of the projected test year, as
2		reflected on line 19.
3		
4	Q70.	How did you develop the projections for the other items included in Other
5		Benefits on Exhibit A-13, Schedule C5.11?
6	A70.	On lines 20 through 25 of Exhibit A-13, Schedule C5.11 are the components of the
7		other items included in the Company's Other Benefits. The 2022 ACA expense of
8		\$19,000 on line 20 reflects the actual expense recognized for the Comparative
9		Effectiveness Research Fee, which is escalated at the annual Active Healthcare
10		inflation rates, resulting in \$22,000 of ACA expense for the projected test year.
11		General Benefits Expense is reflected on line 21 and is projected based on the actual
12		amounts recorded in 2022 of \$2.198 million and escalated at the overall rate of
13		inflation as measured by the Consumer Price Index through the end of the projected
14		test year, which results in projected General Benefits Expense of \$2.395 million.
15		Benefit Plan Administration Fees (line 22) and Retirement Administration Fees
16		(line 23) in 2022 of \$6.697 million and \$325,000, respectively, are projected to
17		increase to \$7.296 million and \$354,000, respectively based on the projected
18		overall inflation rate assumptions. Also included in Other Benefits, Exhibit A-13
19		Schedule C5.11 are Medical Refund Amortization (line 24) and O&M Project
20		reimbursements (line 25), which are both sponsored by Witness Uzenski.
21		
22	Q71.	What are the Company's total projected employee pensions and benefits
23		expenses for the projected test year?
24	A 71	The total precise tod employee panetions and hanafite expanses of \$102,500 million

A71. The total projected employee pensions and benefits expenses of \$103.590 million
is reflected on Exhibit A-13, Schedule C5.11, line 27. After adjustments for the

Line <u>No.</u>

1		impact of the portion of these costs to be capitalized and transferred, as well as the
2		elimination of costs allocated to the Company's separate surcharge programs, as
3		sponsored by Witness Uzenski, employee pensions and benefits expenses for the
4		projected test year are reduced to \$84.259 million, as reflected on Exhibit A-13,
5		Schedule C5.11, line 31.
6		
7	LABO	DR COST ESCALATION
8	Q72.	What annual labor cost escalation assumptions are appropriate for the
9		projected test period?
10	A72.	Annual labor cost escalation assumptions are required for both the Company's
11		represented and non-represented employees. Based on existing Collective
12		Bargaining Agreements, the Company is obligated to increase pay rates by at least
13		3% annually through the term of the contracts. In addition to scheduled pay rate
14		increases, the agreements also provide for progression increases for those
15		employees that have not yet achieved the maximum pay rate for their positions.
16		
17		Non-represented employee compensation is generally adjusted annually based on a
18		review of pay practices of other employers, changes in the external competitive
19		market and internal pay equity. Consistent with this practice, all non-represented
20		non-management employees received an overall pay increase of 3% in 2023. This
21		3% pay adjustment was comparable to the annual pay adjustments in every year
22		since 2010. In addition to the annual pay adjustment program, employees generally
23		receive pay increases based on promotions.

т:		M. S. COOPER
Line <u>No.</u>		0-21534
1		Based on the above, I have determined that annual escalations of 3.0% for 2023,
2		2024, and 2025 are a conservative estimate of the Company's expected increase in
3		its labor rates.
4		
5	EMP	LOYEE COMPENSATION
6	Q73.	What is the Company's compensation philosophy and framework for non-
7		represented employees other than Executives?
8	A73.	Non-represented employees are those employees not covered by any Collective
9		Bargaining Agreements with the Company's union organizations. Compensation
10		for employees covered by Collective Bargaining Agreements is established
11		pursuant to negotiations. Non-executive employees are generally defined as those
12		with titles below Vice President level. DTE Electric's compensation philosophy
13		is to provide pay programs that: 1) attract, retain, and motivate employees; 2)
14		ensure that pay is externally competitive (i.e., paid near market median); and 3)
15		differentiate total rewards based on both organizational unit results and individual
16		contributions.
17		
18		At DTE Electric, total annual compensation for all non-represented employees has
19		two primary components: base pay and variable pay, as delivered through the
20		Company's incentive compensation programs. Employee base pay is reviewed
21		annually and adjusted (if appropriate) based on the position relative to what the
22		external market pays for similar positions and individual performance. Variable
23		pay is based on the achievement of Company, as well as departmental and
24		individual results. Variable pay is made up of both short-term incentive and long-
25		term incentive plans.

3 A74. Incentive compensation programs are a component of total compensation practices 4 for the vast majority of energy companies for their non-represented employee 5 population, as described below. Base pay is set lower than it otherwise would be 6 because of the variable pay component. When considered holistically, the 7 Company's base and variable pay plans provide a framework of market-based total 8 annual compensation pay opportunities for non-represented employees. It is the 9 total annual cash compensation, as represented by these two components, that 10 prospective and current employees use to gauge whether DTE Electric's 11 compensation is competitive with other potential employers.

12

Line

No.

Q75. How does the Company's non-represented compensation philosophy and framework benefit customers?

15 A75. DTE Electric's compensation philosophy and framework provides a benefit to 16 customers by attracting and retaining employees with the requisite skills and 17 experience to ensure safe, reliable, and high-quality customer service delivery, and 18 by recognizing and rewarding effective and efficient performance. A competitive 19 compensation policy also serves to effectively retain employees, minimizing the 20 risks and costs of high employee attrition. This philosophy directly benefits all 21 customers by providing a high level of service at a competitive cost and provides 22 incentives to focus future job performance on those activities that provide the most 23 benefit to customers.

24

1	Q76.	What is the external comparative market used by the Company to determine
2		the external market for compensation?
3	A76.	The external comparative market for positions varies based on the specific job.
4		Some jobs are compared to those in utilities of similar size (e.g., revenue, number
5		of employees, etc.), other jobs are compared to general industry located in
6		Southeastern Michigan, and yet other jobs to general industry located within the
7		United States. The relevant market will depend upon the requisite skills and
8		abilities required of the job and the nature of the recruitment source. For example,
9		the comparative market for an administrative assistant is the general industry
10		within Southeastern Michigan while the comparative market for a manager of
11		nuclear operations is utilities within the Midwestern United States (primarily), or
12		within the entire United States (secondarily).
13		
14	Q77.	How is benchmark data obtained from the external comparative market?
15	A77.	The Company participates in and/or purchases published salary surveys from
16		several different organizations. The surveys typically report median base salary,
17		target incentives, and median total cash compensation by job classification.
18		
19	Q78.	How are base salaries determined?
20	A78.	Base salaries are targeted around the median base salary levels of the competitive
21		market as adjusted for differences in company size and scope where appropriate.
22		All non-executive positions are placed in a salary zone based on external
23		benchmarking. The mid-point of the salary zone is based on the market median
24		for comparable work in comparable companies. A range is provided above and
25		below the midpoint to allow for differentiation based on applicable skills and

		M. S. COOPER U-21534
	experience, as well as demonstrated performance. periodically to help ensure they remain competitive in	The ranges are reviewed the external market.
Q79.	Does the Company benchmark the variable compor	ent of compensation?
A79.	Yes. The Company reviews several surveys that provi	de information on a number

6 of variable pay indices. In addition, the surveys report data for employee groupings 7 such as exempt employees, non-exempt employees, managers, and executives.

8

Line No.

1

2

3

4

5

9 **O80**. Could an alternate compensation system be structured, eliminating variable 10 components?

11 A80. Yes. The Company could raise employees' base pay to the market levels for total 12 compensation in lieu of providing variable pay opportunities to maintain a 13 competitive total compensation level. However, this would have several 14 undesirable effects. For example, raising employees' base pay to the total 15 compensation market levels would result in a higher level of fixed costs tied to base 16 salaries, such as certain defined contribution benefit plans, life insurance, disability 17 insurance, and other salary-based employee benefits. Moreover, given the well-18 recognized motivational value of variable pay compensation programs, as 19 described below, delivering employee compensation solely in fixed salary would 20 diminish the performance incentive for employees to provide superior service to 21 customers. Annual incentives ensure that individuals have an element of "at risk" 22 compensation that allows the Company to differentiate pay based on performance 23 and allocate compensation to those employees that are most deserving.

1	<u>EXE(</u>	CUTIVE COMPENSATION
2	Q81.	How does the compensation program for executives differ from that for non-
3		executives?
4	A81.	The compensation program for executives differs in three respects. First, the
5		comparative market for compensation benchmarking is defined as a specific group
6		of peer companies from which data are obtained through a custom study generally
7		performed every two years. Second, a higher proportion of executives'
8		compensation is delivered in the form of variable pay. The third way in which the
9		executive compensation program differs is with respect to governance. The
10		compensation programs for Company executives must be approved by the
11		Organization and Compensation Committee of the DTE Energy Board of
12		Directors.
13		
14	Q82.	What is the comparative market for executive compensation?
15	A82.	The comparative market used by DTE Energy for determining the alignment of its
16		executive compensation programs with similar companies consists primarily of
17		utilities (including utility holding companies) and broad-based energy companies
18		selected on the basis of revenues, financial performance, geographic location, and
19		availability of compensation information.
20		
21	Q83.	What are the key components of the Executive Compensation Program?
22	A83.	The key elements of the Executive Compensation Program are base salary and
23		variable pay (annual incentive plan and long-term incentive awards).
24		
25	Q84.	How are base salaries determined?

1A84.Base salaries are targeted around the median of the comparative market.2Appropriate methods of measurement are used to consider differences in company3size and scope. In addition, midpoints are established for those executives whose4jobs cannot be easily matched in the comparative market. These midpoints are5designed to allow adequate differentiation for 1) individual potential, 2)6contributions made, and 3) the length of time the executive has been in his or her7position.

8

9 <u>COMPETITIVE COMPENSATION ANALYSIS</u>

10 Q85. Has the Company prepared an analysis of its compensation practices relative 11 to the market medians?

12 Yes. DTE Electric has performed an analysis of virtually all incumbent salaries as A85. 13 of December 31, 2022, showing that DTE's compensation practices are competitive 14 with market medians. Exhibit A-21, Schedule K1 reflects a summary of the market 15 median for all DTE Electric positions for which corresponding positions have been 16 identified, other than those employees covered by collective bargaining 17 agreements. In addition, Exhibit A-21, Schedule K1 reflects those positions at DTE 18 LLC that primarily support DTE Electric. Exhibit A-21, Schedule K1 reflects employee compensation information organized based on Career Family 19 20 classifications used by DTE Electric. A Career Family is a grouping of jobs based 21 on similar skill requirements and job content in a specialized discipline (i.e., 22 Finance, Engineering, Information Technology, etc.) that may or may not fit into a 23 business unit organizational structure. For example, Engineering or Finance Career 24 Families could exist in several organizational units.

25

Line <u>No.</u>		U-21534
1	Q86.	How is an analysis of a competitive pay structure performed?
2	A86.	An analysis of market-based pay structure is performed by identifying comparable
3		positions and determining the compensation ranges paid by similar employers in
4		relevant locations. A more expansive description of the means of assessing a
5		competitive pay structure is provided in an article published by Salary.com,
6		entitled The Basics of Market Pricing a Job (January 26, 2017).
7		
8	Q87.	Is the Company's use of a market pricing approach to employee compensation
9		consistent with others?
10	A87.	Yes. According to a recent survey performed by WorldatWork and Deloitte
11		Consulting, entitled 2019 Survey of Salary Structure Policies and Practices, more
12		than half of the companies surveyed use a market pricing model for setting
13		compensation levels.
14		
15	Q88.	Why are employees covered by collective bargaining agreements excluded
16		from this analysis?
17	A88.	Compensation levels for unionized employees are determined through a negotiated
18		process, which involves a variety of work rules and benefit related issues, rather
19		than determined strictly through market analysis. Moreover, the specialized skills
20		and experience required by many of the positions are not readily comparable to
21		other positions in the local market. Thus, a comparison of pay levels for those
22		employees covered by collective bargaining agreements is not useful in this
23		context.
24		
25	Q89.	What conclusions can be drawn from Exhibit A-21, Schedule K1?

age
ber
age
that
31,
lian
ıy's
and
the
for
son
ive
ı is
the
pay
l a li li ri a li ri a

17

18 **Q90.** What is included in the total cash compensation amounts?

A90. Total cash compensation reflects base pay as of December 31, 2022, and the Target
payout levels for those employees eligible to participate in the Company's shortterm incentive compensation programs. Although the analysis on Exhibit A-21,
Schedule K1 does not reflect the value of the Company's Long-Term Incentive
Plan, as it is primarily for executive level positions, a separate analysis of
executive compensation prepared by Aon, which is inclusive of long-term plans,

Line <u>No.</u>		M. S. COOPER U-21534
1		shows that total compensation is about 9% less than the median of the Company's
2		peer group, as discussed in more detail below.
3		
4	Q91.	How was the market median for the positions determined?
5	A91.	As described above, the Company subscribes to several compensation survey
6		providers that create comprehensive databases of job descriptions that enables the
7		Company to match the job requirements, including education, expertise and
8		experience of existing positions with market surveys. After matching job positions
9		are identified, actual base and total compensation ranges are developed from the
10		salary survey database. The information on Exhibit A-21, Schedule K1 was
11		derived from the Company's compilation of the compensation for positions with
12		an incumbent as of December 31, 2022.
13		
14	Q92.	What proportion of DTE Electric's total employee population as of December
15		31, 2022, is reflected in this analysis?
16	A92.	As of December 31, 2022, practically all (99.5%) of the employee population at
17		DTE Electric, as well as DTE LLC employees that provide supporting services to
18		DTE Electric. This is exclusive of those employees represented by collective
19		bargaining agreements.
20	NCE	
21	INCE	NIIVE COMPENSATION
22	002	
23	Q93.	what are you proposing regarding the level of incentive compensation expense
24		to be included in the Company's revenue requirement?
25	A93.	I am proposing that the projected incentive compensation expense of \$59.504
26		million related to the Company's short-term and long-term incentive compensation

Line

1 plans be included in the revenue requirement adopted by the Commission in this 2 proceeding, as described in more detail below. The components of the projected 3 \$59.504 million of incentive compensation expense are detailed in Table 3 reflected 4 in response to Q120.

5

No.

6 Q94. Is the Company requesting recovery in rates for all incentive compensation 7 expenses?

8 A94. No. While the Company's compensation expenses are reasonable, \$10.157 million 9 of incentive compensation expense related to DTE Energy's Top Five Executive 10 Officers has been excluded. This exclusion is reflected on Exhibit A-3, Schedule 11 C19 as supported by Witness Uzenski and has been excluded from Table 3 reflected 12 in the response to Q120.

13

14 **Q95.** What is the basis for your proposed inclusion of \$59.504 million of incentive 15 compensation expense in the Company's revenue requirement?

16 A95. In summary, my proposal to include all the Company's projected incentive 17 compensation expense, exclusive of the portion related to the Top Five Executive 18 Officers, is based on the prevalence of incentive compensation programs and the 19 resultant need for the Company to have total compensation programs that enable 20 it to be competitive with other employers. As described above, the Company's 21 existing total cash compensation is in line with the market, as is the total 22 compensation for its executives. Moreover, in the absence of the incentive 23 compensation programs, total cash compensation for the Company's employees 24 would be unreasonable as it would total 10.7% less than the market medians, as 25 reflected on Exhibit A-21, Schedule K1, and total compensation for its executives

1		would be 70% less than market, as reflected in Table 2 below in Q100. The
2		remainder of my testimony will demonstrate that the Company's incentive
3		compensation programs are both reasonable and prudent and, therefore, a
4		necessary cost of the Company doing business that should be reflected in the
5		Company's revenue requirements.
6		
7	Q96.	Are there any employee motivational advantages to including an incentive-
8		based compensation component in a company's overall compensation design?
9	A96.	Yes. The underlying principle of incentive compensation plans is to motivate
10		improved organizational performance. An effective incentive compensation plan
11		provides a "pay-for-performance" environment intended to motivate individual
12		and team achievement of measurable goals.
13		
13 14	Q97.	Is there any evidence that incentive-based compensation is effective in
13 14 15	Q97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance?
 13 14 15 16 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on
 13 14 15 16 17 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible
 13 14 15 16 17 18 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in
 13 14 15 16 17 18 19 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance:
 13 14 15 16 17 18 19 20 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance: Research & Best Practices, The International Society for Performance
 13 14 15 16 17 18 19 20 21 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance: Research & Best Practices, The International Society for Performance Improvement, Spring, 2002). This study observes that the source for such
 13 14 15 16 17 18 19 20 21 22 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance: Research & Best Practices, The International Society for Performance Improvement, Spring, 2002). This study observes that the source for such organizational performance improvements is that employees 1) value their work
 13 14 15 16 17 18 19 20 21 22 23 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance: Research & Best Practices, The International Society for Performance Improvement, Spring, 2002). This study observes that the source for such organizational performance improvements is that employees 1) value their work tasks more, 2) have more self-confidence and esteem for their employers, 3) are
 13 14 15 16 17 18 19 20 21 22 23 24 	Q97. A97.	Is there any evidence that incentive-based compensation is effective in motivating improved organizational performance? Yes. A comprehensive analysis of the impact of incentive compensation plans on organizational performance concluded that programs that provide tangible incentives for achievement of certain goals lead to a 27% increase in organizational performance (Incentives, Motivation and Workplace Performance: Research & Best Practices, The International Society for Performance Improvement, Spring, 2002). This study observes that the source for such organizational performance improvements is that employees 1) value their work tasks more, 2) have more self-confidence and esteem for their employers, 3) are more persistent at work tasks, and 4) strive for high levels of accomplishments.

performance improvements. In addition, an Aon study of Variable Compensation
 Measurement Survey issued in 2018 reported that 86% of participants in the
 survey indicated that their variable compensation plans resulted in improved
 business results.

6 Q98. Are incentive compensation programs a typical element in compensation at 7 other companies?

A98. Yes. According to a 2021 study issued by WorldatWork and Compensation
Advisory Partners, most companies had short-term and long-term incentive
programs. This indicates that incentive compensation programs are a prevalent
practice among most companies. (Incentive Pay Practices, Publicly Traded
Companies, WorldatWork and Compensation Advisory Partners). Moreover, a
2018 study by Aon of U.S. Salary Increases shows that 90% of Power and Gas
Service providers utilized broad-based incentive compensation programs.

15

Q99. Do the Company's incentive compensation plans result in unreasonable compensation?

18 A99. No. As explained above, the Company benchmarks its total compensation for non-19 represented employees against relevant peers, inclusive of incentive compensation, 20 and establishes a mid-point salary range based on the median market level. 21 Moreover, based on a recent survey by Aon, the total compensation of DTE 22 Energy's Executives is about 9% less than the median of its peers based on Target 23 level performance, inclusive of the long-term incentive compensation. The 24 Company's incentive compensation programs are merely a component of the total 25 compensation policies required for the Company to be competitive with its peers,

1	rather than a supplement. Indeed, in the absence of the incentive compensation
2	programs, total compensation for the Company's non-represented population
3	would be more than 10% below market, as reflected on Exhibit A-21, Schedule K1.
4	Additionally, as indicated in Table 2 in the response to Q100 below, DTE Energy's
5	Executives would be substantially less than its peers, since about 70% of total
6	compensation is delivered through short and long-term incentive compensation
7	programs, by both DTE and its peers.
8	
9	Q100. How do the components of the Company's total Executive compensation
10	practices compare to the Company's peers?
11	A100. Based on the Aon survey referenced above, a comparison of the relative magnitude
12	of the Company's salary, short-term and long-term pay components for Executives
13	to the 50th percentile of its peers is reflected in Table 2.



1





2

Q101. What are the specific components of the Company's incentive compensation programs?

A101. The Company has in place incentive compensation plans for both its Executive
and all other non-represented employees. Short-term incentive plans are provided
through the Annual Incentive Plan (AIP) and Rewarding Employees Plan (REP).
Additionally, a multiple year incentive plan, which is available to all managers and
above and up to 10% of other eligible non-represented employees, is delivered
through Performance Shares granted pursuant to the Long-Term Incentive Plan
(LTIP).

12

13 Q102. What is the AIP?

A102. The AIP is a short-term variable pay program available to senior management
 level employees to motivate performance. The 2023 AIP measures and relative

Line
<u>No.</u>

1	weights for DTE Electric (other than Nuclear Generation), Nuclear Generation
2	and DTE Energy Corporate Services LLC are reflected on Exhibit A-21
3	Schedules K2, K3 and K4, respectively. For each measure, a Target is established
4	for which a 100% payout will be earned. Performance less than Target, but above
5	a minimum Threshold, results in a payout between 25% of Target and 100%,
6	payout of 100% of Target when performance is at Target, and performance
7	between Target and the Maximum level results in a payout of up to 175% of Targe
8	for non-executive participants of the AIP and up to 200% of Target for Executive
9	participants of the AIP.
10	
11	Q103. Which employee classifications are eligible to participate in the AIP?
12	A103. All Executive level employees, generally those with titles of Vice President and
13	above, and Directors participate in the AIP. All other non-represented employee
14	are eligible to participate in the REP.
15	
16	Q104. What are the components of the REP?
17	A104. The REP is identical to the AIP except that Threshold performance is at 50% o
18	Target and the Maximum performance payout is 150% of Target. The 2023 REI
19	measures and weightings are reflected on Exhibit A-21, Schedules K2 through K4
20	The REP measures are identical to the AIP measures other than the REP exclude
21	the Gallup survey of employee engagement measure in recognition that the
22	Company's leadership is responsible for providing an environment of high
23	employee engagement.
24	
25	Q105. What are the categories of measures included in the AIP and REP?

	U-21534
A105. T	There are four categories of measures in both the AIP and REP. Specifically,
F	inancial Performance, Customer Satisfaction, Safety and Engagement, and
C	Operating Excellence.
Q106. W	hat are the financial measures included in the AIP?
A106. T	There are three financial measures for DTE Electric employees that are designed
to	o create a clear line of sight for all employees to focus on operating excellence by
r	ewarding employees when the Company is successful.
1)	DTE Electric Operating Earnings objective is based on the Company
	realizing the Commission authorized return on equity.
2)	DTE Electric's Cash from Operations is similarly based on the authorized
	return on equity but is adjusted for non-cash items. The inclusion of a cash
	flow measure recognizes the importance of DTE Electric maintaining a high
	credit rating to allow continued access to the capital markets at reasonable
	costs and terms to ensure sufficient capital investment to continue to serve
	our customers.
3)	DTE Energy's Earnings per Share measure is based on the midpoint of 2023
	earnings guidance.
N	uclear Generation Financial Performance measures consist of DTE Electric
Oj	perating Earnings and Nuclear Generation Operation and Maintenance Expense.
Tł	ne Financial Performance measures for DTE LLC reflect DTE Energy's
O	perating Earnings per Share and Cash from Operations.

M. S. COOPER

24 Q107. What are the Customer Satisfaction measures?

Line

<u>No.</u>

1	A107. There are two customer satisfaction measures that are intended to focus employees
2	on improving the experience that our customers have in their interactions with the
3	Company. The measures are:
4	1) The Net Promoter Score is a measure of the extent to which customers are likely
5	to recommend the Company to their friends and colleagues. The Target in 2023
6	is 39, which is the same as the actual NPS in 2022. However, macroeconomic
7	factors in 2022 and 2023, including 40-year high inflation and historically low
8	consumer confidence, as noted by the University of Michigan Consumer
9	Confidence Surveys results, among other factors, have resulted in reduced NPS
10	scores nationwide by virtually all industries. Therefore, considering these
11	conditions, maintaining a NPS score of 39 in 2023 is estimated to represent an
12	effective 4 point increase.
13	
14	2) The MPSC Customer Complaints measure represents the number of formal
15	complaints made to the MPSC regarding both DTE Gas and DTE Electric as
16	reported to the Company by the MPSC. The MPSC Customer Complaints
17	Target for 2023 is 1,912.
18	
19	Q108. What are the measures related to Safety and Engagement?
20	A108. There are three measures related to safety and engagement. One measure pertains
21	to employee engagement as measured by the Gallup survey, as well as two
22	employee safety related measures, as described below.
23	
24	Q109. What is the measure related to Employee Engagement?

1	A109.	The Gallup measure of Employee Engagement is reflective of the direct correlation
2		between the level of active employee engagement and the performance of an
3		organization. The 2023 Target of 4.26 is based on a grand mean of the results of
4		the Gallup surveys of employees and represents top decile performance relative to
5		Gallup's overall database. Employee Engagement is a statistically significant
6		measure of the level of commitment employees have to an organization's success
7		and is not merely a measure of employee satisfaction.
8		
9	Q110.	What are the Safety related measures?
10	A110.	DTE Electric has two safety-related measures.
11		1) The first is the OSHA Recordable Incident Rate (RIR), which measures the
12		recordable injuries per 100 employees divided by the actual number of hours
13		worked, as defined by the Occupational Safety and Health Administration
14		(OSHA). This is a standard measure of safety performance used nationwide.
15		The measure is intended to create a heightened focus on the importance of
16		safety in the workplace. The RIR Target for 2023 is .57, which is near the very
17		top performance in the industry.
18		2) The second is High Energy Serious Injury or Fatality (HSIF), which is a
19		measure adopted by the Edison Electric Institute that recognizes the degree of
20		seriousness of an injury in the context of a dangerous event. The 2023 Target
21		of zero is based on an improvement from the five-year average of 4.
22		
23	Q111.	What are the Operating Excellence measures for 2023?
24	A111.	DTE Electric has four Operating Excellence measures that reflect specific operating
25		priorities for 2023 to motivate the achievement of certain operating objectives

Line <u>No.</u>		U-21534
1	impo	rtant to the Company, its customers, and the Commission. Two of these
2	meas	ures relate to Distribution System Reliability and the other two relate to
3	Gene	ration Reliability.
4		
5	The tw	vo Electric Distribution Reliability Measures are:
6	1)	The System Average Interruption Duration Index (SAIDI) exclusive of
7		Major Event Days (MEDs). The 2023 Target is 150 minutes.
8	2)	The percentage of customers that experience four interruptions or more
9		(CEMI4) in a calendar year. The Target in 2023 is 7.55%.
10		
11	The tv	vo Generation Reliability Measures are:
12	1)	The percentage of hours that DTE Electric's coal, gas, and renewable plants
13		are mechanically available to produce power. The 2023 Target is 81.8%.
14	2)	Nuclear On-Line Reliability Loss Factor (ORLF), which is energy
15		generation losses corrected for refueling outage losses and exempt
16		activities. The 2023 ORLF Target is 1.03%.
17		
18	Q112. What	are the operating measures applicable to the Nuclear Generation
19	busine	ess unit?
20	A112. Nucle	ear Generation has four Safety and Engagement related measures and four
21	Opera	ating Excellence measures, discussed below in further detail.
22		
23	Q113. What	are Nuclear Generation's Safety and Engagement related measures?

1	A113. In ad	dition to Employee Engagement, as measured by Gallup surveys, and the
2	OSH	A Recordable Incident Rate, as described above, Nuclear Generation also has
3	two a	dditional safety measures.
4	1)	The first is the annual Total Industrial Safety Accident Events (TISA
5		Events), which is a nuclear industry measure that is aligned with the
6		Institute of Nuclear Power Operations (INPO). The Target is zero incidents
7		in any calendar year quarter.
8	2)	The second relates to On-Line Radiation Exposure, which is designed to
9		maintain a focus on the safety of personnel. The 2023 Target is 50.6 Rem,
10		which is a standard unit of measure of exposure to radiation.
11		
12	Q114. What	are the Operating Excellence measures related to Nuclear Generation?
13	A114. Nucle	ar Generation has four Operating Excellence measures.
14	1)	The first relates to On-Line Reliability Loss Factor, as described above.
15	2)	The second measure regarding Operational focus pertains to a group of 11
16		measures that relate to Fermi 2 plant performance. The 2023 Target is 93.4.
17	3)	The third measure is an index of Annualized Work Management, which
18		consists of 10 individual indicators. The 2023 Target is 99.8.
19	4)	The final Nuclear Generation measure relates to the Nuclear Refuel Outage
20		Milestone, which is a measure of the effective planning and preparation for
21		refueling planned in 2024. The Target for 2023 is that 30 milestones are
22		achieved at 98% performance and four are achieved with performance
23		between 96% and 98%.
24		
25	Q115. Are th	nere other AIPs and REPs that impact DTE Electric's expenses?

Line
<u>No.</u>

1	A115.	Yes. In addition to the DTE Electric and Nuclear Generation measures described
2		above, there are also AIPs and REPs in place for corporate staff employees at DTE
3		LLC that provide services to all DTE Energy business units, including DTE
4		Electric. The DTE LLC measures reflect certain DTE Electric and Nuclear
5		Generation measures, as well as measures related to DTE Gas. The specific DTE
6		LLC measures and weightings related to DTE Electric and Nuclear Generation are
7		reflected on Exhibit A-21, Schedule K-4.
8		
9	Q116.	What is the Company's Long-Term Incentive Plan?
10	A116.	The LTIP provides the opportunity for certain individuals to receive retention-
11		oriented or performance-based rewards delivered via shares of DTE Energy
12		common stock, either Performance Shares, which are based on the achievement of
13		multi-year performance objectives, or through Restricted Stock. Currently, 70%
14		of the value of awards for executives and directors is through grants of
15		Performance Shares and 30% of the value of awards is through Restricted Stock,
16		while 100% of the awards to other eligible employees are through Performance
17		Shares. The objective in granting shares through this program is to both motivate
18		superior results as well as provide a means to retain key employees and is
19		consistent with the practices of most companies, as reflected in the WorldatWork
20		and Compensation Advisory Partners survey, referenced in Q98 above.
21		
22	Q117.	What are the performance share measures used in the 2023 LTIP?
23	A117.	The measures are shown on Exhibit A-21, Schedule K5.
24		
25	Q118.	What is the rationale for the use of these measures?

1 A118. These measures generally reflect the long-term financial performance of DTE 2 Energy and are intended to motivate employees of the individual operating 3 companies, such as DTE Electric, to keep in mind the role of their own 4 contributions to the overall long-term success of DTE. Accordingly, the 5 predominate measure for DTE Electric and DTE LLC (80% for both) is the total 6 return to DTE Energy shareholders (i.e., capital appreciation and dividends) 7 relative to a group of peer companies over the next three years. The second 8 financial measure included in the LTIP, which contributes 20% to the total 9 weighting, is DTE Energy's three-year cumulative Operating Earnings per Share. The three-year focus of the performance-based measures is designed to motivate 10 11 decisions and actions that produce sustainable benefits rather than short-term 12 actions that may entail long-term risks.

13

14 **Q119.** What is the basis for the costs of the LTIP?

15 The LTIP costs incurred in 2022 pertain to the grants of Performance Shares and A119. 16 Restricted Stock. The expense related to the Restricted Stock is not conditioned 17 on any Company performance measures but rather is exclusively based on the 18 number of shares granted at the date of grant. In contrast, Performance Shares 19 expense is based on the achievement of the predetermined performance objectives. 20 The recognized cost of Performance Shares is based on the number of shares 21 granted at the market price of DTE Energy's common stock at the date of grant 22 but with adjustment in the number of shares based on actual performance. The 23 Performance Shares expense included in Table 3 is based on Target performance.

24

Line <u>No.</u>

Q120. What is the incentive compensation expense if the Company achieves all of its Financial and Operating Targets?

A120. The net expense to DTE Electric in the projected test period of the Company
achieving all its Targets for the incentive compensation plans, exclusive of the
expense related to the Top Five Executive Officers, is \$59.504 million. The table
below summarizes the expense for the projected test period by the nature of the
plans, the classification of the employees eligible and the basis of the metrics used.

Table 3

- 8
- 9

	LTIP	AIP	<u>REP</u>	<u>Total</u>
		(000's C	Omitted)	
Financial				
DTE Electric	\$5,858	\$615	\$7,029	\$13,502
Nuclear Gen	1,395	92	839	2,326
DTE LLC	13,154	3,509	6,741	23,404
	20,408	4,215	14,609	39,232
Operating				
DTE Electric	0	504	5,758	6,262
Nuclear Gen	0	200	2,527	2,727
DTE LLC	0	3,862	7,420	11,281
	0	4,566	15,705	20,271
Total				
DTE Electric	5,858	1,119	12,787	19,764
Nuclear Gen	1,395	292	3,367	5,054
DTE LLC	13,154	7,370	14,161	34,686
	\$20,408	\$8,781	\$30,315	\$59,504

10

11 Q121. Why are the expenses for DTE LLC most of the incentive compensation

12 expenses?

A121. DTE LLC provides a variety of administrative and other services that are common
 to both DTE Electric and DTE Gas for which the costs are billed to the operating

		M. S. COOPER
Line <u>No.</u>		U-21534
1		companies, as explained by Witness Uzenski. In addition, DTE LLC employs all
2		the Executives of DTE Energy, including the Officers of DTE Electric.
3		
4	Q122.	How have you reflected the Operating Excellence measures related to DTE
5		Gas in the AIP and REP for DTE LLC?
6	A122.	While the AIP and REP expenses allocated to DTE Electric in the historic period
7		from DTE LLC include some measures related to DTE Gas, the AIP and REP
8		weightings for DTE LLC have been adjusted to exclude the measures specifically
9		related to DTE Gas.
10		
11	Q123.	Are all incentive compensation costs dependent on the Company's financial or
12		operating performance?
13	A123.	No. As described earlier, a portion of the DTE Energy shares granted under the
14		LTIP are in the form of Restricted Stock. Unlike the Performance Shares, the
15		expense of Restricted Stock is not variable based on either the Company's
16		financial or operating performance. The only contingency is that the employee
17		forfeits the Restricted Stock if they leave the Company, other than through
18		retirement or the event of the employee's death or disability.
19		
20	Q124.	How does the lack of variability in the LTIP expense affect its treatment in
21		your analysis of incentive compensation?
22	A124.	Although Restricted Stock grants are made under the LTIP, the ultimate payouts
23		are not dependent on future Company or employee performance, and therefore,
24		Restricted Stock is not regarded as an element of the Company's incentive

Line		M. S. COOPER U-21534
<u>No.</u>		
1		compensation expense. Accordingly, the projected test year Restricted Stock
2		expense of \$8.960 million has been excluded from Table 3 above.
3		
4	Q125.	Has the Commission provided any criteria for the inclusion of incentive
5		compensation expense in the Company's revenue requirements?
6	A125.	Yes. The Commission has indicated in all its recent Orders addressing incentive
7		compensation programs that inclusion of incentive compensation expense in a
8		company's revenue requirement was dependent on a showing that the incentive
9		compensation programs provided benefits to customers in excess of the expense.
10		
11	Q126.	Has the Company performed an analysis of the customer benefits of the
12		Company's incentive compensation plans?
13	A126.	Yes. The Company has performed a comprehensive analysis of the customer
14		benefits that would be derived from the achievement of the financial and operating
15		metrics included in the Company's short and long-term incentive plans relative to
16		their expense. This analysis, as reflected on Exhibit A-21, Schedule K6,
17		demonstrates that the calculated aggregate benefit of \$104.478 million exceeds the
18		total incentive compensation expense of \$59.504 million by \$44.974 million.
19		
20	Q127.	How did you calculate the benefits of the Financial measures?
21	A127.	While the Company has not quantified the benefits to customers of each of the
22		financial measures, one measure that had specifically quantifiable benefits is the
23		Cash Flow from Operations measure within the AIP and REP, as reflected on line
24		8 of Exhibit A-21, Schedule K6. This measure is focused on the Company
25		maintaining its "A" debt rating from Standard & Poor's and comparable ratings by

1		the other major debt rating firms. The yield spread between utility bonds for bonds
2		with an "A" rating compared to "BBB" rated bonds is 23 basis points. Based on
3		the long-term debt balances included in the capital structure sponsored by Company
4		Witness Vangilder, a downgrade in the Company's credit rating would increase the
5		Company's annual interest costs by \$19.9 million.
6		
7	Q128.	How are the benefits of the Company achieving Target performance for the
8		Operating measures reflected on Exhibit A-21, Schedule K6 determined?
9	A128.	The benefits of the Operating measures are computed based either on the avoided
10		costs to the Company, which results in lower future revenue requirements, or
11		based on the value to customers of improved performance. The reference points
12		to determine improvement are, in most instances, based on the Company's actual
13		performance in the 2022 historical test year, but when 2022 results are not
14		representative, either an historical average or a comparison to external peer groups
15		is used. In those instances, in which the Company's Targets are based on superior
16		performance relative to peers, then measures of peer performance are used. The
17		benefits of achieving Target performance are allocated between the AIP and REP
18		components based on the relative incentive compensation expense for each
19		measure.
20		
21	Q129.	How did you quantify the benefit of achieving Target performance levels in

22

the Customer Satisfaction measures?

A129. The benefits of achieving the 2023 Target of 39 Net Promoter Score (NPS) are
based on the expectation that improvements in the NPS score will result in fewer

Line <u>No.</u>	M. S. COOPER U-21534
1	customer calls. The 2023 Target of 39 is expected to produce \$2.2 million of
2	customer benefits based on avoided Company costs and customer costs.
3	
4	The customer benefits of attaining Target performance for MPSC Customer
5	Complaints measure is based on the avoided costs to both the Company and its
6	customers due to the reduced time spent by employees and customers resolving
7	complaints for a total savings of \$29,000.
8	
9	While the total quantified benefits related to the Customer Satisfaction measures
10	are less than the related expense, there can be little doubt that an emphasis among
11	the Company's employees on improving the experiences customers have with the
12	Company results in additional significant non-quantifiable benefits to both
13	customers and the Commission.
14	
15	Q130. How did you determine the benefits of the Employee Engagement measure?
16	A130. The quantifiable benefits of a highly engaged workforce are based on three critical
17	dimensions identified by Gallup: absenteeism, productivity, and safety incidents.
18	According to Gallup, a 0.1 improvement in the grand mean will result in a 3.1%
19	reduction in absenteeism, a 1.8% increase in productivity, and a 3.8% reduction in
20	safety incidents. Compared to the 80th percentile of Gallup survey results for all
21	companies included in Gallup's database, the achievement of the 2023 Target
22	Gallup Target will generate O&M savings of \$11.9 million, which is attributed
23	exclusively to the AIP because the Employee Engagement measure is not included
24	in the REP.

1 Q131. What are the expected benefits of the Company achieving Target level 2 performance regarding the OSHA Recordable Incident Rate (RIR)? 3 A131. The benefits of achieving the OSHA Recordable Incident Rate (RIR), and the 4 Nuclear Total Industrial Safety Accident Rate goal, are based on the estimated 5 direct costs of non-fatal incidents of \$50,000, as developed by OSHA, as adjusted 6 for inflation through 2022, and a study by Liberty Mutual that estimates the 7 indirect cost of an OSHA recordable incident is about 3.0 times the direct costs, 8 resulting in an estimated total cost of \$201,000 per incident, in current dollars. 9 Based on Target level performance, relative to the Company's five-year average results in an estimated benefit of \$2.6 million net of the savings capitalized. The 10 benefits of achieving the OSHA RIR Target are allocated to all the other safety 11 12 measures in proportion to the costs of each measure, as reflected on lines 29 13 through 35 of Exhibit A-21, Schedule K6. 14 15 While the quantified savings of the safety related metrics are less than the related 16 costs, much like the customer service-related measures, the benefits of maintaining 17 an organizational focus on the safe operation of the Company's system for the 18 benefit of its employees, customers, and the communities where the Company 19 operates are undoubtedly substantial. 20 21 Q132. How did you quantify the savings related to improvements in distribution 22 system reliability? 23 A132. The benefit of achieving the SAIDI excluding MEDs Target is based on comparing 24 the 2023 Target of 150 minutes to the five year average of SAIDI excluding MEDs 25 of 161 minutes, which represents a reduction of 11 minutes. The derivation of the

1	benefits to customers is based on the Interruptions Cost Estimation Calculator as
2	developed by Nexant, Inc. and the Lawrence Berkeley National Lab. A reduction
3	of eleven minutes in the SAIDI excluding MEDs produces an annual customer
4	benefit of \$43.1 million. The benefits of achieving Target performance in the
5	SAIDI excluding MEDs measure have been allocated equally between the SAIDI
6	exclusive of MEDs measures and CEMI4 Percent of Customers measure due to
7	the close relationship of each of these measures to distribution system reliability,
8	as reflected on lines 40 and 42 of Exhibit A-21, Schedule K6.
9	
10	Q133. Have you quantified the benefits of the Generation Availability measure?
11	A133. The 2023 Generation Availability Target of 81.8% reflects a modest increase from
12	the four-year average of actual Generation availability of 81.7%. Accordingly, I
13	have not quantified the customer benefits of the increase in Generation Availability.
14	
15	Q134. What are the benefits of an increase in the Nuclear On-Line Reliability Loss
16	Factor?
17	A134. The benefits of an increase in the Nuclear Power Plant Reliability reflect an increase
18	from the On-Line Reliability Loss Factor at Fermi 2 from the five-year average of
19	4.39% to the 2023 Target of 1.03%. The savings computed are based on the
20	differential between Fermi 2's marginal fuel costs and the average market price of
21	avoided energy purchases combined with value of increased capacity for a total
22	annual savings of \$24.7 million. These savings are allocated to the Nuclear related
23	operating measures included in the AIP and REP in proportion to the costs of each
24	measure. Specifically, \$19.0 million is assigned to Nuclear On-Line Reliability

Line <u>No.</u>	M. S. COOPER U-21534
1	Loss Factor measure and \$1.9 million is assigned to each of the three other Nuclear
2	related measures, as reflected on lines 46 through 52 of Exhibit A-21, Schedule K6.
3	
4	Q135. Have you quantified any additional savings related to the other Nuclear
5	Generation measures included in the AIP and REP?
6	A135. No. The Nuclear On-Line Reliability Loss Factor measure represents the only
7	quantifiable benefits of the Company meeting its Target performance levels for
8	Fermi 2. While there is indisputable value in the various specific measures within
9	the other Nuclear measures, the benefits of Fermi 2 achieving its On-Line
10	Reliability Loss Factor Target has been attributed to the other AIP and REP
11	Nuclear Operating Excellence measures.
12	
13	Q136. What is your conclusion regarding the cost effectiveness of the Company's
14	incentive compensation plans?
15	A136. As reflected on Exhibit A-21, Schedule K6, it is clear the quantified customer
16	benefits of the Company achieving Target performance levels are substantially
17	greater than the related expense.
18	
19	Because the Company's overall employee compensation approximates the market,
20	inclusive of incentive compensation and the quantified benefits exceed the
21	projected incentive compensation expense, the Company's total incentive
22	compensation expense should be included in the revenue requirement adopted by
23	the Commission in this proceeding as a reasonable and prudently incurred expense.

1 Q137. Does this complete your direct testimony?

2 A137. Yes, it does.
STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

JEFFREY C. DAVIS

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF JEFFREY C. DAVIS

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Jeffrey C. Davis (he/him/his). My business address is: 6400 North Dixie
3		Highway, Newport, Michigan, 48166. I am employed by DTE Electric Company at
4		the Fermi 2 Nuclear Power Plant as Expert - Nuclear Strategic Business Operations.
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric Company (Company or DTE Electric).
8		
9	Q3.	What is your educational background?
10	A3.	I graduated from the University of Michigan with bachelor's degrees in nuclear
11		engineering and radiological sciences (NERS) and engineering physics. I have also
12		earned a master's degree and doctorate in NERS from the University of Michigan.
13		
14	Q4.	Please summarize your professional experience.
15	A4.	I have been employed by DTE Energy since 2008. Prior to my current position, I
16		was Manager - Nuclear Strategy and Business Support with responsibility for
17		developing the strategic financial plan and goals for the Nuclear Generation
18		organization. From 2008-2015, I was a principal financial analyst with
19		responsibility for budgeting, forecasting, and reporting operations and maintenance
20		(O&M) and capital expenditures for the Nuclear Generation organization.
21		
22	Q5.	Do you hold any certifications or are you a member of any professional
23		organizations?
24	A5.	I am a member of the American Nuclear Society.
25		

			J. C. DAVIS
Line <u>No.</u>			U-21534
1	Q6.	What are y	our current duties and responsibilities?
2	A6.	I am respons	bible for advancing the strategic financial and operational plan and goals
3		for the Nucl	ear Generation organization.
4			
5	Q7.	Have you p	reviously sponsored testimony before the Michigan Public Service
6		Commission	n (MPSC or Commission)?
7	A7.	Yes. I have	sponsored testimony in the following cases:
8		U-20203	2018 Power Supply Cost Recovery (PSCR) Reconciliation
9		U-20528	2020 PSCR Reconciliation
10		U-20162	2018 DTE Electric Rate Case
11		U-20561	2019 DTE Electric Rate Case
12		U-20836	2022 DTE Electric Rate Case
13		U-21297	2023 DTE Electric Rate Case

1 **Purpose of Testimony**

2	Q8.	What is the	e purpose of you	ur testimony?
3	A8.	The purpose	e of my testimo	ny is to discuss and support the reasonableness of the
4		Company's	actual nuclear	· O&M and capital expenditures for the 12-month
5		historical te	st period ended	December 31, 2022. I will also discuss and support the
6		reasonablen	ess of the proj	ected nuclear O&M and capital expenditures for the
7		bridge forec	ast period and t	he 12-month projected test period ending December 31,
8		2025. In ad	dition, I will di	scuss and support the reasonableness of the projected
9		Nuclear Sur	charge for the p	rojected test period ending December 31, 2025.
10				
11	Q9.	Are you sp	onsoring any ex	whibits in this proceeding?
12	A9.	Yes. I am sp	oonsoring the fo	llowing exhibits:
13		<u>Exhibit</u>	<u>Schedule</u>	Description
14		A-12	B5.3	Projected Capital Expenditures - Nuclear Production
15				Plant and Nuclear Fuel
16		A-13	C5.3	Projected Operation and Maintenance Expenses -
17				Nuclear Power Generation
18		A-13	C5.16	Nuclear Power Generation - Projected PERC O&M
19				Expenditures
20		A-20	J1	Proposed Nuclear Surcharge Projected Test Period –
21				12 Months Ending December 31, 2025
22		A-20	J2	Nuclear Plant Capital Project Detail –
23				Routine and Small Projects
24				

25 Q10. Were these exhibits prepared by you or under your direction?

Line
No.

1 A10. Yes, they we	ere.
---------------------	------

2

3 Q11. How do you plan to proceed with your testimony?

4 A11. I will begin my testimony with the Nuclear Generation capital expenditures; 5 discussing and supporting the actual capital expenditures for the historical test year 6 ended December 31, 2022, the projected capital expenditures for the bridge forecast 7 period and the 12-month projected test period ending December 31, 2025. I have 8 divided my Nuclear Generation capital expenditure discussion into five sections of 9 expenditures: Routine and Small Projects, Non-Routine and Large Projects, Nuclear 10 Fuel, Allowance for Funds Used During Construction (AFUDC), and Plant Activity 11 (removal costs, plant in service and CWIP).

12

I will then discuss and support the actual O&M expenses for the historical test year ended December 31, 2022 and the forecasted O&M expenses for the 12-month projected test period ending December 31, 2025 for Nuclear Generation. I have divided the Nuclear Generation O&M expenses discussion into three sections: rate case adjustments, adjusted historical test period and projected adjustments.

18

I will then discuss and support the Nuclear Surcharge for the 12-month projected
test period ending December 31, 2025 for Nuclear Generation.

21

The Fermi 2 Power Plant is licensed by the Nuclear Regulatory Commission (NRC) to operate through 2045. The capital and O&M expenditures discussed for the historical and projected test periods throughout my testimony reflect appropriate

Line <u>No.</u>		J. C. DAVIS U-21534
1		measures to ensure safe and reliable operation of the Fermi 2 Power Plant through
2		2045.
3		
4	Nucle	ear Generation Capital Expenditures
5	Q12.	Can you provide an outline of your Nuclear Generation capital expenditures
6		discussion?
7	A12.	My testimony will begin with the 2022 – 2025 Capital Projects Overview and then
8		discuss and support the additional details regarding:
9		Routine and Small Projects
10		Non-Routine and Large Projects
11		Total Nuclear Fuel
12		AFUDC Forecast
13		• Plant Activity (Removal Costs, Plant in Service and CWIP)
14		
15	<u>2022</u>	- 2025 Capital Projects Overview
16	Q13.	Can you provide an overview of the Nuclear Generation capital expenditures
17		you support?
18	A13.	I refer you to Exhibit A-12, Schedule B5.3, page 1 which depicts the actual capital
19		expenditures for the historical test year ended December 31, 2022, projected capital
20		expenditures for the bridge forecast period and projected capital expenditures for
21		the 12-month projected test period ending December 31, 2025.
22		
23		Total capital expenditures are composed of Routine and Small Projects, Non-
24		Routine and Large Projects, and Total Nuclear Fuel. Nuclear Generation actual
25		capital expenditures for historical test year ended December 31, 2022, totaled

1		\$257.8 million as shown on line 11, column (b) of the exhibit. Nuclear Generation
2		forecasts total capital expenditures for the projected bridge forecast period at \$451.5
3		million as shown on line 11, column (e) and for the 12-month projected test period
4		ending December 31, 2025 at \$215.9 million as shown on line 11, column (f).
5		
6		I describe and support a portfolio of discrete reasonable and prudent projects and
7		capital fuel expenditures which provides the basis for the historical actual and
8		forecasted Total Capital Expenditures for January 1, 2022 through December 31,
9		2025.
10		
11	Q14.	How do the historical actuals for the 12-month period ending December 31,
12		2022, compare to the Nuclear Generation capital (including nuclear fuel)
13		expenditures authorized for the same period in the U-21297 rate case?
13 14	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7
13 14 15	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear
13 14 15 16	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total
13 14 15 16 17	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital
13 14 15 16 17 18	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period.
 13 14 15 16 17 18 19 	A14.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period.
 13 14 15 16 17 18 19 20 	A14. Q15.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period. What was the Commission treatment of DTE Electric Nuclear Generation
 13 14 15 16 17 18 19 20 21 	A14. Q15.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period. What was the Commission treatment of DTE Electric Nuclear Generation capital expenditures in U-21297 Order, dated December 1, 2023?
 13 14 15 16 17 18 19 20 21 22 	A14. Q15. A15.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period. What was the Commission treatment of DTE Electric Nuclear Generation capital expenditures in U-21297 Order, dated December 1, 2023? DTE Electric's Nuclear Generation capital expenditures depicted in U-21297 were
 13 14 15 16 17 18 19 20 21 22 23 	A14. Q15. A15.	expenditures authorized for the same period in the U-21297 rate case? The U-21297 Order authorized Nuclear Generation capital expenditures at \$258.7 million for the 12-month period ending December 31, 2022. The actual Nuclear Generation capital expenditures for the same period were \$257.8 million. The total variance is approximately 0.3% of projected total Nuclear Generation capital expenditures for the reference period. What was the Commission treatment of DTE Electric Nuclear Generation capital expenditures in U-21297 Order, dated December 1, 2023? DTE Electric's Nuclear Generation capital expenditures depicted in U-21297 were generally accepted and allowed for recovery.

1		However, the Commission also appropriately approved an accounting shift
2		associated with Main Unit Generator Replacement project expenditures (depicted
3		on line 2 of Exhibit A-12, Schedule B5.3, page 4) from rate base to construction
4		work in progress (CWIP) because of the revised timing of the main unit generator
5		installation. Final installation of the main unit generator has been moved from
6		Refueling Outage 22 (RF22) (Spring 2024) to RF23 (Spring 2026).
7		
8	Q16.	Is it fair to conclude the Commission has already had the opportunity to review
9		DTE Electric's Nuclear Generation historical actuals for the 12-month period
10		ending December 31, 2022 in U-21297?
11	A16.	Yes. When DTE Electric filed Case No. U-21297 in 2023, the projected 12-month
12		period ending December 31, 2022, had included ten months of actuals and only two
13		months of forecast. Most notably, as RF21 completed in May 2022, RF21 projects
14		expenditures were complete, known and actuals already included in the expenditures
15		depicted in U-21297 Exhibit A-12, Schedule B5.3; therefore, I will focus on
16		highlighting projects that are more significant in the bridge and projected test years.
17		
18	Q17.	Before you discuss the discrete projects, can you summarize the principles and
19		conduct of asset maintenance at a nuclear generation unit such as Fermi 2?
20	A17.	Nuclear safety is our overriding priority at Fermi 2 and, indeed, throughout the
21		nuclear industry. Our operational and strategic decisions preserve this priority.
22		
23	Q18.	What do you mean by nuclear safety?

1 A18. Nuclear safety is focused on ensuring that we maintain and operate the Fermi 2 2 nuclear asset with a high degree of rigor. Conservatism is necessary to minimize 3 risk and ensure the safe and reliable use of nuclear material. 4 5 Q19. How does DTE Electric manage nuclear safety risk? 6 A19. DTE Electric manages nuclear safety risk through proper training, procedures and 7 governance, operating the plant consistent with Fermi 2's Nuclear Regulatory 8 Commission (NRC) operating license, operating the plant using the traits of a 9 healthy nuclear safety culture (outlined in the World Association of Nuclear 10 Operators (WANO) Principles PL 2013-1), and maintenance of the asset to support 11 operation through 2045. 12 13 Q20. What are the key principles the DTE Electric organization uses for maintaining 14 the nuclear asset? 15 A20. I would summarize our key maintenance principles as: 16 1. Implementation of inspection, surveillance, maintenance and project activities 17 are proactive and condition- or time-based to preclude a failure. Unanticipated 18 equipment failures challenge plant operators and result in unplanned shutdowns 19 or derates of the unit; our strategies are designed to minimize the probabilities 20 of unanticipated equipment failures. 21 2. Work such as capital replacements and modifications are implemented when the 22 plant is in the safest condition to do so. For most of our work at Nuclear 23 Generation, that safest condition is when the Fermi 2 plant is shut down for a 24 refueling outage.

Line <u>No.</u>		J. C. DAVIS U-21534
1		3. Work such as capital replacements and modifications are planned and executed
2		in a reasonable and prudent manner consistent with the other key maintenance
3		and project management principles.
4		
5	Q21.	Why is it safest to perform maintenance on the Fermi 2 plant during a refueling
6		outage?
7	A21.	Refueling outages are the safest time to perform maintenance for the following
8		reasons:
9		1. Nuclear safety - our operating license issued by the NRC requires the plant to be
10		shut down prior to taking many systems out of service for maintenance. These
11		licensing requirements align with minimizing risks to health and safety.
12		2. Personnel safety - many areas of the plant are behind locked doors during
13		operations due to the radiological or atmospheric conditions of the area.
14		Refueling outages offer opportunities to access these otherwise inhospitable
15		areas of the plant for maintenance.
16		
17	Q22.	What is the cadence for the Fermi 2 plant refueling outages?
18	A22.	The Fermi 2 plant operates on a 24-month cycle, meaning every 24 months the
19		Fermi 2 plant shuts down for a refueling outage. The Fermi 2 refueling outages are
20		numbered sequentially and named as such: our winter/spring 2022 refueling outage,
21		which was Fermi 2's twenty-first refueling outage, was named Refueling Outage 21
22		or RF21 and Fermi 2's twenty-second refueling outage scheduled in the spring of
23		2024 (approximately 24 months after RF21) is named Refueling Outage 22 or RF22.
24		
25	Q23.	What is the typical planning cadence for a Fermi 2 plant refueling outage?

Line <u>No.</u>		J. C. DAVIS U-21534
1	A23.	Refueling outages are highly complex and require an integrated work plan to execute
2		thousands of activities in a relatively short duration.
3		
4		Planning for a refueling outage is generally a two-year effort with many intermediate
5		milestones guiding the planning effort; completion of these milestones requires
6		consideration of the existing and projected material condition of the Fermi 2 Power
7		Plant as well as any practical constraints for safe execution of the projected work.
8		The two most relevant of these milestones for capital expenditures are (1) two years
9		prior to the refueling outage (T-24 months), Nuclear Generation confirms the Non-
10		Routine and Large Projects for implementation in the outage and (2) at one year
11		prior to the refueling outage (T-12 months), Nuclear Generation confirms for the
12		Routine and Small Projects to be completed in the outage.
13		
14	Q24.	How does the highly complex and integrated characteristic of refueling outage
15		work impact project planning and execution?
16	A24.	Projects implemented during refueling outages are not stand-alone, independent
17		projects as one may typically think of projects.
18		
19		For example, plant workers such as plant operators, radiation protection, building
20		trades and supervision are not dedicated to individual projects but must be shared
21		across different projects and maintenance because qualified nuclear professionals
22		are finite, nuclear standards are exacting, and gaining clearance to work at a U.S.
23		nuclear plant is non-trivial; suppliers performing work must be chosen to globally
24		improve outage execution - selecting suppliers as if projects were independent

Line <u>No.</u>		J. C. DAVIS U-21534
1		would lead to more expensive work, unnecessary duplication of oversight and
2		potential conflicts between suppliers.
3		
4		As a second example, projects and maintenance activities may only occur in a
5		specific schedule sequence which means performance of one project may impact
6		performance of another project or projects.
7		
8		As I said, this coordination of work and resources is important to finalizing refueling
9		outage plans and takes place in the cycle leading up to the refueling outage.
10		
11	Q25.	How are suppliers chosen to globally improve work execution?
12	A25.	Suppliers of nuclear equipment, components and services are relatively limited and
13		serve a relatively small group of U.S. nuclear power stations. As of December 31,
14		2023, 93 U.S. commercial nuclear reactors were in commercial operations - and
15		consolidation of suppliers is such that in many instances only one or two suppliers
16		are qualified to provide certain nuclear components, equipment or services to
17		nuclear power plants. Fermi 2 is further unique in that the plant is a General Electric
18		Boiling Water Reactor Type 4 design (GE BWR/IV) with a Mark I containment
19		structure and English Electric turbine/generator system. To be reasonable and
20		prudent, selecting suppliers generally requires DTE Electric to weigh more than just
21		the competitively bid costs: DTE Electric must consider supplier qualifications,
22		safety record, original equipment manufacturer (OEM) status, incumbency, market
23		share, industry operating experience and industry feedback, locality, ownership,
24		union status and integration with the local building trades (if applicable), proposed
25		schedule and costs, terms and conditions, likelihood of outcomes, amongst other

Line <u>No.</u>		J. C. DAVIS U-21534
1		factors. If a new participant enters a market, then supporting overall market
2		competition can become a factor as well.
3		
4		In general, DTE Electric secures long-term supplier agreements for Fermi 2 nuclear
5		fuel, reactor services, turbine services, major maintenance services, heavy
6		construction services, radiation protection services and engineering design services
7		through competitive supplier sourcing and negotiation. Individual projects can then
8		source, as needed, suppliers using these long-term agreements which facilitates each
9		major supplier's resources being integrated into the overall work plan. DTE Electric
10		sources other components, equipment and services in a reasonable and prudent
11		manner consistent with the factors I outlined above.
12		
13	<u>Routi</u>	ine and Small Projects Capital Expenditures
14	Q26.	Can you further explain the Routine and Small Projects summarized on line 2
15		of Exhibit A-12, Schedule B5.3, page 1?
16	A26.	Routine and Small Projects are those capital expenditures associated with
17		maintaining the various assets that support the safe operation of Fermi 2 and
18		includes work such as pump, motor, valve and reactor control component
19		replacements and can typically be expressed in number of units replaced. Routine
20		and Small Projects are reasonable and prudent because these types of projects
21		address commonly activated and used equipment that are the core of our proactive
22		maintenance regime to maintain nuclear safety. Proactive replacement of these
23		Fermi 2 components is essential to prioritizing nuclear safety by minimizing the
24		potential for unanticipated or unrecoverable failures during plant operation.
25		

Line No		J. C. DAVIS U-21534
1		Pages 2-3 of Exhibit A-12, Schedule B5.3 provide a listing of the Routine and Small
2		Projects that support page 1, line 2.
3		
4	Q27.	Can you explain the Routine and Small Projects detailed in Exhibit A-12,
5		Schedule B5.3, pages 2-3?
6	A27.	Exhibit A-12, Schedule B5.3, pages 2-3 show the by-project capital expenditures
7		for Routine and Small Projects for the historical test year and the projected
8		expenditures for the 24-month bridge forecast period ending December 31, 2024
9		and the 12-month projected test period ending December 31, 2025 which total \$81.3
10		million, \$135.2 million and \$42.5 million respectively. Additional details for select
11		routine and small projects are provided in Exhibit A-20, Schedule J2 and are also
12		provided in the Part III (Questions 9 and 10) supplemental filing requirements.
13		
14		The expenditures and project make-up are generally consistent each operating cycle
15		and peak during refueling outage periods because of the regulatory and safety
16		requirements governing Routine and Small Projects. I will highlight specific
17		Routine and Small Projects to help convey the type of projects that comprise Routine
18		and Small Projects in my testimony next.
19		
20	Q28.	Prior to discussing the highlighted projects, can you please generally discuss
21		the capital expenditures for the historical year ending December 31, 2022, the
22		projected bridge years ending December 31, 2023 and December 31, 2024, and
23		the projected test year ending December 31, 2025?
24	A28.	Historical year ending December 31, 2022 included Refueling Outage 21 (RF21).
25		Most of the Small and Routine expenditures within the historical year ending

Line <u>No.</u>		J. C. DAVIS U-21534
1		December 31, 2022 were associated with projects (such as the Visual Annunciator
2		System replacement) that completed and went into service during RF21.
3		
4		The projected bridge year ending December 31, 2023 is the year proceeding a
5		refueling outage (RF22 in spring 2024); many of the project expenditures (such as
6		control rod drive mechanism (CRDM) replacements) in 2023 are associated with
7		planning, readying and material procurement for RF22.
8		
9		The projected bridge year ending December 31, 2024 is the year that includes RF22
10		and, as such, most of the Small and Routine expenditures are associated with
11		projects (such as the Residual Heat Removal Service Water (RHRSW) outlet valve
12		(F068A/B) replacement) projected to be completed and go into service during RF22.
13		
14		The projected test period ending December 31, 2025 is again a year that proceeds a
15		refueling outage (RF23 in spring 2026), and similar to the projected bridge year
16		ending December 31, 2023, many project expenditures (such as control rod drive
17		mechanism (CRDM) replacements) in 2025 are associated with planning, readying
18		and material procurement for RF23.
19		
20	Q29.	Does the general expenditure pattern just described apply to multi-year
21		projects such as the Security System Computer replacement project shown on
22		line 4, Plant Radio System project shown on line 5 on Exhibit A-12, Schedule
23		B5.3, page 2, and Plant Wireless project shown on line 35 on Exhibit A-12,
24		Schedule B5.3, page 3?

1	A29.	No. Security System Computer, Plant Radio System and Plant Wireless projects are
2		examples of multi-year Routine and Small Projects with predominately online
3		implementation, so the general pattern of Routine and Small Projects expenditures
4		just discussed is not as relevant to these projects. Because these projects are multi-
5		year, I previously discussed these three projects in DTE Electric Rate Cases U-
6		20836 and U-21297; nonetheless, because of their continued importance to our
7		nuclear safety paradigm, I will again highlight these projects here.
8		
9	Q30.	Can you discuss the expenditures and rationale for the Security System
10		Computer replacement project shown on Exhibit A-12, Schedule B5.3, page 2,
11		line 4?
12	A30.	The Security System Computer replacement project capital expenditures for the
13		historical test year, projected bridge forecast period and projected test period are
14		\$7.1 million, \$26.8 million and \$0.0 million respectively and projects to complete
15		prior to the end of the projected test period. This project addresses aging and
16		obsolescence of the existing security system computer, and support the necessary
17		replacement of the Fermi 2 Security System Computer which includes specialized
18		computer servers, video cameras, other access control and detection devices, and
19		communication cabling. This major plant security system is an aspect of the
20		regulatory-required Fermi 2 Security Protection Plan per Code of Federal
21		Regulation 10 CFR 73.55 which requires a physical security plan that must "ensure
22		that the capabilities to detect, assess, interdict, and neutralize threats up to and
23		including the design basis threat of radiological sabotage as stated in 10 CFR 73.1,
24		are maintained at all times" and "provide defense-in-depth through the integration
25		of systems, technologies, programs, equipment, supporting processes, and

Line

- <u>No.</u>

implementing procedures as needed to ensure the effectiveness of the physical protection program."

3

2

1

4 Q31. Why is replacement of the security system computer necessary within the 5 projected test period?

6 A31. Components of the existing security system computer have exhibited decreased 7 performance as service time has increased. Degradation of security equipment 8 results in multiple alarms that distract the security force from core activities, requires 9 compensatory measures which require unscheduled overtime, requires emergent 10 maintenance, and increases the risk of gaps in meeting the regulatory 11 requirements. In 2022, one of the intrusion detection systems accumulated three 12 times more annual out of service time than it did in 2021, indicating a need to replace 13 the system. Repair and replacement of existing components has become 14 increasingly difficult as equipment becomes obsolete; for example, vendor 15 supported software updates ceased for the security system computer's video 16 monitoring software, video server operating system, and the server and workstation 17 operating system in 2015, 2016 and 2020 respectively. Lack of vendor support for 18 these operating systems or video monitoring systems could lead to extended loss of 19 security video feeds which would require additional security personnel to 20 compensate for the loss of video surveillance.

21

A security computer system used in the security of a nuclear power plant can be reasonably expected to be in service for approximately 10 – 15 years based on anticipated aging and obsolescence factors. Aspects of the Fermi 2 security system computer such as the communications cabling have been in service for more than Line No.

1

2

3

4

5

thirty years; while the security system computer servers, workstations and access controls hardware is comparatively newer – this hardware still relies on late-2000s vintage technology. NRC cyber security regulations and the deeply integrated nature of the security system computer makes replacement components increasingly impractical to procure.

6

Preemptive replacement of the security system computer and its constituent components is a reasonable and prudent action, consistent with our nuclear safety priorities to support DTE Electric continuing to meet its regulatory commitments into the 2030s when DTE Electric anticipates the next routine replacement of the security system computer to occur. Several portions of this project also bring equipment and strategy up to nuclear industry standards. Additionally, these replacements will allow for more efficient equipment maintenance.

14

15 The integrated project also includes addition of equipment, for example, additional 16 cameras, and changes to the location of some equipment to support satisfactory 17 outcomes from NRC-graded Force-on-Force exercises as well as a formal 18 assessment of the Security Strategy.

19

Q32. What is the role of the security computer system within the nuclear safety paradigm you discussed earlier in your testimony?

A32. The security computer system itself is an aspect of the Fermi 2 Physical Security
 Plan (the exact details of physical security plans are safeguarded and protected per
 regulation) – having and maintaining Fermi 2's security equipment in accordance
 with the approved physical security plan is a regulatory requirement and a condition

1	to maintaining the Fermi 2 operating license. Because the consequences of hostile
2	actors acting against a U.S. commercial nuclear plant are significant, each U.S.
3	commercial nuclear site's physical security plan is routinely inspected and tested by
4	the NRC to ensure compliance. DTE Electric has an obligation to ensure that all
5	aspects of the Fermi 2 physical security plan work and will continue to work in the
6	future – hence a preemptive replacement regimen is necessary to ensure components
7	of the security computer system do not unexpectedly or unrecoverably fail.
8	
9	As DTE Electric replaces the existing security computer system, Fermi 2 must
10	remain in compliance with regulations such that: (1) the functions and capabilities
11	of the existing security computer system must be maintained while the new system
12	is being installed, (2) design, configuration control and work to replace the existing
13	security computer systems must be performed so as to maintain operability of other
14	Fermi 2 plant systems including taking special care when excavating to replace
15	cabling and other components, (3) the new security computer system must meet
16	NRC cyber security requirements, (4) the new system must be designed and tested

for continuous operations with minimal maintenance time. Total project expenditures are commensurate with these regulatory requirements.

19

17

18

20 Q33. Was the Security System Computer project competitively sourced?

A33. Yes. Consistent with the commercial principles I discussed earlier, the Security
 System Computer project uses competitively-sourced suppliers. While commercial
 processes and agreements are sensitive information, DTE Electric provides relevant
 sourcing documents, subject to non-disclosure orders, within the natural order of

Line No.		J. C. DAVIS U-21534
1		this proceeding; other supplier and project information can be found in this
2		proceeding's Part III, Attachment 9 supplement filing.
3		
4		Total project costs reasonably and prudently reflect actual and projected costs based
5		on the commercial solicitations and agreements. As I discussed earlier, commercial
6		solicitation processes such as competitive sourcing is a principle of prioritizing
7		nuclear safety to support safe, reliable and efficient project execution and post-
8		implementation equipment operations.
9		
10	Q34.	Can you discuss the expenditures and rationale for the Plant Radio System
11		replacement project shown on Exhibit A-12, Schedule B5.3, page 2, line 5?
12	A34.	The Plant Radio System capital expenditures for the historical test year, projected
13		bridge forecast period and the projected test period are \$4.2 million, \$7.5 million
14		and \$0.0 million respectively, do not extend beyond the projected test period,
15		address security and operations vulnerabilities of the existing plant radio system,
16		and support the necessary replacement of the Fermi 2 plant radio system which
17		includes computers, radio repeaters, radio antenna, uninterruptible power supplies
18		and communications cabling. This major system is an aspect of the regulatory-
19		required Fermi 2 Physical Security Plan and the regulatory-required Fermi 2
20		Radiological Emergency Response Plan and has the purpose to be the primary
21		means of communication for plant personnel including site security and fire brigade
22		during operations and potential accident scenarios; loss of the plant radio system
23		would degrade plant operators' ability to safely operate the Fermi 2 Power Plant.
24		

Line No.

Q35. Why is replacement of the plant radio system necessary within the projected test period?

3 A35. Security and operations vulnerabilities. Replacement of the plant radio system began 4 in 2017 with the replacement of plant radio equipment in the Fermi 2 Main Control 5 Room (MCR); field radio communications to the MCR were becoming increasingly 6 inaudible within the MCR which was unduly burdening plant operators during plant 7 operations. Additionally, radio communications within the power plant uses an 8 antenna system installed in the early 1980s, experiences a significant signal loss 9 between the base station and the distributed antennas and is capable of transmitting 10 only the UHS frequency band. Replacement of the plant radio system distributed 11 antenna system, communications cabling and uninterruptible power supplies (which 12 is the scope of work during the bridge and projected test periods in this case) will 13 improve plant radio signal fidelity throughout the plant and add two additional radio 14 frequencies bands (VHS and 800 MHZ) within the power plant.

15

Improving plant radio signal fidelity within the plant supports improved operations
 communications, especially for emergency responders such as fire brigade in all
 areas of the plant.

19

Adding the two additional radio frequency bands also allows DTE Electric to evaluate changes to the Fermi 2 Physical Security Plan, further improve Fermi 2's security posture and enhance security's communication capabilities with outside emergency responders such as the Michigan State Police.

24

1

2

Q36. What is the role of the plant radio system within the nuclear safety paradigm you discussed earlier in your testimony?

3 A36. The plant radio system is an aspect of the Fermi 2 Radiological Emergency 4 Response Plan – having and maintaining Fermi 2's plant radio equipment in 5 accordance with the approved emergency response plan is a regulatory requirement 6 and a condition to maintaining the Fermi 2 operating license. Because the 7 consequences of an ineffective radiological emergency response are significant, 8 each U.S. commercial nuclear site's emergency response plan is routinely inspected 9 and tested by the NRC and the Federal Emergency Management Agency (FEMA) 10 to ensure compliance. DTE Electric has an obligation to ensure that the components 11 of the Fermi 2 Radiological Emergency Response Plan work and will continue to 12 work in the future – hence a preemptive replacement regimen is reasonable and 13 prudent.

14

15 The plant radio system is the primary communication means for plant operators and 16 security officers responding to emergency conditions – unexpected or unrestorable 17 failure or interruption of this equipment would be an unacceptable risk to first 18 responders to any Fermi 2 plant emergency; it is imperative that the plant radio 19 system maintains its capabilities throughout the plant and through all postulated 20 operating scenarios.

21

As Fermi 2 replaces the existing plant radio system, the Company must remain in compliance with regulations such that: (1) the functions and capabilities of the existing plant radio system must be maintained while the new system is being installed, (2) design, configuration control and work to replace the existing plant radio system must be performed as to maintain operability of other Fermi 2 plant
systems, (3) the new plant radio system must meet NRC cyber security
requirements, and (4) the new system must be designed and tested for continuous
operations with minimal maintenance time. This requires installing 16 new antennae
and approximately 5800 feet of new conduit and cable. Total project expenditures
are commensurate with these regulatory requirements.

7

8

9

Q37. Can you discuss the expenditures and rationale for the Plant Wireless project shown on Exhibit A-12, Schedule B5.3, page 3, line 35?

10 A37. The Plant Wireless project capital expenditures for the historical test year, projected 11 bridge forecast period and the projected test period are \$0.3 million, \$7.7 million 12 and \$0.0 million respectively, do not extend beyond the projected test period, 13 address operational vulnerabilities and support the replacement and expansion of the 14 existing Fermi 2 plant wireless system which includes modems, network switches, 15 and wireless antennae. The purpose of the plant wireless system is to provide 16 wireless data communications capacity to plant personnel during normal operations; 17 not replacing and expanding the plant wireless system would challenge operations 18 to effectively operate the plant. In addition, the Plant Wireless project is resource-19 optimized with the Plant Radio System replacement project by sharing the conduit 20 and cable trays.

21

Q38. What is the role of the plant wireless system within the nuclear safety paradigm you discussed earlier in your testimony?

A38. Installation of a wireless communication backbone throughout the nuclear power
 block directly impacts the ability to progress with other cost-savings and

1 radiological dose-savings initiatives including Electronic Work Orders, Electronic 2 Operator Rounds, remote dose monitoring and remote equipment monitoring. NRC 3 regulations require management measures which include configuration 4 management, maintenance, training and certification, procedures, records 5 management, and other quality assurance methods, generally on a continuing basis, 6 that are applied to items relied on for safety, to ensure the items are available and 7 reliable to perform their functions when needed. Plant wireless system provides the 8 networking infrastructure and capacity necessary for Fermi 2 to modernize and 9 maintain these management measures. Plant wireless networks are used in the 10 nuclear industry to provide efficiency in recording and automatically storing 11 regulatory-required documentation and for additional monitoring of equipment 12 important to nuclear safety and plant reliability without incurring the large costs of 13 permanent imbedded cabling.

14

Line

No.

15 Existing management measures require controlled paper copies of work orders, 16 plant drawings, engineering design documents, purchasing agreements, time sheets 17 and procedures in the field – not that different from when the Fermi 2 first started 18 commercial operations in 1988. While these paper-document management measures 19 continue to support safe and reliable operations, modern industry-best practices have 20 evolved to use paperless work orders and procedures, automated document control 21 and records management, and electronic time keeping systems to reduce human 22 error precursors and to maintain positive configuration control of the plant.

23

As DTE Electric replaces and expands the existing plant wireless system, the Company must remain in compliance with regulations such that: (1) design,

1		configuration control and work to replace and expand the existing plant wireless
2		system must be performed so as to maintain operability of other Fermi 2 plant
3		systems, (2) wireless network signals from the plant wireless system must strike a
4		difficult engineering balance between strong signal strength and bandwidth against
5		requirements that the signals not interfere with the function of other plant equipment
6		and (3) the new plant wireless system must meet NRC cyber security requirements.
7		Total project expenditures are commensurate with these regulatory requirements.
8		
9	Q39.	What do you mean by "aging and obsolescence?"
10	A39.	Aging in the context of nuclear plant operations refers to the general process in
11		which characteristics of equipment or components gradually degrade with time or
12		use.
13		
14		Component obsolescence in the context of nuclear plant operations refers to
15		equipment or components that are no longer manufactured or qualified by their
16		original manufacturers.
17		
18	Q40.	Why is obsolescence a particular concern for DTE Electric at the Fermi 2
19		Power Plant?
20	A40.	I have discussed aging and obsolescence a few times already because aging and
21		obsolescence concerns are not just a focus for DTE Electric, but a focus for the entire
22		U.S. nuclear industry. Configuration management at a nuclear power plant specifies
23		allowed components by manufacturer and model number. Once manufacturers cease
24		operations, change ownership or cease production of a particular model, nuclear
25		operators must identify potential replacements. This process of identifying potential

1 replacements is rigorous as all aspects of the potential replacement's fit, form and 2 function must be evaluated by qualified engineers. Potential replacements may also 3 require physical modification to the plant to be usable – Security System Computer 4 is one such project that requires modifications to the Fermi 2 plant to address aging 5 and obsolescence. 6 7 Unexpected or unrecoverable failures of obsolete components are a vulnerability to 8 safe and reliable plant operations. Of course, as components age, the vulnerability 9 of unrecoverable failure increases. Unexpected or unrecoverable failures of obsolete 10 components could result in the extended compensatory measures that burden operations, security, or other plant personnel; shutdown of the plant is also a 11 12 possibility until potential replacements are identified and actions are taken to make 13 the replacement usable within the plant. 14 15 Q41. What actions must a nuclear operator such as DTE Electric take to physically

16 **modify the plant?**

17 A41. When new or replacement components or equipment require a plant modification, 18 in addition to the physical field work of the modification there are several 19 management actions required: (1) plant drawings and component databases must be 20 updated, (2) plant calculations must be revised to ensure sufficient structural loading 21 or electrical loading margins exist, (3) physical security and emergency response 22 plans must be evaluated and possibly revised, (4) operating license and safety 23 analysis reporting must be evaluated and possibly revised, and (5) training, 24 operations and maintenance programs must be evaluated and possibly revised.

25

2

1

The resources, time, and costs of these regulatory-required management measures are non-trivial.

3

4 Q42. Can you discuss the expenditures and rationale for the Undervessel 5 Replacements project shown on Exhibit A-12, Schedule B5.3, page 2, line 2?

6 A42. I previously discussed the routine Undervessel Replacements project, as well as the 7 related projects involving Control Rod Blade Replacements and Control Rod Drive 8 Mechanisms Replacements, in Case No. U-21297. DTE Electric has depicted the 9 ongoing and updated capital expenditures for these projects in each DTE Electric 10 rate case dating back to at least U-16472 without contention. I would like to again 11 establish the importance of these Routine and Small Projects with a discussion here, 12 starting with the Undervessel Replacements project. The Undervessel Replacements 13 capital expenditures for the historical test year, projected bridge forecast period and 14 projected test period are \$8.0 million, \$6.6 million, and \$0.0 million respectively. 15 These expenditures do extend beyond the projected test period and through the 16 balance-of-life of the Fermi 2 Power Plant, address component aging, and support 17 the necessary replacement of undervessel components which include control rod 18 drives and nuclear instrumentation such as local power range monitors (LPRMs). 19 The purpose of undervessel components goes to the heart of safely operating a 20 nuclear reactor and directly affects control and monitoring of power levels 21 throughout the reactor core (undervessel components are so named because the 22 components are driven by equipment located underneath the reactor pressure 23 vessel); unplanned or unrecoverable loss of these components would challenge plant 24 operator's ability to safely operate the Fermi 2 plant.

25

1 Q43. Can you discuss the expenditures and rationale for the Control Rod Blade 2 **Replacements project shown on Exhibit A-12, Schedule B5.3, page 3, line 45?** 3 A43. The Control Rod Blade (CRB) Replacement project capital expenditures for the 4 historical test year, projected bridge forecast period and projected test period are 5 \$0.1 million, \$1.0 million, and \$0.9 million respectively, do extend beyond the 6 projected test period and through the balance-of-life of the Fermi 2 Power Plant, 7 closely relates to the Undervessel Replacements projects, address CRB component 8 aging, and support the necessary replacement of the CRBs (DTE Electric replaced 9 19 CRBs in RF21 and projects replacement of 22 CRBs in RF22). The purpose of 10 Fermi 2's 185 CRBs is to control power levels within the reactor core and to 11 ultimately safely accomplish shut down of the reactor when appropriate; unplanned 12 or unrecoverable loss of the CRBs would challenge plant operator's ability to safely 13 operate the Fermi 2 plant.

14

Q44. Can you discuss the expenditures and rationale for the Control Rod Drive Mechanisms project shown on Exhibit A-12, Schedule B5.3, page 2, line 28?

A44. The Control Rod Drive Mechanism (CRDM) replacement project capital 17 18 expenditures for the historical test year, projected bridge forecast period and projected test period are \$0.9 million, \$5.2 million, and \$4.9 million respectively, 19 20 do extend beyond the projected test period and through the balance-of-life of the 21 Fermi 2 Power Plant, closely relates to the Undervessel Replacements projects, 22 address CRDM component aging, and support the necessary replacement of the 23 CRDMs (DTE Electric replaced 20 CRDMs in RF21 and projects replacement of 24 20 CRDMs in RF22 and 20 CRDMs in RF23 (spring 2026)). The purpose of Fermi 25 2's 185 CRDMs is to control power levels within the reactor core and to ultimately <u>No.</u>

1

2

safely accomplish shut down of the reactor upon receiving either manual or automatic signals; unplanned or unrecoverable loss of the CRDMs would challenge plant operator's ability to safely operate the Fermi 2 plant.

4

3

Q45. Why is Fermi projecting to replace 22 CRBs in RF22 and only 20 CDRMs in RF22?

7 A45. Although CRBs and CRDMs are part of the same control rod drive system, the aging 8 mechanism is very different between CRDMs and CRBs. CRDMs (hydraulic piston 9 assemblies located underneath the reactor pressure vessel) are subject to harsh 10 environmental conditions such as extreme heat, moisture and radiation; after time, 11 the components of the CRDM will naturally stress, fatigue and wear and must be 12 replaced. CRBs (crucible-shaped, metal-tube components that contain a neutron-13 absorbing material located inside the reactor core adjacent to fuel assemblies) are 14 subject to the extreme environment of the reactor itself; after time, the neutron-15 absorbing material is consumed preventing it from fully performing its function to 16 shutdown the reactor or the CRB structural material will stress, fatigue and wear and 17 may become damaged during operation which could directly impact fuel integrity.

18

Each component of the control rod drive system must be evaluated and replaced on its own schedule. For CRBs, DTE Electric determines this schedule based on analysis of the operational history of the individual CRBs, calculates remaining useful core life, and performs confirmatory testing to ensure the CRBs perform as expected. For CRDMs, DTE Electric levelizes the replacements of the CRDMs over their approximately 12-cycle in-service life.

25

1	Q46.	What is the status of the commercial agreements for the Undervessel
2		Replacements, CRBs and CRDMs?
3	A46.	DTE Electric has negotiated long-term commercial agreements (using the
4		commercial principles I discussed earlier) for the OEM suppliers to provide these
5		vital nuclear components and services through at least 2027. These long-term
6		agreements provide DTE Electric with high assurance of adequate supply of
7		nuclear-quality plant components at predictable quality, compatibility and cost -
8		which is certainly reasonable and prudent.
9		
10	Q47.	What are the expenditures and rationale for the Roof Replacements project
11		shown on Exhibit A-12, Schedule B5.3, page 3, line 51?
12	A47.	The Roof Replacements project capital expenditures for the historical test year,
13		projected bridge forecast period and projected test period are \$0.0 million, \$3.3
14		million, and \$0.0 million respectively with complete replacements of the Office
15		Building Annex (OBA), Office Service Building (OSB), and Warehouse A roofs
16		already complete in 2023. Of course, DTE Electric projects other roofs to be
17		replaced in the future but those future project expenditures would occur beyond 12-
18		month projected test period ending December 31, 2025 and are not included in this
19		proceeding.
20		
21	Q48.	Why was replacement of these roofs necessary in 2023?
22	A48.	Aging. The roofs in scope are original to the plant and leaked and further repair was
23		constrained by their antiquated design. The Fermi 2 OBA and OSB house nuclear
24		operations staff, work control, outage management staff and maintenance staff as

25 well as the Fermi 2 maintenance shops (Mechanical, Electrical and Instrument &

Line <u>No.</u>		J. C. DAVIS U-21534
1		Controls (I&C) and machine shop). Warehouse A is the warehouse within the Fermi
2		2 Protected Area used for staging parts and materials for upcoming work.
3		
4	Q49.	What is the role of the Roof Replacements project within the nuclear safety
5		paradigm you discussed earlier in your testimony?
6	A49.	All workers – at a nuclear power plant or otherwise, should be able to work in an
7		environment safe from industrial hazards such as leaking roofs.
8		
9		Our U.S. nuclear industry refers to workers at nuclear power plants as "nuclear
10		professionals." Our industry places considerable expectations on nuclear
11		professionals and appropriately so given the obligation to safely operate nuclear
12		power plants. One of these expectations is that nuclear professionals are to practice
13		good housekeeping and control of work areas to minimize the potential for injuries,
14		likelihood of human error, the spread of contamination and the generation of nuclear
15		waste; tolerating leaking roofs, which have the potential to undermine any of the
16		aspects of the expectation I just outlined risks undermining a criterion of nuclear
17		professionalism – which would not be reasonable and would not be prudent.
18		
19	Non-	Routine and Large Projects Capital Expenditures
20	Q50.	Can you discuss the Non-Routine and Large Projects summarized on line 3 of
21		Exhibit A-12, Schedule B5.3, page 1?
22	A50.	Non-Routine and Large Projects are projects that are necessary to properly maintain
23		the Fermi 2 asset and are incremental to normal routine capital expenditures.
24		

Line No.		J. C. DAVIS U-21534
1		Refer to Page 4 of Exhibit A-12, Schedule B5.3 for a listing of the projects that
2		support page 1, line 3.
3		
4	Q51.	Can you explain the Non-Routine and Large Projects detailed in Exhibit A-12,
5		Schedule B5.3, page 4?
6	A51.	Yes. This exhibit shows the by-project capital expenditures for Non-Routine and
7		Large Projects, as noted by line 3 of Exhibit A-12, Schedule B5.3, page 1. These
8		projects for the historical test year, the projected expenditures for the 24-month
9		bridge forecast period ending December 31, 2024 and the 12-month projected test
10		period ending December 31, 2025 total \$173.2 million, \$204.3 million and \$38.4
11		million respectively. A discussion of certain Non-Routine and Large Projects
12		follows with additional details for other Non-Routine and Large Projects provided
13		in the Part III (Questions 9 and 10) supplemental filing documents.
14		
15	Q52.	Can you explain the expenditures and rationale for the Main Unit Generator
16		projects shown on line 2 and line 5 of Exhibit A-12, Schedule B5.3, page 4?
17	A52.	The main unit generator projects are a series of replacements necessary to address
18		both an Original Equipment Manufacturer (OEM) design vulnerability and improve
19		overall reliability through 2045. These projects also support electrical grid
20		reliability. Replacement of this model of generator is the identical approach other
21		nuclear generation owners have taken over the years to mitigate operational risk. To
22		support reliable operation of Fermi 2 through 2045, major refurbishments and
23		replacement of the existing generator asset is reasonable and prudent. The
24		replacement main unit generator stator, as of January 2024, is at the manufacturing
25		facility in New York. Work is ongoing to ready the replacement main unit generator

stator. DTE Electric will continue to make reasonable and prudent decisions to ensure the main unit generator project, once complete, will support safe and reliable operations through Fermi 2's operating license termination date in 2045. The Main Unit Generator rotor replacement project as depicted on line 5 replaced the existing main unit generator rotor with a refurbished spare rotor during RF21. This replacement was performed to mitigate operational vulnerabilities associated with the existing main unit generator. This replacement occurred during RF21 and has capital expenditures for the historical test year, projected bridge forecast period, and projected test period of \$15.9 million, \$0.0 million and \$0.0 million The Main Unit Generator Replacement project as depicted on line 2 is to replace the generator stator and rotor with a matched stator and rotor. This replacement is projected to occur during RF23 (Spring 2026) and has capital expenditures for the historical test year, projected bridge forecast period and projected test period of \$47.1 million, \$87.9 million and \$14.3 million respectively.

J. C. DAVIS

U-21534

18

Line

No.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

respectively.

19 Q53. Why was the Fermi 2 main unit generator rotor replaced in RF21?

20 A53. The Midcontinent Independent System Operator (MISO) identified that Trenton 21 Channel Unit 9 would be designated as a System Support Resource (SSR) (and thus 22 would be required to continue to be operable and not eligible for retirement) unless 23 an alternative solution was identified to resolve violations of applicable reliability 24 criteria upon the unit's retirement. Replacement of the existing Fermi 2 main unit 25 generator rotor (and the generator excitation automatic voltage regulator (AVR)

1		depicted on line 6 of Exhibit A-12, Schedule B5.3, page 4) was required in
2		conjunction with replacement of Service System Transformer #65 (depicted on line
3		7 of Exhibit A-12, Schedule B5.3, page 4) prior to retirement of the Trenton Channel
4		Power Plant in May of 2022 to resolve the reliability issues that would otherwise
5		occur. The Fermi 2 generator rotor and AVR that were in-service prior to RF21 were
6		not capable of generating sufficient reactive power to solve the reliability issues
7		identified by MISO. RF21 was the Company's last window of opportunity to replace
8		the Fermi 2 generator rotor to maintain the Trenton Channel Unit 9 planned 2022
9		retirement date as required by the 2020 Consent Decree between the Company and
10		the United States Environmental Protection Agency ¹ .
11		
12	Q54.	What is the basis to replace the Fermi 2 main unit generator in RF23?
13	A54.	The existing Fermi 2 generator (stator) is the original plant equipment,
13 14	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator
13 14 15	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and
13 14 15 16	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies;
13 14 15 16 17	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent
13 14 15 16 17 18	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present
 13 14 15 16 17 18 19 	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present a generation risk but also present operational risk to the plant operators responsible
 13 14 15 16 17 18 19 20 	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present a generation risk but also present operational risk to the plant operators responsible for maneuvering the plant to a shutdown condition following a generator failure.
 13 14 15 16 17 18 19 20 21 	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present a generation risk but also present operational risk to the plant operators responsible for maneuvering the plant to a shutdown condition following a generator failure.
 13 14 15 16 17 18 19 20 21 22 	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present a generation risk but also present operational risk to the plant operators responsible for maneuvering the plant to a shutdown condition following a generator failure. A matched rotor will be installed in RF23 for two reasons: (1) a matched rotor can
 13 14 15 16 17 18 19 20 21 22 23 	A54.	The existing Fermi 2 generator (stator) is the original plant equipment, manufactured in the early 1970s using the technology of that time. The generator stator is approaching end of life (EOL). To date, multiple known vulnerabilities and degradation have been mitigated through increased maintenance bridging strategies; however, design vulnerabilities associated with the stator continue to represent increased risk for sudden failure. Unplanned or unexpected failures not only present a generation risk but also present operational risk to the plant operators responsible for maneuvering the plant to a shutdown condition following a generator failure. A matched rotor will be installed in RF23 for two reasons: (1) a matched rotor can be fit with the replacement stator prior to field work during RF23 which minimizes

¹ <u>https://www.justice.gov/enrd/consent-decree/file/1276421/download</u>, accessed January 6, 2024.

Line No.

1

2

contaminated with metallic particles after use with the original stator and its design flaw which could jeopardize the integrity of the replacement stator if the current rotor were to be reinstalled.

3 4

5 DTE Electric continues the necessary work to complete the replacement stator and 6 have the replacement main unit generator (stator and rotor) in a ready state. 7 Implementing the Main Unit Generator Replacement project in RF23 is a reasonable 8 and prudent action because of the current state described above. DTE Electric has 9 implemented and will continue to implement reasonable and prudent bridging strategies to mitigate the short-term reliability risks associated with the existing 10 11 Fermi 2 main unit generator; however, given the main unit generator's importance 12 with respect to safe and reliable plant operations through 2045, DTE Electric has 13 scheduled implementation of the Main Unit Generator Replacement project in 14 RF23.

15

16 Q55. What specific work is being performed at the manufacturer facility in New 17 York?

A55. Subsequent inspections of the new generator stator revealed unsatisfactory foreign
 material within the coatings applied to the stator. The generator stator has been
 completely disassembled, and the coatings were removed. The stator parts were then
 reinspected, recoated and reassembled.

22

Q56. Why did the projected in-service date for the Main Unit Generator
 Replacement project change from RF22 (2024) in U-21297 to RF23 (2026) in
 this proceeding?

1	A56.	Transportation from the manufacturing facility in New York to the Fermi 2 Power
2		Plant is performed via the St Lawrence Seaway. The Seaway and canals are
3		generally closed to shipping during the winter months. Rather than attempt to use
4		higher risk transportation methods or routes to support a delivery date that fully
5		supported sufficient time to ready the replacement generator for RF22 install, DTE
6		Electric made a well-reasoned and prudent decision to change the generator
7		replacement to RF23.
8		
9	Q57.	Can you discuss the expenditures and rationale for the Underground Safety-
10		Related Service Water Piping project shown on line 4 of Exhibit A-12, Schedule
11		B5.3, page 4?
12	A57.	The Underground Safety-Related Service Water Piping capital expenditures for the
13		historical test year, projected bridge forecast period and projected test period are
14		\$23.3 million, \$42.9 million and \$0.0 million respectively. The Underground
15		Safety-Related Service Water Piping project replaces nuclear safety-related piping
16		that delivers cooling water to various components that support the operation of the
17		nuclear reactor. A portion of the underground safety-related service water piping
18		was replaced in RF21, with the remaining piping to be completed in RF22. The
19		replacement of the underground safety-related service water piping is necessary to
20		address age-related degrading pipe-wall thickness and to ensure this pipe will
21		continue to support plant operations through the end of the operating license in 2045.
22		
23	Q58.	What does it mean to be "safety-related" piping?
24	A58.	In the U.S. nuclear industry, the term "safety-related" applies to systems, structures,
25		components, procedures, and controls that are relied upon to remain functional
1 during and following design-basis events. Per NRC regulations, materials, 2 equipment and components of safety-related systems have very strict manufacturing 3 tolerances and quality control; new materials, equipment and components are 4 inspected against technically developed procurement specifications. Post-delivery 5 modifications to safety-related materials such as cutting, fitting and welding pipe 6 must be to design, properly controlled, traceable, and work inspected by qualified 7 inspectors. Work on safety-related equipment requires an exactness in performance 8 that is not common in non-nuclear industry.

9

10 11

12

Q59. Can you discuss the expenditures and rationale for the General Service Water (GSW) intake groin replacement shown on line 20 of Exhibit A-12, Schedule B5.3, page 4?

13 A59. The General Service Water (GSW) intake groin replacement project capital 14 expenditures for the historical test year, projected bridge forecast period and 15 projected test period are \$0.0 million, \$18.0 million, and \$0.0 million respectively, do not extend beyond the projected test period, address natural erosion of the 16 17 existing GSW intake groin structure, and support the necessary replacement of the 18 GSW intake groin structure. The Fermi 2 GSW intake groin structure is comprised 19 of two armored-earthen jetties that jut into Lake Erie; the jetties' armor is rock and 20 concrete tetrapods which are designed to mitigate Lake Erie erosion action and yet 21 allow enough movement within the armor structure itself to mitigate Lake Erie ice 22 action from damaging the armor. The purpose of Fermi 2 GSW intake groin 23 structure is to protect the Fermi 2 GSW intakes from Lake Erie wave action, 24 minimize bio-material accumulation at the GSW intake and to minimize sediment 25 accumulation at the GSW intake; the Fermi 2 GSW system itself provides cooling 1

water to plant equipment; unplanned or unrecoverable loss of the GSW would challenge the plant operator's ability to safely operate the Fermi 2 plant.

3

2

4 Q60. Can you discuss the expenditures and rationale for the License Renewal 5 Implementation (LRI) project shown on line 8 of Exhibit A-12, Schedule B5.3, 6 page 4?

7 A60. The License Renewal Implementation (LRI) project capital expenditures for the 8 historical test year, projected bridge forecast period and projected test period are 9 \$5.8 million, \$15.3 million, and \$0.7 million respectively, do extend beyond the 10 projected test period, address DTE Electric's NRC renewed operating license 11 commitment, and support the necessary first-time and only-time inspection required 12 from Fermi 2 to operate during its Period of Extended Operations which begins in 13 2025. To ensure safe operations during a plant's Period of Extended Operation, the 14 NRC mandates programs to monitor and intrusively inspect passive plant systems 15 that may be impacted by plant age; the Fermi 2 LRI project coordinates and conducts 16 the first-time and one-time inspections associated with this new and regulatorilyrequired monitoring and inspection regime; failure to complete these first-time and 17 18 one-time inspections would result in NRC violations and possible suspension of 19 Fermi 2's renewed operating license.

- 20
- 21 22

Q61. Can you discuss the expenditures and rationale for the Circulating Water (CW) Discharge Pipe project shown on line 9 of Exhibit A-12, Schedule B5.3, page 4?

A61. The Circulating Water (CW) Discharge Pipe project capital expenditures for the
historical test year, projected bridge forecast period and projected test period are
\$5.3 million, \$0.0 million, and \$0.7 million respectively, extend beyond the

Line <u>No.</u>

1		projected test period, address natural aging of the Fermi 2 CW discharge piping, and
2		support the necessary in situ replacement of the CW discharge piping pressure
3		boundary with a carbon-fiber shell that lines the interior surface of the CW discharge
4		pipe. The Fermi 2 CW piping is two interconnected sets of underground 144"
5		diameter, pre-stressed concrete cylinder pipe (PCCP); total pipe length is
6		approximately a mile and comprised of approximately 450 pipe segments. The
7		purpose of Fermi 2 CW piping is to transport circulating water from the CW pond
8		to the Main Unit Condenser (CW inlet piping) and to transport the circulating water
9		from the Main Unit Condenser to the Fermi 2 natural draft cooling towers (CW
10		discharge piping); the Fermi 2 CW system itself provides cooling water to Main
11		Unit Condenser; unplanned or unrecoverable loss of the CW piping would challenge
12		plant operator's ability to safely operate the Fermi 2 plant and cause a unit shutdown.
13		
13 14	Q62.	Why is it necessary to replace the pressure boundary of the CW discharge
13 14 15	Q62.	Why is it necessary to replace the pressure boundary of the CW discharge piping?
 13 14 15 16 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground
 13 14 15 16 17 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile
 13 14 15 16 17 18 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate
 13 14 15 16 17 18 19 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires
 13 14 15 16 17 18 19 20 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires corrode, the strength of the PCCP deteriorates and the PCCP will catastrophically
 13 14 15 16 17 18 19 20 21 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires corrode, the strength of the PCCP deteriorates and the PCCP will catastrophically fail.
 13 14 15 16 17 18 19 20 21 22 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires corrode, the strength of the PCCP deteriorates and the PCCP will catastrophically fail.
 13 14 15 16 17 18 19 20 21 22 23 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires corrode, the strength of the PCCP deteriorates and the PCCP will catastrophically fail. Because the failure mode of PCCP is catastrophic failure, the reaction time of plant
 13 14 15 16 17 18 19 20 21 22 23 24 	Q62. A62.	Why is it necessary to replace the pressure boundary of the CW discharge piping? The CW pipe is original to plant construction and is aging – as all underground concrete pipes do. The PCCP has a concrete core, a thin steel cylinder, high tensile prestressing wires and a mortar coating. As PCCP ages the mortar will delaminate exposing the prestressing wires to corrosion forces; as the prestressing wires corrode, the strength of the PCCP deteriorates and the PCCP will catastrophically fail. Because the failure mode of PCCP is catastrophic failure, the reaction time of plant operators to safely maneuver the plant is greatly reduced. DTE Electric is taking the

Line

<u>No.</u>

1

2

3

pipe pressure boundary with a carbon-fiber liner, pipe segment by pipe segment, over time and in stages based on priorities derived from inspections to minimize refueling outage time.

4

5 Q63. Can you discuss the expenditures and rationale for the Feed Water Heaters 6 Replacements project shown on line 10 of Exhibit A-12, Schedule B5.3, page 4? 7 A63. The Feed Water Heaters Replacements capital expenditures for the historical test 8 year, projected bridge forecast period and projected test period are \$4.9 million, 9 \$11.1 million and \$4.7 million respectively. The Feed Water Heaters Replacements 10 project replaces six of Fermi 2's twelve feed water heaters that condition the nuclear 11 feed water for return to the reactor core. The six feed water heaters will be replaced 12 during RF23 (spring 2026) and RF24 (spring 2028); the remaining six feed water 13 heaters experience less operational stress and do not require replacement at this time. 14 The replacement of these feed water heaters, which are original plant equipment, is 15 necessary to address normal end-of-life degradation and improve operational 16 margins. Additionally, internal degradation of the existing feed water heaters 17 contributes to radiological dose rates in the plant. The new feed water heaters are 18 being constructed from materials that, as they wear and degrade during operation, 19 will not contribute radiological dose.

20

Q64. Are there logistical complexities associated with the replacement of the feed water heaters?

A64. These feed water heaters are quite large (i.e. approximately the size of a semi-trailer
 and weighing between 80,000 and 130,000 pounds each) and located in enclosed
 rooms within Fermi 2 Turbine Building, surrounded by pipes. To get these feed

1 water heaters into the Turbine Building requires disassembly of the east wall of the 2 Turbine Building and relocation of structures within the building. Additionally, each 3 of the piping interferences must be removed from the feed water heater rooms to 4 allow the existing feed water heaters enough space to be removed and new feed 5 water heaters moved into place; the interference piping must then be restored along 6 with the Turbine Building wall prior to unit startup. 7 8 **Q65.** Can you discuss the expenditures and rationale for the drywell cooler projects 9 shown on lines 11, 16 and 18 of Exhibit A-12, Schedule B5.3, page 4? A65. These drywell cooler projects are part of a staged, multi-year effort to proactively 10 and systematically address a series of necessary drywell cooler replacements in a 11 12 manageable fashion based on risk of potential leakage. The replacements have been 13 grouped by refueling outage implementation. The replacement of these coolers is 14 necessary to address the normal end of life status and degradation of these coolers 15 which are original plant equipment. Excessive leakage from drywell coolers can 16 and have resulted in plant shutdowns to repair. Fermi 2 has 14 drywell coolers which 17 provide the containment structure that surrounds the reactor with atmospheric 18 cooling during normal operations. 19 20 Drywell Coolers #10 and #14, as depicted on line 18, were replaced in RF20 in the

spring of 2020 and have capital expenditures for the historical test year, projected
 bridge forecast period and projected test period of \$0.0 million, \$0.0 million and
 \$0.0 million respectively.

24

Line <u>No.</u>		J. C. DAVIS U-21534
1		Drywell Coolers #12 and #13, as depicted on line 11, were replaced in RF21 and
2		have capital expenditures for the historical test year, projected bridge forecast period
3		and projected test period of \$3.5 million, \$0.0 million and \$0.0 million respectively.
4		
5		Drywell Cooler #8 is depicted on line 16, is forecasted to be replaced in RF23 and
6		has capital expenditures for the historical test year, projected bridge forecast period
7		and projected test period of \$1.5 million, \$0.0 million and \$0.6 million respectively.
8		
9	Q66.	Are there additional complexities associated with the replacement of the
10		drywell coolers?
11	A66.	The drywell coolers are located in the Fermi 2 drywell. The drywell immediately
12		surrounds the reactor pressure vessel and its environment is typically characterized
13		by high temperatures, radiologically contaminated surfaces and significant
14		radiological dose presence with densely configured plant equipment; while sealed
15		from entry during normal plant operations due to an inert nitrogen atmosphere, the
16		drywell does have two equipment hatches and a personnel hatch to allow equipment
17		and workers into the drywell during refueling outages. The travel paths for the
18		drywell coolers can be complex with many interferences that must be navigated
19		using potentially complex lifting and rigging evolutions or removed and later
20		reinstalled to successfully replace the coolers. Work must be highly scripted by
21		qualified individuals to address plant configuration challenges, minimize
22		radiological dose, and minimize human performance errors.
23		
24	Q67.	Can you discuss the expenditures and rationale for the Boraflex Fuel Storage

25 Racks project shown on line 12 of Exhibit A-12, Schedule B5.3, page 4?

1	A67.	The Boraflex Fuel Storage Racks capital expenditures for the historical test year,
2		projected bridge forecast period and projected test period are \$3.4 million, \$4.0
3		million and \$0.0 million respectively. The Boraflex fuel storage racks project will
4		replace the end-of-life Boraflex fuel storage racks with new neutron-absorbing
5		material. The replacement of the Boraflex fuel storage racks is an NRC commitment
6		tied to Fermi 2's license renewal and is necessary to restore safety margins for the
7		storage of the spent fuel through the end of the operating license in 2045.
8		
9	Q68.	Can you discuss the expenditures and rationale for the Radiation Monitors
10		project shown on line 13 of Exhibit A-12, Schedule B5.3, page 4?
11	A68.	The radiation monitors capital expenditures for the historical test year, projected
12		bridge forecast period and projected test period are \$2.7 million, \$13.2 million and
13		\$2.6 million respectively. The Radiation Monitors project replaces Fermi 2's
14		radiation monitor computer referred to as "SS1," as well as the plant's SPING
15		(detects particulate, iodine and noble gases) and AXM (accident range effluent
16		monitor) radiation monitors; together this radiation monitor system monitors and
17		analyzes the plant's gaseous effluents to affirm the plant's radiation levels remain
18		within proper specification. This radiation monitor system is credited in Fermi 2's
19		Emergency Response Plan due to its capacity to monitor and analyze potential
20		radioactive releases thus directly impacts recommendations provided to the state for
21		instituting emergency actions for the public in the event of an emergency. The
22		radiation monitor system will be replaced in phases throughout the bridge and test
23		period and is expected to be completed in 2025. The replacement of this radiation
24		monitor system is necessary to address aging and obsolescence, reduce the resource
25		and dose impact of compensatory sampling, and improve regulatory margins;

1 2 unexpected or unrecoverable loss of this radiation monitor system could result in NRC enforcement action.

3

4 Q69. Can you discuss the expenditures and rationale for the Fire Header Restoration 5 project shown on line 17 of Exhibit A-12, Schedule B5.3, page 4?

6 A69. The Fire Header Restoration project capital expenditures for the historical test year, 7 projected bridge forecast period and projected test period are \$0.8 million, \$4.0 8 million, and \$0.0 million respectively, extend beyond the projected test period, 9 address natural aging of the Fermi 2 fire header piping, and support the necessary 10 replacement of the Fermi 2 fire header piping. The Fermi 2 fire header piping is 11 approximately 5000' of underground "ring header" comprised of 12" unlined, 12 ductile iron pipe that routes around the Fermi 2 Power Plant and a separate 6" header 13 for the station blackout diesels. The purpose of Fermi 2 fire header is to distribute 14 firefighting water from the normal or alternate sources of water to the scene of a 15 postulated fire; with fire being one of the most consequential events at a nuclear 16 power plant, unplanned or unrecoverable loss of the fire header piping would 17 challenge plant operator's ability to safely operate the Fermi 2 plant.

18

19 Q70. Why is it necessary to replace the Fermi 2 fire header?

A70. Normal aging. The fire header pipe is original to plant construction and is
approaching fifty years of in-service time. As a fire header, the piping is exposed to
raw lake water which degrades the interior surfaces of the pipe, causing leaks and
loss of water pressure. The existing fire header pipe would not support safe and
reliable operations through Fermi 2's current operating life ending in 2045. DTE
Electric is taking the reasonable and prudent approach to replace the fire header pipe

Line

<u>No.</u>

1 2 over time and in stages based on priorities derived from inspection and testing; this also allows for minimal fire header outage time and minimal operational compensatory measures to protect the plant while replacement is occurring.

4

3

5 Q71. Can you discuss the expenditures and rationale for the Fire Detection System

6 **Replacement project shown on line 24 of Exhibit A-12, Schedule B5.3, page 4?** 7 A71. The Fire Detection System Replacement project capital expenditures for the 8 historical test year, projected bridge forecast period and projected test period are 9 \$0.0 million, \$2.3 million, and \$1.3 million respectively, extend beyond the 10 projected test period, address obsolescence of the Fermi 2 fire detection system, and support the necessary replacement of the Fermi 2 fire detection system. The Fermi 11 12 2 fire detection system consists of detection and annunciation systems. The purpose 13 of the Fermi 2 fire detection system is to detect fire and signal fire alarms, and is 14 designed to supplement Fermi 2's other fire safeguards such as design, procedures 15 and behaviors; with fire being one of the most consequential events at a nuclear 16 power plant, unplanned or unrecoverable loss of the fire detection system would 17 challenge plant operator's ability to safely operate the Fermi 2 plant.

18

Q72. Can you discuss the expenditures and rationale for the Reactor Recirculation Motor-Generator (RRMG) Replacements project shown on line 26 of Exhibit A-12, Schedule B5.3, page 4?

A72. The Reactor Recirculation Motor-Generator (RRMG) replacement project capital
 expenditures for the historical test year, projected bridge forecast period and
 projected test period are \$0.0 million, \$0.0 million, and \$6.2 million respectively,
 extend beyond the projected test period, address aging of the two Fermi 2 RRMG

sets, and support the necessary replacement of the Fermi 2 RRMGs. The existing
 Fermi 2 RRMGs consist of an RRMG motor, fluid coupler, oil system, generator
 and scoop tube positioner. The purpose of the Fermi 2 RRMG sets is to provide
 variable power to the Fermi Reactor Recirculation System (RRS) pump motors, one
 RRMG set controls one RRS pump motor.

6

7 Q73. Why is it necessary to replace the Fermi 2 RRMG sets?

8 A73. Primarily aging. The RRMG motor rotors, in particular have been in service since 9 plant start up in the 1980s and have increasing risk of developing shorts as in-service time extends past 30 years. The Fermi 2 RRMG sets use complex mechanical 10 11 interactions to vary voltage to the RRS motors, and though this system had wide 12 spread usage when plants similar to Fermi 2 were built, the vast majority of US 13 Boiling Water Reactors (BWRs) have replaced the mechanical RRMG sets with 14 solid-state devices known as Variable Frequency Drives (VFDs), also known as 15 Adjustable Speed Drives (ASDs); these VFDs are mechanically simpler than 16 RRMGs, have developed a history of reliable operation, and use significantly less 17 house power to operate. DTE Electric is projecting to replace the Fermi 2 RRMG 18 sets in Refueling Outage 24 (Spring 2028).

19

20 Q74. Can you discuss the expenditures and rationale for the Sanitary System 21 replacement project shown on line 28 of Exhibit A-12, Schedule B5.3, page 4?

A74. The Sanitary System replacement project capital expenditures for the historical test
 year, projected bridge forecast period and projected test period are \$0.0 million, \$0.0
 million, and \$6.5 million respectively, extend beyond the projected test period,
 address aging and undersized piping, and support the necessary replacement of the

1		Fermi sanitary system. The sanitary wastewater system is designed to dispose of
2		nonradioactive plant sewage liquid waste in accordance with state and local
3		regulations and consists of piping and a pumping station. The current pump house,
4		which was originally built to support Fermi 1 operations, consists of a septic tank,
5		settling Tank, wet well, and pumps to transfer sewage around the facility and to
6		discharge out the forced main; however, the pumps are not designed to pump solid
7		waste and the concrete structure is in need of repair or replacement - due to the
8		location, a failure of the structure risks a release into Lake Erie. The sanitary system
9		project replaces this antiquated sanitary wastewater disposal with a more modern
10		two pump system capable of safely disposing of Fermi 2's sanitary wastewater.
11		
12	Q75.	Do any of the projects listed in Exhibit A-12, Schedule B5.3, pages 2-4 contain
13		contingency amounts?
14	A75.	No. The capital expenditures as shown in Exhibit A-12, Schedule B5.3, pages 2-4
15		do not include contingencies. The capital expenditures shown in Exhibit A-12,
16		Schedule B5.3, pages 2-4 are good faith estimates (without contingencies) based on
17		relevant data available using reasonable and prudent forecasting methods.
18		
19	Q76.	Does the absence of contingency amounts in Exhibit A-12, Schedule B5.3, pages
20		2-4 impact individual project expenditure variances from DTE Electric rate
21		case to rate case?
22	A76.	Certainly. The need for and use of contingency amounts at the individual project
23		level and at the portfolio level is well understood in project management and
24		portfolio management. Because DTE Electric's Nuclear Generation projects don't
25		include contingencies, some known scope with highly uncertain costs have

1	projected expenditures excluded from exhibits (such as the Security Computer
2	Replacement project) until such time the expenditures are capable of being
3	identified with reasonable specificity to include in the exhibit; therefore, projects
4	expenditures will necessarily change as less defined scope and previously excluded
5	expenditures transition into better identified and included expenditures. This is a
6	reasonable and prudent approach in light of the expectation to exclude contingency
7	amounts from DTE Electric's rate case exhibits and subsequent revenue
8	requirements.
9	
10	Q77. How does the Nuclear Generation organization manage its capital expenditures

11

without contingencies?

12 A77. Nuclear Generation manages total capital expenditures for the period and expects 13 that capital expenditures in total will be incurred as projected. In general, Nuclear 14 Generation maintains a prioritized list of projects such that as project forecasts are 15 over or under expected amounts, Nuclear Generation uses this prioritized list 16 consistent with the key principles I described earlier to manage the Nuclear 17 Generation portfolio of projects.

18

19 Nuclear Fuel Capital Expenditures

20 Q78. Can you explain Total Nuclear Fuel summarized on line 10 of Exhibit A-12,

- 21 Schedule B5.3, page 1?
- A78. Yes. Total Nuclear Fuel includes those capital expenditures for the various
 components of the nuclear fuel cycle: (1) Uranium, (2) Conversion, (3) Enrichment
 and (4) Fabrication.
- 25

1	Uranium refers to the costs associated with mining and milling uranium. Natural
2	uranium is obtained from the exploration and mining of uranium ore. Milling is the
3	mechanical and chemical process of extracting uranium from the mined ore in the
4	form of U3O8, commonly referred to as yellowcake. The U3O8 is the feed material
5	for the conversion process.
6	
7	Conversion refers to the costs associated with chemically converting U3O8 into
8	UF6, uranium hexafluoride. The UF6 is the gaseous compound used as a feed in the
9	enrichment process.
10	
11	Enrichment refers to the costs to enrich the uranium from a natural 0.7% U235
12	content to a 4% to 5% U235 content required for light water reactor fuel. The
13	enriched UF6 is used as a feed in the fabrication process.
14	
15	Fabrication refers to the chemical conversion of the enriched UF6 to UO2 (uranium
16	dioxide) powder which is then pressed and sintered into hard ceramic fuel pellets
17	that are loaded into long, narrow zirconium alloy tubes called fuel rods; fuel rods
18	are then assembled into fuel bundles using spacers and end fittings to hold the fuel
19	rods together. The Fermi 2 reactor core requires 764 of these fuel bundles to operate.
20	
21	The amount of fuel purchased is determined by the design of the fuel and by the
22	expected generation during the life of the fuel. Nuclear fuel capital expenditures
23	were developed on the basis that Fermi 2 transitioned from its 18-month operating
24	cycle to the 24-month operating cycle following RF21 in winter/spring of 2022,
25	which occurred.

1		The accounting of nuclear fuel expenditures completes with the delivery of the
2		fabricated nuclear fuel to the Fermi 2 Power Plant. Expenditures arising from on-
3		site activities such as new fuel receipt, new fuel storage and insertion of the new
4		nuclear fuel into the reactor core are recorded in the appropriate expense account.
5		
6	Q79.	Can you explain the Total Nuclear Fuel expenditures as shown on Exhibit A-
7		12, Schedule B5.3, page 1, line 10?
8	A79.	Yes. The Total Nuclear Fuel capital expenditures for the historical test year,
9		projected bridge forecast period and projected test period are \$3.3 million, \$112.0
10		million and \$135.1 million respectively and are consistent with Fermi 2's
11		projections in the Company's 2024 PSCR Plan in Case No. U-21425.
12		
12 13	Q80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year?
12 13 14	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2
12 13 14 15	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed
12 13 14 15 16	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital
12 13 14 15 16 17	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore,
12 13 14 15 16 17 18	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow
12 13 14 15 16 17 18 19	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow a repeating two-year pattern.
12 13 14 15 16 17 18 19 20	Q80. A80.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow a repeating two-year pattern.
12 13 14 15 16 17 18 19 20 21	Q80. A80. Q81.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow a repeating two-year pattern. How would you characterize the level of expenditures for Fermi 2's Total
 12 13 14 15 16 17 18 19 20 21 22 	Q80. A80. Q81.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow a repeating two-year pattern. How would you characterize the level of expenditures for Fermi 2's Total Nuclear Fuel?
 12 13 14 15 16 17 18 19 20 21 22 23 	Q80. A80. Q81. A81.	Can you explain why Total Nuclear Fuel expenditures vary from year-to-year? Yes. Total Nuclear Fuel expenditures vary from year-to-year because Fermi 2 operates on a 24-month fuel cycle and fuel expenditures occur at relatively fixed points in time relative to that 24-month fuel cycle (most nuclear fuel capital expenditures occur approximately six months prior to a refueling outage); therefore, Total Nuclear Fuel capital expenditures can be expected to vary each year but follow a repeating two-year pattern. How would you characterize the level of expenditures for Fermi 2's Total Nuclear Fuel? Fermi 2's fuel expenditures are reasonable and prudent. I expect fuel expenditures

Line <u>No.</u>		J. C. DAVIS U-21534
1		conversion, enrichment and fabrication through the projected test period ending
2		December 31, 2025.
3		
4	<u>AFU</u>	DC Forecast
5	Q82.	Can you explain the Allowance for Funds Used During Construction (AFUDC)
6		as shown in Exhibit A-12, Schedule B5.3, page 5?
7	A82.	Nuclear Generation capital expenditures include an Allowance for Funds Used
8		During Construction (AFUDC) for eligible projects that are in Construction Work
9		in Progress (CWIP); eligible projects are those projects greater than \$50,000 and
10		lasting more than six months. The actual historical period Total AFUDC - Nuclear
11		Production Plant was \$10.8 million as shown in Exhibit A-12, Schedule B5.3, page
12		5, line 33, column (b). The forecasted Total AFUDC – Nuclear Production Plant for
13		the projected test period is \$13.1 million as shown in Exhibit A-12, Schedule B5.3,
14		page 5, line 33, column (c).
15		
16	Q83.	How did you forecast the AFUDC as shown in Exhibit A-12, Schedule B5.3,
17		page 5?
18	A83.	The Nuclear Production Plant - Routine Expenditures AFUDC forecast uses a
19		historical trend to estimate AFUDC as the mix of eligible projects is fairly consistent
20		year-to-year. The Nuclear Production Plant - Project Specific AFUDC forecast
21		explicitly calculates AFUDC for eligible projects using project-specific CWIP
22		balances multiplied by the AFUDC rate where the AFUDC rate is the authorized
23		cost of capital rate of 5.561% consistent with the December 1, 2023 Order in Case
24		No. U-21297.
25		

Line <u>No.</u>		J. C. DAVIS U-21534
1		Removal Costs, Plant in Service and CWIP Forecast
2	Q84.	What is provided on the schedule entitled Removal Costs, Plant in Service and
3		CWIP schedule on Exhibit A-12, Schedule B5.3, page 6?
4	A84.	This schedule provides a breakdown of plant activities which are used by Witness
5		Uzenski to forecast Plant in Service, Accumulated Depreciation and CWIP on the
6		projected balance sheet.
7		
8		Capital expenditures consistent with page 1 are summarized in columns (c) through
9		(f). Routine and Non-Routine projects are sub-totaled on Lines 1 and 31
10		respectively, while Fermi 2 License Renewal has been identified separately on line
11		33 because this is recorded to Plant Held for Future Use. Column (b) includes a
12		corresponding in-service assumption: "Annual" is indicated for both routine and
13		non-routine spend because these projects are generally unitized within the year of
14		spend.
15		
16		Column (g) includes an estimated percentage of removal costs that are included
17		within the capital expenditures. Removal costs, as discussed by Witness Uzenski,
18		are charged to Accumulated Depreciation rather than Plant/ CWIP and are therefore
19		not depreciable. Removal cost of 15% based on historical trend of removals as a
20		component of capital expenditures is applied to Routine and Non-Routine project
21		expenditures.
22		

23 Column (h) through (j) reflect calculated removal costs based on projected Capital 24 Expenditures in columns (d) through (f) multiplied by the removal cost percentage in column (g). The remaining Capital Expenditures will appear in Plant in Service 25

		J. C. DAVIS
L1ne <u>No.</u>		U-21534
1		columns (k) through (m) since the in-service assumption is "Annual." The CWIP
2		columns (n) through (p) show CWIP activity.
3		
4	<u>2022</u>	– 2025 Capital Projects Summary
5	Q85.	What is your opinion regarding the reasonableness of the forecasted capital
6		expenditures for Nuclear Generation?
7	A85.	I believe the forecasted capital expenditures for Nuclear Generation are reasonable
8		and prudent. I believe the forecast as depicted by line 11 of Exhibit A-12, Schedule
9		B5.3, page 1, accurately represents the capital expenditures that can reasonably be
10		expected to continue operation of nuclear assets of similar age and vintage. My
11		summation of projects reflects DTE Electric's commitment to ensure the safe and
12		reliable operation of Fermi 2 through its current operating license expiration in 2045.
13		As I have expressed previously, these capital expenditures are prudent and
14		reasonable given the regulations, goals and conditions under which Fermi 2
15		operates.
16		
17	Nucle	ear Generation O&M Expense
18	Q86.	Can you provide an outline of your Nuclear Generation O&M discussion?
19	A86.	Yes. My testimony will begin with the O&M Expenses Overview and then discuss
20		and support the additional details regarding:
21		Rate Case Adjustments
22		Adjusted Historical Test Period
23		Projected Adjustments
24		

1 <u>O&M Expenses Overview</u>

2 Q87. Can you provide an overview of the Nuclear Generation O&M expenses 3 supported by your testimony?

A87. Exhibit A-13, Schedule C5.3, page 1, line 24 from left to right depicts the O&M
expenses for the 12-month historical test period ended December 31, 2022,
adjustments to the historical test period, and then the forecasted O&M expenses for
the 12-month projected test period ending December 31, 2025.

8

Line

No.

9 The actual O&M expenses by FERC account for the 12-month historical test period 10 ended December 31, 2022 were \$220.3 million as shown in column (c). Rate case 11 adjustments are made in column (d) to reduce O&M by \$28.6 million to account for 12 the Nuclear Surcharge, in column (e) to reclassify Project Evaluation Review 13 Committee (PERC) nuclear O&M project expenditures, and zero other historical 14 adjustment in column (f). These rate case adjustments result in \$191.8 million of 15 adjusted O&M for the 2022 historical test period as shown in column (g).

16

Projected adjustments of \$5.1 million, \$4.8 million and \$4.9 million in columns (h),
(i) and (j) respectively account for inflation. The \$35.9 million decrease in column
(k) is subtracted to account for outage accrual adjustments and O&M is reduced by
\$11.4 million in column (l) to account for the total PERC expense in the forecasted
test period as supported by calculations performed by Company Witness Uzenski.
These projected adjustments yield a total change of \$32.4 million as shown in
column (m).

24

U-21534 , the forecasted O&M expenses for the 12-month .4 million as shown in column (n). lear Power Generation O&M expenses are you
, the forecasted O&M expenses for the 12-month .4 million as shown in column (n). lear Power Generation O&M expenses are you
.4 million as shown in column (n). lear Power Generation O&M expenses are you
lear Power Generation O&M expenses are you
lear Power Generation O&M expenses are you
otal Nuclear Power Generation O&M expenses of
Exhibit A-13, Schedule C5.3, line 24, column (n) as
for the Rate Case Adjustments in column (d) of
6, page 1?
protection costs were removed from base rates and
rcharge as established in DTE Electric Case No. U-
ge reduction of \$28.6 million as summed on line 24,
requirement. The complete elimination of all financial
ear Surcharge are supported by Witness Uzenski.
for the Rate Case Adjustments in column (e) of
, page 1?
nent nets to zero as shown on line 24, column (e). This
o make explicit the \$15.0 million PERC Base Expense
e) and the \$16.3 million of PERC Regulatory Asset
22, column (e) are not inflated in the projected

		J. C. DAVIS
Line <u>No.</u>		U-21534
1		adjustments. I will explain the PERC Regulatory Asset mechanism later in my
2		testimony.
3		
4	<u>Adju</u>	sted Historical Test Period
5	Q91.	Can you explain the components that constitute the actual Total Nuclear Power
6		Generation O&M expenses for adjusted historical test period in line 24, column
7		(g) of Exhibit A-13, Schedule C5.3, page 1?
8	A91.	Total Nuclear Generation O&M of \$191.8 million consists of the Nuclear
9		Organization, PERC Base Expense, amortization of the PERC Regulatory Asset,
10		regulatory assessments and dues, and refueling outage expenses. I detail these
11		expenses for the 2022 historical period on page 2 of Exhibit A-13, Schedule C5.3.
12		
13	Q92.	What is the need for and basis of the "Nuclear Organization" expenses that are
14		included in the 2022 historic period for Operation and Maintenance Expenses
15		on Exhibit A-13, Schedule C5.3, page 2, line 1?
16	A92.	Nuclear Organization expenses are the baseline employee, services and material
17		expenses required to safely and reliably operate Fermi 2. The Nuclear Organization
18		expenses for the historical test period ended December 31, 2022 were \$94.3 million.
19		
20	Q93.	What is the need for and basis for the "PERC Base Expense" expenses that are
21		included in the 2022 historic period for Operation and Maintenance Expenses
22		on Exhibit A-13, Schedule C5.3, page 2, line 2?
23	A93.	As explained and supported by Witness Uzenski, the Commission Order in Case
24		No. U-18014 approved an annual base level of PERC expenses of \$4.9 million for
25		nuclear O&M projects and the Commission Order in Case No. U-20561 increased

		J. C. DAVIS
Line <u>No.</u>		U-21534
1		the approved annual base level of PERC expenses to \$15.0 million; the PERC Base
2		Expense of \$15.0 million depicted on line 2 recognizes those approvals.
3		
4	Q94.	What is the need for and basis for the "Reg Asset Amortization - PERC"
5		expenses that are included in the 2022 historic period for Operation and
6		Maintenance Expenses on Exhibit A-13, Schedule C5.3, page 2, line 3?
7	A94.	As explained and supported by Witness Uzenski, the Commission Order in Case
8		No. U-18014 approved a regulatory asset for annual PERC projects O&M
9		expenditures that exceed the annual base level of PERC expenses of \$4.9 million
10		for nuclear O&M projects. In Case No. U-20561, the Commission Order updated
11		the approved regulatory asset for annual PERC projects O&M expenditures that
12		exceed the annual base level of PERC expenses of \$15.0 million for nuclear O&M
13		projects. The Order in Case No. U-18014 established the amortization period of this
14		regulatory asset as five years. Consistent with that Order, the \$16.3 million depicted
15		on line 3 is the amount of the PERC Regulatory Asset amortized in 2022.
16		
17	Q95.	What is the need for and basis for the "Regulatory Assessments and Dues"
18		expenses that are included in the 2022 historic period for Operation and
19		Maintenance Expenses on Exhibit A-13, Schedule C5.3, page 2, line 4?
20	A95.	A majority of these assessments and dues are regulatory driven, such as those
21		assessments and dues required by the NRC to cover oversight of the plant. In
22		addition, assessments and dues are associated with licensing requirements including
23		the Emergency Response Organization (ERO) and various industry groups.
24		

1		Industry groups include the Institute of Nuclear Power Operations (INPO), which
2		assists utilities in operating nuclear plants to the highest safety standards, the
3		Nuclear Energy Institute (NEI), which assists in common issues impacting the
4		nuclear industry, as well as the Electric Power Research Institute (EPRI) and the
5		General Electric Boiling Water Reactor Owners' Group, both of which sponsor
6		research that is used by nuclear plants to operate more safely and economically.
7		
8		The ERO supports the Fermi 2 Emergency Plan which is a license requirement
9		necessary to ensure the health and safety of the public during emergency response
10		events. The ERO funds federal, state and local county emergency facilities in
11		support of the Fermi 2 Emergency Plan.
12		
12	000	
13	Q96.	Which assessments and dues are non-discretionary (i.e. mandated)?
13	Q96. A96.	NRC, INPO and ERO assessments and dues are non-discretionary (i.e. mandated)?
13 14 15	Q96. A96.	NRC, INPO and ERO assessments and dues are non-discretionary (i.e. mandated)?
13 14 15 16	Q96. A96. Q97.	Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues?
13 14 15 16 17	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such
13 14 15 16 17 18	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular,
13 14 15 16 17 18 19	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of
13 14 15 16 17 18 19 20	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of products and services to ensure nuclear asset owners benefit as a whole from shared
 13 14 15 16 17 18 19 20 21 	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of products and services to ensure nuclear asset owners benefit as a whole from shared information. These products and services would be unaffordable without group
 13 14 15 16 17 18 19 20 21 22 	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of products and services to ensure nuclear asset owners benefit as a whole from shared information. These products and services would be unaffordable without group participation and funding. The role provided by NEI is valuable to plant owners and
 13 14 15 16 17 18 19 20 21 22 23 	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of products and services to ensure nuclear asset owners benefit as a whole from shared information. These products and services would be unaffordable without group participation and funding. The role provided by NEI is valuable to plant owners and operators in helping to shape important industry issues and regulation through a
 13 14 15 16 17 18 19 20 21 22 23 24 	Q96. A96. Q97. A97.	 Which assessments and dues are non-discretionary (i.e. mandated)? NRC, INPO and ERO assessments and dues are non-discretionary. Why does the Company pay the discretionary assessments and dues? Although not specifically mandated, voluntary participation with organizations such as EPRI and NEI are critical within a nuclear business model. In particular, organizations like EPRI that support research and development include sharing of products and services to ensure nuclear asset owners benefit as a whole from shared information. These products and services would be unaffordable without group participation and funding. The role provided by NEI is valuable to plant owners and operators in helping to shape important industry issues and regulation through a coordinated and solidified approach. The nuclear industry clearly recognizes that

		J. C. DAVIS
Line <u>No.</u>		U-21534
1		a result, this industry believes in significant group participation and knowledge
2		sharing to help preclude such an event.
3		
4	Q98.	What are some specific benefits that EPRI provides DTE Electric and
5		contributes to the safe, reliable, and economic operation of the Fermi 2 Power
6		Plant?
7	A98.	EPRI provides DTE Electric with the benefit of access to state-of-the-art industry
8		research in the functional areas such as nuclear fuel reliability, reactor vessel and
9		internals aging management, value-based maintenance, training, nuclear risk and
10		safety management, and radiation safety.
11		
12		To further provide an example of a specific benefit, EPRI membership is an integral
13		part of DTE Electric's (and indeed the nuclear industry's) probabilistic risk
14		assessment (PSA) program. The PSA engineer qualification at Fermi 2 requires
15		learning the EPRI PSA courses and PSA tools used by DTE Electric such as MAAP
16		5, GOTHIC and PHOENIX, which are all developed and supported by EPRI.
17		Without EPRI membership, DTE Electric would have to develop duplicative PSA
18		education courses and PSA tools which would not be reasonable nor prudent.
19		
20	Q99.	What are some specific benefits that NEI provides DTE Electric and
21		contributes to the safe, reliable, and economic operation of the Fermi 2 Power
22		Plant?
23	A99.	NEI provides DTE Electric (as an NEI member) access to its Personnel Access
24		Database System (PADS). NEI membership is required to access PADS. PADS is a
25		database maintained and administered by NEI and contains information provided by

Line No.

> 1 PADS participants concerning individuals who request access to a commercial 2 nuclear facility; this information includes dates that an individual was granted or 3 denied access, an individual's training and radiological dosage records. NRC 4 regulations do not require the use of PADS but PADS does offer an efficient method 5 for commercial nuclear plant licensees to comply with NRC regulations at 10 CFR 6 73.56 and to share information about individuals who were denied access or have 7 had their access terminated per NRC regulations. Without access to PADS, DTE 8 Electric would have to create a duplicative system of verifying an individual's plant 9 access history – which would not be reasonable nor prudent.

10

11 NEI also provides DTE Electric with resources known as the Composite Adversary 12 Force (CAF) to support NEI Force-on-Force security inspections. NEI membership 13 is required to use the CAF. Since 2004, the NRC has relied on the NEI CAF to 14 provide a credible, well-trained and consistent mock adversary in Force-on-Force 15 inspections; Force-on-Force inspections assess a nuclear power plant's physical protection measures to defend against a "design-basis treat." To avoid conflicts of 16 17 interest, the NRC requires a clear separation of functions between the mock 18 adversary and the plant security forces. NRC regulations do not require the use of 19 the NEI CAF but the NEI CAF does provide NEI members with an efficient means 20 for commercial nuclear licensees to conduct NRC Force-on-Force inspections. 21 Without NEI CAF, DTE Electric would be required to establish a duplicative mock 22 adversary force using independent mock adversaries that met NRC standards -23 which would not be reasonable nor prudent.

24

1 Q100. How does NEI support safer nuclear operations through collective nuclear 2 industry action?

A100. NEI has supported a collective industry response to the events concerning the
Fukushima Dai-ichi – in particular, NEI led the nuclear industry's adoption of the
Diverse and Flexible Coping Strategies (FLEX) which increases each plant's
defense-in-depth for beyond-design-basis scenarios. NEI has also led industry
efforts to strengthen cybersecurity regulations. Certainly, these initiatives to make
nuclear generators safer are in the best interests of our communities and DTE
Electric's association with NEI is reasonable and prudent.

10

Q101. Does DTE Electric use other discretionary memberships to benefit our customers and the communities the Company serves?

13 A101. Yes. An example of another discretionary membership is NUPIC (Nuclear 14 Procurement Issues Corporation) which is a cooperative program for performing 15 and sharing audits of suppliers providing DTE Electric (and the nuclear industry) 16 nuclear-quality parts. NRC regulations (generally, Appendix B to Part 50) require 17 NRC licensees such as DTE Electric to audit its suppliers of nuclear-quality parts 18 and maintain an Approved Suppliers List (ASL) – the number of such suppliers is 19 quite large, so NUPIC allows members to use the audits of other members to 20 maintain the suppliers on each licensee's ASL. Without NUPIC, DTE Electric 21 would be required to audit every supplier listed on its ASL by itself which would 22 not be reasonable nor prudent.

23

Q102. What is the need for and basis for "Total Refueling Outage" expenses for the
2022 historical period on Exhibit A-13, Schedule C5.3, page 2, line 10?

1	A102. As discussed earlier in my testimony, the Fermi 2 plant operates on an 24-month
2	refueling cycle such that every 24 months Fermi 2 would shut down to refuel the
3	reactor. The "Total Refueling Outage" expenses are those costs necessary to (1)
4	refuel the Fermi 2 reactor and (2) perform offline maintenance to ensure Fermi 2
5	can operate safely and reliably for the next operating cycle.
6	
7	The "Total Refueling Outage" expense consists of the actual refueling outage costs
8	(line 7), the refueling outage accrual (line 8) and the refueling outage accrual
9	reversals (line 9) for the 2022 historical period. Line 10 nets these three components
10	and represents an accounting practice of levelizing incremental refueling expenses
11	by accruing the anticipated refueling expenses over the term of an operating cycle.
12	
13	Q103. Why does DTE Electric levelize its incremental refueling outage expenses?
13 14	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the
13 14 15	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE
13 14 15 16	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the
 13 14 15 16 17 	 Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections
 13 14 15 16 17 18 	 Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's
 13 14 15 16 17 18 19 	 Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's projections, then the Company would be presenting an unnecessarily high cost of
 13 14 15 16 17 18 19 20 	 Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's projections, then the Company would be presenting an unnecessarily high cost of providing Fermi 2 generation over the period the rates are in effect. The inverse is
 13 14 15 16 17 18 19 20 21 	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's projections, then the Company would be presenting an unnecessarily high cost of providing Fermi 2 generation over the period the rates are in effect. The inverse is also true if the Company used a non-refueling outage year projection for the same
 13 14 15 16 17 18 19 20 21 22 	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's projections, then the Company would be presenting an unnecessarily high cost of providing Fermi 2 generation over the period the rates are in effect. The inverse is also true if the Company used a non-refueling outage year projection for the same purpose. This is consistent with the treatment in prior cases where the Commission
 13 14 15 16 17 18 19 20 21 22 23 	Q103. Why does DTE Electric levelize its incremental refueling outage expenses? A103. DTE Electric levelizes its incremental refueling outage expenses so that the difference in expense between outage and non-outage years does not burden DTE Electric customers with large rate fluctuations or create financial swings for the Company. For example, if the Company bases the rate request on the projections for a refueling outage year and all the expenses of that outage appear in that year's projections, then the Company would be presenting an unnecessarily high cost of providing Fermi 2 generation over the period the rates are in effect. The inverse is also true if the Company used a non-refueling outage year projection for the same purpose. This is consistent with the treatment in prior cases where the Commission has allowed levelized refueling outage expenses in setting rates.

1	Q104. What is the basis for the "Refuel Outage" expense at \$73.1 million for the 2022
2	historical period shown on Exhibit A-13, Schedule C5.3, page 2, line 7?
3	A104. This is the actual refuel outage expenditures incurred in the 2022 historical period
4	for RF21.
5	
6	Q105. How does DTE Electric manage incremental refueling outage expenses?
7	A105. The Company manages incremental expenses through structured planning and
8	preparation that is consistent with industry standards and processes. We
9	implemented rigorous financial controls that supported daily management of
10	resources during the execution phase of the refueling outage. This management of
11	resources includes daily reviews of scope completion, schedule and budget. As work
12	completes, contracted resources exit promptly from the site to ensure that costs are
13	controlled.
14	
15	Q106. What is the basis for the "Refuel Outage Accrual" expenses at \$18.4 million for
16	the 2022 historical period shown on Exhibit A-13, Schedule C5.3, page 2, line
17	8?
18	A106. This is the actual amount accrued in the historical period for RF21 and RF22.
19	
20	Q107. How does DTE Electric determine the value of the Refuel Outage Accrual?
21	A107. As the purpose of the Refuel Outage Accrual is to levelize the costs of refueling
22	outages over the appropriate time horizon, DTE Electric developed a model outage
23	template that defines a routine baseline refueling outage in terms of timing, and
24	incremental O&M expenditures for labor, services, materials and other outage costs.
25	It is important to note that the Refuel Outage Accrual is for those incremental O&M

1	costs associated with a refueling outage; routine expenses such as DTE Electric
2	Nuclear Generation strait-time labor, structural overtime and year-round supplier
3	services that are incurred regardless of the outage are "Nuclear Organization."
4	
5	As I will discuss later in my testimony, incremental outage costs that are generally
6	not associated with the baseline outage activities or cause significant variation in
7	outage costs from outage-to-outage are assigned to PERC O&M.
8	
9	Q108. What is the basis for the "Refuel Outage Reversal" of \$38.0 million for the 2022
10	historical period shown on Exhibit A-13, Schedule C5.3, page 2, line 9?
11	A108. This is the actual amount of outage accrual that had been accrued in advance for
12	RF21 and credited to O&M in the historical test period.
13	
14	Projected Adjustments
15	Q109. Can you explain the basis for the inflation adjustments in columns (h), (i) and
16	(j) on line 24 of Exhibit A-13, Schedule C5.3, page 1?
17	A109. The labor and material prorated inflation adjustment rates of 3.2% for 2023, 2.9%
18	for 2024 and 2.9% for 2025 are supported by the testimony of Witness Uzenski.
19	Nuclear Generation applied these forecasted inflation rates to the adjusted historical
20	test period costs in column (g).
21	
22	Q110. Can you explain the basis for the Outage Accrual adjustment in column (k) on
23	line 24 of Exhibit A-13, Schedule C5.3, page 1?
24	A110. The Outage Accrual adjustment is to normalize the outage accrual for the projected
25	test period to approximately \$22.5 million. This Outage Accrual adjustment reflects

Line <u>No.</u>	J. C. DAVIS U-21534
1	our commitment to improving refueling outage performance and reducing future
2	outage O&M expenditures.
3	
4	Q111. What duration have you projected for RF22?
5	A111. The 2024 PSCR Plan (Case No. U-21425) projected an outage duration of 45 days
6	for RF22 (projected for spring 2024).
7	
8	Q112. Can you explain the basis for the PERC Amortization adjustment in column
9	(l) on line 24 of Exhibit A-13, Schedule C5.3, page 1?
10	A112. As explained and supported by Witness Uzenski, the Commission Order in Case
11	No. U-18014 not only approved an annual base level of PERC expenses for nuclear
12	O&M projects, but also provided deferral and amortization treatment for any
13	expenses over or under the base amount. The PERC Base expense was changed by
14	\$10.1 million from \$4.9 million per year to \$15.0 million per year in the May 8,
15	2020 Order in Case No. U-20561.
16	
17	The PERC Amortization reduction of \$11.4 million in column (1) on line 24 consists
18	of the \$0.0 million change in the approved annual PERC Base Expense as shown in
19	column (l) on line 21 and a forecasted reduction of \$11.4 million in the amortization
20	of the PERC Regulatory Asset as shown in column (l) on line 22.
21	
22	The Total PERC Expense for the projected test period is forecasted at \$19.9 million
23	as shown in column (n) on line 23. The derivation of this Total PERC Expense is
24	shown on Exhibit A-13, Schedule C5.17 and is sponsored by Witness Uzenski; I

Line <u>No.</u>	J. C. DAVIS U-21534
1	detail the projects comprising line 2 of Exhibit A-13, Schedule C5.17 in Exhibit A-
2	13, Schedule C5.16, page 1.
3	
4	Q113. Can you explain the Total PERC O&M Expenditures detailed in Exhibit A-13,
5	Schedule C5.16, page 1?
6	A113. This exhibit shows the by-project PERC O&M expenditures for the 2022 historical
7	period and projected Calendar Years 2023, 2024, and 2025 planned expenditures
8	totaling \$18.1 million, \$8.9 million, \$22.6 million and \$8.6 million respectively.
9	
10	Q114. Can you explain how DTE Electric determines which projects are included in
11	PERC O&M as detailed in Exhibit A-13. Schedule C5.16, page 1?
12	A114. Exhibit A-13, Schedule C5.16 is the updated list of PERC O&M projects. DTE
13	Electric has provided similar updated exhibits in each of the past rate cases since
14	Case U-18014 established the PERC O&M regulatory asset construct. PERC O&M
15	projects expenditures are those incremental expenditures associated with Nuclear
16	Generation O&M projects. I will provide a rationale for select project's inclusion in
17	the PERC O&M later in my testimony.
18	
19	Q115. How do the Total PERC O&M Expenditures on line 30 of Exhibit A-13,
20	Schedule C5.16, page 1 relate to Exhibit A-13, Schedule C5.17?
21	A115. As an example, the projected total PERC O&M expenditures of approximately \$8.9
22	million for Calendar Year 2023 shown in Exhibit A-13, Schedule C5.16, page 1,
23	line 30, column (c) flows to Exhibit A-13, Schedule C5.17, page 1, line 2, column
24	(d).
25	

1	Q116. How does the PERC amortization expense on line 15 of Exhibit A-13, Schedule
2	C5.17, page 1 relate to Exhibit A-13, Schedule C5.3, page 1?
3	A116. Exhibit A-13, Schedule C5.17 shows the calculation for PERC amortization that
4	was derived from Exhibit A-13, Schedule C5.16, Page 1. Exhibit A-13, Schedule
5	C5.17, page 1, line 15, column (g) shows \$4.9 million as the calculated amortized
6	portion of PERC O&M for the 12-month projected test period ending December 31,
7	2025. This \$4.9 million is used in Exhibit A-13, Schedule C5.3, page 1, line 22,
8	column (n).
9	
10	Q117. What was the rationale for the Refueling Outage Planning, Readiness and
11	Demobilization project shown on line 1 of Schedule A-13, Schedule C5.16, page
12	1?
13	A117. As I discussed earlier in my direct testimony, DTE Electric begins planning for the
14	upcoming refueling outage at approximately T-24 months prior to the refueling
15	outage. Expenditures for refueling outage planning, scheduling and readiness follow
16	a 24-month pattern and as such, do not lend themselves to a levelized expenditure
17	schedule; the amount of expenditures can also vary from outage-to-outage
18	depending on refueling outage scope. Planning activities include work package
19	planning, work order reviews and resource planning; scheduling includes work plan
20	integration and resource levelization efforts; readiness includes physical tasks such
21	as staging parts, building some scaffolding that can be done prior to the refueling
22	outage, readying temporary power carts, and setting up temporary infrastructure
23	needs such as additional computers and housing trailers. The Refuel Outage
24	Planning line item was included in the original PERC O&M discussion in Case No.

Line <u>No.</u>	J. C. DAVIS U-21534
1	U-18014 and has been updated accordingly with each subsequent DTE Electric rate
2	case.
3	
4	Q118. What was the rationale for the Desludge - Torus project shown on line 2 of
5	Schedule A-13, Schedule C5.16, page 1?
6	A118. The torus is a water-filled donut-shaped containment structure designed to absorb
7	excess thermal energy and provide emergency water to the reactor core during a
8	postulated accident scenario. Each refueling outage specially-qualified divers de-
9	sludge the torus to minimize the amount of debris within the torus; this debris
10	normally accumulates over the course of the operating cycle. Once the torus has
11	been de-sludged the divers inspect and repair the submerged coatings of the torus
12	containment structure; the divers also inspect and replace pump suction strainers.
13	The Desludge – Torus project was first included in the PERC O&M exhibit in Case
14	No. U-20162 and has had updated project expenditures included in subsequent rate
15	case PERC O&M exhibits.
16	
17	Q119. What was the rationale for the Reactor Feed Pump Turbine (RFPT)
18	Inspections project shown on line 3 of Schedule A-13, Schedule C5.16, page 1?
19	A119. The Reactor Feed Pump Turbines (RFPTs) require a full tear-down inspection
20	approximately every ten years to satisfy loss control criteria. Fermi 2 has two RFPTs
21	(North and South). Each RFPT drives one Reactor Feed Pump (RFP) which in turn
22	supplies the driving force for reactor feedwater. DTE Electric completed the
23	inspection of the South RFPT in RF21 (2022) and projects to complete the North
24	RFPT inspection in RF22 (2024). The RFPT inspections were first included with

No. 1 the Case No. U-20836 PERC O&M Exhibit and has had updated project 2 expenditures with subsequent rate case PERC O&M exhibits. 3 4 Q120. What was the rationale for the Residual Heat Removal Heat Exchanger (RHR 5 HX) coating project shown on line 4 of Schedule A-13, Schedule C5.16, page 1? 6 A120. A requirement for the renewed Fermi 2 operating license is to perform inspections 7 of internal coatings of certain piping, piping components, heat exchangers and tanks 8 where the loss of the coating or lining could impact the ability of that equipment to 9 perform its function during the Fermi 2 Period of Extended Operations; the Fermi 2 10 Residual Heat Removal Heat Exchangers (RHR HX) have such internal coatings. 11 Fermi 2 has two RHR HXs ('A' and 'B'), both of which are nuclear-safety 12 equipment. Each RHR HX supports an independent and redundant division of 13 nuclear-safety equipment where the RHR HX transfers residual heat away from the 14 nuclear systems and to the Fermi 2 Ultimate Heat Sink during certain accident 15 scenarios. Previous inspections of the original RHR HX coatings had shown 16 evidence of degradation; therefore, to ensure the RHR HX coatings would support safe operations through 2045 DTE Electric is replacing the internal coatings of the 17 18 RHR HXs. DTE Electric completed the coating replacement of the RHR HX A in 19 RF21 and projects to complete the replacement of the RHR HX B coating in RF22. 20 The RHR HX coating replacements project was first included with the Case No. U-21 20836 PERC O&M Exhibit and has had updated project expenditures with 22 subsequent rate case PERC O&M exhibits.

23

- Q121. What was the rationale for the Hydraulic Control Unit (HCU) preventative
 maintenance project shown on line 5 of Schedule A-13, Schedule C5.16, page
 1?

4 A121. The Fermi 2 Hydraulic Control Units (HCUs) require a one-time preventative 5 maintenance (replacement of internal soft components such as diaphragms and 6 gaskets, filters as well as directional control valves) to ensure safe operations 7 through 2045. Fermi 2 has 185 HCUs – one for each control rod drive mechanism 8 (CRDM). The HCU controls hydraulics to the CRDM. DTE Electric has levelized 9 the HCU preventative maintenance over several outages and completed preventative 10 maintenance activities on 37 HCUs in RF21 and projects to complete preventative 11 maintenance activities on 34 HCUs in RF22. The HCU preventative maintenance 12 project was first included with the Case No. U-20162 PERC O&M Exhibit and has 13 had updated project expenditures with subsequent rate case PERC O&M exhibits.

14

Q122. What was the rationale for the Force-on-Force inspections (FOF) shown on line 6 of Schedule A-13, Schedule C5.16, page 1?

A122. Force-on-Force (FOF) inspections are NRC inspections and exercises that assess the 17 18 ability a nuclear licensee such as DTE Electric to defend a nuclear power plant from 19 a design-basis-threat. The NRC FOF includes a mock adversary force (MAF) that 20 simulates hostile actions against the plant's security personnel and systems. These 21 NRC FOF inspections occur approximately every three years. The NRC last 22 performed a FOF at Fermi 2 in 2022 and DTE Electric projects the next NRC FOF 23 in 2025. The FOF inspections were first included with the Case No. U-20162 PERC 24 O&M Exhibit and has had updated project expenditures with subsequent rate case 25 PERC O&M exhibits.

- 1 2 **Q123.** What was the rationale for the Integrated Leak Rate Test (IRLT) shown on 3 line 7 of Schedule A-13, Schedule C5.16, page 1? 4 A123. The Integrated Leak Rate Test (ILRT) is an NRC-required evolution to confirm the 5 plant's primary containment system is performing its function (generally, Appendix 6 J for Part 50). A licensee such as DTE Electric must perform the ILRT at least once 7 every 15 years – the NRC transitioned to this longer periodicity in 2012 based on 8 research performed by EPRI and surveys conducted by NEI (previously an ILRT 9 was required at least once every ten years), saving the Company (and thus 10 customers) time and money. DTE Electric successfully completed the Fermi 2 IRLT 11 in RF21. The Fermi 2 ILRT was first included with the Case No. U-20836 PERC 12 O&M Exhibit and has had updated project expenditures with subsequent rate case 13 PERC O&M exhibits. 14 15 Q124. What was the rationale for the High Energy Line Break (HELB) analysis 16 shown on line 8 of Schedule A-13, Schedule C5.16, page 1? 17 A124. Fermi 2 Power Plant is maintained and operated per its NRC license. Supporting the
- 18 Fermi 2 license are many technical specifications, designs, configuration controls 19 and design calculations. One such design calculation affects environmental 20 (temperature, humidity, pressure) conditions that can be assumed during plant 21 operating scenarios such as a high energy line break (HELB). The HELB analysis 22 updates the Fermi 2 environmental calculations using modern models such as the 23 EPRI GOTHIC which in turn allows DTE Electric to reevaluate and provide 24 additional margin to certain Fermi 2 technical specifications and reduce the 25 likelihood of an unplanned limited condition of operation.

Q125. What was the rationale for the Independent Spent Fuel Storage Installation (ISFSI) and ISFSI fuel characterization shown on lines 28 and 13 of Schedule A-13, Schedule C5.16, page 1?

4 A125. Fermi 2 ISFSI campaigns remove spent nuclear fuel assemblies from the Fermi 2 5 spent nuclear fuel pool, load the spent nuclear fuel assemblies into NRC-licensed 6 dry casks, and then transport the dry casks to their interim storage location at the 7 Fermi 2 ISFSI Pad. Prior to loading the spent nuclear fuel assemblies into the casks, 8 DTE Electric must characterize the spent nuclear fuel to ensure the spent nuclear 9 fuel assembly remains intact and that its composition is as expected to ensure the 10 spent nuclear fuel loaded into each cask is consistent with the dry cask license. The 11 2023 ISFSI campaign included 10 dry casks and transitioned 680 spent nuclear fuel 12 assemblies from the Fermi 2 spent fuel pool to the Fermi 2 ISFSI Pad. The ISFSI-13 related expenditures were first included with the Case No. U-20162 PERC O&M 14 Exhibit and has had updated project expenditures with subsequent rate case PERC 15 O&M exhibits.

16

Q126. What was the rationale for the Spent Fuel Pool (SFP) cleanup campaign shown on line 14 of Schedule A-13, Schedule C5.16, page 1?

A126. The Fermi 2 Spent Fuel Pool (SFP) is a small, water-filled pool adjacent to the
reactor and is used to store spent nuclear fuel, incoming new nuclear fuel, control
rod blades (CRBs) and nuclear instrumentation equipment such as dry tubes and
local power range monitors (LPRMs). While ISFSI campaigns transition spent
nuclear fuel from the SFP to dry-cask storage, the SFP storage locations for CRBs
and nuclear instrumentation equipment are also finite and periodically DTE Electric
must dispose of this depleted equipment to clear space for the CRB/SRM/IRM
1	removals projected in upcoming refueling outages. DTE Electric removed and
2	disposed 28 CRBs and 7 dry tubes and 3 LPRMs from the SFP. The SFP cleanup
3	campaigns were first included with the Case No. U-20162 PERC O&M Exhibit and
4	has had updated project expenditures with subsequent rate case PERC O&M
5	exhibits. DTE Electric projects the next SFP campaign to occur around the year
6	2030.
7	
8	Q127. What was the rationale for the Core Shroud Inspections shown on line 17 of
9	Schedule A-13, Schedule C5.16, page 1?
10	A127. The core shroud is a cylindrical shroud that directs coolant flow through the core
11	and helps maintain fuel alignment to ensure control rods can be inserted into the
12	core. DTE Electric performs core shroud inspections approximately every ten years
13	to monitor the integrity of the core shroud per EPRI guidelines endorsed by the
14	NRC; however, with Fermi 2's transition to the 24-month cycle, DTE Electric was
15	required to perform the core shroud inspections one outage year earlier than
16	otherwise required. DTE Electric projects to perform the core shroud inspections in
17	RF22. DTE Electric last performed the core shroud inspection in RF18 (2017) which
18	was depicted in the Case No. U-20162 PERC O&M exhibit.
19	
20	Q128. What was the rationale for the License Renewal Inspections shown on line 27
21	of Schedule A-13, Schedule C5.16, page 1?
22	A128. Once Fermi 2 transitions to its Period of Extended Operations in 2025, the capital
23	project License Renewal Implementation will complete and be in service. There will
24	be ongoing incremental inspections required as a part of the Fermi 2 renewed license
25	which DTE Electric will account for in the License Renewal Inspection project. The

JCD-72

Line <u>No.</u>	J. C. DAVIS U-21534
1	License Renewal Inspection project was included in the Case No. U-21297 PERC
2	O&M Exhibit.
3	
4	Q129. What was the rationale for the Feed Water Heater (FWH) Bridging Strategy
5	project analysis shown on line 20 of Schedule A-13, Schedule C5.16, page 1?
6	A129. I have discussed the technical importance of the FWHs in the capital discussion.
7	Emergent repairs to the #3S FWH were performed in RF20. DTE Electric performed
8	inspections of these six FWHs in RF21 to support safe, reliable operation until
9	RF22. DTE Electric is projecting to perform inspections and repairs to the #3S, #3N,
10	#4S, #4N, #5S and #5N FWHs to support reliable operation until these six FWHs
11	are replaced in RF23 and RF24. This proceeding is the first inclusion of the FWH
12	Bridging Strategy expenditures as PERC O&M.
13	
14	Q130. What was the rationale for the Circulating Water Pump (CWP)
15	refurbishments shown on line 21 of Schedule A-13, Schedule C5.16, page 1?
16	A130. The Fermi 2 Circulating Water Pumps (CWP) and motors require refurbishment
17	approximately every 10 years to ensure reliable operation. Fermi 2 Power Plant has
18	five CWPs, each driven by a 5000-horsepower motor, that supply the driving force
19	for the Fermi 2 Circulating Water System. In general, Fermi 2 Power Plant only
20	requires four of the five CWPs to be at full-power operations during the cooler

requires four of the five CWPs to be at full-power operations during the cooler
months of October – April. It's during this time that DTE Electric can remove a
CWP from service, ship the pump and motor offsite for refurbishment, and then
reinstall the pump and motor prior to the warmer months when all five CWPs are
required for full-power operations. The CWP refurbishments were first included

Line	J. C. DAVIS U-21534
<u>No.</u>	
1	with the Case No. U-20162 PERC O&M Exhibit and has had updated project
2	expenditures with subsequent rate case PERC O&M exhibits.
3	
4	Q131. What was the rationale for the High Pressure Turbine (HPT) inspection shown
5	on line 25 of Schedule A-13, Schedule C5.16, page 1?
6	A131. The High Pressure Turbine (HPT) requires a full tear-down inspection
7	approximately every 120,000 hours of operation to satisfy loss control criteria. The
8	Fermi 2 main turbine system consists of a high pressure element (the HPT) in
9	tandem with three low-pressure elements (low-pressure turbines (LPTs)). DTE
10	Electric projects to complete the HPT inspection in RF23 (2026). The HPT
11	inspections were first included with the Case No. U-20162 PERC O&M Exhibit and
12	has had updated project expenditures with subsequent rate case PERC O&M
13	exhibits.
14	
15	Q132. What was the rationale for the 24-Month Operating Cycle project shown on
16	line 11 of A-13, Schedule C5.16, page 1?
17	A132. The 24-month operating cycle project reduces the frequency of Fermi 2 refueling
18	outages and improves operating time. Operating on a 24-month cycle results in three
19	refueling outages every six years; operating on an 18-month operating cycle results
20	in four refueling outages every six years. Prior to the 24-month operating cycle
21	project, Fermi 2 previously operated with 18-month operating cycles; therefore,
22	transitioning to a 24-month operating cycle results in additional generation over a
23	six-year cycle due to fewer refueling outages.
24	

1	Fermi 2's cycle length is limited by our NRC license. The 24-Month Operating
2	Cycle project performed an analysis to ensure the plant could operate 24 months
3	between refueling outages and submitted that analysis as a license amendment
4	request to the NRC to update the Fermi 2 license to allow a 24-month cycle. DTE
5	Electric received NRC approval in early 2021 and began its first 24-month operating
6	cycle in 2022 upon exiting RF21.
7	
8	The Company first introduced the 24-Month Operating Cycle project in Case No.
9	U-20162. The Commission responded favorably and approved cost recovery
10	associated with the 24-Month Operating Cycle project in the Case No. U-20162
11	Order dated May 2, 2019.
12	
13	Q133. What are the Total Nuclear Power Generation O&M expenses that you support
13 14	Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025?
13 14 15	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the
13 14 15 16	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24,
 13 14 15 16 17 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and
 13 14 15 16 17 18 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for
 13 14 15 16 17 18 19 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable.
 13 14 15 16 17 18 19 20 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable.
 13 14 15 16 17 18 19 20 21 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable. Nuclear Surcharge
 13 14 15 16 17 18 19 20 21 22 	Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable. Nuclear Surcharge Q134. Is the Company requesting a change to the Nuclear Surcharge?
 13 14 15 16 17 18 19 20 21 22 23 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable. Nuclear Surcharge Q134. Is the Company requesting a change to the Nuclear Surcharge? A134. Only with respect to inflation for the Site Security and Radiation Protection portion
 13 14 15 16 17 18 19 20 21 22 23 24 	 Q133. What are the Total Nuclear Power Generation O&M expenses that you support for the projected test period ending December 31, 2025? A133. I support Total Nuclear Power Generation O&M expenses of \$159.4 million for the projected test period as shown in Exhibit A-13, Schedule C5.3, page 1, line 24, column (n). As I have discussed previously, these projected Total Operation and Maintenance expenses are required for the safe and reliable operation of Fermi 2 for the projected test period. I consider these expenses to be prudent and reasonable. Nuclear Surcharge Q134. Is the Company requesting a change to the Nuclear Surcharge? A134. Only with respect to inflation for the Site Security and Radiation Protection portion of the Nuclear Surcharge. The Company is proposing an updated Nuclear Surcharge

	J. C. DAVIS
Line <u>No.</u>	U-21534
1	U-18014, U-18255, U-20162, U-20561, U-20836 and U-21297 and depicted in
2	Exhibit A-20, Schedule J1.
3	
4	The Site Security and Radiation Protection portion of the surcharge has been
5	updated to reflect 2022 historical expense adjusted for inflation on line 2. The
6	inflation rate is supported by Witness Uzenski on Exhibit A-13, Schedule C5.15.
7	
8	The Nuclear Decommissioning Funding portion of the surcharge shown on line 3 is
9	unchanged.
10	
11	The Low Level Radioactive Waste (LLRW) Disposal Funding portion of the annual
12	surcharge shown on line 4 is unchanged.
13	
14	The resulting nuclear surcharge set forth in Company rates is supported by Company
15	Witness Willis on Exhibit A-16, Schedule F6.
16	
17	Q135. What is the Nuclear Surcharge that you support for the 12-month projected
18	test period ending December 31, 2025?
19	A135. I support the Proposed Nuclear Surcharge of \$40.1 million for the projected test
20	period as shown in Exhibit A-20, Schedule J1, page 1, line 5, column (b); this
21	represents a change of approximately \$1.2 million from the current authorized
22	Nuclear Surcharge shown on line 6, column (b). The Proposed Nuclear Surcharge
23	funds Fermi 2 site security, radiation protection, nuclear decommissioning and the
24	disposal of LLRW; these activities are required for safe and secure operation of the

Line <u>No.</u>	J. C. DAVIS U-21534
1	Fermi 2 Power Plant for the projected test period. I consider the Proposed Nuclear
2	Surcharge to be prudent and reasonable.
3	
4	Q136. Does this complete your direct testimony?
5	A136. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

SATVIR S. DEOL

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF SATVIR S. DEOL

Line No.

1 Q1. What is your name, business address and by whom are you employed? 2 A1. My name is Satvir S. Deol (he/him/his), and my business address is One Energy 3 Plaza, Detroit, Michigan, 48226 and I am employed by DTE Electric Company 4 (DTE Electric or Company). 5 6 Q2. On whose behalf are you testifying? 7 A2. I am testifying on behalf of DTE Electric. 8 9 **Q3**. What is your educational background? 10 A3. I received a Bachelor of Science Degree in Electrical Engineering specializing in 11 Power Distribution from Michigan Technological University. I graduated from the 12 University of Minnesota with a Master of Science in Electrical Engineering 13 specializing in Power System Control. I also have a Master of Business 14 Administration specializing in Finance from University of Michigan, Dearborn. 15 Furthermore, I have attended professional development courses in power system 16 design & protection and circuit modeling & power flow analysis. I was also trained 17 in the Toyota Production System (TPS) continuous improvement methodologies. 18 19 Q4. Please summarize your professional experience. 20 I worked for Shell Western Exploration & Production, Inc. (SWEPI) as a facilities A4. 21 engineer from 1990 to 1992. I was responsible for coordinating & performing 22 maintenance on substations, co-generation facilities, and the power distribution

network for all oil production fields and offshore platforms in California. I also
supported the field electrical teams for emergent issues and was the project manager
for several major electrical projects. I worked for Ford Motor Company (Ford)

Line	
No.	

1	from 1995 to 2007. Through my twelve-year career at Ford, I had numerous
2	assignments with increasing responsibility. As a product design engineer, I
3	designed electrical motors and received two patents. I have experience in the
4	production and assembly of electrical components as a manufacturing engineer. I
5	have worked internationally, launching an alternator rectifier assembly line in
6	India, and upgrading a plant in Brazil. As a product planning analyst, I worked
7	with hybrid, electrical and fuel cell vehicle architectures and gained experience
8	working within industry consortiums. I obtained leadership experience as a
9	powertrain capacity planning supervisor and then as an ignition system supervisor,
10	where I had design and release responsibility of all current and future ignition
11	systems for all North America produced V-engines. Also, I achieved my six-sigma
12	black belt certification and led numerous continuous improvement projects.

I joined DTE Energy in 2007 as a program manager to implement continuous improvement programs within the Materials & Logistics organization. After a series of roles with increasing responsibility, in 2010 I was promoted to senior supply chain manager supporting Fossil Generation Operations.

18

In 2013, I moved to Distribution Operations as a program leader for a continuous improvement project focusing on the oil distribution breaker inspection process. In 2014, I assumed the role as a service center manager leading the Southwest region for Substation Operations. In this role, I was responsible for the operation, planned and corrective maintenance, and executing capital projects for substations. I was given the additional responsibility of the Southeast region in 2016. In 2018, I was promoted to director of Substation Operations.

1		As director of Substation Operations, I was responsible for safe and reliable			
2		operation of all the substations within the DTE Electric service territory. The major			
3		areas of focus were: 1) safety, 2) planned maintenance, 3) emergent and corrective			
4		maintenance, 4) capital replacement programs, and 5) continuous improvement.			
5		In 2023, I assumed the role of director of Central Engineering.			
6					
7	Q5.	Do you hold any certifications or are you a member of any professional			
8		organizations?			
9	A5.	I am a Lean Six Sigma Blackbelt.			
10					
11	Q6.	What are your current duties and responsibilities?			
12	A6.	As director of Central Engineering, I lead the Central Engineering organization that			
13		is responsible for determining the health of the Company's electric distribution			
14		assets and developing projects and programs to maintain and improve their safe,			
15		reliable, and cost-effective operation. I oversee Central Engineering activities,			
16		which include defining technical standards for the equipment to be utilized on the			
17		distribution system, long-term system planning including grid modernization, and			
18		developing major projects needed for customer connections, relocations, increasing			
19		loads, infrastructure improvements, reliability upgrades, and technology			
20		enhancements.			
21					
22	Q7.	Have you previously sponsored testimony before the Michigan Public Service			
23		Commission (MPSC or Commission)?			
24	A7.	Yes. I sponsored testimony in the following DTE Electric cases:			
25		U-21297 DTE Electric 2023 Rate Case			

1	<u>Purpo</u>	pose of Testimony				
2	Q8.	What is the purpose of your testimony?				
3	A8.	As reference	d in witness K	Kryscynski's description of the Distribution Operations		
4		organization	, the purpose o	f my testimony is to support, as reasonable and prudent,		
5		the historical	l capital expen	ditures for 2022 and projected capital expenditures for		
6		2023 through	n December 31	, 2025, in the distribution strategic investment category		
7		of Infrastruct	ture Redesign a	and Modernization and the programs associated with the		
8		Company's I	Infrastructure I	Recovery Mechanism (IRM).		
9						
10	Q9.	Are you spo	Are you sponsoring any exhibits in this proceeding?			
11	A9.	Yes. I am sp	oonsoring the f	following exhibits:		
12		<u>Exhibit</u>	<u>Schedule</u>	Description		
13		A-12	B5.4	Projected Capital Expenditures – Distribution Plan		
14				(Pages 1, 2, 14-16, and 19-26)		
15		A-23	M6	Distribution Plant Capital Project Detail –		
16				Infrastructure Redesign and Modernization		
17		A-23	M11	Appoline Report		
18		A-23	M13	Benefit Cost Analysis Whitepaper		
19		A-28	R1	Buffalo Charles Letter of Support		
20						
21	Q10.	Were these	exhibits prepa	ared by you or under your direction?		
22	A10.	Yes, they we	ere.			
23						
24	Q11.	How is your	• testimony or	ganized?		
25	A11.	My testimon	y consists of th	he following parts:		

Lina			S. S. DEOL
<u>No.</u>			0-21554
1		Part I	Infrastructure Recovery Mechanism (IRM) Support
2		Part II	Infrastructure Redesign and Modernization
3			
4	<u>Part I</u>	Infrastructur	e Recovery Mechanism (IRM) Support
5	Q12.	Are any of t	the programs you are supporting impacted by the Company's
6		Distribution	Infrastructure Recovery Mechanism (Distribution IRM or
7		IRM)?	
8	A12.	Yes, as descri	bed by Company Witness Foley in his testimony, in its December 1,
9		2023 Order	in Case No. U-21297 (December 2023 Order), the Commission
10		authorized IR	M treatment for the Conversion projects (4.8kV Conversion and
11		Consolidation	(CC), 4.8kV ISO Conversion, 8.3kV CC, and City of Detroit
12		Infrastructure	(CODI)), and the Subtransmission Redesign & Rebuild program
13		from Decemb	er 1, 2023 through the end of 2025.
14			
15	Q13.	Is the Comp	oany proposing any additional investment in these programs
16		during the b	ridge and/or test years beyond what the Commission previously
17		authorized fo	or recovery through the IRM?
18	A13.	Yes, as refle	cted in Exhibit A-12, Schedule B5.4, the Company is proposing
19		additional Co	onversions and Subtransmission Redesign & Rebuild investment
20		during the br	idge and test years of this case. Additional Conversions program
21		investment is	captured on Page 14 (Lines 28-36), Page 15 (Lines 37-56), and Page
22		16 (Lines 79	0-91). Additional Subtransmission Redesign & Rebuild program
23		investment is	captured on Page 14 (Lines 5-27) and Page 15 (Lines 66-78). This
24		investment is	incremental to the investment already authorized for IRM treatment

Line		5. 5. DEOL U-21534
<u>No.</u>		
1		during these years and will support different work to avoid double recovery of the
2		same investment.
3		
4	Q14.	Is the Company proposing recovery for any additional investment in these
5		programs through the IRM beyond the test year of this case?
6	A14.	Yes, as described by Company Witness Foley, the Company is proposing a two-
7		year extension of the IRM (i.e., calendar years 2026 and 2027). As part of that
8		extension the Company is proposing recovery of additional Conversions and
9		Subtransmission Redesign & Rebuild capital investment as captured in Exhibit A-
10		33, Schedule X1.
11		
12	<u>Part I</u>	I: The Infrastructure Redesign and Modernization Pillar
13	Q15.	Can you describe the Company's Infrastructure Redesign and Modernization
13 14	Q15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar?
13 14 15	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally
13 14 15 16	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid
 13 14 15 16 17 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving
 13 14 15 16 17 18 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms
 13 14 15 16 17 18 19 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in
 13 14 15 16 17 18 19 20 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in which customers are interacting with the grid.
 13 14 15 16 17 18 19 20 21 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in which customers are interacting with the grid.
 13 14 15 16 17 18 19 20 21 22 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in which customers are interacting with the grid.
 13 14 15 16 17 18 19 20 21 22 23 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in which customers are interacting with the grid.
 13 14 15 16 17 18 19 20 21 22 23 24 	Q15. A15.	Can you describe the Company's Infrastructure Redesign and Modernization Pillar? The Infrastructure Redesign and Modernization Pillar focuses on fundamentally rebuilding and modernizing the near century old grid to support the long-term grid needs. The specific investments in this pillar are essential to meeting the evolving needs of customers, including adoption of electric vehicles (EVs) and other forms of electrification, distributed energy resources (DER), and the evolving ways in which customers are interacting with the grid. The goals of the projects and investments in this pillar are to add capacity and operational technology, while hardening the grid to enhance safety, reliability, and resiliency. These projects include elimination of loading constraints, redesign and

Line <u>No.</u>		U-21534
1		rebuild of the subtransmission system to provide operational redundancy and
2		address lack of capacity on significant portions of the Company's grid.
3		
4	Q16.	What grid investment areas are included in the Infrastructure Redesign and
5		Modernization Pillar?
6	A16.	Infrastructure Redesign and Modernization investments focus on the distribution
7 8		and subtransmission segments of the grid.
9		The distribution system is designed to distribute electricity from a substation to the
10		customers. The Company's current distribution system has voltages of 4.8 kV, 8.3
11		kV, and 13.2 kV. In analyzing the long-term grid needs and to address the current
12		challenges of the 4.8 kV and 8.3 kV circuits, the Company plans to convert all 4.8
13 14		kV and 8.3 kV grid infrastructure to a higher voltage over time.
15		The Company's Conversion Program investments focus of converting the 4.8 kV
16		and 8.3 kV circuits to a higher voltage. With evolving climate change, the
17		Company is experiencing an increased number of severe weather events of greater
18		frequency and severity. Weather impacts, aged electrical infrastructure, and the
19		need to support current and future load growth require a higher voltage, harden, and
20		resilient grid.
21		
22		The distribution system is also addressed by the System Loading project
23		investments. These projects focus on relieving system overloads, improving
24		reliability, and adding capacity predominantly on the 13.2 kV distribution system.

<u>No.</u> 1 The subtransmission system consists of the infrastructure that provides higher 2

Line

voltage into substations that then convert the higher voltage to lower-level 3 distribution voltages (4.8 kV, 8.3 kV, and 13.2 kV). The Company's 4 subtransmission system has voltages of 24 kV, 40 kV, and 120 kV. 5 6 The Company's Subtransmission Redesign & Rebuild program investments focus 7 on this critical upstream feed to the distribution system. These projects focus on 8 improving the reliability, redundancy, and capacity of the subtransmission system. 9 10 Figure 1 below illustrates the difference between the distribution and 11 subtransmission system. 12 13

Figure 1 Electrical Distribution System Overview



14

1		Summary level Capital investment details for Infrastructure Redesign and
2		Modernization projects are provided in Exhibit A-12, Schedule B5.4, pages 14-16
3		and Exhibit A-23, Schedule M6. Also included in Exhibit A-12, Schedule B5.4 for
4		this category is AFUDC on page 19 and plant activity on pages 20-26, described in
5		more detail by Company Witness Kryscynski.
6		
7	Q17.	Can you discuss in more detail the Infrastructure Redesign and Modernization
8		programs?
9	A17.	I would like to expand on these programs because I believe that will be helpful in
10		establishing a deeper understanding of their key objectives, scope, the rationale for
11		making the investments, and the benefits customers will receive.
12		Conversion Programs
13		• 4.8 kV Conversion
14		• City of Detroit Infrastructure (CODI)
15		• 4.8 kV ISO Conversion
16		 8.3 kV CC Pontiac Conversion
17		Subtransmission Redesign & Rebuild
18		Strategic Undergrounding Projects
19		Primary Deconductoring
20		System Loading
21		
22		Conversion Programs
23		4.8 kV Conversion
24		
25	Q18.	Can you describe the Company's 4.8 kV distribution system?

1 A18. The Company's original distribution system voltage is 4.8 kV. The system was 2 designed nearly a century ago with standards of the time that included an 3 ungrounded delta configuration with banked secondary. For an ungrounded delta configuration protective trip device to operate on the system, two of the high-power 4 5 lines need to contact each other or ground. Thus, a single downed wire is 6 challenging for the protective devices to detect in a delta configuration. A banked 7 secondary configuration has multiple transformers interconnected to provide power to a local area of customers. Figure 2 below shows a banked secondary 8 9 configuration. 10 11 **Figure 2 Banked Secondary Configuration** 12 13 The 4.8 kV delta configuration coupled with the banked secondary is a design from

14

the early 1900's, which for many decades provided good reliability with a low



SSD-10

Line

<u>No.</u>

1

2

3

number of outages for the Company's customers. Currently, the 4.8 kV delta system has many challenges which include safety, reduced distribution capacity, and degrading reliability due to its age.

4

5

6

Q19. Can you describe in more detail the challenges and issues associated with the 4.8 kV system?

A19. Improving safety risk associated from downed wires on the current 4.8 kV
ungrounded delta circuits is a major focus of the conversion program. It is more
susceptible to wire-downs due to small #6 and #4 copper conductors, which are
weaker in strength compared to current higher standard wires, and in many cases
have deteriorated and weakened by age and the annealing effects of thermal
cycling. Due to the ungrounded configuration of the 4.8kV delta system, a downed
wire can potentially remain energized until mitigated by the Company's workforce.

14

15 Capacity is limited due to the inherently lower rating of equipment at 4.8 kV, 16 including, but not limited to, substation transformers and conductor or cable sizes. 17 On many circuits, this impacts the Company's ability to connect new customers or 18 facilitate growth of existing customers.

19

Reliability of the 4.8 kV system, both in terms of outages (frequency and duration)
and power quality, impacts the customer experience. When originally constructed,
the 4.8kV system was modern, accessible, and reliable for a customer base with a
much lower electrical demand. Driven by a combination of the age of the system,
inaccessibility of infrastructure, and changing customer demands, the 4.8 kV
system is no longer a reliable design choice.

2

3

4

5

In addition to the lower reliability and capacity constraints of the 4.8kV system, it also limits the operability for the Company. Smaller wire sizes and lower circuit/substation ratings limit the ability to reconfigure the system to restore customers in adjacent areas during planned or unplanned outages. This can result in larger area and longer duration outage events for the Company's customers.

7

6

8 Accessibility is another major challenge of the 4.8 kV system. In most 9 neighborhoods, the 4.8 kV system was constructed as overhead rear-lot poles and 10 wires, which customers find aesthetically preferable to front-lot construction. 11 Initially, right-of-way truck access was readily available through municipally 12 maintained alleys in many areas, including much of Detroit. Starting in the mid-13 1950's, many municipalities began abandoning the alleys and allowed property 14 owners to extend their fence lines, inhibiting Company truck access to the poles 15 and wires. Consequently, the limited access results in extended time to locate and 16 repair trouble on the 4.8 kV system, as well as increases in time to perform tree 17 trimming and other maintenance work.

18

19 Other key challenges impacting the Company's 4.8 kV system are:

20

21

• The 4.8 kV system can experience more significant voltage drops than higher voltage systems.

Ringed circuit and banked secondary designs make maintenance, fault
 identification, troubleshooting, and restoration more difficult and therefore
 can result in outages that are longer in duration.

1	•	The 4.8 kV system is less able to incorporate current technology automation
2		standards because it has a limited amount of remote monitoring and control
3		capability when compared to higher grid voltages. Due to inherent space
4		limitations and equipment age, the retrofits on 4.8 kV substations to enhance
5		remote monitoring and control capability are more costly and challenging.
6		For example, the original 4.8 kV substation design included individual relays
7		for individual functions, usually installed on a 3-foot-by-7-foot granite
8		panel. When a new breaker is installed these granite panels are removed and
9		a new prewired relay panel with current technology is installed. Even though
10		the new prewired panel reduces installation time at the substation, all the
11		new control wires still must be installed from the panel to the breaker, which
12		is time consuming, and costly.

Line

<u>No.</u>

14 Q20. Why does the Company plan to convert its 4.8 kV system?

15 A20. As described earlier, the 4.8 kV system has many challenges related to safety, 16 capacity, reliability, operability, and accessibility, and this negatively impacts the 17 customers served by the 4.8 kV system. In analyzing the long-term grid needs and 18 to address the current challenges of the 4.8 kV system, the Company has determined 19 that a higher grid voltage system is required. The conversion program will build 20 new, modern, higher voltage substations. The newly constructed higher voltage 21 distribution circuits will be built to the current construction standards that will 22 harden the grid and implement a higher level of automation. The conversion 23 program will improve safety by reducing wire-down events. Converting to a higher 24 system voltage will add capacity to support new and growing customer load, and 25 better support new electrification technologies and DERs. The hardened circuits

1		will improve reliability, operability, and reduce emergent maintenance costs.
2		Automation will allow for remote operations to reduce the number of customers
3		impacted by outages and reduce restoration time by quickly identifying trouble
4		locations. The new circuits will be designed and built to improve accessibility by
5		relocating to be truck accessibility wherever possible allowing for quicker crew
6		response time.
7		
8		Through the conversion program, the Company expects to see a reduction of up to
9		90% in customer minutes of interruption, wire downs, and trouble events.
10		
11	Q21.	What is the scope of the 4.8 kV Conversion program?
12	A21.	The detailed scope of the 4.8 kV conversion program is as follows:
13		• Building new, higher voltage substations or in some cases expanding and
14		upgrading existing 13.2 kV substations. This will improve the ability to
15		connect new customers and allow for load growth for existing customers.
16		• Completing overhead pre-conversion work including rebuilding pole top
17		equipment, replacing poles, wires, and transformers as needed, and installing
18		neutral wire.
19		• Undergrounding of the overhead wires will also be evaluated for
20		construction feasibility, customer acceptance, and cost effectiveness.
21		• Reconfiguring circuits and establishing new jumpering points will be
22		completed to improve operability. Jumpering is used during outage
23		circumstances and is the act of feeding a circuit that has become deenergized
24		by connecting it to an adjacent circuit, thus restoring power to the customers
25		on the deenergized circuit.

	S. S. DEOL U-21534
	• Converting and transferring the load from the 4.8 kV substations to the 13.2
	kV substations.
	• Installing controls and automation in the substations and circuits to current
	design standards.
	• Remove arc wire and Detroit Public Light Department primary from the
	Company's system, on applicable Detroit circuits.
	• Decommissioning of aging 4.8 kV substations and associated
	subtransmission infrastructure.
Q22.	Do customers benefit from overhead pre-conversion work when it is
	constructed prior to building a new higher voltage substation or in parallel
	with substation construction?
A22.	Yes. In projects where overhead pre-conversion work is performed early or in
	parallel with the substation construction, the customers will see the reliability
	benefits sooner, even though upgraded equipment will continue to operate at 4.8
	kV until the area is ready for conversion. Upgraded pole-tops and wires deliver
	reliability improvements by a reduction in wire downs. Once the substation is
	subsequently built, the additional capacity benefits will be achieved as the circuits
	are converted to the higher voltage.
Q23.	How are conversion projects prioritized?
A23.	The Company's engineers develop conversion projects based on substation firm
	rating, circuit overloads, wire downs per OH mile, and substation risk. Consistent
	with other strategic projects and programs, conversion projects are prioritized using
	the Global Prioritization Model (GPM), which was updated in the 2023 DGP and
	Q22. A22. Q23. A23.

SSD-15

1	is discussed in detail by Witness Kryscynski. A conversion project's GPM score
2	is primarily impacted by the projects ability to address substation firm rating, circuit
3	overloads, wire downs per OH mile, and substation risk plus the reliability
4	improvement benefits and investments in Energy Justice (EJ) communities. More
5	detail is provided in Exhibit A-23 Schedule M8 DGP, section 9.3.4 Prioritization
6	of Conversion Projects.

8 Q24. What are the 4.8 kV Conversion projects included in this case?

9 A24. Table 1 below provides the high-level summary of the 4.8 kV Conversion projects
10 included in this case. Detailed information for each of these projects is provided in
11 exhibit A-23 schedule M6.

13

12

14

Project Name Municipality Drivers Cortland/ Oakman/ Reliability & Operation: Detroit Linwood This project is part of a larger program to reduce 4.8kV breaker positions, transformers, and Consolidation regulators. This will reduce O&M costs and provide spare components for equipment which is no longer manufactured. (LINWD SUB has 2 transformers, 2 regulators, and 11 breaker positions which are at or near end of life). This project will also eliminate associated underground cable I-94 Substation and Detroit Safety: Significant assets are at high risk level including transformers, regulators, oil circuit Circuit Conversion breakers and disconnects. Along with 4.8kV and 24kV underground cable. (Promenade) Reliability: This area experiences wire down events which exceed the system average. Capacity: The Detroit Economic Growth Corporation has assembled the I-94 Industrial Park site - a 186-acre site north of I-94 between Mt. Elliott and Van Dyke on Detroit's east side. It is part of the 3,203-acre Mt. Elliot Development Zone, which is the single largest industrial district in Detroit and encompasses automotive, metal, transportation and logistics clusters. It offers access to major transportation assets. The site is a federally designated Historically Underutilized Business Zone and a state designated Renaissance Zone. Recent new loads were fed from the aging Lynch and Lambert 4.8 kV substations. The new substation is required to serve the load growth in and around I-94 industrial park and allows for decommissioning of the aging Lynch, Lambert, and Pulford 4.8 kV substations. Operability: Promenade will have loop schemes and jumpering points. Almont Relief and Village of Almont, Safety: 4.8kV causes a higher safety risk in an event of a wire-down. Each Almont circuit is Circuit Conversion Almont Township, ~55 OH line miles. (Midas OH) - DO Lapeer County, MI Reliability: Almont substation was built in 1956 and there are no spare parts available for the breakers. Capacity: Almont 4.8kV substation is 132% of its firm rating. ALMOT DC 304 is 93% of the day-to-day rating of 5.1MVA and ALMOT DC 303 is 87% of the day-to-day rating of 4.8MVA. Both ALMOT circuits, DC 304 and DC 303, exceed the Distribution Design Order limit of 3MVA for a 4.8kV circuit. Five Method of Service requests have been received for new load on the substation but there is no capacity to serve these requests. Operability: There are little to no jumpering options available for Almont circuits because Almont is surrounded by 13.2kV circuits and substations. In 2019, a cable failure occurred causing a breaker failure and an extensive outage for the Almont area. Due to the high loads, the substation was blocked from automatic throwover.

Table 1Conversion Projects

Table 1 Conversion Projects, Continued

Project Name	Municipality	Drivers
Buckler Circuit Conversion McKinstry Sub Decomposition	Ann Arbor Detroit	Argo substation was built in 1926 and is a three transformer 4.8kV substation serving downtown Ann Arbor. Safety: 4.8kV Wire down elimination Capacity: The substation is currently unable to meet capacity needs in the rapidly growing downtown Ann Arbor area. The Argo circuits are limited to 3MVA based on the Distribution Design Order limit for a 4.8kV circuit. Argo substation is at 92% of its firm rating. The loading in this area will continue to increase which will eventually overload the substation and the circuits at Argo. Buckler substation was built to support current and future loads of Argo and the surrounding substations. Operability: Increased loading on 4.8kV circuits will inhibit the ability to transfer load. McKinstry is a 24kV/4.8kV Class C substation. As part of the Gordie Howe Bridge Project, all of its circuits was been consolidated and transferred to Zenon 120kV/(13.2kV)
		Class A substation. This specific project is to decommission McKinstry Substation, demolish the substation build and remove all associated equipment. Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Capacity: MCKNY has no load on the substation, all loads have been transferred elsewhere Other: Decommission (3) 24kV trunk lines. Decommission McKinstry Substation and demolish the building
Quincy Conversion	Yale	Safety: Power transformer sits on railroad ties instead of a transformer pad. Overhead stress from the leaning transformer causes safety concerns for those working on site. Other: QUNCY substation has low oil levels due to oil leaks, potentially causing future environmental impacts. QUNCY transformer is constructed on railroad ties that are rotten, causing the transformer to lean, adding stress to the overhead equipment.
Pinegrove Substation Relocation and Conversion (Neon)	Port Huron, St. Clair County, MI	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: PINGV circuits were last trimmed in 2020. Capacity: PINGV substation is 72% of firm rating of 20.6 MVA. IMLAY0302 exceeds the 4.8kV DDO of day to day loading limits. Other: MDOT has requested the removal of the Pine Grove (PINGV) substation in Port Huron to facilitate the expansion of the Blue Water Bridge Plaza. PINGV substation is ~100 years old and is a 4.8kV substation located at the base of the Blue Water Bridge in Port Huron. The substation and its associated infrastructure support 16.3MVA of load for 5,340 customers on nine circuits. PINGV substation is not a standard configuration as it has high speed ground switches instead of a circuit switcher on the high side of the transformer. This project will decommission the aging 4.8kV PINGV substation and build a new 13.2kV NEON substation. Constructing a modern distribution system with a new 13.2kV substation and more robust infrastructure will improve reliability and provide options for future capacity expansion in the Port Huron area.
Hawthorne Relief and Circuit Conversion	Dearborn, Dearborn Heights, Detroit, Garden City, Livonia, Redford Township	Hawthorne substation area is a dense, 4.8 kV service territory with many commercial and residential customers. Adjacent substations are Daly, Biltmore, Villa, and Glendale. Safety: Higher frequency of 4.8kV wire-down events (3X higher than the DTE system average) Reliability: Aging 4.8kV infrastructure at GLEND (built in 1947), BLTMR(built in 1953), DALY (built in 1954), VILLA (built in 1961) and HAWTH (built in the 1950's) Capacity: Overloaded substations with very high %firms HAWTH(128%), VILLA (110%) and DALY (106%), Limited load capacity to accommodate projected load growth in the area Operability: Limited jumpering opportunities due to geography coupled with heavily loaded nearby circuits
Hawthorne Trf #2 and Secondary Cable Replacement	Dearborn Heights	Hawthorne Substation is located in and feeds very dense areas of Dearborn Heights. To improve the loadability at the substation, this project will replace 750VCL secondary bus cable from both transformers with larger 1500KCM cable. The existing Position "H" 1200A disconnect will also be upgraded to a 2000A disconnect. Safety: Larger cable allows for higher ampacity ratings, replaces an older cable, which means that the cable is less vulnerable to failure and other safety issues. Reliability: VCL cable is recognized as a high-risk cable in the DTE system. Capacity: Substation is at 129% of firm rating, limited by secondary cables Operability: Over firm condition limits ability to transfer load and maintain service.

Line <u>No.</u> 1

Table 1 Conversion Projects, Continued

Project Name	Municipality	Drivers
Crestwood Substation- Property	Dearborn	Other: Crestwood is an existing 120kV-13.2kV two transformer substation located in Dearborn, MI. The substation's property lease agreement expires in August of 2022. This request is to purchase this property from current land owner instead of extending the lease for another 49 years. Purchasing the property instead of extending the lease, would save approximately \$1,000,000.
MAUME 8241 Downtown Clawson Conversion	Clawson	Reliability: Multiple frequent outages in 2020 and 2021 impacting Downtown Clawson. Several customer/town hall meetings involve Clawson city government, as well as Clawson DDA.
Power Line Conversion MADSN175L - W	Detroit	Reliability & Operation: Work is necessary to convert MADSN LPL 175 L-W standard to Power Lines (PL) and remove PIL 175L-W due to pilot cable failure. Pilot wire circuit is unjacketed, leaded cable. Numerous attempts to repair the circuit have been unsuccessful; cable continues to fail hi-pot test
GRFIN & WMSTN 4.8 kV ISO Conversions	Webberville and Williamston, Ingham County	Safety: Circuits have long 4.8kV (ungrounded) overhead miles because of the large 4.8kV ISO down areas. Many outages occur during storms and many wires were laying on the ground from the tornado in summer 2023. Reliability: GRFIN9799, GRFIN9883, and WMSTN9856 are some of the largest circuits in DTE and have limited jumpering points because of numerous ISO-down transformers limiting capacity and small conductor sizes on backbone limiting capacity. Capacity: Multiple method of services (industrial customer requests) have been received on GRFIN9799. Customer load creates a circuit DDO violation on GRFIN9799 and substation firm violation on GRFIN as the firm is surpassed before a project is executed. Williamston (WMSTN) substation is adjacent to GRFIN substation and is below its firm rating with capacity available. WMSTN DC 9856 also has capacity available on it. Load can be cascaded from GRFIN DC 9799 to WMSTN DC 9856 to mitigate the DDO violation. To facilitate this load transfer, 4.8kV ISO down pockets on both circuits must be converted to 13.2kV operation. Operability: There are no jumpering options for either of the two circuits due to overloads and low voltage after jumpering. Jumpering points are limited because 4.8kV ISO down pockets are limiting jumpering, these circuits are bordering Consumer's Energy circuits, and there are small overhead line sizes for the circuits' backbone. Other: MOS QPS 1 was received in 2019 and MOS QPS 2 was received in 2021. The buildings are located in an open industrial zoned area with other industrial customers nearby and more industrial customers are expected in the future.
SCOTN Circuit Consolidation	Detroit	Safety: flooding in the Scotten (SCOTN) substation affected and condemned associated position breakers. After further investigation, the EPPM group at DTE concluded that all (36) position breakers will need to be replaced. The intent of this project is to minimize the number of breakers to be replaced by consolidating lightly loaded circuits and to put the substation back to normal configuration. Reliability: In June 2021, flooding in the Scotten (SCOTN) substation affected and condemned associated position breakers Other: The intent of this project is to minimize the number of breakers to be replaced by consolidating lightly loaded circuits and to put the substation affected and condemned associated position breakers
Yale-Slater Decommissioning and Circuit Conversion	Yale, St. Clair County, MI	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: SLATR DC2652 customers report voltage as low as 110V. Capacity: SLATR substation is at 112% of Firm. SLATR DC2652 is at 112% of DD and exceeds the DDO limit of 3MVA. YALE's throw over circuit is unable to carry the load of YALE DC2615. YALE DC2633 is approaching the emergency rating of the throw over circuit soon will be unable to throw over. Operability: YALE and SLATR substations are surrounded by 13.2kV substations and therefore has limited jumpering capabilities. Other: SLATR substation lacks oil containment, potentially causing future environmental impacts. SLATR transformer is constructed on railroad ties that may add stress to the equipment.

2

3

Line <u>No.</u> 1

Table 1 Conversion Projects, Continued

Project Name	Municipality	Drivers
Unionville Decommissioning and Circuit Conversion	Unionville, Tuscola County, MI	Safety: Existing 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: Ageing substation equipment increases risk of failure. Capacity: Unionville substation is a 4.8kV distribution substation with two load carrying circuits. The substation is 111% of its firm rating and 91% of its emergency rating. Unionville substation is equipped with three single phase 500kV transformers which are the limiting element at the substation. Fairgrove substation is adjacent to Unionville substation. It is 116% of its firm rating and 86% of its emergency rating. Fairgrove substation is equipped with a 2.5MVA transformer which is the limiting element at the substation. Operability: Limited jumpering capabilities. Other: There have been 7 Method of Service requests in the Unionville area but the requests did not move forward due to the substanital upgrade costs which has led to repeated escalation and MPSC complaints.
Unionville DC 301 B1 Conversion - resolve voltage problem	Unionville	Safety: Existing 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: Two residential customers filed MPSC complaints in January 2023. These customers are seeing a larger voltage flicker driven primarily by a residential on-demand water heater operating. However, the area has a history of motor start issues. The area is predominately agricultural. All sites have motors that operate within limits but collectively operate outside of limits. The issues will persist and complaints will continue until work is done to improve the circuit performance. Capacity: Unionville substation is a 4.8kV distribution substation with two load carrying circuits. The substation is 111% of its firm rating and 91% of its emergency rating. Operability: Limited jumpering capabilities.
Zenon Circuit Conversion Phase 2	Detroit	Zenon Class A substation was constructed in 2012 with dual winding secondary voltage (4.8/13.2kV) transformers as a means to quickly transfer 4.8kV load from McKinstry substation while facilitating future 13.2kV conversion. Zenon Phase 1 was driven by the construction of the Gordie Howe International Bridge (GHIB) crossing, and the McKinstry substation conflicts with the project. Four 13.2kV circuits were commissioned to either remove, consolidate, and/or convert portions of McKinstry & West End in direct conflict with the bridge plaza and the remaining McKinstry circuits were transferred to the 4.8kV side of Zenon. Due to recent flooding events in the Scotten substation area, low reliability, high propensity of wiredowns on the 4.8kV system in the area, and load increases driven by West Riverfront and Corktown development, the second phase of Zenon Conversions is to be initiated. The scope within this project was submitted for Round 1 of GRIP/IIJA grants in 2023. The Company was not awarded a grant in Round 1 and is submitting a modified application in Round 2 in 2024. If the Company is awarded a grant in Round 2, the timing of the project will be accelerated. Safety: Zenon Class A substation was constructed in 2012 with dual winding secondary voltage (4.8/13.2kV) transformers as a means to quickly transfer 4.8kV load from McKinstry substation while facilitating future 13.2kV conversion Reliability. Recent flooding events in the Scotten substation area, low reliability, high propensity of wiredowns on the 4.8kV system in the area Capacity: Load increases driven by West Riverfront and Corktown developments Operability: Completing this work will decommission WSEND and SCOTN substation along with their associated 24kV trunk lines
Calla Circuit Conversion	Dexter	Safety:4.8kV Wire down elimination Reliability: Customers on a DIMND circuit regularly experience frequent and long duration outages. For this circuit, the SAIFI 5 year average is 2.25 and SAIDI 5 year average is 681. Capacity: This circuit is also over the Distribution Design Order limit of 8 MVA. DIMND Substation is 137% of firm rating. Operability: Customers at the end of this circuit are about ten miles from the substation and regularly experience low voltage/power quality issues. It also has limited jumpering points and capacity in the area needed to relieve load at adjacent substations. Other: Calla Substation and one distribution circuit from Calla were commissioned in 2021. The second Calla circuit will be established to relieve load from Diamond Substation and address the circuit's issues (listed above).

2

3

Line <u>No.</u> 1

Table 1 Conversion Projects, Continued

Project Name	Municipality	Drivers
Lapeer - Elba Expansion and Circuit Conversion (Apollo)	Lapeer and Elba	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: Lapeer and Elba substations have aging infrastructure and islanded 4.8 kV systems. Elba has problematic subtransmission infrastructure that has a history of poor reliability performance and limits shutdown capability for operation and maintenance. Capacity: Lapeer substation has a 13.2kV substation and a 4.8kV substation. The 13.2kV substation is at 107% of its firm rating. One circuit is at its day-to-day rating with another one approaching its day-to-day rating. Four circuits exceed the Distribution Design Order limit of 8MVA for a 13.2kV circuit. Elba substation is a two circuit 4.8kV substation. It is 125% of its firm rating and the substation transformer exceeds its day-to-day rating. One circuit exceeds its day-to-day rating. General load growth has been strong in the area (6-8% in 2017 and 2018). Operability:Limited jumpering options are available at Elba substation since it is an islanded 4.8kV substation. Other: The Lapeer-Elba area has also experienced several low voltage and power quality issues.
Birmingham Decommission and Circuit Conversion	City of Birmingham, Troy, and Bloomfield Hills	Safety: Birmingham substation is at high substation outage risk Reliabilty: This project is to address the loading, aging infrastructure and substation outage risk at Birmingham substation. In addition, Quarton Rd. substation is a 1948 vintage switchgear. QTNRD circuits will be left as an island with no jumper capability after BIHAM conversion. QTNRD has significant number of customer complaints due to aging infrastructure. Capacity: The substation is operating at its substation firm rating. Any new customer load or hot summer days will place the substation over its firm rating and in violation of DTE Electric's Distribution Design Standards. Operability: Birmingham substation, mainly serving downtown Birmingham, has a high substation outage risk. The stranded load is estimated at 21 MVA after possible load transfers and 19 MVA after mobile fleet deployments.
Hemlock Decommissioning and Circuit Conversion - 01	Ann Arbor	Safety: Mitigating 4.8kV wire downs and replacing aging infrastructure including equipment at an approximately 67 year old substation will improve public and operational safety Reliability: SAIFI 5 year average is 1.00 and SAIDI 5 year average is 485. Capacity: Two circuits exceed the Distribution Design Order limit of 3MVA for a 4.8kV circuit. Hemlock (HEMLK) is a 4.8kV substation that is at 93% of its firm rating. The Ann Arbor area has a high percentage of electric vehicle adoption and has a goal of carbon neutrality and the elimination of natural gas heating; as a result, there is a 44% projected 15- year load growth in the area. Operability: Hemlock area is adjacent to both 13.2kV and 4.8kV substation areas which limits the jumpering capabilities for emergency restoration.
White Lake Decommissioning and Circuit Conversion	White Lake Twp., Springfield Twp., Highland Twp., Rose Twp.	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: WHTLK substation is an older substation with multiple at-risk equipment that need to be upgraded or replaced. There is also a 40kV capacitor (CAP1-1) that has multiple at- risk equipment in need of upgrade or replacement. The existing substation site is too small to support replacing major equipment. Capacity: White Lake (WHTLK) has a 4.8kV substation and a 13.2kV substation. Each one has a single transformer and a single circuit. The 13.2kV substation is 88% of its firm rating. The circuit exceeds the Distribution Design Order limit of 8MVA for a 13.2kV circuit. The 4.8kV substation is 100% of its firm rating. The circuit is at 100% of its day to day rating and exceeds the Distribution Design Order limit of 3MVA for a 4.8kV circuit. Operability: White Lake circuits cannot be jumpered to one another because of the different operating voltages (4.8kV)

1	Q25.	Are there specific 4.8 kV Conversion projects you would like to discuss in more
2		detail?
3	A25.	Yes. In addition to the CODI 4.8 kV conversion projects that are discussed later in
4		my testimony, I would like to highlight a couple of examples beyond what is
5		contained in the exhibits to establish a deeper understanding of their scope, the
6		rationale for making the investments, and the benefits customers will receive.
7		• I-94 Substation and Circuit Conversion (Promenade)
8		• Lapeer – Elba Expansion and Circuit Conversion (Apollo)
9		
10	Q26.	What are the drivers of the I-94 Substation and Circuit Conversion
11		(Promenade)?
12	A26.	The Detroit I-94 industrial park is expected to add new commercial and industrial
13		customers to this area. This will result in increased loads that the current 4.8 kV
14		system will not be able to adequately support.
15		
16		The Promenade project will also provide relief to the increased capacity demand
17		from the Detroit Public Lighting Department (PLD) conversions. This increased
18		demand is caused by the transfer of customers from the former Detroit owned PLD
19		system to the Company's system, resulting in overloads in some areas which
20		created planning criteria violations with detrimental impact to operational
21		flexibility and service reliability.
22		
23		Also, the Promenade project address existing ITC transmission system loading
24		violations. Currently, the ITC transmission system feeding the east downtown area
25		has several Midcontinent Independent System Operator (MISO) loading violations

2

3

4

which require mitigation. Engineers from ITC and DTE Energy collaborated to develop a set of projects to resolve the transmission system violations, with Promenade being one of these projects, resulting in a \$130M reduction over the original proposed ITC solution.

5

6 Q27. What is the scope of the I-94 Substation and Circuit Conversion (Promenade)?

7 A27. This project is located on the eastside of Detroit and involves construction of the 8 new 120 kV to 13.2 kV Promenade substation and the conversion and transfer of 9 4.8 kV circuits out of Lambert, Lynch, and Pulford to the new Promenade 10 substation. In total 23 circuits (8 Lambert, 5 Lynch, and 10 Pulford circuits) 11 comprising of approximately 100 miles of 4.8 kV circuits will be modernized and 12 converted to six 13.2 kV circuits. Transferring the 23 circuits to Promenade will 13 support the decommissioning of Lambert, Lynch, and Pulford substations. Additionally, the new 120 kV transmission feed will allow for the decommissioning 14 of four 24 kV trunk lines with a weighted average age (WAA)¹ of 90 years. 15

16

17 Q28. What are the benefits of the I-94 Substation and Circuit Conversion 18 (Promenade) project?

A28. The I-94 Substation and Circuit Conversion (Promenade) project eliminates
existing ITC transmission system violations and provides 30% additional
substation distribution capacity to serve residential, commercial, and industrial
customers in the city of Detroit and in the area southwest of Detroit City Airport.
The new 13.2 kV Promenade substation will support the decommissioning of
existing 4.8 kV substations Lambert, Lynch, and Pulford; all of which have

¹ Weighted Average Age - The ages of the cables weighted by length.

1		surpassed the practical service life and are beyond 70 years old . Decommissioning
2		these substations will remove at risk equipment, including 10 transformers, more
3		than 20 regulators, more than 20 oil circuit breakers and disconnects, more than 20
4		miles of 4.8 kV underground cable, and more than 30 miles of 24 kV underground
5		cable. In addition to capacity, conversion of the circuits will improve safety and
6		reliability for the customers in this area with a projected 75-80% reduction in SAIDI
7		and removal of all PLD primary and arc wire in this area.
8		
9	Q29.	What are the drivers of the Lapeer – Elba Expansion and Circuit Conversion
10		project?
11	A29.	Lapeer substation consists of 40 kV to 4.8 kV infrastructure and 40 kV to 13.2 kV
12		infrastructure, while Elba is a 4.8 kV substation. The Lapeer 4.8 kV substation is
13		approaching its firm rating at summer peak, and Elba substation has already
14		exceeded its firm rating (124%), thus it is unable to accommodate any additional
15		load growth in the area. Furthermore, there is no capability for Elba's downstream
16		load to be transferred to an adjacent substation since it is an islanded 4.8kV area
17		surrounded by 13.2 kV substations. This condition, if not mitigated, will result in
18		extended restoration time in the event of an outage due to equipment failure.
19		
20		Elba substation is almost 70 years old and is fed from a 6-mile 40 kV dedicated
21		overhead line that has experienced poor reliability performance due to its location
22		in a heavily treed right-of-way with limited shutdown capability for operation and
23		maintenance. Due to the age of the electrical infrastructure in this area, there are
24		several reliability and operability concerns.
25		

3 A30. This project is in Lapeer County, just north of I-69, and involves construction of 4 the new 120 kV to 13.2 kV Apollo substation. Once the Apollo substation is 5 energized, load from Lapeer, Hunters Creek, and Elba substations will be 6 transferred to Apollo and four 4.8 kV circuits totaling 32 miles from Lapeer and 7 Elba substations will be converted and consolidated to two 13.2 kV circuits. 8 Following the transfer of all load, the Elba substation, the 40 kV subtransmission 9 overhead line feeding Elba, and the 4.8 kV substation at Lapeer will be 10 decommissioned.

11

Line

No.

Q31. What are the benefits of the Lapeer – Elba Expansion and Circuit Conversion project?

- A31. The Lapeer Elba project provides load relief and a 50 MVA capacity increase for
 new growth in Lapeer County. The decommissioning of Elba and Lapeer 4.8 kV
 substations will reduce outage risk by removing aging infrastructure from the
 system. Additionally, new jumpering capability will be established with the
 elimination of the 4.8 kV islanded system. Furthermore, reliability and power
 quality will be enhanced with the upgraded distribution circuits and elimination of
 the poor performing 40 kV overhead infrastructure feeding Elba.
- 21
- 22

City of Detroit Infrastructure (CODI) Conversion Program

23

24 Q32. What geographic areas of Detroit are addressed by the CODI program?

A32. As shown in Figure 3, the CODI program directly impacts the core Downtown,
Midtown, and New Center areas of Detroit. Additional projects within the CODI





6 Q33. How many customers are served in the CODI area?

A33. There are 31,800 customers served in this area including 27,486 residential, 4,299
commercial, and 15 industrial customers. Because customers are counted on a per
meter basis, in some cases a single customer count in the CODI area could be a
large commercial building, such as the Renaissance Center or a multi-tenant
building with hundreds of residential tenants. In addition to residential housing, this
area of Detroit is vital to hospitals, universities, tourism, and recreation in the region
including shopping, major sports and cultural venues, and parks.

1 **O34**. What are the drivers of the CODI program? 2 A34. The earliest electrical grid in southeast Michigan was developed in the downtown 3 area in the city of Detroit. Significant portions of the electrical infrastructure in 4 Detroit were placed in service in the early part of the 20th century, and much of 5 that original infrastructure remains. For example, Garfield substation was 6 constructed in 1930 and still provides electrical service to the Midtown area of 7 Detroit surrounding Wayne State University and the museum district. The early 8 electrical system architecture was designed to be extremely reliable; but as the age 9 of the infrastructure has increased, so have the equipment failure rates. These 10 customers continue to experience power outages and power quality issues from 11 equipment failures related to aging infrastructure on the system (4.8 kV & 24 kV 12 cable, netbank transformer, and substation induction regulator failures). 13 14 In addition to the challenge of aging equipment, the downtown CODI area has 15 experienced 9.5% load growth (31 MVA) in the last decade, with the potential for 16 an additional 10% load growth by the end of 2035. Additional load growth is 17 mainly driven by the completion of downtown development projects in 18 construction whose completion was delayed by the pandemic, known developer 19 and economic development projects, and increased electrification. 20 21 The CODI area is extremely critical to the City of Detroit and the Michigan 22 economy. Therefore, the system aging infrastructure, which is nearing one hundred 23 years in service, must be upgraded to maintain its integrity and to serve the 24 increasing load in the area. Some of the notable new load projects in the last decade

are Little Caesars Arena, David Whitney Building, Q Line Light Rail System,

25

<u>No.</u>

Wayne State School of Business and Hillberry Theater Expansion, Book Tower, 1 2 David Stott Building, Detroit Pistons Performance Center, and the Huntington 3 Bank Tower. These along with dozens of other completed new build/renovations 4 in the New Center, Midtown, and Central Business District areas of Detroit have 5 created significant load growth and economic momentum in the CODI area, which 6 will continue with the pipeline of future projects. 7 8 Q35. Are there additional drivers for the CODI program? 9 A35. Yes. The load growth realized over the last decade and projected in the future are 10 not the only drivers of the CODI program. The aged 4.8 kV & 24 kV electrical 11 infrastructure (substations, underground cable, manholes, network equipment, and 12 other assets) in this area is experiencing higher failure rates which increases the risk 13 of long-duration outages impacting customers and leading to high reactive 14 maintenance costs. Eighty percent of the installed 4.8 kV and 24 kV infrastructure 15 in the CODI footprint has been in service for over 60 years and is considered "at 16 risk" as evidenced by the historical failure rate curve shown in Figure 4. 17

Figure 4 CODI 4.8 & 24 kV mileage distribution over system failure

rate curve



Line No.

1

2

The existing 4.8 kV multi-level in-building substations are space constrained to install or replace infrastructure with modern equivalents. Vintage equipment continues to be refurbished or repaired post failure and put back into service. This practice is not only costly, but it is also not considered to be good utility practice. The continued implementation of the CODI program is necessary to address this aging infrastructure to serve the customers safely and reliably.

10

3

11 Q36. What are the challenges with implementing the CODI program?

A36. Due to the complexity and the interdependency of the electrical infrastructure in this area, the Company developed the CODI program. The construction of new substations, upgrades to existing substations, converting the existing AC network system from 4.8 kV to 13.2 kV, and additional circuit upgrades must be sequenced and conducted in a robust, multi-year program as opposed to individual projects in isolation to each other. These projects require complex system shutdowns in a congested downtown district that must be managed carefully due to the critical Line No.

customer loads that will be impacted, including hospitals, federal and municipal
 emergency centers, and multiple corporate headquarters. The CODI program is
 sequenced to perform the needed upgrades in a manner that is least impactful to
 customers.

5

Q37. What unique drivers that support prioritizing the CODI program to be completed in the next decade?

8 A37. The CODI area is served primarily by an all-underground system with manhole 9 access located in busy city center streets. Its reliability is dependent upon the ability 10 to have redundant capacity available on all power lines to transfer load in the event 11 of cable failures or planned shutdowns on the distribution and subtransmission 12 systems. This system is designed for N-1 contingency situations, which means that 13 if a single trouble event is occurring on the system at any one time, the system is 14 still able to serve all load. Manholes typically support multiple system cables, and 15 a failure of one cable can impact adjacent cables resulting in cascading failures. 16 Due to the amount of aging high-risk cable and equipment, the integrity, and the 17 reliability of the underground system is compromised. This has resulted in an 18 increased frequency of cases of multiple trouble events occurring simultaneously 19 that are beyond the original system design criteria (N-1-1 and N-2 events) resulting 20 in critical customer outages or complex contingency staging and planning of 21 emergency equipment throughout downtown Detroit. Frequently when outage or 22 next contingency events do occur in the CODI area, the Company has limited 23 ability to respond and restore customers with alternative emergency measures; such 24 as portable substations, diesel generators, or circuit load transfers given the space 25 constraints of the congested downtown environment, inaccessible underground
2

3

4

Company infrastructure, and customer service gear located deep below grade in sub basements. These contingency plans are often not only time consuming but extremely challenging to execute.

5 When the CODI strategy was first conceptualized in 2015, the majority of the 24 6 kV and 4.8 kV cable in scope had a weighted average age of 65 years with some of 7 the oldest sections being beyond 90 years of service age. With the current target 8 completion date of 2035, sections of 4.8 kV and 24 kV cable will be in service for 9 over 110 years at that point. With the failure rate of paper and lead cable increasing 10 with age, these cables must be replaced to maintain the integrity and reliability of 11 the system. The current pace of the CODI program addresses these necessary 12 replacements in the maximum allowable timeframe and the Company continues to seek ways to increase efficiencies and accelerate implementation. 13

14

To ensure crew safety, DTE underground work rules prohibit personnel from entering manholes with swollen or leaking lead sleeves, shown in Figure 5, due to the possibility of an imminent failure, and therefore, these cables may need to be de-energized before entering.

Figure 5 Leaking & swollen sleeve examples





2

3

4

5

6

7

8

9

An increasing frequency of these types of adjacent hazards occurring simultaneously within the same manholes requires the Company to go to significant and impactful measures and implement emergency responses such as customer intentional interruptions, installation of temporary cable at grade, distributed generator staging installation in tight urban areas requiring street shutdowns, and expensive temporary re-routes of circuits, etc. to address safety issues and restore the system to normal.

10

11 The only method to completely mitigate the undergrounding reliability and safety 12 issues is the replacement of old paper and lead cable with new ethylene propylene 13 rubber (EPR) cable that does not have the same high failure rates and hazard issues 14 with lead joints. The CODI program complements other grid investment programs 15 by also reducing the totality of the 4.8 kV and 24 kV system that need to be 16 replaced.

1		Without these investments, the increasing failure rates of aged equipment, coupled
2		with the load growth in the CODI area, will increase the frequency of outage events
3		that affect large portions of the downtown system. These events will impact more
4		customers and become more expensive and complicated to repair and restore.
5		
6	Q38.	What is driving the near-term AC Network replacements that are a critical
7		part of the CODI program?
8	A38.	The AC Network distribution system is recognized industry wide as the most
9		reliable circuit topology due to its meshed design with multiple, parallel sources.
10		This reliability advantage can only be preserved when the system is operated within
11		its contingency design, which for the DTE Energy AC Network is N-1.
12		
13		Due to the age of the system with components beyond their useful life, it is common
14		for the Detroit AC Network to experience concurrent failures. These failures can
15		lead to customer and system impacts including cascading low voltage issues, grid
16		fires, manhole eruptions and customer outages. Table 2 lists the AC network outage
17		events from 2016 through 2023.

YEAR	FAILURE EVENTS	N-1	N-1-1	N-2	OUTAGE EVENTS
2016	24	21	1	2	3
2017	21	20	1	0	1
2018	19	17	2	0	2
2019	27	22	3	2	5
2020	14	12	1	1	2
2021	15	11	3	1	4
2022	16	12	2	2	4
2023	16	15	1	0	1
TOTAL	152	130	14	8	22

1	The downtown Detroit AC Network has experienced customer outages 22 times
2	since 2016 or an average of 2.75 outages per year. This is concerning, as AC
3	Network systems normally provide reliability that exceeds radial systems.
4	Typically, a network customer can expect to be out of service once every 58 years
5	and experience 4% of the interruptions of a radial underground system (New York
6	Public Service Commission, 2009 as quoted in Smith & Moffat 2010) ² .
7	
8	Downtown Detroit AC Network customers have not only experienced significantly
9	more outages than typical indices, which will become more frequent as age related
10	failure rates increase (as shown in Figure 4 above), but AC Network outages are
11	also long duration events that are difficult to quickly restore as previously stated.
12	Typical CAIDI for networks is 3.4 times longer than that of a radial system (New
13	York Public Service Commission 2009 as quoted in Smith & Moffat 2010).
14	
15	The existing AC Network system, operating at 4.8 kV, is capacity constrained in
16	some local areas of growth based on cable size and number of network feeders, thus
17	necessitating the conversion to a higher voltage class. Conversion allows for fewer
18	network feeders to serve a given area of the system while increasing capacity. The
19	Garfield Network Conversion project, as an example, reduces the number of
20	netbank transformers required by 30% but increases Network Capacity by 21.8
21	MVA, all while reducing the weighted average age of the system primary cable by
22	69 years at project completion. The reduction in equipment will reduce associated
23	maintenance costs over time. Figure 6 shows some of the Garfield AC network
24	project benefits

² D. Smith and J. Moffat, "EPRI Underground Distribution Systems Reference Book" (City: Publisher, 2010), Chapter 21, p. 21.





Line

No.

1

2

4 Q39. What is the scope of the projects in the CODI program included in this case? 5 A39. The CODI program converts and consolidates substations, the AC network, and 6 associated overhead circuits. This program will construct two new 13.2 kV 7 substations (Corktown and Island View), expand three existing 13.2 kV substations 8 (Midtown, Alfred, and Cato), and decommission five 4.8 kV substations (Charlotte, 9 Walker, Howard, Kent, and Gibson). This program also converts and consolidates 10 the AC network system, as well as converting and consolidating the associated 11 overhead circuits from 4.8 kV to 13.2 kV. The program also includes 12 decommissioning the aged underground 4.8 kV and 24 kV cables in the CODI 13 footprint as shown in Figure 3. Table 3 provides a high-level summary of the 14 projects in the CODI program with additional details provided in Exhibit A-23 Schedule M6. 15

Table 3	City of Detroit Infrastructure Project	ts
---------	--	----

Project	Key Scope of Work	Estimated Timeline	
CODI: Charlotte Network Upgrade	 * Rebuild 30 miles of network feeder cable * Rebuild 7 miles of system cable * Replace or remove 83 netbank transformers * Convert 8 primary customers * Convert the circuits to 13.2kV * Decommission Charlotte substation 	2016-2025	
CODI: Targeted Network Secondary Cable Replacement	Replace targeted sections of the secondary network cable system that have a higher probability of failure	2017-2025	
CODI: Midtown Substation Expansion	Expand 13.2kV Midtown substation by installing a 3rd transformer and a 12-position switchgear	2017-2024	
CODI: Alfred Substation Expansion	Expand 13.2kV Alfred substation by installing a 3rd transformer and a 12-position switchgear	2018-2025	
CODI: Corktown Substation	Build a new general-purpose substation	2018-2023	
CODI: Garfield Network Upgrade	 * Rebuild 36 miles of network feeder cable * Replace or remove 78 netbank transformers * Convert 24 miles of overhead * Convert and consolidate the circuits to 13.2kV fed by Stone Pool substation * Remove 4.8kV and 24kV cable and decommission Garfield substation 	2019-2026	

Line

<u>No.</u>

Table 3 City of Detroit Infrastructure Projects, Continued

Project	Key Scope Of Work	Estimated Timeline
CODI: Islandview Substation	*Construct a new 13.2kV substation * Convert 32 existing 4.8kV circuits from Walker and Pulford *Decommission Walker substation * Decommission aging 24kV cables and infrastructure	2020-2031
CODI: Kent/Gibson Conversion	Kent Substation Rebuild 6 miles of system cable Convert 1 primary customer Convert 7 miles of overhead Convert and consolidate the circuits to 13.2kV fed by Corktown substation Decommission and remove 2 miles of 4.8kV cable Remove 24kV cable and equipment Remove 6 breakers and decommission Kent substation <u>Gibson Substation</u> Rebuild 10 miles of system cable Convert and consolidate the circuits to 13.2kV fed by Corktown substation Gibson Substation Rebuild 10 miles of system cable Convert and consolidate the circuits to 13.2kV fed by Corktown substation Becommission and remove 4 miles of 4.8kV cable Remove 24kV cable and equipment Remove 8 breakers and decommission Kent substation 	2021-2028
CODI: CATO Substation Expansion	Expand 13.2kV Cato substation by installing a 3rd transformer and a 12-position switchgear	2021-2027

Table 3 City of Detroit Infrastructure Projects, Continued

Project	Key Scope Of Work	Estimated Timeline
CODI: Garfield	* Convert 17 miles of overhead from 4.8kV to	2022-2026
Radial (Midtown	13.2kV	
Circuits)	* Convert 11 primary customers from 4.8 kV	
	to 13.2 kV	
	* Convert and consolidate the circuits to 13.2	
	kV fed by Midtown substation	
	* Decommission 5 miles of UG cable	
CODI: Howard	* Rebuild 6 miles of network feeder cable	2023-2032
Conversion	* Rebuild 12 miles of system cable	
	* Replace or remove 89 netbank transformers	
	* Convert 26 primary customers	
	* Convert 3 miles of overhead	
	* Convert and consolidate the circuits to	
	13.2kV fed by Corktown, St. Antoine, Cato,	
	and Temple substations	
	* Decommission Howard substation	

2

Q40. What steps is the Company taking to ensure that the CODI program is executed successfully to achieve the projected investment forecast?

5 A40. The Company's recently formed Project Management Office (PMO) is using 6 developed project management expertise as well as updated processes and 7 leveraging project learnings to ensure the successful execution of all DO capital 8 projects, including the CODI program. The formation of this team focused on 9 construction of investments is further discussed by Witness Kryscynski.

10

11 The Charlotte and Garfield AC Network conversion projects were able to identify 12 the equipment, technologies, and standards that would be used in AC network and 13 urban underground conversions going forward. As a result, in these early projects, 14 much of the up-front investment was in foundational engineering and design 15 considerations that will benefit subsequent projects. With this work now

2

3

completed, the pace of field execution will be able to advance faster on inflight and future projects.

The initial years of the CODI project, as shown in Figure 7, were used to construct 4 5 much of the 13.2 kV substation infrastructure, to support the subsequent projects 6 including circuit conversion and the transfer load from the 4.8 kV CODI systems. 7 During this timeframe, the construction was limited to only a few simultaneous 8 projects (Midtown, Alfred, Island View and Corktown substation) and the CODI 9 funding levels reflected these limited investments. Currently, in the ninth year of 10 this program as shown in Figure 7, up to eight simultaneous projects of multiple 11 labor resource types (substation, conduit/netbank construction, underground 12 pulling and splicing, and overhead pre-conversion and conversion) are running at 13 any one time in different areas of the CODI system. The CODI program can now 14 support an increased level of spending because the different design and labor 15 resources do not conflict with one another's execution.

- 16
- 17
- 18



Figure 7 CODI Strategy Initiatives and Projects

Line No. 1 4.8 kV ISO Conversion Program 2 3 **Q41**. What is an ISO down? 4 In some areas, the Company operates portions of circuits at 4.8 kV fed from a 13.2 A41. 5 kV substation, known as isolation down circuits (ISO down). The reason for this 6 grid configuration is that in some instances, there was a need to address immediate 7 overloading on a circuit or circuits fed from a substation at which other circuits 8 were not overloaded. The circuit overload issue can be addressed by building a 9 higher voltage substation, typically 13.2 kV, and initially converting only the 10 overloaded circuits, or portions of the circuits, to the higher voltage, while operating 11 the remaining non-overloaded circuits at the existing voltage, typically 4.8 kV. 12 Portions of the circuits which were not modernized and converted to 13.2 kV will 13 include an isolation down transformer and continue to be served at 4.8 kV. Figure 14 8 illustrates a 13.2 kV circuit utilizing an ISO down.

15







- 18 Table 4 provides the number of circuits with ISO downs, number of customers
- 19 served, and the 4.8kV OH and underground line miles.

No.	

Line

1
T.

2

	Number of Circuits	Number Of Customers	Miles Overhead Circuit	Miles Underground Circuit
4.8kV ISO Downs	432	142,335	5,596	417

Table 4Number of Circuits with ISO Downs

3 Q42. Why are ISO downs not considered a permanent solution to address 4 overloaded circuits?

5 A42. The installation of ISO's has been a cost-effective and faster approach to address 6 loading concerns at source substations without full conversion of the entire 7 downstream circuits. This was always intended as a temporary measure. While at 8 the time they didn't face the overloads that caused the substations and some circuits 9 to be converted, the 4.8 kV ISO downed areas of the circuits have not been 10 upgraded or modernized and have the same characteristics of ungrounded 4.8 kV 11 circuits fed from 4.8 kV substations. They have the same reliability issues, safety 12 risks, and operational concerns, and face the same challenges when it comes to 13 incorporating increasing EVs and DERs.

14

15 Q43. What is the scope of work for converting ISO down circuits?

A43. Similar to circuit conversions that are part of the Conversions program, the ISO
down program is aimed at modernizing the 4.8 kV portions of the circuits to a
higher voltage. The scope of work for the 4.8 kV ISO down conversions includes:

- 19 20
- Completing overhead pre-conversion work including rebuilding pole tops, replacing poles and transformers as needed, and installing neutral wire.
- 21
- Rebuilding underground infrastructure as needed.

SSD-40

Line <u>No.</u>		U-21534
1		• Reconductoring overhead wires as needed based on new circuit
2		configurations and existing wire size.
3		• Reconfiguring circuits and establishing new jumpering points.
4		• Installing controls and automation in the substations and circuits to our latest
5		design standards
6		Removing ISO down transformers.
7		
8	Q44.	What are the benefits of the 4.8 kV ISO Conversion program?
9	A44.	The ISO conversion projects are expected to bring multiple benefits similar to full
10		conversion projects, including safety improvements by reducing wire downs,
11		improving reliability through newly updated equipment, enabling technology
12		modernization, providing additional capacity; and avoiding costs associated with
13		increasing failure of aging infrastructure. Like a full conversion and consolidation
14		project, 4.8kV ISO conversions are expected to deliver up to 90% reliability
15		improvements for the areas impacted, as described in detail starting on page SSD-
16		14.
17		
18	Q45.	How are circuits in the 4.8kV ISO Conversion program prioritized?
19	A45.	The 4.8kV ISO Conversion program is ranked as a whole using the GPM which
20		considers substation firm rating, circuit overloads, wire downs per OH mile,
21		substation risk, and energy justice (EJ), as discussed in detail by Witness
22		Kryscynski. The Company prioritizes the order to address ISO down locations
23		based on specific criteria, with safety being the primary driver in the prioritization
24		efforts. Work is prioritized at the substation level, as it is more efficient to plan and

25 perform the work for the group of circuits tied to the same substation. Each ISO

Line <u>No.</u>	S. S. DEOL U-21534
1	down is scored based on the following factors, with total scores rolling up to the
2	substation level:
3	1) Recorded wire downs;
4	2) Total substation SAIDI;
5	3) Total outage and non-outage events, such as low voltage, requiring the dispatch
6	of a line crew.
7	
8	Additionally, the Company recognizes that other priorities such as load growth and
9	the need for operational flexibility are also important considerations in determining
10	the execution order of ISO down conversion and will incorporate these
11	considerations on as needed basis.
12	
13	Work to begin 4.8 kV ISO conversions has been initiated on the four highest
14	priority substations, which are shown in Table 5.
15	Table 5ISO Conversion Rankings

Ranking	Substation	Community	4.8kV miles to convert
1	Camden	Pontiac	3.8
2	Kern	Pontiac	8.3
3	Gilbert	Romulus	5.8
4	Biddle	Wayne	11.7

	8.3 kV	Pontiac	Conversion
--	--------	---------	------------

1

3 Q46. What are the drivers of the 8.3 kV Pontiac Conversion program?

4 A46. The Pontiac area is the only 8.3 kV in the Company's distribution system, as the 5 system was acquired from CMS Energy in the 1980s (additional detail on the 8.3 6 kV system can be found in Exhibit A-23 Schedule M8 DGP starting on page 123). 7 Unlike the 4.8 kV and 13.2 kV systems, contingency options to support alternate 8 routing of power under an outage situation are very limited for the 8.3 kV system 9 through jumpering. The 8.3 kV system is essentially an island surrounded by the 10 13.2 kV system, making it extremely challenging to transfer load from 13.2 kV 11 circuits to 8.3 kV circuits and from 8.3 kV circuits to 13.2 kV circuits. This results 12 in a high risk for stranded load in the event of a substation outage event.

13

14 Adding to this operational challenge, the 8.3 kV system is aged, and many 15 replacement parts are no longer available. Due to the design configuration and 16 timeframe when these substations were built, they have tighter, non-standard 17 clearances between equipment. For Company employees to prevent arc flashes and 18 maintain safe working conditions, total substation shutdowns are required when 19 doing equipment maintenance, versus isolating a single piece of equipment as is 20 done in other voltage substations. This leads to extended customer interruptions 21 during outage events and leaves the system in an abnormal state for extended 22 periods of time if any 8.3 kV equipment fails.

23

Additionally, the 8.3 kV conversion program is necessary to increase capacity,
improve reliability, safety, and operability.

1	Q47.	What is the scope of the 8.3 kV Pontiac Conversion Program?
2	A47.	The 8.3 kV system is served by four substations: Bartlett, Paddock, Rapid Street,
3		and Stockwell and their combined eighteen (18) distribution circuits. The plan to
4		address the 8.3 kV system has been developed, starting with upgrading the system
5		underground vaults, additional project detailed information is provided in exhibit
6		A-23 Schedule M6 as well as Section 9.3.7 of Exhibit A-23 Schedule M8 DGP.
7		The additional scope for converting the 8.3 kV system includes expanding the
8		existing 13.2 kV Catalina and Wheeler substations to add capacity. Once the
9		Catalina and Wheeler substation expansions are completed, the overhead and
10		underground infrastructure from Bartlett, Paddock, Rapid Street, and Stockwell
11		substations will be converted and transferred to new 13.2kV circuits.
12		
13		Additionally, the 8.3 kV conversion program will decommission all four 8.3 kV
14		substations in the Pontiac area. The removal of at-risk, outdated, and obsolete 8.3
15		kV equipment from the system will reduce emergent costs and improve response
16		time for customer restoration.
17		
18	Q48.	What are the 8.3 kV Pontiac Conversion projects included in this case?
19	A48.	The table below provides the high-level summary of the 8.3 kV Pontiac Conversion
20		projects included in this case. Detailed information for each of these projects is
21		provided in exhibit A-23 schedule M6.

Line <u>No.</u>

-1	
_	

Table 68.3 kV Pontiac Conversion Projects

Project Name	Municipality	Drivers
Infrastructure to support decommission of (8.3KV) sub - Pontiac OH	Pontiac	 Safety: 8.3kV causes a higher safety risk in the event of a failure due to aging and obsolete equipment Reliability: Replacement parts are no longer available for 8.3 kV breakers, other substation equipment. Non-standard clearances require substation shutdowns for operations and maintenance. This leads to extended customer interruptions during outage events and leaves the system in an abnormal state for extended periods of time if any 8.3 kV equipment fails. Capacity: The City of Pontiac is experiencing an economic rebound, with an estimated 40 MVA (37 percent) load growth in the next five to ten years. Operability: Because the 8.3 kV system is an island surrounded by the 13.2 kV system, it is impossible to transfer load from 8.3 kV circuits to neighboring facilities. This results in a high risk for stranded load in the event of an 8.3kV substation outage event.
Pontiac Underground Conversion	Pontiac	Safety: The aging 8.3kV system is Pontiac is obsolete and pose safety hazard for any repairs needed to be made. Reliability: Replacement parts are no longer available for 8.3 kV breakers, other substation equipment and equipment in the underground vaults due to their obsolescence. Non-standard clearances require substation shutdowns for operations and maintenance. This leads to extended customer interruptions during outage events and leaves the system in an abnormal state for extended periods of time if any 8.3 kV equipment fails. Operability: The 8.3kV system serves 29.5MVA of load and over 7,000 customers. The largest services are delivered through 8.3kV rated underground equipment. These services contain customer-owned switchgear, fuses, and transformers. Replacement of the 8.3kV substations with 13.2kV infrastructure requires the replacement of these services with 15kV rated equipment to enable better operability.

2

3 Q49. What are the benefits of the 8.3kV Pontiac Conversion?

4 A49. Like the other conversion programs, the 8.3 kV Pontiac conversion program is 5 projected to provide a net percentage reduction of up to 90% in customer minutes 6 of interruption, wire downs, and trouble events. Additionally, converting the 7 Pontiac system to 13.2kV will provide jumpering points from nearby 13.2 kV 8 substations. This will improve system operability and reduce outage restoration 9 time by allowing the Company to restore customers prior to repairing future 10 damaged infrastructure (restore before repair). The expanded 13.2 kV Wheeler 11 substation will provide capacity for future needs and better prepare the area for 12 adoption of EVs and DERs.

Line <u>No.</u>		S. S. DEOL U-21534
1		Subtransmission Redesign & Rebuild
2		
3	Q50.	Can you describe the Company's Subtransmission system?
4	A50.	The Company's Subtransmission system is an interconnected web that transmits
5		higher transmission voltage across the service territory to stations that step down
6		the voltage to distribution levels to serve customers. The subtransmission system
7		(operated at the voltages of 24 kV, 40 kV, or 120 kV) provides a vital service as
8		each subtransmission circuit serves one or more distribution substations, which
9		directly feed customers.
10		
11		The design of the subtransmission system is intended to provide redundancy and
12		therefore greater reliability to the feed points of the distribution substations. The
13		redundancy provides continued service to the customers during a single
14		contingency situation ³ .
15		
16		The Company's subtransmission system differs from that of most other utilities
17		because it includes station equipment, radial, and network designs. The radial
18		configuration, called a trunk line shown in Figure 9, has one source station which
19		then feeds one or multiple substations. The network configuration, called a tie line
20		shown in Figure 10, has multiple source stations, and feeds multiple substations.
21		

 $^{^{3}}$ The contingency state exists when there is an unplanned loss/failure of a component of the electric power system (e.g., transformer, cable, wire or breaker).





11 Q51. What type of analysis was performed to determine potential capacity 12 limitations in the subtransmission system?

- 13 A51. Subtransmission Planning Engineers analyze the condition of the system annually
- 14 to determine any existing or potential limitations to having adequate capacity to

Line No

1

2

3

4

5

<u>No.</u>

support customers in a single contingency situation. This analysis is conducted by utilizing industry-standard modeling software (PSSE & TARA), using both individual substation loads, and electric models used by the Midcontinent Independent System Operator (MISO).

6 The electric models provided by MISO include multiple system loading scenarios, 7 including current and projected future peak loading conditions. Using these 8 models, the engineers run a study on each individual subtransmission trunk or tie 9 line, with potential contingency situations assessed to identify all violations of 10 subtransmission planning criteria. The planning criteria focuses on both thermal 11 overloads and voltage violations under normal system conditions and during a 12 single contingency configuration. A thermal overload indicates that load on the 13 equipment on the circuit or station exceeds its rating, and a voltage violation 14 indicates that the voltage on at least part of the circuit is no longer within an 15 acceptable range. Similar methodology and guidelines are commonly used by other 16 utilities when performing their capital planning.

17

18 Q52. Why does the company plan to a single contingency scenario for the 19 subtransmission system?

A52. The company, consistent with standard industry planning approach, plans to a
single contingency scenario to provide continued service to customers in an outage
event. As an example, Figures 11 and 12 show a high-level trunk line configuration
in normal and single contingency scenario respectively. In a normal configuration,
two different trunk lines feed the multiple substations. Substations 1, 2, and 3 load
will be split between the two subtransmission circuits, as shown in Figure 11.

2

3

4

5

6

7

9

When one of the subtransmission circuits experiences an outage (single contingency), the second subtransmission circuit will have to carry all the load served by substations 1, 2, and 3 to prevent an extended outage, as shown in Figure 12. If this redundancy is not available, then the result is potentially a long duration outage that requires the deployment of costly mobile generation or portable substations to restore customers.

8

Figure 11









4 **Q5** 5

Q53. What are the challenges and issues associated with the subtransmission system?

6 Similar to the distribution system, the subtransmission system is experiencing A53. 7 aging, beyond 80 years old in some areas, and storm related resiliency challenges, 8 as well as increased loading in some areas, leading to loss of contingencies. Some 9 areas of the subtransmission overhead system are in difficult-to-access, deeply wooded areas and along railroads, increasing the time and difficulty for restoring 10 11 service or maintaining equipment. These factors are leading to an increased number 12 of failures on both the overhead and underground subtransmission systems and 13 lengthy restorations. Because of the role of subtransmission in powering and connecting substations in the larger grid, these failures can often result in much 14 15 larger sustained outages as well as the loss of redundancy, depending on the system 16 configuration. An outage event on the distribution system, downstream in the grid 17 from the subtransmission system, can typically impact up to $\sim 1,000$ customers, 18 depending on the size of the circuit. By comparison, an outage on the

Line No.

1

2

3

4

5

6

7

8

9

10

11

subtransmission system, because it's upstream in the grid, can impact multiple substations, which in some areas can result in more than 10,000 customers impacted.

Capacity analysis of the subtransmission system is performed annually, where actual and forecasted, loading is compared to a standard or target state, which is called "planning criteria." The Company performed an analysis on the subtransmission system that revealed approximately one-third of the circuits on the subtransmission system violated the Company's planning criteria. These violations have been/will be analyzed by the engineering team, and projects to resolve the capacity constraints are/will be developed.

12

13 In addition to current performance challenges impacting customer reliability, the 14 analysis showed that the Company's aging subtransmission system overall is not 15 adequate to serve short and longer-term needs, given its limited capacity and 16 reliability performance. In some areas of the grid loads have increased over time 17 and impacted customer outages by reducing the redundancy that is essential for 18 continued reliability as well as operability of the system. Existing overloads and 19 the aging equipment place loading constraints on the system. These constraints 20 limit the Company's ability to plan for shutdowns required for system upgrade 21 projects and routine maintenance to only be completed during periods of lower 22 loading or through the deployment of portable equipment. These periods of lower 23 loading are typically only during a few weeks in the spring and the fall season. The 24 loading constraints also make it challenging to add new customers or provide 25 additional capacity for existing customers with increased load.

Line <u>No.</u>

<u>No.</u>		
1	Q54.	What are the benefits of the Subtransmission Redesign and Rebuild Projects?
2	A54.	A rebuilt, hardened, resilient subtransmission system will dramatically improve
3		safety, reliability, and operability, and increase capacity. The resiliency of the
4		overhead subtransmission system will be achieved by rebuilding to the Company's
5		grade B standard which will harden against weather impacts such as high winds
6		and lighting. The rebuilt overhead subtransmission system will have stronger steel
7		poles and larger conductor to provide additional capacity and reduce voltage drop
8		over long distances. The underground subtransmission reliability will improve due
9		to the removal of at-risk or overloaded cables. Additionally, rebuilding the
10		subtransmission system will also remove aging equipment reducing the probability
11		of equipment failures. Furthermore, the rebuilt subtransmission system will be
12		designed to provide redundancy to reduce subtransmission level outages impacting
13		customers.
14		
15		This rebuilt and redesigned subtransmission system will support area load growth
16		for existing and new customers, and with updated technology will provide the
17		ability to support DER interconnections, including large-scale solar arrays. As the
18		generation profile is expected to change with the integration of more DERs and the
19		retirement of fossil generation plants, improvements to the subtransmission system
20		will support the changing power flows on the system.
21		
22	Q55.	What is the scope of the Subtransmission Redesign & Rebuild program?
23	A55.	The subtransmission redesign and rebuild program is focused on installing new
24		station equipment, as well as rebuilding both the overhead and underground
25		portions of the subtransmission system. The station work involves the installation

1	of large new transformers, capacitor banks and associated equipment, which
2	provides significant improvements to the system with additional redundancy and
3	voltage support. The overhead work will be completed to updated, more resilient
4	standards which include the replacement of aged wood poles with new steel poles,
5	porcelain insulators with polymer clamp top insulators, and smaller and aging
6	conductors with larger wires. The new stronger poles are able to withstand winds
7	up to 90 mph resulting in a much more storm resilient system. The larger wire
8	standard conductor delivers multiple benefits such as providing significantly more
9	capacity on each circuit, reducing the magnitude of voltage drop over long distances
10	on the system, and additionally providing approximately twice the strength of
11	existing conductors to withstand contact with a tree limb during storms or other tree
12	related events. Similar to overhead construction, the underground work consists of
13	replacing at-risk or overloaded cable with new sections and rebuilding cable poles
14	to new standards, supporting greater reliability for both the underground cables
15	themselves, as well as preventing cable failure impacts to adjacent cables in the
16	same underground section of the system.

18 Q56. How did the Company develop the Subtransmission Redesign & Rebuild 19 Program?

A56. The Subtransmission Redesign & Rebuild Program was developed to address the
 identified planning criteria violations and the reliability performance concerns in
 the subtransmission system. To determine which subtransmission projects would
 have the greatest impact on reliability and resiliency of the system, the Company
 reviewed:

Lina	S. S. DEOL
No.	0-21334
1	1) current system planning criteria violations, related to loading and
2	voltage challenges;
3	2) future distribution system plans and loading projections; and
4	3) customer outages caused by subtransmission failures.
5	
6	The Company then ranked the planning criteria violations based on severity, and
7	projects were identified that could address the limiting elements on the system.
8	
9	The scope of the projects and future subtransmission system configuration also
10	support distribution system conversion plans that include the construction of new
11	higher voltage and retirement of aged lower voltage substations. The distribution
12	system conversion plans provide the necessary input to ensure the scope of the
13	subtransmission projects will meet the requirements of our customers for decades
14	to come.
15	
16	In addition to planning criteria violations and future distribution system plans, the
17	Subtransmission Planning engineers monitor the reliability of the system and
18	identify circuits with multiple reliability issues related to subtransmission failures.
19	These circuits are identified, and the subtransmission-related outages are analyzed
20	to determine the most effective project to improve reliability performance. The
21	planning engineers consider both existing routes of the lines that may require
22	rebuilding in place, and sections where multiple wire down events have occurred,
23	which might merit relocation. Based on their analysis, the planning engineers
24	identify which sections to focus on for redesign and rebuild of the lines. The
25	projects that address individual sections of subtransmission include rebuilding to

Line <u>No.</u>		S. S. DEOL U-21534
1		the current more resilient construction standards and relocating the lines to road
2		accessibility wherever possible.
3		
4	Q57.	How does the Company determine priorities when selecting circuits for
5		Subtransmission Redesign and Rebuild program?
6	A57.	The company's engineers select circuits for the Subtransmission Redesign and
7		Rebuild program by evaluating system loading and reliability on an annual basis
8		and rank the violations based on severity. DTE Energy considers six criteria when
9		ranking the violations, described in Table 7. The first four criteria are part of what
10		are called planning criteria violations. A planning criteria violation means that in
11		either normal state or single contingency state, the system does not have adequate
12		capacity to serve the existing load without exceeding equipment ratings or voltage
13		standards. Projects are then developed to alleviate the violations.

Table 7	Subtransmis	sion Priority	Criteria

Subtransmission Priority Criteria	Definition
Load Loss for Single Contingency	Total load that will be shed when a subtransmission line can no longer support the substation and does not have a back-up or the back-up cannot support the load
Load over Emergency Rating for Single Contingency	Total lþad when a subtransmission line exceeds its emergency rating of its alternative route during an event (i.e., outage)
Load over Day to Day Rating, Normal Conditions	Total load that exceeds the rating of a subtransmission line during normal conditions
Voltage Violation	Consideration given to subtransmission lines that experience low voltage conditions when they are not in their normal configuration (i.e., due to an outage)
Strong Load Growth Prospect	Consideration given to subtransmission lines that are predicted to experience load growth
Reliability Impact	Consideration given for the reliability of the subtransmission lines based on total sustained outages, miles of circuit, exposure, construction standards & equipment total customers and total load served and ability to serve load from an alternate source

3		Consistent with other strategic projects and programs, the Subtransmission Rebuild
4		and Redesign projects are prioritized using the GPM which is discussed in detail
5		by Witness Kryscynski.
6		
7	Q58.	Can you please describe the Subtransmission Redesign and Rebuild projects
8		included in this case?
9	A58.	Table 8 provides the high-level summary of the Subtransmission Redesign and
10		Rebuild projects included in this case. Detailed information for each of these
11		projects is provided in exhibit A-23 schedule M6.

Table 8Subtransmission Projects

Project Name	Municipality	Drivers
Ann Arbor System Improvements: State Substation	Ann Arbor	Reliability: The existing distribution system in the Greater Ann Arbor area experiences frequent reliability and power quality issues. Voltage sags and outages are frequent in the area, negatively affecting customers. Capacity: The subtransmission system in Ann Arbor is not adequately sized to accommodate existing load and accelerated load growth in the area. The overloaded system is an impediment to economic growth. Operability: There is currently limited ability to jumper/transfer load to adjacent substations during emergency situations or for routine maintenance. This project, coupled with the other Ann Arbor System Improvements Projects Apex, Argo, and Buckler Circuit Conversions, will address these issues.
Ann Arbor System Improvements: Apex (Blue) Substation	Ann Arbor	Reliability: The existing distribution system in the Greater Ann Arbor area experiences frequent reliability and power quality issues. Voltage sags and outages are frequent in the area, negatively affecting customers. Capacity: The subtransmission system in Ann Arbor is not adequately sized to accommodate existing load and accelerated load growth in the area. The overloaded system is an impediment to economic growth. Operability: There is currently limited ability to jumper/transfer load to adjacent substations during emergency situations or for routine maintenance.
Ann Arbor System Improvements: Argo 40kV Reconfiguration	Ann Arbor	Capacity: Due to high growth in Ann Arbor, ARGO substation does not have capacity to serve downtown Ann Arbor. This is part of the ARGO decommissioning project and will remove Argo from service (see related project Buckler Circuit Conversions).
Transformer High Side Protection Program	Bunce Creek, Chestnut, Newburgh, Northeast, Sunset, Wabash, Hancock, Hines, Pontiac, Spokane, Stephens, Troy, Wayne, Waterman, Wixom	Reliability: Several subtransmission and distribution transformers require the installation of high side protection, either a circuit switcher or breaker, to mitigate observed NERC reportable system issues during simulated contingency conditions that may result in the loss of service to 100+ MVA of customer load. These issues were discovered during annual studies performed by ITC and are required to be mitigated by NERC TPL-001-4 standards.
Subtransmission Redesign & Rebuild: Maxwell Amherst	Detroit	Operability: Amherst industrial substation was partially relocated to Maxwell station during an trouble/emergent job. The drivers for this project is to fully relocate Amherst industrial substation to Maxwell to meet the industrial customer service needs.
Subtransmission Redesign & Rebuild: Trunk 7106	City of Southfield	Capacity: Trunk 7106 is loaded to 134% of the equipment's summer normal rating and 126% of the equipment's summer emergency rating, violating the Subtransmission Planning Criteria. Operability: Load will automatically be shed at Farmington substation to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Trunk 2255	Detroit	Capacity: Trunk 2255 is loaded to 110% of the Summer Emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Glendale and Villa substations to prevent this equipment overload.

Table 8 Subtransmission Projects, Continued

Project Name	Municipality	Drivers
Subtransmission Redesign & Rebuild: Trunk 2237-ST	Redford	Capacity: Trunk 2237 is loaded to 100% of the equipment's summer normal rating and 110% of the equipment's summer emergency rating, violating the Subtransmission planning criteria. Operability: There is an Emergency Load Control scheme at Six Mile Substation that will automatically shed load (10.3 MVA) to prevent from overloading equipment on Trunk 2237 and protect the equipment from any permanent damage
Subtransmission Redesign & Rebuild: Kennett	Madison Heights	Capacity: Trunk 7333 is loaded to 129% of the summer normal rating and 126% of the summer emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Brazil & Kenney substations to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Sandusky Transformer 101 Breaker	Sandusky	Capacity: Sandusky Transformer 101 is loaded to 126% of the equipment's summer normal rating, violating the Subtransmission Planning Criteria.
Subtransmission Redesign & Rebuild: Boyne	Macomb, Harrison, Clinton, Mt. Clemens, Chesterfield, New Baltimore	Capacity: Trunk 7909 is loaded to 120% of its summer emergency rating, violating the Subtransmission Planning Criteria. Operability: Load will be automatically shed at Omega and Beach Substations to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Tie 4105	Lexington, Croswell, Port Sanilac, Applegate, Carsonville	Reliability: TIE 4105 has experienced frequent outages, escalated complaints, and is one of the worst performing Subtransmission lines.
Subtransmission Redesign & Rebuild: Tie 1568	Ypsilanti	Capacity: Tie 1568 is loaded to 99% of the equipment's summer emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Crown substation to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Trunk 4217	Grosse Pointe, Harper Woods & Detroit	Capacity: Trunk 4217 is loaded to 123% of the equipment's summer normal rating and 116% of the equipment's summer emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Grosse Pointe and Vernier substations to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Trunk 3509	Troy City Shelby SC Territory	Capacity: Trunk 3509 is loaded to 100% of the equipment's summer normal rating and 109% of the equipment's summer emergency rating, violating the Subtransmission Planning Criteria. Operability: Load will automatically be shed at Patton Substation to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Trunk 4266	East Pointe	Capacity: Trunk 4266 is loaded to 108% of the equipment's summer emergency rating, violating the Subtransmission Planning Criteria. Operability: Load will automatically be shed at Savoy Substation to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Praxair	301 E Great Lakes Ave, River Rouge	Operability: The normally open section disconnect at Praxair Substation is not rated high enough to interrupt the transformer load. Therefore, the customer's operation need to be interrupted everytime the switch need to be operated. The number of shutdowns currently required for DTE maintenance activities greatly impacts the primary customer's business and coordination of this work is challenging.
Subtransmission Breaker Short Circuit Violations	Bad Axe, Taylor, East Pointe, Detroit, Royal Oak, Milford, Warren, & Monroe	Safety/Reliability: 20 breakers on the Subtransmission system are in violation of the Subtransmission Planning criteria by exceeding their interrupting ratings. This could result in equipment damage or catastrophic failure of these breaker positions.
Subtransmission Redesign & Rebuild: Slocum	Trenton	Other: The Trenton Channel Power Plant, including all outlying structures and buildings are planned for retirement in 2022 with subsequent demolition. 3 trunk lines will be redesigned to remove all unused equipment that is currently being used to feed system service transformers at the power plant.
Subtransmission Redesign & Rebuild: 40kV Capacitor Banks at Armada and Adair	Macomb and St. Clair Counties Shelby and Marysville SC Territories	Capacity: Tie 810 is a three-ended tie line consisting of 50 miles of overhead lines serving 10 substations. Low voltage levels are currently seen on this circuit due to significant circuit mileage and load.
Subtransmission Redesign & Rebuild: Oak Beach Capacitor	Port Austin	Capacity: Oak Beach and Caseville substations experience low voltage violations for an outage on Tie 3205, violating the Subtransmission Planning Criteria. Operability: The System Operations Center restricts shutdowns on Tie 3205 to prevent this low voltage. During an outage, manual load shed would be return the voltage to our operating limits.

Table 8 Subtransmission Projects, Continued

Project Name	Municipality	Drivers
Subtransmission Redesign & Rebuild: Tie 810 (Gramer)	Macomb and St. Clair Counties Shelby and Marysville SC Territories	Capacity: Tie 810 experiences low voltages in multiple single contingency scenarios, which violates the Subtransmission planning criteria. Tie 810 experiences overloads in multiple single contingency scenarios. Operability: Load will automatically be shed at various substations to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Tie 7504	Novesta Twp	Reliability: Customer complaints and escalations have been received due to frequent outages on TIE7504. Capacity: Substations served from TIE7504 experience low voltage during a single contingency, violating the Subtransmission Planning Criteria. Operability: 7 MVA of load is automatically shed on TIE7504 to prevent low voltage.
Subtransmission Redesign & Rebuild: Trunk 2308	Macomb	Capacity: Trunk 2308 is loaded to 99% of its summer emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Benson Substation to prevent this equipment overload.
Subtransmission Redesign & Rebuild: Tie 3205	Pigeon, Caseville, Oak Beach, Port Austin	Reliability: TIE3205 has experienced frequent outages. This tie line is one of the worst performing circuits and it does not meet current design standards.
Subtransmission Redesign & Rebuild: Reverse Power Relay Scheme Program	Ann Arbor, Bad Axe, Chelsea, Commerce TWP, Fostoria, Grant TWP, Harbor Beach, Highland Park, Madison Heights, Monroe, Lenox, Rochester Hills,	Station locations do not have appropriate equipment to prevent backfeed onto the transmission system. Not having this equipment additional operating actions need to be take place creating additional work on DTE's side for switching, often reduces system reliability, and frequently can introduce additional restrictions on much needed shutdowns. This has resulted in ITC Operations requesting DTE to install reverse relay schemes at various locations.
Subtransmission Redesign & Rebuild: Tie 4104 North	Sherman and Sand Beach Townships	Reliability: TIE4104 has experienced frequent outages and deterioration of the conductor has been identified from testing.
Subtransmission Redesign & Rebuild: Badax Transformer 102 Addition	Bad Axe	Capacity: The tielines out of Bad Axe station experience low voltage violations for the loss of Bad Axe Transformer 101, violating the Subtransmission Planning Criteria. Operability: The System Operations Center restricts shutdowns on Bad Axe Transformer 101 to prevent this low voltage. During an outage, manual load shed up to 23.4 MVA would be return the voltage to our operating limits.
Subtransmission Redesign & Rebuild: Trunk 4245	Eastpointe	Reliability: The conduit crossing I-94 at 9 mile is damaged causing cable to become stuck in the ducts. Shores substation is at risk of losing their subtransmission feeds if cable failures occur.
Subtransmission Redesign & Rebuild: Trunk 4911	Lenox Twp. Chesterfield Twp. City of New Baltimore Ira Twp.	Capacity: Trunk 4911 experienced multiple overloads in a normal and emergency scenario up to 130% of the equipment rating, violating the Subtransmission Planning Criteria. Trunk 4911 also experienced low voltages in multiple emergency scenarios, violating the Subtransmission Planning Criteria. Operability: Load will be automatically shed at New Baltimore and Chesterfield substations to prevent equipment overload.
Subtransmission Redesign & Rebuild: Custer Republic	Monroe	Operability: Transformer 3 at Republic substation is 71 years old and carrying no load. Breaker equipment at Custer 68 years old. Reconfiguring the trunk lines between Custer and Republic will allow these under-utilized assets to be decommissioned.
Station Upgrade: Cortland Station Expansion	Highland Park	Reliability: Cortland Station was identified as a high-risk station in the Operational Risk Assessment. Operability: The existing station transformers at Cortland have physical constraints that do not allow for replacement in their existing locations. If a transformer failure were to occur, there are minimal options to serve the load if the next contingency were to occur. Many portable generators would be required.

3

4 Q59. What is the Subtransmission Small Projects and Reserve Program?

5 A59. There are times when the Company experiences issues on the subtransmission

- 6

system that are less complex, and that unlike the larger subtransmission projects

1	can be executed without extensive engineering and planning. These projects are
2	generally smaller in scope and level of investment, requiring \$500,000 or less in
3	capital. The typical scope of work for these projects addresses thermal or voltage
4	violations, under either normal or single contingency situations. Projects of this
5	nature are identified during the yearly engineering analysis, which is the same
6	methodology used to identify all the subtransmission projects under the
7	Subtransmission Redesign and Rebuild program. Because the Company
8	experiences this type of situation every year and they can be solved quickly without
9	extensive engineering and planning, the Company has created a Small Projects and
10	Reserve program. This program allows the Company to address these less complex
11	issues on the subtransmission system in a short amount of time, without the more
12	involved planning and engineering required for a larger, more extensive project. A
13	high-level summary of these projects for 2024 is provided in Table 9

- 14
- 15

Table 9	Projects in the Small	Projects and Reser	ve Program
---------	-----------------------	---------------------------	------------

Project ID	Municipality	Drivers
TRK 2508	Warren	Capacity: Trunk 2508 is loaded to 98% of its emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Centerline substation to prevent this equipment overload.
TRK 2506	Warren	Capacity: Trunk 2506 section is loaded to 98% of its emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Centerline substation to prevent this equipment overload.
Trunk 7114 -7115	Southfield	Capacity: Trunk 7114-7115 is loaded to 120% of its emergency rating, exceeding the Subtransmission planning criteria. Operability: Load will automatically be shed at Sargent and Gary substations to prevent this equipment overload.

1	Q60.	How do customers benefit from the Small Projects and Reserve program?
2	A60.	Similar to other subtransmission projects, the Small Projects and Reserve program
3		will provide multiple customer benefits including safety, improved reliability and
4		operability, and increased capacity, but within a shorter period of time due to the
5		much more limited scope and compressed schedule required to address identified
6		system issues. With the ability to address the system conditions and provide more
7		immediate benefits to the customers with a relatively quick solution, the projects
8		are executed shortly after identification instead of following the more structured
9		project management steps of a larger project.
10		
11		Strategic Undergrounding Program
12		
13	Q61.	Why is the Company interested in the undergrounding of circuits as part of
14		conversion projects?
15	A61.	The combination of aged overhead infrastructure and increasingly frequent and
16		severe storms has resulted in negative reliability impact for many of our customers.
17		A frequent question from our customers and other stakeholders in response to
18		frequent outages has been "why not underground the lines?". The Company is
19		interested in making undergrounding a viable option when circuits are being
20		converted as that is the optimum time to take advantage of the synergy of the
21		rebuilding process instead of just replacing the existing overhead infrastructure.
22		
23		Undergrounding protects the electrical infrastructure from increased storm
24		frequency and severity, thus providing resiliency and improving reliability. An
25		undergrounded circuit also has safety advantages since there are no downed wires

Line <u>No.</u>

1 during storm events. Furthermore, over the life cycle of the assets, undergrounding 2 can provide the benefit of reduced maintenance and repair costs due to eliminating 3 the need for tree trimming, pole top maintenance, and in most storm cases, trouble 4 response. 5 6 Through benchmarking, the Company has learned that many other utilities are also 7 pursuing undergrounding of their existing overhead lines as a means to harden their 8 systems for greater resiliency, increase reliability, and improve storm response. 9 10 To take advantage of this unique opportunity to be able to underground larger 11 portions of the new converted system, the Company plans to conduct pilot projects, 12 and initially seek out areas where there are construction synergies, which could be 13 achieved by jointly working with municipalities or other utilities. This approach 14 will allow the Company to learn, develop best processes for undergrounding in 15 mature urban, suburban, and rural areas while focusing on reducing implementation 16 cost. These pilot projects will also allow the Company to further demonstrate the 17 benefits of undergrounding and determine when/where this design choice can be 18 applied effectively. 19 20 Q62. How do the Strategic Undergrounding pilot projects differ from the 21 Company's existing underground infrastructure and undergrounding that is 22 done in new developments? 23 A62. The Company has been implementing underground residential distribution (URD) 24 infrastructure since the 1970s for new construction subdivisions. Furthermore, the

25 Company has a vast underground cable system utilizing the typically manhole

construction in the city of Detroit and other urban areas in its service territory.
Combined, over 30% of the Company's electric system is already underground.
However, the Company has limited experience undergrounding existing overhead
electrical infrastructure as part of the conversion process in mature and developed
urban, suburban, and rural areas of the distribution grid. The rebuilding of existing
overhead infrastructure to underground is significantly different in scope than
installing underground infrastructure in a new development.

8

9 To learn and gain experience on undergrounding of existing overhead 10 infrastructure, the Company is implementing undergrounding pilot projects. The 11 main object of the pilot projects is to understand the challenges of undergrounding 12 in a mature urban setting, define scenarios and situations when undergrounding can 13 reap of rewards of safety, reliability, and resiliency benefits, and refine 14 underground construction processes to gain cost efficiency on the installation. An 15 additional goal is to analyze the longer-term benefits of undergrounding, to better 16 support a refined benefit-to-cost analysis in the future.

17

18 Q63. Has the Company piloted undergrounding existing overhead lines?

19 A63. Yes. Per case U-20169, the Company was asked to explore potential pilot projects 20 to eliminate rear-lot overhead infrastructure and its associated hazards. With the focus on reducing the safety hazards associated with rear-lot infrastructure, the 21 22 Company initiated a pilot project on Appoline DC1346 (Appoline) in Detroit to 23 move rear-lot overhead assets to rear-lot underground infrastructure, including the 24 service lines. Appoline pilot project included 61 residential customers on two city The scope of this pilot project included installation of 25 blocks in Detroit.

approximately 1,300 feet of primary cable, six transformers, and underground
 services to residences.

3

4 Q64. What were the objectives of the Appoline pilot project?

5 A64. The objectives of the Appoline pilot project were to assess the safety improvements 6 of undergrounding rear-lot overhead infrastructure, gather information on actual 7 installation costs of undergrounding in a mature rural neighborhood, understand 8 customer acceptance, and determine opportunities to improve cost and construction 9 efficiency.

10

11 Q65. What was the timing of the Appoline undergrounding pilot project?

12 A65. The Company began engineering for the Appoline pilot project in 2018 and 13 construction started in 2019. The Company initially had challenges with clearing 14 rear alley structures and debris to gain access to the distribution infrastructure, and 15 then ran into challenges with getting approvals from owners of rental properties as 16 well as challenges posed by the Pandemic, delaying the final construction of a small 17 number of customer service lines. The pilot project was completed in October 2023 18 with all customers converted to underground service and all related overhead 19 infrastructure decommissioned. After internal benchmarking with DTE Gas, the 20 Company took a more direct approach to connect all customers via an 21 undergrounded service.

22

23 Q66. What were the lessons learned from the Appoline underground pilot project?

A66. From the Appoline pilot project, the Company gained valuable experience in
 undergrounding existing overhead infrastructure in a mature urban neighborhood.

Line No.

> 1 With all overhead customer services undergrounded and the removal of rear lot 2 overhead lines, the associated safety hazards of rear lot overhead lines were 3 eliminated for this area. Additional learnings were that early customer engagement prior to construction is critical for success. The Company had difficulty in 4 5 contacting the homeowners, often landlords at remote locations instead of onsite 6 residents, to obtain approvals required to modify the electric service attachments to 7 their homes. Before installation work could begin, the overhead infrastructure 8 located in rear alleyways required extensive vegetation and debris removal. 9 Furthermore, routing underground services from the rear-lot was very challenging 10 due to garages, patios, and other customer obstructions that have accumulated from 11 decades of neglect. Essentially every customer required a unique route to 12 underground their service. Exhibit A-23 Schedule M11 provides detailed 13 information for the Appoline pilot. Due to these challenges, the schedule, and the cost for the Appoline pilot were negatively impacted. 14

15

16 Q67. Was a benefit-to-cost analysis (BCA) completed for the Appoline pilot 17 project?

18 A67. Yes. An initial BCA for the Appoline pilot project based on a partial subset of 19 customer installations was presented in the MPSC case U-21297, however it was 20 Since that time, the Company inconclusive due to limited customer data. 21 collaborated with an independent consulting firm to create an updated BCA based 22 on methodology utilized by other utilities in other states (such as IN, OH, IL, MD, 23 FL, and OK). This analysis uses a long-term, present value methodology to 24 compare the customer and utility benefits to the costs associated with investment 25 The Appoline underground pilot project was compared with the options.
1	alternatives of PTMM and overhead rebuild. The benefits of the Appoline
2	underground pilot project included the present value of the avoided future costs of
3	vegetation management, PTMM, and emergent reactive events. The model also
4	included the benefits associated with the customer impacts of outages, using the
5	Lawrence Berkeley National Laboratory (LBNL) Interruption Cost Estimate (ICE)
6	calculator. The LBNL ICE calculator is used by many utilities to approximate
7	customers' costs of interruptions, although many including LBNL acknowledge
8	that the model is conservative and underestimates the true costs of the outages.
9	Then a benefit-to-cost ratio (BCR) was calculated for each investment option and
10	compared to alternatives. The detailed BCA for the Appoline pilot is provided in
11	Exhibit A-23 Schedule M13.

13 Q68. What were the results from the BCA for the Appoline pilot project?

14 A68. This analysis indicated that the BCR of the Appoline pilot project was lower than 15 the overhead rebuild, but higher than PTMM. In this analysis a higher BCR 16 indicates that there are more benefits than cost as a ratio, so either higher estimated benefits or lower costs of the project can raise the ratio. As this was an initial pilot 17 18 project with initial learnings that included the substantial costs to remediate rear 19 alley debris, this pilot BCR was not unexpected. Several factors contributed to the 20 lower Appoline BCR. As discussed earlier and in Exhibit A-23 Schedule M11, 21 there were challenges in getting approval from all the customers, in particular non-22 resident landlord owners. This delayed the project completion and caused 23 additional mobilization and demobilization costs. Furthermore, to connect each of 24 the customers' service from the rear-lot underground infrastructure required a 25 unique design and process for each customer, adding additional cost for this pilot.

<u>No.</u>

1

2

3

Adding on the cost for vegetation and debris removal to implement this pilot, these challenges further impacted the project cost. These specific learnings have been included in subsequent undergrounding work.

4

Q69. Are there additional important benefits that are not included in the BCA for the Appoline pilot project?

7 A69. Yes. Significant benefits of safety and resiliency for customers are not included in 8 the financial BCR of the Appoline pilot project. With the rear lot overhead 4.8 kV 9 conductors removed, the wire down hazard for this section of the distribution circuit 10 has been eliminated. Furthermore, by undergrounding the overhead lines, the 11 community and the customers also reaped the significant benefit of greater 12 resiliency against the more frequent and more severe extreme weather events that 13 could lead to prolong outages. The ICE Calculator described earlier, although 14 meant to capture the benefit of incremental reliability, "may not accurately reflect 15 current interruption costs, given that around half of the data in the meta-database is from surveys that are 15 or more years old. To address this issue, the 2009 study 16 included an intertemporal analysis, which suggested that interruption costs did not 17 18 change significantly throughout the 1990s and early 2000s. However, during the 19 past decade in particular, technology trends may have led to an increase in 20 interruption costs. For example, home and business life has become increasingly 21 reliant on data centers and "cloud" computing, which may have led to an increase in interruption costs for both producers and consumers of these services. Therefore, 22 23 the outdated vintage of the data presents concerns that underscore the need for a 24 coordinated, nationwide effort that collects interruption cost estimates for many 25 regions and utilities simultaneously, using a consistent survey design and data

1		collection method." ⁴ Both of these benefits, safety and resiliency, are not easily
2		quantifiable in a way that matches present day customer needs or impacts. The
3		Company will continue to collaborate with the MPSC and industry stakeholders to
4		determine an appropriate way to quantify these benefits.
5		
6	Q70.	Is the Company pursuing other strategic undergrounding pilot projects?
7	A70.	Yes. By collaborating closely with the city of Detroit, the Company developed a
8		project to underground portions of the STLUS DC116 circuit in the Buffalo-
9		Charles neighborhood. This is a bold initiative to underground approximately four
10		miles of residential distribution lines using front-lot construction in a mature urban
11		neighborhood with the intent of capturing additional benefits of joint gas and
12		electric work.
13		
14	Q71.	Why was Buffalo-Charles neighborhood selected as the next underground
15		pilot project?
16	A71.	The Company considered multiple criteria in the selection process for the next
17		undergrounding pilot. Selection criteria included wire downs per mile (safety),
18		sustained and momentary outages for the circuit (reliability), impact to the
19		community (energy justice), and construction cost. Over several meetings with
20		City of Detroit officials, DTE Gas, and internal subject matter experts, six Detroit
21		neighborhoods were reviewed and analyzed. The Buffalo-Charles neighborhood
22		was very comparable with the other five areas that were evaluated. However, the
23		Buffalo-Charles neighborhood was additionally attractive because it allowed the

⁴ Sullivan, M.J., J. Schellenberg and M. Blundell (2015). Updated Value of Service Reliability Estimates for Electric Utility Customers in the United States. Lawrence Berkeley National Laboratory Report No. LBNL-6941E, pg. 18

Line
<u>No.</u>

1		Company the opportunity to work with DTE Gas, who are also doing underground
2		gas main work in many areas of the city. Collaborating with DTE Gas will allow
3		DTE Electric an opportunity to achieve synergies in the construction process to
4		explore opportunities for further cost reductions and construction efficiency in co-
5		located projects. By jointly working with DTE Gas, DTE Electric can utilize the
6		same contractor for construction synergies that can lower the cost of the project.
7		Furthermore, this is a benefit for customers in the project area, since gas main
8		replacement and electrical infrastructure undergrounding is done at the same time,
9		resulting in less disruption and impact on the neighborhood as compared with two
10		separate projects at different times.
11		
12	Q72.	How has the Company engaged customers and other stakeholders in the
13		Buffalo-Charles pilot project?
14	A72.	Throughout the inception of this project, DTE has worked closely with the City of
15		Detroit Mayor's office, City council, and other infrastructure partners. Per exhibit
16		A-28 Schedule R1, the City of Detroit Mayor's office is very supportive of this

- A-28 Schedule R1, the City of Detroit Mayor's office is very supportive of this
 undergrounding pilot because it will improve the quality of life for its residents
 through improved safety, resiliency, and reliability.
- 19

Once the specific project location was confirmed, a community town hall was held on September 13, 2023, at the Lasky Recreation Center. During this community town hall meeting, the company provided in-person communications with all customers and stakeholders to explain the scope and expectations of the project. Door to door communications preceded the town hall to let members of the community know about the project and to invite them to the event. Additional

Line <u>No.</u>		S. S. DEOL U-21534
1		communications have also occurred throughout the construction including blog
2		posts, direct mailings, and door hangers.
3		
4	Q73.	What is the scope of the Buffalo-Charles project?
5	A73.	The scope is to underground portions of the STLUS DC1136 circuit in the Buffalo-
6		Charles neighbor of Detroit to 13.2 kV capable front-lot underground residential
7		distribution infrastructure and remove the aged 4.8 kV overhead rear-lot
8		distribution equipment. In relocating to front-lot construction, the scope of
9		undergrounding Buffalo-Charles is an enhancement from the rear-lot scope of
10		Appoline. As the industry has evolved, peer utilities have adopted to use accessible,
11		front-lot URD construction for undergrounding in an urban environment.
12		Furthermore, front-lot URD has the potential for reduce construction cost.
13		
14		The scope for the Buffalo-Charles pilot included constructing 3.9 miles of
15		underground residential distribution to service 459 customers using front-lot
16		construction. This project will install 4.3 miles of primary conduit, 3.9 miles of
17		underground primary cable, 4.5 miles of underground secondary cable, and 8.9
18		miles of service cable. Additionally, this project will install 48 pad-mounted
19		transformers, 153 secondary handholes, 459 junction boxes, 31 cable poles, and 12
20		ISO-UP transformers. Furthermore, this project will remove 2.8 miles of overhead
21		primary, 3.5 miles of overhead secondary, 459 overhead services, and 3.5 miles of
22		PLD/ARC wire.
23		

24 Q74. What is the timing of the Buffalo-Charles project?

1	A74.	After meeting with stakeholders throughout the summer of 2023, engineering and
2		design were completed in late fall of 2023, with construction beginning in late
3		October. The Buffalo-Charles project is expected to be completed by end of 2024.
4		
5	Q75.	Did the Company conduct a BCA for the Buffalo-Charles project?
6	A75.	Yes. The Company used the same approach to conduct the BCA for Buffalo-
7		Charles as it did for the Appoline pilot as described above. The detailed BCA for
8		the Buffalo-Charles is provided in Exhibit A-23 Schedule M13.
9		
10		The BCR results for Buffalo-Charles were similar to Appoline in that it was lower
11		than the overhead rebuild, but nearly equivalent to PTMM. As with the Appoline
12		BCR, the Buffalo-Charles project BCR result was not unexpected, given that the
13		Company is still in the early stage of undergrounding pilots. Several factors
14		contributed to the lower Buffalo-Charles BCR. The analysis used an initial cost
15		estimate for implementing front-lot underground infrastructure in a mature urban
16		neighborhood while removing old rear-lot overhead construction. The Company
17		believes that actual project costs may come in lower with rigorous project
18		management and the realization of project efficiencies with greater pilot experience.
19		
20	Q76.	Are there additional important benefits that are not included in the BCA for
21		the Buffalo-Charles pilot project?
22	A76.	Yes. Similar to the Appoline pilot project, significant benefits of safety and
23		resiliency for customers are not included in the financial BCR of the Buffalo-
24		Charles pilot project. When the rear lot overhead 4.8 kV conductors will be
25		removed, the wire down hazard for this section of the distribution circuit will be

1 eliminated. Furthermore, by undergrounding the overhead lines, the community 2 and the customers will reap the significant benefit of greater resiliency against the 3 more frequent and more severe extreme weather events that could lead to prolong outages. The ICE Calculator described earlier, although intended to capture the 4 5 benefit of incremental reliability, "may not accurately reflect current interruption 6 costs, given that around half of the data in the meta-database is from surveys that 7 are 15 or more years old. To address this issue, the 2009 study included an 8 intertemporal analysis, which suggested that interruption costs did not change 9 significantly throughout the 1990s and early 2000s. However, during the past 10 decade in particular, technology trends may have led to an increase in interruption 11 costs. For example, home and business life has become increasingly reliant on data 12 centers and "cloud" computing, which may have led to an increase in interruption 13 costs for both producers and consumers of these services. Therefore, the outdated vintage of the data presents concerns that underscore the need for a coordinated, 14 15 nationwide effort that collects interruption cost estimates for many regions and 16 utilities simultaneously, using a consistent survey design and data collection method."⁵ Both of these benefits, safety and resiliency, are not easily quantifiable 17 18 in a way that matches present day customer needs or impacts. The Company will 19 continue to collaborate with the MPSC and industry stakeholders to determine an 20 appropriate way to quantify these benefits.

⁵ Sullivan, M.J., J. Schellenberg and M. Blundell (2015). Updated Value of Service Reliability Estimates for Electric Utility Customers in the United States. Lawrence Berkeley National Laboratory Report No. LBNL-6941E, pg. 18

Q77. How do the Company's undergrounding pilot projects' scope compare to other utilities that it benchmarked?

3 A77. Many benchmarked utilities are undergrounding as a means to make their grid safer 4 and more resilient to increased frequency and severity of weather events. However, 5 the scope of utility undergrounding varies based upon the utility strategy and 6 geography. Several utilities in the West are undergrounding in and around defined 7 high fire risk areas. The majority of these identified fire risk areas are in rural, less 8 densely populated areas. Similarly, many of the utilities benchmarked in the South 9 and Midwest are undergrounding in rural parts of their territory to improve storm 10 response time and to improve their reliability metrics. The typical construction 11 method used is trenching in road right of way and then either direct bury the cables 12 or use conduit. With many of the utilities leaving the customer services overhead. 13 DTE is one of the few utilities that is undergrounding in dense urban environments.

14

Q78. Why is the Company choosing to pilot undergrounding in dense urban environments?

17 A78. The main reasons that an urban environment was selected was based on the priority 18 of safety, eliminate the hazards associated with 4.8 kV ungrounded delta system 19 rear-lot construction, and to improve storm response for resiliency by reducing the 20 number of customer services down. To achieve these objectives, the construction 21 method utilized is to bore conduit for primary and secondary connections instead 22 To improve storm response and resiliency for single customer of trenching. 23 outages, often of longer duration in a large storm, the Company is also 24 undergrounding customer service drops. These factors of the urban dense customer 25 environment and undergrounding customer services will result the Company's

S. S. DEOL U-21534
undergrounding costs being higher when compared with another utility's scope of
implementing in a rural environment without service drop replacement.
Q79. Is the Company considering additional undergrounding pilot projects?
A79. Yes. The Company believes that undergrounding brings a set of unique benefits
and is of high interest to our customers. Undergrounding is the only investment
option that eliminates the safety risk associated with downed wires and structures.
Undergrounding provides the highest overall benefit in reducing emergent reactive
costs and customer outages. Undergrounding is the most resilient option for severe
weather-related events. Due to these advantages of undergrounding, the Company
believes that it needs to conduct additional pilots to continue to learn and focus on
reducing implementation costs, to increase the overall benefit to cost ratio.
The future projects are planned to involve a mix of geography; urban, suburban, and
rural. Learnings from these projects will be used to refine the current benefit cost
models to help identify segments of overhead infrastructure that are good candidates
for undergrounding. This approach will allow the Company to develop a cost
competitive undergrounding program.
Primary Deconductoring
Q80. What is Primary Deconductoring?
A80. Primary Deconductoring is the removal of unneeded or underutilized infrastructure
such as aged small-sized primary wire, PLD arc wire, overhead transformers, and

SSD-74

I	j	n	e
•	Ŧ		

<u>No.</u>

1 2 other pole top equipment in abandoned or blighted neighborhoods in the city of Detroit.

3

4 Q81. What are the benefits of Primary Deconductoring ?

5 A81. The benefit of removing overhead lines that are not fully utilized, and any 6 associated arc wire, reduces wire downs and improves safety in that area. 7 Removing unnecessary overhead lines also eliminates the potential for power 8 outages caused by those lines failing or being damaged thus improving reliability 9 in the area. In some situations, primary deconductoring may require the installation 10 of new secondary lines to serve the few remaining homes in the neighborhood. 11 When new secondary lines are installed, they are constructed to the current 12 standards.

13

14 **Q82.** What is the scope of work for Primary Deconductoring?

15 A82. The scope of work for Primary Deconductoring includes the removal of unneeded 16 or underutilized infrastructure such as aged small-sized primary wire, abandoned 17 arc wire, OH transformers, and other pole top equipment in abandoned or blighted 18 neighborhoods. In addition, where necessary the Company will reconductor 19 secondary wires and upgrade transformers and other pole top equipment, and where 20 possible install equipment in truck accessible locations.

21

22 Q83. Has the Company completed the Primary Deconductoring pilot?

- A83. The Company has completed pilots on two circuits in 2023. In Case No. U-21297,
 the Commission approved \$1.8M of investment in 2022. The Company had an
- additional 36,000 of investment in 2023 to complete these two pilots.

1	Q84.	How is Primary Deconductoring used as part of current circuit planning?
2	A84.	Per the success of the two completed pilots, the Company has rolled primary
3		deconductoring into the 4.8 kV Hardening program and 4.8 kV Conversion
4		projects, were applicable.
5		
6		System Loading Projects
7		
8	Q85.	Can you describe a system overload?
9	A85.	System overloads occur on a circuit or substation when there is insufficient capacity
10		to meet customer demands while maintaining grid operation within equipment
11		operating ratings. Capacity needs are analyzed for two conditions: normal state and
12		contingency state. The normal state exists when all equipment and components are
13		in service and operating as designed. The contingency state exists when there is
14		either a temporary, planned equipment shutdown or the unplanned loss/failure of a
15		component of the electric power system (e.g., transformer, cable, or breaker). Under
16		contingency state conditions, equipment in the rest of the system may see an
17		increase in loading to compensate for the out-of-service equipment, delivering
18		additional power above normal state.
19		
20		To meet the two capacity needs of the system, most components and equipment have
21		two ratings: day-to-day and emergency. These ratings are calculated to maintain the
22		viability of an asset throughout its expected useful life. Operating equipment above

23

its designated ratings can cause immediate failure or accelerate end-of-life and is

considered an overload. DTE definitions for day-to-day rating, emergency rating,

2

3

4

and substation firm rating are consistent with industry definitions such as those available from National Electrical Reliability Corporation⁶,

- The day-to-day rating (for normal state conditions) is the load level at which the equipment can be operated for its expected life span.
- The emergency rating (for contingency state conditions) is typically higher
 than the day-to-day rating and indicates the load level that the equipment
 can operate for short periods of time only. Operating towards the emergency
 rating adds stress to the equipment and may shorten its lifespan. If a piece
 of equipment exceeds its emergency rating, the Company's ESOC
 personnel will take immediate steps to transfer load or shed load if
 necessary.
- 12 Substations also have a firm rating, which is the maximum load the 13 substation can carry under a single contingency condition and is based on 14 the lowest emergency rating of any substation equipment that is required to 15 serve the load; such as incoming subtransmission feed, transformer, and 16 secondary cables. Figure 13 below shows an illustration of a substation 17 with a firm rating of 45 MVA. The substation consists of 2 transformers. 18 Transformer 1 has an emergency rating at 45MVA and transformer 2 has 19 an emergency rated at 50 MVA. Transformer 1 has the lowest emergency 20 rating of the equipment inside the substation, therefore 45 MVA is the firm 21 rating of the substation in this example. Under normal operation both 22 transformers serve customer load that they are designed to serve. In a single 23 contingency situation, such as the failure of a transformer or loss of a

⁶ Glossary of Terms Used in NERC Reliability Standards, available at <u>https://www.nerc.com/pa/Stand/Glossary%20of%20Terms/Glossary_of_Terms.pdf</u>, accessed March 12, 2024

1 subtransmission feed, automatic operations will occur within the substation 2 and customer load will continue to be served to avoid a large, sustained 3 outage. Figure 14 below shows the same substation operating in a single 4 contingency situation where transformer 2 is down. Transfer 2 breaker is 5 opened to isolate and deenergize it. The tiebreaker is closed to allow 6 customer load to be rerouted through transformer 1. The total load on the 7 substation is below firm rating so all the customers can be fed from 8 transformer 1. If the total load on the substation is over the firm rating, the 9 extra load on transformer 1 would cause it to operate above its emergency 10 rating. Typically, the Company does not operate its equipment at or above 11 emergency ratings. To prevent operating at or over emergency rating, the 12 loading on Trans 1 would need to be reduced. This would require load to be 13 shed and customers would experience an outage until the situation is remediated. 14

Line

No.







Figure 14 Substation under Single Contingency



3

4 Q86. What are the challenges and issues with system overloads?

A86. When equipment is operated in a system overload condition, the equipment is
stressed, and useful life is reduced. Additionally, this impacts system operability
by limiting jumpering abilities needed to support customer reliability during outage
events. Without jumpering capabilities to adjacent circuits, outages will be
sustained for longer periods of time because the failed equipment must be replaced

1

2

3

4

5

6

7

8

9

10

11

- to restore customers. Furthermore, overloaded equipment can also increase the probability of emergent failures leading to customer outages.
 Also, when there are overloads on the system it is challenging for the Company to serve new customers and provide the ability for existing customers to expand, therefore, in areas where system overloads exist, the absence of electrical capacity inhibits DTE's ability to support economic growth in SE Michigan. This challenge is also expected to increase with increasing loads brought by electrification and distributed generation as part of the clean energy transition.
 Q87. How does The Company forecast and mitigate system overloads?
- 12 A87. The Company conducts annual Area Load Analysis (ALA) on all distribution 13 circuits and substations to determine where there are overloads on the system. 14 Based on a study of historical ALA's, approximately one-third of distribution 15 substations have loading constraints. This includes substations operating over its 16 firm ratings and/or circuit equipment working near or over its day-to-day rating 17 during peak hours.
- 18

19In areas that have seen and continue to see steady load growth, capital investments20are required to prevent overloads. These projects are categorized as System21Loading projects. The projects in the table below are proposed within the System22Loading category with additional details within Exhibit A-23 Schedule M6.

Table 10 System Loading Projects

Project Name	Municipality	Drivers
Brest Substation	Monroe	Project is completed.
		Project Drivers were:
		Safety: Concrete and support structures at BREST substation required significant repair and
		Capacity: secondary driver to increase capacity while decommissioning 4.8kV switchgear
Carleton	Ash Twp	Project is completed.
Substation	I.	Capacity: Carleton substation 196% of the maximum loadability.
Upgrades		Transformer 2 is at 112% of its day to day rating.
		CARLT DC 312 is at 124% of its day to day rating and exceeds the 3MVA distribution design
		Operability: Limited jumpering options due to substation and circuit loading. Failure can lead
		to customer outages/stranded load.
Grayling	Shelby Twp	Project is completed
		Capacity: Grayling substation is a heavily loaded 120-13.2kV substation providing service to
		Township. All Gravling circuits are at capacity
		Reliability: Improve SAIDI by 50%
		Operability: Grayling substation is surrounded by overloaded substations
Prospect	Superior Twp	Capacity: Prospect Transformer 1 has exceeded the day-day rating at 119% in 2020 and
		substation at 119% of Firm Rating. As Engineering developed scope for this project ungrades at Prospect have been cancelled as
		all load from Prospect substation will be served by the upgraded Grenada System Loading
		Project. Load from Prospect has temporarily been transferred to adjacent circuits to mitigate
	P 101	overload conditions.
Mandy 307 Load	Royal Oak	Reliability and Operability: Mandy DC30/ is currently 126% of its firm rating. The day-to- day circuit rating is violated since 2016. The day-to-day rating for Mandy DC307 is 2.7 MVA
11 ansier		and the peak for the circuit is 3.4 MVA. The circuit Mandy DC307 is surrounded by a dense
		tree area creating significant amount of outages.
Mack Transformer	Detroit	Project is completed.
102		MACK TRF102 installation was completed to allow for the repair of inoperable LTCs on MACK TPF101 and MACK TPF104 without putting sustamers served out of MACK at rick
		for a long outage. Upon completion of the needed repairs TRF102 is to operate in standby to
		provide additional reliability. This would have put 101MVA (26,000 customers) at risk for a
		long outage if the other TRF were to fail during the shutdown.
Globe	Vassar Twp, Tuscola County MI	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Capacity: GLOBE is at 2.4 MVA, or 75% of its DD rating
	Tuscola County, WI	Vassar Township has been issuing permits for Indoor Agricultural Centers, resulting in high
		load demand, which cannot be supported by existing Globe infrastructure.
		Operability: No jumpering option available between Globe and nearby Sheridan substation.
		SHRDN substation
		Active customer load addition requests in the area pending project completion.
Brown City	Brown City,	Safety: 4.8kV causes a higher safety risk in the event of a wiredown.
	Marlette and Imlay	Capacity: Substations over firm rating. Circuits approaching Day to Day rating
	City	substation, which is a 13 2kV distribution substation. This limits immering options for
		BRCTY substation.
Port Sanilac	Sanilac county	Safety: Aging infrastructure has a risk of failure. 4.8kV causes a higher safety risk in an event
		of a wire-down.
		333kVA pole mount transformers at Forester are also at-risk equipment at Forester substation
		The circuits at Port Sanilac are limited by substation regulators that are considered at-risk with
		no spare parts available.
		Capacity: Substations over firm rating. Circuits over Day-day rating. Forester substation is a
		Operability: There is limited/no jumpering options during peak since Port Sanilac is
		surrounded by Forester and Applegate substations, both of which are approaching/exceeding
N. 1. 1/4	N ' 1 1 1	their substation transformer limits. Failure can lead to customer outages/stranded load.
Kichmond/Armada	Kichmond and	Safety: 4.8kV causes a higher safety risk in an event of a wire-down. Reliability: The 4.8kV switchgear at Richmond substation was installed in 1056 and is the
	1 Millaua	only oil filled truck type outdoor switchgear remaining on the DTE system. The breakers
		along with the CTs have no spare parts available.
		Capacity: Substation over firm rating. Circuits over distribution design order.
		Operability: Armada has limited jumpering options so when the substation needs maintenance, a portable substation is required to pick up the load
	Armada	Reliability: The 4.8kV switchgear at Richmond substation was installed in 1956 and is the only oil filled truck type outdoor switchgear remaining on the DTE system. The breakers along with the CTs have no spare parts available.
		Operability: Armada has limited jumpering options so when the substation needs maintenance a nortable substation is required to pick up the load

Table 10 System Loading Projects, Continued

Project Name	Municipality	Drivers
Cody	South Lyon / Lyon Township	Safety: There are large 4.8kV (ungrounded system) ISO-down pockets, which are a hazard to the public. Reliability: The last tree trim was in 2015 which explains the second largest outage factor of
		trees. Capacity: Substation over firm rating. Circuits exceed distribution design order. Additional load growth expected due to new development.
		Operability: Due to loading there are no jumpering options inside of sub and little no jumpering options outside of the sub in the case of a failure. Failure can lead to customer outages/stranded load.
Otsego/Capac/Shaw	Imlay Twp	Capacity: Substations over firm rating. Circuits exceed distribution design order limit. Operability: Substation throwover is blocked due to loading. Little to no outside jumpering available. Failure can lead to customer outages/stranded load. Other: Execution of the project is key in providing capacity on OTSGO substation to initiate a different project to move IMLAY load to OTSGO and allow for decommissioning of IMLAY.
Macomb Substation	Clinton Twp, Macomb County, MI	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Capacity: Substations over firm rating. Circuits over Day to Day rating. Circuits exceed Distribution design order of 8MVA per 13.2kV circuit.
Grenada	Ann Arbor	Grenada substation is located in Ann Arbor. There are four substations serving the general area: Grenada, Price, Prospect and Wolverine. Safety: 4.8kv areas of Pospect: 4.8kV wire down elimination
		Reliability: GRENA has a 3-year average SAIDI of 1,487 Capacity: Substations over firm rating. Circuits over distribution design order. There is continued load growth in the area and the existing substations and circuits are unable to support Ann Arbor's electrification goals. Operability: There is a lack of jumpering capability for Grenada, Prospect and Price
		substations. The use of distributed generation would be required in the case of any failure at the substations mentioned above. Failure can lead to customer outages/stranded load.
Lark/Spruce	Ann Arbor	Safety: Spruce substation (SPRUC) has equipment that has been designated as high risk. It will be easier to replace this equipment once the substation expansion is completed at LARK (120-40kV ITC/DTE Station in proximity of Spruce). Reliability: Spruce circuits have frequent outages that have resulted in higher than system average SAIDI and CAIDI minutes. There are sections of circuits that are located in difficult to access areas which are problem areas for downed wires. Capacity: Spruce substation loading is over its firm rating. There are circuits that have exceeded the Distribution Design Order (DDO) limit for 13.2kV loading with other circuits approaching that limit in the near future. There is limited capacity for load growth in the area. Operability: Spruce circuits have areas that are 13.2kV islands (adjacent to 4.8kV) which has led to limited jumpering points and little opportunity for load transfers.
Jeweli	Washington Twp	Reliability: The largest causes of outages is due to trees and equipment break. The circuits have been close to and have gone over the DTE average for SAIDI/CAIDI. Capacity: Substation over firm rating. Multiple circuits over and approaching day to day rating. Multiple circuits exceed distribution design order. There is load growth and new business across the Jewell Substation area. Operability: little to no load transfers available. Failure can lead to customer outages/stranded load. Other: There has been several residential developments happening on JEWEL within the past couple years. JEWEL area has a lot of open land so we can expect for more businesses and residential developments to come.
Mayville	Mayville, Clifford	Safety: 4.8kV causes a higher safety risk in the event of a wiredown. Reliability: The area has suffered from extensive outage events that lead to a large amount of stranded load for more than 24 hours. Capacity: Substations over firm rating. Circuit over day to day rating. Circuits over distribution design order limit.
Goodison	Oakland Twp	Reliability: GODSN SAIDI and SAIFI usually is above the DTE system average. Issues from TIE line cause outages to the substation, especially in 2023. Capacity: GODSN is at 129% of its firm rating. Both GODSN circuits exceed the Distribution Design Order limit of 8MVA for a 13.2kV circuit. Operability: Jumpering options outside of GODSN are not available during summer peak due to TINKN and JEWEL substations exceeding their firm ratings and because of the heavy loading on neighboring circuits. Overloads and low voltage occur when load is jumpered over to neighboring substation.

Table 10 System Loading Projects, Continued

Project Name	Municipality	Drivers
Wixom	Wixom	 Safety: Existing PDC and TRF1 are in close proximity, which is a fire hazard and is a worker safety hazard. In addition to the loading concerns at the substation, the existing switchgear at the substation is reaching its end of life and the breakers are at an elevated risk due to interruption medium. Reliability: SAIDI fluctuates year after year for WIXOM circuits and a few circuits exceed DTE system average. Most outages occur during storm. Capacity: Substation over firm rating. Circuits over distribution design order. Circuits above nominal cable day to day ratings. Operability: When a substation transformer fails, then at least (2) diesel generators are needed to support load at summer peak. There are only (2) jumpering points outside of Wixom substation at summer peak. Other: Receiving multiple method of services (customer load requests). WIXOM cannot support industrial customers due to existing circuit loadings. Wixom is the fastest growing city in Michigan.
Diamond	Dexter	Diamond substation is a two transformer, four circuit substation and is at 137% of its firm rating. Reliability: In summer 2018, load shedding was implemented at the substation due to equipment overloads. SAIFI 5 year average is 1.97 and SAIDI 5 year average is 566. Capacity: Two of the four circuits exceed the distribution design order standard of 8MVA for a 13.2kV circuit. The substation is currently at 137% of firm rating. Operability: Transformer #1 was replaced during an emergency failure event in March 2019; firm rating is now limited by smaller sized transformer #2.
Spokane/Seneca	Rochester Hills	Safety: Substation flooding due to the lack of a drainage system at Spokane substation has damaged the conduit system by causing it to cave in. This has impeded the use of the 9- position switchgear and the associated third transformer at the site. Capacity: Substations over firm rating. Circuits exceed distribution design orders of 8MVA per circuit. Operability: Limited jumpering options outside of Spokane substation due to overloads at adjacent Seneca and Tienken substations. Failure can lead to customer outages/stranded load. Other: DTE's Equipment Performance and Protective Maintenance group recommends the replacement of the current 11-position switchgear, as it is at risk of failure.
Sterling	Sterling Heights, Macomb County	Capacity: Circuit approaching day to day limit. Circuits exceed distribution design order limit. There is evidence of re-development and steady growth still coming into the Substation area. Load cannot be transferred to adjacent circuits without causing similar loading issues. There are no positions available at Sterling Substation to create new circuits to provide relief and additional capacity. Other: The current switchgear at Sterling substation is not the standard DTE setup. It is a straight bus switchgear which is exposed to a single point of failure.
Disco	Sterling Heights	Safety: There is a high chance of wire downs in the area due to DISCO OH lines being surrounded by many trees. The main cause of wire downs in the area are caused by winds and trees. A portion of DISCO OH lines are also truck inaccessible. Reliability: DISCO circuits currently have limited jumpering options due to the neighboring circuits being over loaded. In 2022 the SAIDI and CAIDI for all DISCO circuits were above the DTE system average due to several day outages. Trees and wind were the main causes for the outages. Capacity: Substation over firm rating. Circuits over distribution design order. Operability: DISCO circuits have limited jumpering options due to neighboring circuits being overloaded. Failure can lead to customer outages/stranded load.
Tahoe	Novi	Capacity: Tahoe substation is over its firm rating. Since Novi Substation is being decommissioned and the load is being transferred to Tahoe, peak loads at TAHOE DC 8928 and TAHOE DC 9512 will exceed the distribution design order standard of 8.0 MVA for a 13.2kV circuit. TAHOE DC 9511 is also approaching the Distribution Design Order limit. Operability: Current loading conditions inhibit the creation of jumpering points and installation of loop schemes in the area.

Table 10 System Loading Projects, Continued

Project Name	Municipality	Drivers
New Baltimore /	Chesterfield/	Safety: 4.8kV causes a higher safety risk in the event of a wiredown.
Chesterfield	New Baltimore	Reliability: NBALT is over its blocking limit to protect TRK4911 and a loss of transformer 3
		will result in 3MVA of stranded load.
		Capacity: Substations over firm rating. Circuits over day to day rating. Circuits over distribution
		design order limit.
		Operability: Limited jumpering options available. Failure can lead to customer outages/stranded
		load.
		Other: There have been three Method of Service requests since January 2021 totaling 2.3MVA
		load increase at NBALT substation.
		There have been 6 Method of Service requests since January 2021 bring 2.24MVA of load to
		CHEST substation.
Kings Point	Clinton	Safety: 4.8kV causes a higher safety risk in the event of a wiredown.
	Township and	Capacity: Substation over firm rating. Circuits over day to day rating. Circuits over distribution
	Mount Clemens,	design order. Nearby Omega substation is a 40kV-13.2kV substation which is 5.4MVA of its
	Macomb Twp	blocking limit. The loss of either transformer at Omega substation results in 5.8MA of stranded
		load.
		The subtransmission lines are overloaded in the area (Trunk 7909 and Trunk 6759). The current
		infrastructure is unable to support new load growth in the area.
		Operability: Omega and surrounding substations high loading limits jumpering options. Failure
		can lead to customer outages/stranded load.

3

4 Q88. What are the benefits of System Loading projects?

5 A88. System Loading projects alleviate the stress on the system caused by overloads and 6 reduce potential failures. These projects increase capacity and reconfigure the 7 system to eliminate projected overloads on specific pieces of equipment (overhead 8 wire, underground cable, transformers), or at the circuit/substation level. While 9 each project may add a different amount of new capacity, following completion of 10 a system loading project, substations shall be under 100% of firm rating, and all 11 equipment shall be under 100% of day-day rating. Capital investment to address 12 these system overloads will also improve reliability and provide capacity for new 13 and existing customers. Additionally, system loading projects help 14 maintain/improve system operability by restoring/creating jumpering capabilities 15 and removing aged equipment from the system.

Line
No.

1		The best way to demonstrate the benefits of System Loading projects is to use an
2		example. The Grenada project will deliver on system loading, conversions, and
3		automation benefits. The first step of the project is to rebuild and convert a portion
4		of an adjacent Prospect circuit which will deliver improved reliability from the
5		rebuilds, but also mitigate an overload at Prospect substation which is currently
6		over 100% of firm rating. Construction of a new Grenada substation will increase
7		capacity by 77% versus the existing Grenada substation, providing capacity for
8		continued growth and mitigating circuit overloads. Finally, additional conversions
9		will enable installation of loop schemes and circuit automation; none of which are
10		possible without the capacity delivered in the system loading project. When fully
11		implemented, the project is anticipated to deliver an 88% improvement in reliability
12		versus three-year historic SAIDI for the area.
13		
14		Even though each of the projects in the System Loading program are designed to
15		address the concerns/issues for a particular part of the grid, they have similar
16		benefits in the range of what was discussed for Grenada.
17		
18	Q89.	What is the scope of work for System Loading projects?
19	A89.	System Loading projects include scope to add capacity to the distribution system,
20		and typically include:
21		• Acquisition of land for new substations, if necessary
22		• Construction of new substations
23		• Expansion of current substations by installing additional transformers
24		Replacing existing transformers
25		• Installing new switchgear lineups

Line <u>No.</u>		S. S. DEOL U-21534
1		Creating new distribution circuits
2		• Reconductoring circuits (overhead wire and/or underground cable)
3		• Converting circuits to higher voltage, where necessary and transferring
4		load once additional capacity has been created
5		Many areas identified in the priority ranking for system load relief are addressed as
6		part of CODI, 4.8 kV Conversion, or 8.3 kV Pontiac Conversion programs. Load
7		relief needs excluded from conversion programs are included in the System
8		Loading projects category.
9		
10	Q90.	How are system loading projects prioritized?
11	A90.	Distribution engineers assess the load on the system and its impact on individual
12		pieces of equipment under two conditions: normal state and contingency state. This
13		analysis determines if adequate distribution system capacity exists to serve both
14		current and projected future demands.
15		
16		System loading information from this analysis is updated and evaluated annually.
17		Projects are evaluated for load relief on how they address five factors: substation
18		equipment overload, substation over firm rating, circuit equipment overload, strong
19		load growth or circuits over 8 MVA for 13.2 kV circuits and 3 MVA for 4.8 kV.
20		Based on these variables a priority ranking of the load relief projects is developed.
21		More information about Load Relief criteria and prioritization can be found in
22		Section 9.1 of the DGP (Exhibit A-23 Schedule M8 sponsored by Witness
23		Kryscynski).

1	Q91.	Can you summarize the key themes of your testimony?
2	A91.	Yes. Projects in Infrastructure Redesign and Modernization pillar are a key part of
3		the Company's plan for the grid of the future and fundamentally change the way
4		the grid operates. These projects add capacity by converting the distribution system
5		to a higher voltage for growing customer load, reduce outages and shorten outage
6		restoration time by incorporating modern technology and equipment, hardening the
7		grid, improve redundancy and resiliency of the system, and increase safety. IRM
8		treatment of these types of investments can benefit customers by ensuring that
9		projects are deployed where they are needed most.
10		
11		The projects in this pillar are vital to support the continued resurgence of the city
12		of Detroit and to provide the needed energy to ensure a bright future for Michigan.
13		
14	Q92.	Does this complete your direct testimony?
15	A92.	Yes, it does.

Line <u>No.</u>

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

MORGAN ELLIOTT ANDAHAZY

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF MORGAN ELLIOTT ANDAHAZY

Line No. 1 Q1. What is your name, business address, and by whom are you employed? 2 A1. My name is Morgan Elliott Andahazy (she/her/hers). My business address is One 3 Energy Plaza, Detroit, Michigan 48226. I am employed by DTE Electric Company 4 (DTE Electric or Company). 5 6 Q2. On whose behalf are you testifying? 7 A2. I am testifying on behalf of DTE Electric Company (DTE Electric or Company). 8 9 03. Please state your educational background. 10 A3. I hold a Bachelor of Science in Engineering (Industrial and Operations Engineering) 11 and a Master of Business Administration, both from the University of Michigan, Ann 12 Arbor. 13 Do you have any professional certifications or other certificates? 14 **Q4**. A4. I received my Lean Six Sigma Black Belt certification in 2009. 15 16 17 Q5. Please summarize your work experience. A5. In 2007, I joined DTE Electric as a contract employee supporting the Distribution 18 19 Operations Continuous Improvement (DOCI) team. In March 2008, I joined DTE 20 Electric as a full-time employee and a Project Lead within the DOCI team. As a Project 21 Lead, I was responsible for measuring and improving productivity within the Electric Field Operations (EFO) organization. During this time, I obtained my Lean Six Sigma 22 Black Belt certification based on work I did with EFO Productivity projects. In 2009, 23

24 I transitioned to the Continuous Improvement (CI) Manager for Distribution

Line <u>No.</u>

1 Operations (DO) where I was responsible for the team of Project Leads supporting 2 improvement projects throughout DO. In March 2010, I moved to a new developmental 3 assignment as a Field Supervisor for the Underground (UG) Cable Pulling team at the 4 Trombly Service Center. At Trombly, I was responsible for overseeing the daily 5 construction work performed by the UG Cable Pullers and supervising a Unionrepresented workforce. In January 2011, I was promoted to the CI Manager for 6 7 Corporate Services. I was responsible for coordination and implementation of CI 8 training within the organization, and I led the team of CI experts responsible for 9 improvement projects. In October 2011, I transitioned to Manager, Trombly Service 10 Center, where I was responsible for all UG operations (cable pulling and cable splicing) 11 for the Southeast (SE) Region of DO. In April 2013, my role expanded to Manager, SE 12 Region, which consisted of three service centers (Trombly, Redford, and Caniff) and 13 included all Overhead (OH) and UG operations in the SE Region. In March 2016, I was 14 promoted to Director, Service Operations responsible for all OH and UG operations in Southwest (SW), Northwest (NW), and Northeast (NE) regions in DO. In this role, I 15 also assisted in Local 17 contract negotiations. In October 2017, I assumed the position 16 17 of Director, Advanced Distribution Management System (ADMS). I lead the team 18 responsible for the successful implementation of the new ADMS. This team was 19 responsible for the strategic direction, vendor selection, and implementation of all 20 ADMS components including the Generation Management System (GMS), Energy 21 Management System (EMS), Outage Management System (OMS), Distribution 22 Management System (DMS), and the Network Management System (NMS). In April 23 2022, I transitioned to the Director, Project Management Organization (PMO) within 24 Electric Distribution Operations (DO). In this role, I led the team that was responsible

Line <u>No.</u>		U-21534
1		for managing the execution of all strategic capital programs and projects. As of July
2		2023, my role has shifted to the management of only the strategic capital programs.
3		
4	Q6.	What are your current duties and responsibilities?
5	A6.	As Director - PMO Programs, I lead the team that is responsible for managing the
6		execution of the programs making up the majority of the Infrastructure Resilience and
7		Hardening strategic investment discussed in my direct testimony. My team consists of
8		the project managers, project coordinators, construction/field supervisors, engineers,
9		and the leadership/support teams required to manage and track the progress of our
10		investments.
11		
12	Q7.	Have you previously sponsored testimony before the Michigan Public Service
13		Commission (MPSC or Commission)?
14	A7.	Yes. I have sponsored testimony in the following cases:
15		U-20836 2022 DTE Electric Rate Case
16		U-21297 2023 DTE Electric Rate Case

1	<u>Purp</u>	ose of Test	<u>imony</u>	
2	Q8.	What is	the purpose of	your testimony in this proceeding?
3	A8.	The purp	ose of my testir	nony is to support, as reasonable, prudent and necessary, the
4		historical	capital expend	itures for 2022 and projected capital expenditures for 2023
5		through	December 31,	2025, in the distribution strategic capital category of
6		Infrastru	cture Resilience	and Hardening.
7				
8	Q9.	Are you	sponsoring any	v exhibits in this proceeding?
9	A9.	Yes. I ar	n supporting the	e following exhibits:
10		<u>Exhibit</u>	<u>Schedule</u>	Description
11		A-12	B5.4	Projected Capital Expenditures – Distribution Plant (Pages
12				1, 2, 13, 19-26)
13		A-12	B5.4.8	4.8kV Hardening and Pole & Pole Tope Maintenance and
14				Modernization (PTMM) – Details
15		A-23	M5	Distribution Plant Capital Project Detail – The
16				Infrastructure Resilience and Hardening Pillar
17		A-23	M9	Wood Pole Maintenance Specification
18		A-23	M10	Pole Top Maintenance Specification
19		A-23	M12	4.8kV Hardening Technical Conference
20		A-23	M13	PTMM Benefit Cost Analysis Whitepaper
21				
22	Q10.	Were the	ese exhibits pre	pared by you or under your direction?
23	A10.	Yes, they	were.	
24				
25				

Line

No.

Line	
No	

<u>INO.</u>		
1	Q11.	How is your testimony organized?
2	A11.	My testimony consists of the following parts:
3		Part I: The Infrastructure Recovery Mechanism
4		Part II: The Infrastructure Resilience and Hardening Pillar
5		
6	<u>Part I</u>	: The Infrastructure Recovery Mechanism (IRM)
7	Q12.	Are any of the programs you are supporting impacted by the Company's
8		Distribution Infrastructure Recovery Mechanism (Distribution IRM or IRM)?
9	A12.	Yes, as described by Company Witness Foley in his testimony, in its December 1, 2023
10		Order in Case No. U-21297 (December 2023 Order) the Commission authorized IRM
11		treatment for the Breaker Replacement Program and the URD Replacement Program.
12		IRM treatment was authorized starting on December 1, 2023, and running through the
13		end of 2025.
14		
15	Q13.	Is the Company proposing any investment in these programs during the bridge
16		and/or test years beyond what the Commission previously authorized for recovery
17		through the IRM?
18	A13.	Yes, as reflected in Exhibit A-12, Schedule B5.4, Page 13, Lines 16 and 18, the
19		Company is proposing recovery of investment in these programs made in 2023 prior to
20		the IRM being authorized by the Commission in its December 2023 Order. All bridge
21		and test year investments in these programs after the IRM was authorized is being
22		recovered through the IRM. As such, 2024 investment (column d) and 2025 investment
23		(columns e and g) are \$0 in the exhibit, reflecting no recovery is being proposed through
24		base rates for these programs in those years.
25		

<u>No.</u>		
1	Q14.	Is the Company proposing recovery for any additional investment in these
2		programs through the IRM beyond the test year of this case?
3	A14.	Yes, as described by Company Witness Foley, the Company is proposing a two-year
4		extension of the IRM (i.e., calendar years 2026 and 2027). As part of that extension the
5		Company is proposing recovery of additional Breaker Replacement Program
6		investment and URD Replacement Program investment as captured in Exhibit A-33,
7		Schedule X1, Lines 4 and 5.
8		
9	Q15.	Is the Company proposing any additional programs be authorized for IRM
10		treatment beyond the test year of this case?
11	A15.	Yes, as part of the proposed two-year IRM extension described by Company Witness
12		Foley, the Company is proposing that the Pole and Pole Top Maintenance &
13		Modernization (PTMM) program be authorized for IRM treatment. The Company is
14		proposing \$150 million of capital investment in 2026 and \$200 million of capital
15		investment in 2027 for this program, as captured in Exhibit A-33, Schedule X1, Line
16		7.
17		
18	Q16.	Why is the Pole and Pole Top Maintenance & Modernization (PTMM) program
19		a good candidate for IRM treatment?
20	A16.	There are three screening criteria that the Company used to identify the capital
21		programs it proposed to be authorized for IRM treatment. Specifically, the Company
22		looked for programs that had the following characteristics:
23		• Critical to customer safety, reliability, and/or resiliency

• Sufficient size and duration

24

Line

• Well-understood scope

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		
2		The Company believes that the PTMM program meets these criteria and therefore is a
3		good candidate to be authorized for IRM treatment.
4		
5	<u>Part I</u>	I: The Infrastructure Resilience and Hardening Pillar
6	Q17.	What is the Infrastructure Resilience and Hardening Pillar?
7	A17.	The Infrastructure Resilience and Hardening Pillar includes programs and projects
8		focused on near-term grid infrastructure investments to harden the system against an
9		increasing frequency and severity of high winds and storms ¹ , address frequent outage
10		circuits, and replace damaged and/or defective infrastructure. These investments
11		support employee and public safety, customer reliability, and reduce risk to the grid.
12		
13		Capital investment details of programs and projects in this category are included in the
14		following:
15		• Exhibit A-12, Schedule B5.4, page 13 – Infrastructure Resilience and Hardening
16		Capital Investments;
17		• Exhibit A-12, Schedule B5.4.8 – 4.8kV Hardening Program and PTMM Program
18		Details;
19		• Exhibit A-23, Schedule M5 – Infrastructure Resilience and Hardening Program and
20		Project Charters; and
21		• Exhibit A-12, Schedule B5.4 includes AFUDC for this category on page 19 and
22		plant activity on pages 20 and 21, described in more detail by Company Witness
23		Kryscynski.
24		

¹ The severity of recent storm activity is discussed by Company Witness Hill beginning on page BLH-9.

Line <u>No.</u>		U-21534
1	Q18.	What programs and projects fall under the Infrastructure Resilience and
2		Hardening Pillar?
3	A18.	The Infrastructure Resilience and Hardening Pillar consists of the following programs
4		and projects:
5		• 4.8kV Hardening Program
6		• Pole and Pole-Top Maintenance and Modernization (PTMM) Program
7		Substation Risk Projects
8		• Frequent Outage Programs (CEMI ²)
9		Cable Replacement Program (System Cable)
10		Underground Residential Distribution (URD) Replacement Program
11		Breaker Replacement Program
12		Mobile Fleet Program
13		Pontiac Vaults Projects
14		• 40kV: Automatic Pole Top Switch Program
15		Disconnect and Switcher Replacement Program
16		Steel Pole Highway Crossings Program
17		Batteries and Chargers Replacement Program
18		SCADA Pole Top Device Replacement
19		Substation Regulator Replacement
20		Portable Generators Program
21		
22	The 4	.8kV Hardening Program
•••	010	

Q19. Why was the 4.8kV Hardening Program created? 23

² Customers Experiencing Multiple Interruptions (CEMI) is an industry term that is often used interchangeably with frequent outages.

Line
No.

1	A19.	The 4.8kV Hardening Program was developed in 2017 to be a near-term, cost-effective
2		way to improve public safety and reliability in and around the City of Detroit. The
3		program improves safety by removing Detroit Public Lightning Department (DPLD)
4		arc wire where it is co-located with DTE equipment and is therefore at risk of becoming
5		energized. The program improves reliability by replacing damaged poles and pole-top
6		equipment in locations that contain some of the oldest infrastructure in DTEE's service
7		territory. The 4.8kV Hardening Program allows for a more rapid removal of arc wire
8		alongside improved reliability and safety, ahead of the longer-term circuit conversions
9		that will ultimately replace 4.8kV infrastructure.
10		
11	Q20.	What is the scope of the 4.8kV Hardening Program?
12	A20.	The scope of the 4.8kV Hardening Program includes all overhead circuits in and around
13		the city of Detroit in areas known to contain DPLD arc wire.
14		
15		The program's work activities are listed below:
16		• Test all utility poles that have Company equipment attached and replace or
17		reinforce those poles as needed.
18		• Trim trees, as required, to support construction activities.
19		• Remove DPLD arc wire from Company-owned equipment; ensure the
20		remaining Company wires are left in a safe configuration.
21		• Remove DPLD distribution wire from Company-owned equipment when it can
22		be confirmed that the wire is not serving customers.
23		• Replace wooden crossarms with fiberglass crossarms as needed.
24		• Replace other pole-top equipment as required, allowing for rebalancing of the
25		remaining conductor.

Line <u>No.</u>	U-21534
1	• Remove service lines to abandoned properties.
2	• Remove primary conductor in sparsely populated areas (primary
3	deconductoring).
4	• Perform any additional work necessary as dictated by field conditions.
5	
6	Figures 1 and 2 show examples of before and after the 4.8kV Hardening work activities
7	are completed.
8	

PR



PLD: DPLD Distribution Wi	re
ARC: DPLD Arc Wire	
PRI: DTEE Primary Wire	
SEC: DTEE Secondary Wir	e

2

3

4

5

6





3

4

Line

No.

- Q21. Why does the 4.8kV Hardening Program include tree trimming and pole and poletop equipment replacement rather than only removing DPLD arc wire?
- 5 A21. These additional activities beyond removing DPLD arc wire are necessary to make the 6 worksite accessible for field crews, and safe for both field crews and the public. Tree 7 trimming is necessary for field crews to gain access to the poles as well as the wire.
1 Testing and replacing or reinforcing poles is necessary to make the site safe and 2 supports improved resiliency and reliability. Crossarm replacement and rebalancing is 3 likewise necessary, as removing the DPLD arc wire only could potentially leave 4 crossarms dangerously unbalanced and create hazards. Unbalanced crossarms may 5 occur because DPLD arc wire and the Company's overhead lines were originally 6 installed to provide equal force on each side of the crossarm; when the arc wire is removed, the remaining DTE wires exert force on only one side of the crossarm, 7 8 resulting in the need for the wires to be rebalanced so they are properly supported. 9 10 **Q22.** Has the Commission previously supported the Company's investments in the **4.8kV Hardening Program?** 11 12 A22. Yes. The Commission approved 4.8kV Hardening Program investments in Case Nos. 13 U-20162, U-20561, U-20836, and U-21297. The 4.8kV Hardening Program aligns with the Commission's expectation that the Company remove DPLD arc wire³. 14 15 The Commission has since reiterated its support for the 4.8kV Hardening Program in 16 Case No. U-21297 stating: 17 Completing this work is crucial to the residents and businesses located 18 19 in areas that contain abandoned arc wire and the Commission agrees 20 with the Staff that the removal of the arc wire should be going faster. 21 While the work is expensive (in part because hardening means going 22 back to the same pole twice), comprehensively addressing the safety and 23 equity concerns is a priority and the Commission recognizes that

³ In its September 28, 2018 Order in Case No. U-18484 the Commission noted that "[a]ppropriate integration of arc wire removal with other DTE Electric programs, such as the hardening and conversion programs, is a crucial aspect of planning and executing strategies." (U-18484 Order, pg. 6)

Line <u>No.</u>		U-21534
1		conversion takes much longer than hardening the Commission
2		approves the requested bridge period and test year funding and expects
3		to see results in DTE Electric's next rate case, including an accelerated
4		removal of the arc wire as discussed by the Staff. (U-21297 -
5		Commission Order, December 1, 2023, p. 93-94)
6		
7	Q23.	What stakeholder engagements for the 4.8kV Hardening Program were required
8		by the Commission in Order No. U-20836?
9	A23.	The Company was directed to hold stakeholder engagements in the first quarter of 2023
10		covering the following items:
11		• Complete a full analysis that demonstrates the specific costs of hardening,
12		conversion, distributed energy resources (DERs), tree trimming, and/or other
13		alternatives compared with the benefits, such as improving safety and reducing
14		System Average Interruption Index (SAIDI) and System Average Interruption
15		Frequency Index (SAIFI).
16		• Conduct an analysis of the capabilities/constraints of the 4.8kV system and how
17		it affects the use of DERs and electric vehicles (EVs) compared to conversion
18		to a 13.2kV system.
19		• Complete a full analysis and comparison of alternatives to hardening including
20		use of DERs and EVs compared to conversion to a 13.2kV system.
21		• Complete a full analysis of optimal reliability-focused distribution technologies
22		and plan a course of action for arriving at an equitable future for environmental
23		justice and other disadvantaged communities.
24		• Calculate the miles of arc wire removed to date, the estimated miles of arc wire
25		remaining, the level of confidence that all arc wire is captured in the Company's

Line <u>No.</u>		U-21534
1		inventory, the cost of removal with the 4.8kV hardening program, and the cost
2		without the program.
3		
4	Q24.	Did the Company perform the alternatives analysis and host the Technical
5		Conference in Q1 2023?
6	A24.	Yes, the Company presented an overview of its distribution system and alternatives to
7		the 4.8kV Hardening Program at the DTE Electric 4.8kV Technical Conference hosted
8		by the MPSC Staff on March 22, 2023. This presentation can be found in Exhibit A-
9		23, Schedule M12 - 4.8kV Hardening Technical Conference.
10		
11	Q25.	What was presented to the MPSC Staff and Intervenors regarding the 4.8kV
12		Hardening Program in the March 22, 2023, Technical Conference?
13	A25.	The Company presented the following:
14		• An overview of the 4.8kV distribution system,
15		• A comparison of the 4.8kV and 13.2kV distribution systems,
16		• A list of considerations for the implementation of electric vehicles and
17		distributed energy resources,
18		• An overview of the City of Detroit and DPLD arc wire infrastructure,
19		• A description of the program scope and customer benefits of the 4.8kV
20		Hardening Program, and
21		• A discussion of alternatives to the 4.8kV Hardening Program.
22		
23		The March 22, 2023, Technical Conference materials (including the agenda,
24		presentation slides, video recording of the meeting, and follow-up questions and

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		answers) can be found at https://www.michigan.gov/mpsc/consumer/electricity/dte-
2		electric-4-8kv-technical-conference.
3		
4	Q26.	What alternatives were considered to the 4.8kV Hardening Program?
5	A26.	Four alternatives were considered: arc wire removal, pre-conversion, conversion, and
6		microgrids, and their associated required investment, execution complexity, and
7		anticipated customers benefits (Table 1).
8		
9		Arc Wire Removal includes trimming trees as necessary, reinforcing/replacing poles
10		and replacing pole top equipment as necessary, removing DPLD arc wire, and
11		rebalancing cross arms.
12		
13		Pre-conversion includes trimming trees as necessary, rebuilding pole tops, replacing
14		poles and transformers as necessary, removing DPLD arc wire, reconductoring
15		overhead lines as needed, installing neutral wire, and rebuilding underground
16		infrastructure as necessary.
17		
18		Conversion includes all pre-conversion activities as well as substation expansions as
19		necessary, new substation construction as necessary, new circuit construction, circuit
20		reconfiguration, and load transfer work activities.
21		
22		Microgrids includes all pre-conversion activities as well as solar and battery storage
23		installation, support equipment installation (inverters, switchboards, communication
24		gateways, reclosers, etc.), and site preparation needed to house this equipment.
25		

		Arc Wire Removal	Improved Reliability	Improved Safety/ Wire down	Improved Capacity	Cost Level	Execution Complexity
	Tree Trimming	\bigcirc	$\overline{}$		\bigcirc	Low	Low
_	РТММ	\bigcirc			\bigcirc	Low	Low
5 1	Arc Wire Removal				\bigcirc	Medium	Low
sti Stati	4.8kV Hardening			$\overline{}$	\bigcirc	Medium	Low
ਸੂ 3	Pre-conversion					High	Medium
1	Conversion					High	High
<mark>õ</mark> s	Microgrids				$\overline{}$	Very High	Very High
	DERs	0	0	0		Medium	Medium
	Energy Efficiency	\bigcirc	\bigcirc	\bigcirc		Low	Medium
	Storage	\bigcirc		\bigcirc		High	Medium

Table 1. Hardening Program Alternatives Overview

Line

Q27. How does the 4.8kV Hardening Program compare to these alternatives in terms of investment required and expected benefits?

5 A27. The Company presented Table 2 during the March 22, 2023, Technical Conference. 6 This table shows the average investment required per mile, expected wire-down 7 reduction, SAIFI⁴ reduction, CAIDI⁵ reduction, capacity impact, DER⁶ support, and 8 execution complexity for the 4.8kV Hardening Program and its alternatives.

²

⁴ System Average Interruption Frequency Index (SAIFI) is an industry term and is the measurement of the average frequency of outage events any given customer on the Company's system would experience.

⁵ Customer Average Duration Interruption Index (CAIDI) is an industry term is a measurement of the average outage duration that any given customer on the Company's system would experience. CAIDI is the average outage restoration time for a customer outage.

⁶ Distributed Energy Resources (DER) are devices such as electric vehicle chargers and customer-owned solar panels.

1

	Avg. Cost per Mile (\$ thousands)	Wire down Reduction	SAIFI Reduction	CAIDI Reduction	Capacity Increase	Increased DER Usage	Execution Complexity	Potential Use Case
Arc Wire Removal	\$191	13%	22%	36%	No	No	Low	Lowest overall cost to remove arc wire
4.8kV Hardening	\$353	26%	44%	72%	No	No	Low	Highest benefit/cost for reliability improvement
Pre- conversion	\$1,700	90%	85%	85%	No	Yes	Medium	Provides step change in reliability performance
Conversion	\$2,700	90%	85%	85%	Yes	Yes	High	Best benefit/cost for significant capacity needs
Microgrids	\$14,600	90%	95%	95%	Yes	Yes	Very High	Potentially application for grid areas with critical reliability needs

Table 2. Hardening Program Alternatives Comparison

2

3

4

5

The 4.8kV Hardening Program strikes the best balance of removing DPLD arc wire in the near-term while also offering significant reliability improvements and being affordable for customers.

6

Q28. In addition to the analysis presented in the Technical Conference, what additional
 analyses for the 4.8kV Hardening Program were required in Order for Case No.
 U-21297 on December 1, 2023?

10 A28. The Commission ordered the Company to:

Create a comprehensive, detailed, and longer-term plan for this work that
 includes an equity and safety analysis. The equity analysis must meet the
 following requirements include EJ analyses that provide community
 vulnerability gradations based on the MiEJScreen tool using 0% to 5%, 5% to

Line <u>No.</u>		U-21534
1		10% , and 5% gradations all the way to $95\%\mathchar`-100\%$ of the MiEJScreen composite
2		score;
3		• Identify and qualify the potential hazard associated with other DPLD wire for
4		which DTE Electric has not provided documentation to date; and
5		• Show how equity has informed, and continues to inform, the Company's
6		actions with respect to 4.8kV Hardening and arc wire removal efforts.
7		
8	Q29.	Has the Company completed the Environmental Justice (EJ) analyses as directed
9		by the Commission pertaining to the 4.8kV Hardening Program?
10	A29.	Yes. The Company has performed an EJ/equity analysis of the 4.8kV Hardening
11		Program by mapping its circuits to census tracts and cross-referencing with the
12		MiEJScreen tool. The MiEJScreen tool can be found at
13		https://www.michigan.gov/egle/maps-data/miejscreen.
14		
15		As shown in Company Witness Kryscynski's testimony, 85% of all 4.8kV Hardening
16		Program investments from 2018-2025 impact communities that score between the top
17		80-100% MiEJ scores and are deemed vulnerable. More details of EJ/equity analysis
18		can be found in Company Witness Kryscynski's testimony.
19		
20	Q30.	What progress has been made through year-end 2023 on the 4.8kV Hardening
21		Program?
22	A30.	The Company hardened approximately 373 miles in 2023 (Table 3) and has hardened
23		nearly 1,500 miles total from 2018-2023, which represents approximately 70% of the
24		total program scope. The Company has removed approximately 208 miles of arc wire
25		in 2023, and approximately 640 miles total from 2018-2023.

MEA - 19

A total of 307 circuits, representing approximately 196,000 customers in the city of Detroit and surrounding areas, have been hardened by the program through year-end 2023.

4

Line

No.

1

2

3

5

4.8kV Hardening	2018 Actual	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Forecast	Total
Miles Hardened	105	128	209	202	475	373	1,492
Arc Wire Miles	59	52	105	64	155	208	643
Capital Investment (\$ thousands)	\$40,325	\$48,278	\$55,165	\$65,362	\$157,482	\$127,010	

7	Q31.	Why are there fewer miles of DPLD arc wire removed than miles hardened in
8		each year of the 4.8kV Hardening Program?
9	A31.	There are fewer miles of DPLD arc wire removed because the DPLD system does not
10		perfectly overlap DTE's distribution system. The Company has observed that there is,
11		on average, approximately twice as much DTE distribution wire on Detroit circuits as
12		there is DPLD arc wire.
13		
14	Q32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc
14 15	Q32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire?
14 15 16	Q32. A32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire? No. The 4.8kV Hardening Program does not target areas that do not contain DPLD arc
14 15 16 17	Q32. A32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire? No. The 4.8kV Hardening Program does not target areas that do not contain DPLD arc wire. The program targets all circuits on substations in areas known to contain DPLD
14 15 16 17 18	Q32. A32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire? No. The 4.8kV Hardening Program does not target areas that do not contain DPLD arc wire. The program targets all circuits on substations in areas known to contain DPLD arc wire. However, it is often the case that a circuit does not contain as much DPLD
14 15 16 17 18 19	Q32. A32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire? No. The 4.8kV Hardening Program does not target areas that do not contain DPLD arc wire. The program targets all circuits on substations in areas known to contain DPLD arc wire. However, it is often the case that a circuit does not contain as much DPLD arc wire as DTE distribution wire. Because there is a fixed cost to planning work and
14 15 16 17 18 19	Q32. A32.	Does the 4.8kV Hardening Program target areas that do not contain DPLD arc wire? No. The 4.8kV Hardening Program does not target areas that do not contain DPLD arc wire. The program targets all circuits on substations in areas known to contain DPLD arc wire. However, it is often the case that a circuit does not contain as much DPLD arc wire as DTE distribution wire. Because there is a fixed cost to planning work and

Line No. 1 mobilizing and demobilizing crews, the Company hardens the entire circuit so that all 2 customers in the area benefit from improved safety and reliability. 3 4 Q33. What is the Company's plan to accelerate and complete the 4.8kV Hardening 5 **Program?** The 2024 4.8kV Hardening workplan includes the hardening of approximately 145 6 A33. circuit miles and removing 95 miles of arc wire. The Company has accelerated its plans 7 8 for removing arc wire in response to the direction provided by the Commission⁷. The 9 2025 4.8kV Hardening workplan includes hardening approximately 310 circuit miles 10 and removing 189 miles of arc wire. The 2026 4.8kV Hardening workplan includes 11 hardening approximately 116 circuit miles and removing 89 miles of arc wire. Table 12 4 shows the total planned circuit miles hardened and DPLD arc wire removed at the 13 conclusion of the 4.8kV Hardening Program in 2026. 14 15 A total of approximately 500 circuits, representing approximately 295,000 customers in the city of Detroit and surrounding areas, will have been hardened at the conclusion 16

of the program.

⁷ In its December 1 Order in Case No. U-21297 the Commission stated, "completing this work is crucial to the residents and businesses located in areas that contain abandoned arc wire and the Commission agrees with the Staff that the removal of the arc wire should be going faster." (Order at pg. 93)

Line <u>No.</u>

1	Miles Har	dened an	d DPLD A	Arc Wire	Removed					
4.8kV Hardening	2018 Actual	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Forecast	2024 Forecast	2025 Forecast	2026 Forecast	Total
Miles Hardened	105	128	209	202	475	373	145	310	116	2,063
Arc Wire Miles	59	52	105	64	155	208	95	189	89	1,015
Capital Investment	\$40,325	\$48,278	\$55.165	\$65.362	\$157.482	\$127.010	\$80.000	\$125,000	\$35,960	

2

(\$ thousands)

3

4

Q34. At the conclusion of 2026, how much of the DPLD arc wire that is co-located with DTE equipment will be removed and how much will be remaining?

- A34. The Company had patrols conducted on its infrastructure in and around the City of
 Detroit, and the final combined total of co-located DPLD arc wire identified was
 approximately 1,268 miles (Table 5).
- 8
- 9

Table 5.DPLD Arc Wire Removal 2018-2026

Program	Arc Wire Miles
4.8kV Hardening	1,015
Remaining DPLD Arc Wire	253
Total	1,268

11	The Company estimates that approximately 1,015 of these DPLD arc wire miles will
12	be removed by the 4.8kV Hardening Program from 2018-2026 and that 253 miles of
13	DPLD arc wire will be remaining. The Company is continuing to evaluate its plans for
14	removing the remaining DPLD arc wire with the remaining miles being addressed with

Line <u>No.</u>		U-21534
1		circuit conversion projects, and the possibility of further 4.8kV Hardening work to
2		ensure timely removal.
3		
4	Q35.	Has the Company patrolled and catalogued all DPLD arc wire beyond that which
5		is co-located with Company infrastructure?
6	A35.	No. The Company has only patrolled and identified DPLD arc wire that is co-located
7		with Company equipment. The Company focused on cataloging co-located DPLD arc
8		wire because it represents a safety risk due its close proximity to energized wire and
9		has the potential to become energized as explained in Question 20.
10		
11	Q36.	How does the 4.8kV Hardening Program benefit customers?
12	A36.	Results show that the 4.8kV Hardening Program has been effective in improving the
13		safety, reliability, and resiliency of circuits (Figures 3, 4, and 5).
14		
15		The Company reviewed the three-year historic average for reliability and wire-downs
16		of the circuits hardened prior to the year hardened, and compared those numbers to the
17		year after hardening was complete. The Company also reviewed the three-year historic
18		average for reliability and wire-downs for circuits in the control group (which includes
19		the city of Detroit, and surrounding areas), that were not hardened in that time period.
20		The circuits included in this analysis were hardened in 2019, 2020, and 2021. Three
21		key metrics were reviewed to determine the effectiveness of the 4.8kV Hardening
22		Program: All-Weather System Average Interruption Frequency Index (SAIFI), System

All-Weather SAIFI reflects the frequency of the outage events experienced by customers on the circuits regardless of weather conditions. SAIDI Ex-MEDs is an indicator of the amount of time customers are without power excluding the most significant weather event days, such as very large storms. The reduction in the number of wire-downs is a measure of the safety improvements for the circuits that were hardened.





12

Line

No.

1

2

3

4

5

6

7

8

9

⁸ Major Event Days (MEDs) is an industry term that denotes a day in which a utility experienced a catastrophic event which exceeds reasonable design or operational limits of the electric power system and during which at least 10% of the customers within an operating area experience a sustained interruption during a 24-hour period. More information about MEDs and their calculation can be found at https://cmte.ieee.org/pes-drwg/wp-content/uploads/sites/61/2003-01-Major-Events-Classification-v3.pdf.

1 Figure 3 displays the All-Weather SAIFI improvement of hardened circuits vs. the 2 control group; the customers on hardened circuits experienced a 38% improvement in 3 All-Weather SAIFI, while the control group circuits degraded by 23%, resulting in a 4 net improvement of 61% for hardened circuits. 5





6

Line

No.

7 Figure 4 displays the SAIDI Ex-MEDs improvement of hardened circuits vs. the control group; the customers on hardened circuits experienced a 65% improvement in 8 9 SAIDI Ex-MEDs, while the control group improved by 3% improvement, resulting in a net improvement of 62% for hardened circuits. 10

- 11
- 12
- 13







Figure 5 displays the wire-down event improvement of hardened circuits vs. the control group; the customers on hardened circuits demonstrated a 25% improvement, while the control group degraded by 22%, resulting in a net improvement of 47% for hardened circuits.

7

2

8 Q37. Why does the 4.8kV Hardening Program perform deconductoring on some 9 circuits?

A37. As stated in Company Witness Deol's testimony, the customer benefits of
 deconductoring are the elimination of potential wire-downs by removing overhead
 lines that are not fully utilized and the elimination of potential power outages caused
 by those lines failing or being damaged. The primary drivers of the 4.8kV Hardening
 Program are to remove DPLD arc wire to reduce wire-downs and improve safety, and

Line No. 1 to evaluate the poles and pole-top equipment for replacement to balance the crossarms 2 and improve reliability. As such, deconductoring fits into the scope of the 4.8 kV3 Hardening Program. 4 5 How can customers stay informed about 4.8kV Hardening work being performed **Q38**. 6 in their area? Customers interested in seeing if 4.8kV Hardening work is being performed in their 7 A38. website 8 respective visit Company's external area can the at 9 https://dte.maps.arcgis.com/apps/webappviewer/index.html?id=5d9dc2eb1244456189 10 59ce788086e00e. These maps are regularly updated to inform our customers of the 11 reliability work the Company is performing on their behalf, to visually display work 12 completed in the last 6 months, and to show work scheduled to be completed within 13 the next 12 months. Please note that the 4.8kV Hardening and PTMM Programs are 14 called "Upgrading Existing Infrastructure" in the map provided on this website. This map also shows Tree Trimming, Customer Excellence (called "Rapid Response"), and 15 Circuit Conversion (called "Rebuilding Significant Portions of the Grid"). A current 16 example of this map showing only the Upgrading Existing Infrastructure layer can be 17 18 seen in Figure 6.

Eastpointe

Line No. 1

DTE Electric Reliability Improvements Map

₩ 🗄 🛸

Trimming Trees - Historically, equipment damage from fallen tree limbs and branches is responsible for nearly 50% of the time customers spend without power. That's why we've accelerated our efforts to trim trees away from our power lines and poles to reduce damage to our equipment during storms.

reduce damage to our equipment during storms. Upgrading Existing Infrastructure – Strengthening the existing utility poles, power lines and electrical equipment that deliver your power to better withstand extreme weather. Rapid Response – Trimming trees away from our poles and wires and repairing or replacing the equipment on our poles to quickly improve reliability in communities experiencing issues in between planned maintenance work. Rebuilding Significant Portions of the Grid - Removing and replacing electrical substation equipment and the underground and overhead infrastructure that delivers power, including installing new poles and wiring. Necessary tree trimming will be completed in advance of pole replacements.





2

The Pole and Pole-Top Maintenance and Modernization Program (PTMM) 3



Q39. What is the Pole and Pole-Top Maintenance and Modernization (PTMM) Program?

A39. The PTMM Program is the Company's program to inspect and maintain overhead
 distribution equipment, in support of improving the system reliability and resilience to
 weather, storms, and tree-related events as described below. Formerly called the Pole Top Maintenance (PTM) Program, the modernization aspect was included in late 2019,
 and the program renamed to PTMM to reflect updated standards for inspection
 methods, and updated standards for equipment, and materials.

9

10 **Q40.** What are the drivers of the Company's PTMM Program?

11 A40. Approximately 70% of DTEE's infrastructure is overhead. Overhead equipment 12 failures cause approximately 25% of all outages customers experience during all 13 weather conditions, and over 30% of all outages customers experience excluding Major 14 Event Days (MEDs). Poles and pole-top equipment are some of the most critical and 15 visible parts of the distribution and subtransmission grid, and are continually exposed 16 to harsh conditions (e.g., tree strikes, ice, heat, rain, lightning, sunlight, and wind), causing them to degrade, weaken, and fail over time. Examples of equipment damage, 17 18 also called inspection defects, are shown in Figure 7.

M. ELLIOTT ANDAHAZY U-21534

Figure 7. Pole and Pole-Top Defect Examples



The Company has approximately 31,000 miles of overhead distribution and 3 4 subtransmission lines, collectively containing approximately one million Company-5 owned wood poles and associated pole-top equipment. Utility poles have a useful life 6 expectancy of approximately 40-50 years and have elevated failure risk as they age 7 beyond their useful life. Useful life is a standard industry term that does not represent 8 the actual life of an asset, but rather the age at which an installed asset is expected to 9 experience increasing failure rates and deliver reduced performance, such that it is often 10 more prudent to replace than to continue to repair and maintain. Figure 8 displays 11 DTEE owned utility pole counts currently in use in the system by age range.

12

Line

No.







2

Aging poles and pole-top equipment increase the risk of overhead equipment failures, which can subsequently cause outages. In addition to outages, examples of incidents that can occur in the event of pole and pole-top equipment failures include property damage, fires, and traffic accidents. Additionally, long and costly customer outages can result when this equipment fails unexpectedly from tree impacts or from other causes. Figure 9 displays an example of a pole-top equipment failure.



Line No. 1



2

3

4

5

6

Pole and pole-top maintenance programs are standard utility industry programs that inspect circuits for damaged or defective poles and pole-top equipment, replacing them before they cause failures. Details regarding industry benchmarking the Company has conducted can be found below.

7

8

Q41. What benchmarking has the Company performed on PTMM?

A41. The Company has performed three benchmarking studies in 2018, 2021, and 2022 on 9 10 the PTMM practices at fifteen peer utilities. While these studies varied in what portion 1 of the PTMM programs were in focus, the Company found that all of the utilities had 2 some sort of maintenance program to proactively address defective pole and pole-top 3 assets in the field before they fail. Additionally, the benchmarking identified that the Company's inspection standards, including a 10-12 year pole inspection cycle, are in 4 5 line with other utilities. Table 6 displays the Pole Inspection and Pole-Top Inspection 6 cycle identified in seven of the utilities located in the Northeast and Midwest, indicating 7 that most utilities operate on a 10-year (or less) cycle time for pole inspections and 8 construction, and a 5-year cycle time for pole-top inspections and construction.



PTMM Benchmarking

	Company 1 Northeast	Company 2 Northeast	Company 3 Midwest	Company 4 Midwest	Company 5 Midwest	Company 6 Midwest	Company 7 Midwest
Pole Inspection Cycle	10 years	5 years	10 years	10 years	10 years	12 years	8-12 years
Pole-Top Inspection Cycle	4 years	5 years	5 years	5 years	5 years	12 years	8-12 years

11

9

10

Line

No.

In addition to industry utility benchmarking, the Company consulted multiple industry
expert publications and guidelines when developing and updating its PTMM program
policies, as noted in Table 7.

1

Table 7.Industry Standards & Guidelines

Summary of Industry Standards and their Application in DTE's Pole Inspection Specification

Report	DTE Application					
IEEE National Electric Safety Code (NESC)	 Per the NESC standard, 67% pole strength is used as the threshold to accept or reject a pole in DTE's specification 					
	The report outlines the frequency of pole inspection cycle of 10 years in Michigan					
Rural Utilities Services UEP Bulletin 1730B-121	 DTE's specification leveraged the guidelines in this report for other conditions aside from pole strength that could justify rejection of a pole such as severe woodpecker hole damage and split top 					
	 DTE also leveraged this report for classifying a rejected pole as a restorable reject where a remedial treatment is applied or a non-restorable reject where the pole is replaced 					
	 The Oregon State Forest Research Lab report references the NESC safety standard for pole strength and UEP Bulletin pole classifications as described above, further validating the practice as industry standard 					
Wood Pole Maintenance Manual (2012) Oregon	 The report provides a sample pole inspection procedure that details various methods and equipment to inspect poles 					
Lab	 Methods include excavation, partial excavation, sounding, boring, shell thickness measurements for evidence of decay, and applying remedial treatment to reinforce poles 					
	 DTE's pole inspection specification leverages the methods outlined in the report 					
American Wood Protection Association	 The AWPA report details methods for inspection, similarly to the Oregon State Forest Research lab report, further validating the practices as industry standard 					
Guidelines for a Pole Maintenance Program	 The report includes additional consideration in the design of a pole inspection program, such as workforce/personnel and data management 					

2

Q42. How has this benchmarking and industry research impacted the way the Company manages its PTMM program?

5 A42. The Company has continued to use internal expertise, combined with benchmarking 6 and industry standards, to develop and update the PTMM program and associated 7 specifications to ensure best practices are implemented timely to improve reliability for 8 customers. Based on these findings, the Company is aspiring to implement a PTMM 9 program capable of inspecting, and completing the required construction, for poles on 10 a 10-year cycle and pole-top equipment locations on a 5-year cycle to match the 11 industry best practice identified in the benchmarking efforts discussed above.

Line
No.

1	Q43.	What is the scope of DTEE's PTMM Program?
2	A43.	The PTMM Program inspects all wood poles and all pole-top equipment on distribution
3		and subtransmission overhead circuits, and identifies and replaces poles and pole-top
4		equipment that fails inspection. The PTMM Program scope includes all overhead
5		circuits except those included in the 4.8kV Hardening Program.
6		
7		The PTMM Program's work activities are described below:
8		1. Poles are inspected for damage that will undermine structural integrity.
9		(a) Poles younger than 20 years are visually inspected above grade.
10		(b) Poles older than 20 years are visually inspected and excavated below grade
11		level and physically tested.
12		2. Poles which fail inspection are treated and reinforced, or replaced.
13		3. Trees are trimmed, as required, to support construction activities.
14		4. Pole-tops and pole-top equipment are visually inspected for damaged and/or
15		defective equipment.
16		5. Pole-top equipment which fails inspection is replaced. Examples include:
17		(a) Damaged wooden crossarms are replaced with fiberglass crossarms.
18		(b) Damaged/defective porcelain cutouts are replaced with polymer cutouts.
19		(c) Damaged/defective porcelain insulators are replaced with polymer
20		insulators.
21		
22		Figures 10 and 11 show the improvements made before and after PTMM is complete
23		at a pole-top location.
24		









5

2

3 4

Line

<u>No.</u> 1

6 Q44. Does the PTMM Program replace poles and pole-top equipment based solely on
7 age?

Line

No.

1

- A44. No. The PTMM Program inspects poles and pole-top equipment and only replaces those which fail inspection.
- 3

4

2

Q45. How does the Company decide whether a pole should be reinforced or replaced?

5 A45. The Company's pole inspection process is shared in Exhibit A-23, Schedule M9 Pole 6 Specification. This exhibit contains the inspection process, pole data collected and 7 calculated, and the decision criteria for determining whether a pole should be treated, 8 reinforced, or must be replaced.

9

The following data is collected on poles older than twenty years: measured circumference at groundline, measured shell thickness at groundline, minimum measured pole circumference below groundline, measured external pole decay, measured internal pole decay, and orientation of the pocket in regard to line of lead. These data points are used to calculate 1) groundline effective circumference, 2) percent remaining pole strength, and 3) groundline condition of the pole. Figure 12 shows pole testing and inspection processes.

17

As a result of these inspections and calculations, poles are classified as acceptable, restorable rejects, or non-restorable rejects. Acceptable poles may be treated internally and/or externally depending on the specific circumstances. Restorable reject poles may be treated and/or reinforced but must be replaced instead if they meet the criteria listed below that disqualify them from reinforcement. Non-restorable reject poles are replaced.

Line <u>No.</u>

1

2

3

4

All poles below 100% strength are candidates for internal treatments unless they must be replaced. Internal treatments are designed to protect the heartwood of the pole against fungus and insect attacks but are not used on poles that do not have measurable evidence of decay, voids, infestations, are near water, at sites with well water, on schoolgrounds, farmland, or vegetable gardens.

6

5

7 All acceptable and restorable reject poles (except those that must be replaced due to the 8 criteria listed below that disqualify from reinforcement) that were fully excavated are 9 treated with exterior groundline treatment. External groundline treatments are designed 10 to protect the outer shell of the pole at groundline and reduce the loss of residual 11 circumference due to decay. Poles that are 65 feet or shorter and are measured to 12 determine if they have 67-99% of their strength remaining and are therefore deemed 13 acceptable and are candidates for external groundline treatments. Poles that are 70 feet or taller and are measured to determine if they have 75-99% of their strength remaining 14 and are therefore deemed acceptable and are candidates for external groundline 15 16 treatments.

17

The Company's pole inspection standard is in line with the Institute of Electrical and Electronics Engineers (IEEE) National Electrical Safety Code standard that poles 65 feet or shorter fail inspection if they are below 67% of their original strength, and must be treated, reinforced, or replaced. Poles that are 70 feet or taller fail inspection if they are below 75% of their original strength, and must be treated, reinforced, or replaced.

<u>No.</u>	
1	Poles that are 65 feet or shorter and are measured to have 15-66% of their strength
2	remaining, are deemed restorable rejects. Poles that are 70 feet or taller and are
3	measured to have 15-74% of their strength remaining, are deemed restorable rejects.
4	
5	All poles of any height that are measured to have less than 15% of their strength
6	remaining are deemed non-restorable rejects.
7	
8	The following criteria make a pole ineligible for reinforcement per the Company's
9	standards:
10	• An excessively leaning pole (e.g. a 40-foot pole leaning 7 inches or
11	greater at a height of 5 feet above grade) cannot be reinforced unless it
12	is it possible to straighten;
13	• A pole damaged by carpenter ants;
14	• Poles supporting wire crossing railroad tracks or highways
15	• Poles that were treated in the past with "Cellon" processes
16	• Poles cannot be reinforced under the following conditions:
17	- Poles in non-testable locations and > 50 years old
18	- Poles with less than 15% of their original strength
19	- Poles identifiable as restorable candidates but not pass above
20	grade inspection
21	- Poles with an average sound shell thickness of less than 1"
22	• Non-DTEE-owned poles;
23	• Poles smaller than class 5 (e.g. 6, 7, 8, 9);
24	• DTEE Riser poles;
25	• Poles within 100' of school property or water locations;

Line

Line <u>No.</u>	M. ELLIOTT ANDAHAZY U-21534
1	• Poles that are not candidates for remedial treatments;
2	• Electrical cable poles; and
3	• DTEE owned poles with no electrical overhead conductor
4	
5	Additionally, poles that fail visual inspection due to the following cannot be reinforced:
6	• Shell rot or surface rot decay outside ground line area
7	• Woodpecker holes around or below the hardware that appear hollow
8	• Split tops that affect the integrity of bolts or equipment
9	• Split tops that do not have a bolt running perpendicular to the split
10	• Decayed tops with decay and crowning close to hardware
11	• Spur cut that results in 1" of the pole outer shell being removed
12	• Compression wood damage resulting in horizontal cracking that
13	penetrates 1" deep into the shell and covers a large surface
14	
15	Poles that fail inspection and are not eligible for reinforcement based on the criteria
16	listed above are replaced.
17	



Figure 12. **Physical Pole Testing and Inspection**





2		
3	Q46.	How does the Company decide whether pole-top equipment should be replaced?
4	A46.	The Company's pole-top inspection process is shared in Exhibit A-23, Schedule M10
5		Pole-Top Specification.
6		
7		In general, the following items are examples of what is replaced if they are found to be
8		environmentally hazardous, broken, cracked, decayed, melted, burned, arcing, or
9		missing:
10		• Transformers
11		• Cutouts

<u>No.</u>		
1		• Crossarms
2		• Braces
3		• Brackets
4		• Insulators
5		• Arrestors
6		• Hot taps
7		Ground wire
8		Ground wire molding
9		• Conductors
10		• Spools
11		• Hardware (nuts, bolts, etc.)
12		
13	Q47.	Did the Commission address the PTMM Program in Case No. U-21297?
14	A47.	The Commission approved cost recovery for PTMM in Case No. U-21297 at an
15		investment level of \$63.45 million annually, however they expressed concerns
16		regarding the clarity around recent increases in investment levels.
17		
18	Q48.	Has the MPSC provided guidance on an appropriate cycle for pole inspections in
19		the past?
20	A48.	Yes. On November 20, 2009, the Michigan Public Service Commission Staff published
21		the "Utility Pole Inspection Program Investigation Staff Report". In that report, the
22		Staff recommended that DTEE achieve a 10-12 year pole inspection cycle frequency
23		to correlate with the standard recommended by the USDA Rural Utility Service for
24		Michigan's decay zone. The Staff also requested DTEE to provide a brief Pole
25		Inspection Report to Staff each year by September 1, beginning in 2010.

Line

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1	Q49.	Has the Company provided annual pole inspection reports to the MPSC Staff?
2	A49.	Yes, the Company has provided pole inspection reports to Staff annually since 2010.
3		
4	Q50.	What did the Commission order regarding PTMM inspection reporting and
5		benefit cost analysis in Case No. U-21297?
6	A50.	The Commission ordered the Company to prepare an annual pole and pole-top
7		inspection report, that is similar to the Company's Annual Tree Trimming Report, and
8		to complete a benefit cost analysis of the program.
9		
10	Q51.	Is the Company preparing an annual PTMM report to comply with the
11		Commission's directive described above?
12	A51.	Yes, at the time this testimony was being prepared, the data for the required report was
13		being assembled.
14		
15	Q52.	Has the Company performed a benefit cost analysis (BCA) for PTMM to comply
16		with the Commission's directive as described above?
17	A52.	Yes. The Company completed a BCA, as directed, in February 2024. The Company
18		collaborated with an external consulting firm to create a BCA for PTMM based on a
19		methodology utilized by other utilities in other states (such as IN, OH, IL, MD, FL, and
20		OK). This BCA utilized a bottoms-up, asset-based approach to capture the present
21		value of the benefits over a 40-year study period, compared to the upfront investments
22		to implement the PTMM program, creating a benefit cost ratio by circuit. For this
23		statistical model, the benefits are calculated as the avoided cost of emergent reactive
24		events caused by running equipment to failure, and includes the use of the LBNL ICE
25		calculator to model customer impacts from these outages. The "upfront investments"

1 are calculated by totaling the investment forecasted to properly complete pole and pole-2 top inspections, pole remediation and reinforcements, and pole and pole-top equipment 3 replacements required per the inspection process. The overall average system benefit 4 cost ratio for the system was calculated at 5.7, meaning if PTMM could be conducted 5 on 100% of the Company's distribution grid, the benefits realized by the customers for completing PTMM would be 5.7 times greater than the benefits realized if the 6 Company decided to run all poles and pole-top equipment to failure. The PTMM BCA 7 8 Whitepaper is included to this instant case as Exhibit A-23, Schedule M13.

9

10

Q53. What changes has the Company made to its PTMM program in recent years?

11 A53. The Company's PTMM program has gone through a transformation over the past few 12 years to support a more resilient overhead infrastructure, including alignment with the 13 industry standards discovered through benchmarking activities. The first improvements the Company implemented followed the first set of benchmarking in 14 15 2018 and 2019, and included updating the pole inspection process (as defined above), and transitioning the previous Pole Top Maintenance (PTM) Program to the Pole and 16 Pole-Top Maintenance and Modernization Program. The addition of "Modernization" 17 18 simply meant that when a pole, or piece of pole-top equipment failed inspection, the 19 Company would no longer replace like-for-like, rather the equipment would be 20 replaced with the equipment that met the new, higher-level specification to incorporate 21 more modernized equipment into the field.

22

The second set of improvements were implemented in 2021 and 2022, and included only using PTMM inspections solely (and no longer utilizing Joint Use inspections) to meet the 10-12 year cycle, and assembling a new team to enhance the PTMM program 1

2

3

4

5

6

management including more rigorous quality reviews of work completed and implementing process improvements based on industry standards learned through benchmarking. The decision to no longer utilize Joint Use inspections in the PTMM program was due to the fact that they were less rigorous than PTMM inspections and focused on telecommunications equipment and clearances, rather than focused on the Company's pole-top equipment, and were no longer suitable to use for PTMM.

7

8 The third set of improvements were implemented in 2023, and could be grouped into 9 two categories -1) inspection quality control, and 2) process improvements. First, the 10 inspection quality control improvements were implemented prior, during, and post 11 inspections to ensure adherence to DTEE's PTMM specification. They include: hands-12 on training required for all inspectors including a knowledge test; inspectors are 13 equipped with picture-based field manuals to help identify defective equipment; DTEE 14 field leads provide daily guidance to inspectors and perform quality checks on work 15 completed; and more than 50% of all job packages receive a field audit from a thirdparty to ensure accuracy. Second, the PTMM program team performed multiple 16 process improvements including developing a Geographic Information System (GIS) 17 18 based application (app) used to digitize inspection results, and streamline the 19 remediation of defective assets. Now, when the inspector submits their inspection 20 findings into the app, the team processes a completed construction job package that 21 includes a material list, compatible units (which define the specific work to be 22 completed), and four pictures of each work location. This allows the PTMM program 23 management team real-time visibility into field activities, improved coordination of 24 resources, and reduces the cycle time from inspection to construction completion.

Line <u>No.</u>

1 Q54. What has led to the increase in PTMM investments in recent years?

A54. Historically, the PTMM program has measured number of poles inspected, number of poles replaced, number of poles reinforced, and total line miles modernized (meaning pole-top equipment locations where construction is complete to remediate failed equipment identified through the inspection process). The largest cost driver of the PTMM Program is the increased quantity of defective pole and pole-top locations identified through the inspection process.

8

9 As seen in Table 8 and Table 9 below, the stringent adherence to PTMM standards and 10 enhanced quality controls has led to an increased volume of defects identified and 11 remediated on our system. In 2022 and 2023, the program increased defective pole 12 replacements by over 2,900 poles per year driven by 1) higher pole reject rates, 2) 13 higher levels of PTMM inspections (not including Joint Use). 3) and a focus on backlog reduction. During the same timeframe, the program increased defective pole-top 14 equipment replacements by approximately 5,500 pole top locations per year driven by 15 1) higher pole-top defect rates based on updated inspection standards, 2) enhanced 16 quality control (training, field audits, etc.), 3) higher circuit miles being addressed. In 17 18 this instant case, the planned investment increases per circuit mile in the PTMM 19 Program are based off the higher pole and pole-top equipment location failure rates that 20 have been recorded since improvements were made to the program.

21

Table 8.

8. **PTMM – Pole Defects per Mile**

	2019	2020	2021	2019-2021 Average	2022	2023
Poles Replaced per Circuit Mile	1.3	1.0	0.7	1.0	2.9	3.7

Line No.

.

1

-		•	
Ta	ble	<u>9.</u>	

PTMM – Pole-Top Defects per Mile

	2019	2020	2021	2018-2021 Average	2022	2023
Pole-Top Locations per Circuit Mile	1.2	1.2	2.1	1.5	3.6	12.7

2

3 Q55. What work did the PTMM program complete in 2023?

A A55. The PTMM program completed construction on 1,418 circuit miles which included
approximately 9,500 pole-top equipment locations, and replaced 3,814 poles.
Additionally, the program completed inspections on 12,650 poles.

7 8

Table 10. Historical PTMM Work Units Performed

2019 2020 2021 2022 2023 Actual Actual Actual Actual Forecast **Circuit Miles** 1,027 1,496 1,541 1,562 1,418 Poles Replaced 1,333 1,431 1,016 4,537 3,814 Poles 27 109 150 2,717 1,116 Reinforced Pole Top Locations 1,795 5,621 9,500 1,232 3,236 Replaced Capital Investment \$26,892 \$36,364 \$31,647 \$80,879 \$79,075 (\$ thousands)

9

10 Q56. Why did the PTMM program complete fewer inspections in 2023 than in prior

11 years?

A56. Prior to 2023, the Company had been consistently meeting the expectation of inspecting
 poles on a 10-12 year cycle following the MPSC direction discussed above (Figure 13).

1 However, the Company was unable to complete the required construction activities to 2 remediate the failing poles and pole-top equipment locations identified in a timely 3 manner with its total investment, thus a backlog of construction work was created. 4 Additionally, as the Company stopped utilizing Joint Use inspections in 2022, and only 5 used PTMM Program inspections, there was an increase in the number of poles and pole-top equipment locations that failed inspection per circuit mile. This compounded 6 7 the issue and grew the backlog of work which failed inspection and required 8 construction. At the beginning of 2023, the Company had a total of 4,695 poles and 9 14,654 pole-top equipment locations that failed inspection, and made the strategic 10 decision to pause most new inspections, and focus efforts on completing the required 11 construction already identified. 12 Figure 13. **Pole Inspections 2017-2023**



Pole Inspections (Thousands, 2017-2022 Actual, 2023 Estimated)

13

Line

No.

14 Q57. What is the status of the PTMM work ready for construction?
Line No.

> 1 As of January 1, 2024 the Company had 3,744 poles and 9,353 pole-top locations that A57. failed inspection and still require construction to be completed.

3

2

4 Q58. Is the Company planning to complete inspections in 2024 and 2025 consistent with 5 the 10-12 year inspection cycle previously completed?

6 Not in this instant case. Since the customer only benefits from the PTMM program A58. once the construction is complete, and the Company does not want to create a situation 7 8 where the backlog of work begins to rise above approved investment levels, DTEE has 9 made the strategic decision to only conduct pole and pole-top equipment location 10 inspections on the amount the PTMM program is funded to complete the associated 11 construction activities. Given the current approved funding levels for PTMM, and the 12 pole and pole-top equipment location failure rates, the Company will not be able to 13 meet the 10-12 year pole inspection cycle in this instant case. However, the Company is planning to continue to seek approval to increase PTMM investment levels in this 14 15 instant case and beyond, to allow a return to a 10-year pole inspection and construction cycle, and the 5-year pole-top equipment location inspection and construction cycle to 16 match the industry standard programs identified in benchmarking activities. The 17 18 specific inspection plans for 2024 and 2025 are discussed further below.

19

20 **O59**. How has the PTMM Program changed the way it prioritizes circuits for 2024?

21 A59. Due to the increase in capital investment required per circuit mile discussed above, and 22 the supported annual funding for PTMM at \$63.45 million, the Company has created a method of prioritizing work based on the worst reliability circuits for 2024. 23

24

This analysis includes categorizing circuits into four tiers, based on the frequency and magnitude of reliability issues customers experience (Table 11), where Tier 1 are the worst performing circuits and Tier 4 are the best performing circuits.

4

Line

No.

1

2

3

5

Table 11.Circuit Reliablity Tiers

Circuit Tier Prioritization Criteria		Circuit Count	Customer Count (thousands)
Tier 1	AW SAIFI or AW SAIDI in worst 500 circuits for 3+ years (2019-2023)	365	426
Tier 2	AW SAIFI or AW SAIDI in the worst 800 circuits for 3+ years (2019-2023)	322	389
Tier 3	All Circuits not classified as Tier 1, 2, or 4	461	491
Tier 4	AW SAIFI or AW SAIDI in the best 1,000 circuits for 3+ years (2019-2023)	1,118	880
Total		2,266	2,186

6

Circuits that are ranked in the worst 500 performing circuits (based on All Weather
(AW) SAIFI and AW SAIDI) from three prior years are categorized as Tier 1, and the
highest reliability risk. Circuits that are ranked in the worst 800 performing circuits
from three prior years, are categorized as Tier 2, and the second highest reliability risk.
Circuits that are ranked in the best 1,000 performing circuits from three prior years are
categorized as Tier 4, and all remaining circuits are categorized as Tier 3.

13

14 This method of determining reliability tiers was validated using January through July 15 2023 reliability data as seen in Figure 14, where the results of the analysis show that circuits ranked as Tier 1 and Tier 2 have worse AW SAIFI and AW SAIDI performance
 than Tiers 3 and 4 and the system-wide average.

Figure 14. Distribution Circuit Reliability Tier Comparison







5

Line

No.

3 4

6 Once the tiers were identified, the Company created the 2024 construction plan, 7 optimizing the selection of Tier 1 and Tier 2 circuits, the work that was already in 8 process of construction, and distributing the workload throughout the service territory. 9 When the BCA discussed above was completed, the Company validated the 2024 10 workplan had a high benefit cost ratio.

11

12 Q60. How is the PTMM Program prioritizing circuits for 2025?

Line

No.

1

2

3

A60. The Company selected circuits for 2025 based on the benefit cost ratios calculated by the PTMM BCA model and then further prioritized based on reliability risk tier to ensure they are reasonable and prudent for inclusion in the workplan.

- 4
- 5

6

Q61. Is the Company still working towards a 10-year pole and 5-year pole-top equipment location inspection and construction cycle in the PTMM program?

Yes. However, while the Company is unable to execute a 10-year pole and 5-year pole-7 A61. 8 top cycle in the short term based on current inspection failure rates being realized 9 through the PTMM inspection process, the Company plans to increase PTMM 10 investments to reach a 10-year pole and 5-year pole-top cycle. As described above, the 11 Company used the reliability tier model, and other operational data, to create the 2024 12 workplan based on the current approved investment level, and utilized the BCA output 13 to validate the reliability benefit for the customers included on the selected circuits. In this instant case, the Company is requesting approval to increase investment in PTMM 14 in 2025 to \$121 million, still utilizing the reliability tier model and BCA output, to 15 select the optimal mix of circuits to improve customer reliability. The Company has 16 plans to continue to seek increases in investment levels in the PTMM program, 17 18 consistent with PTMM inspection failure rates, beyond this instant case, to ultimately 19 reach a 10-year pole, and 5-year pole-top equipment location inspection and 20 construction cycle matching industry standard levels identified through benchmarking 21 efforts discussed above.

22

23 Q62. What is in the Company's 2024 and 2025 PTMM workplan?

A62. Based on a planned investment level of \$63.4 million consistent with the order in Case
 No. U-21297, the 2024 PTMM workplan includes replacing poles and pole-top

Line <u>No.</u>

> equipment on approximately 750 circuit miles. This translates to replacing approximately 1,700 poles, and replacing pole-top equipment which has failed inspection at approximately 8,655 pole-top equipment locations. In addition, the PTMM program will inspect approximately 39,250 poles to support the workplan for future investment plans.

In this instant case, the Company is requesting approval to invest \$121 million in the PTMM program to fund the 2025 workplan to replace poles and pole-top equipment on approximately 1,100 circuit miles. This translates to replacing approximately 3,965 poles, and replacing pole-top equipment that has failed inspection at approximately 13,800 locations. In addition, the PTMM program will inspect approximately 53,500 poles to support the workplan for future investments. The activity after the projected test year is covered in the IRM section of this testimony.

- 14
- 15

Table 12.	PTN
-----------	-----

PTMM 2024-2025 Workplan

	2024	2025
Circuit Miles	750	1,100
Poles Replaced	1,700	3,965
Poles Reinforced	100	200
Pole-Top Locations Replaced	8,655	13,800
Capital Investment (\$ thousands)	\$63,450	\$121,000

16

17 Q63. What are the BCA analysis results of the 2024 and 2025 PTMM workplan?

Line
No.

1	A63.	When evaluating the subset of circuits included in the 2024 workplan, the benefit cost
2		ratio calculated was 8.3. And the benefit cost ratio calculated for the subset of circuits
3		selected for the 2025 workplan was 11. In both cases, the workplans include circuits
4		that have a higher benefit cost ratio for completing PTMM than the system average,
5		thus validating the Company's selection criteria of focusing on Tier 1 and Tier 2
6		circuits to maximize customer impacts while working towards implementing a full 10-
7		year pole and 5-year pole top equipment PTMM cycle in future years.
8		
9	Q64.	How can customers stay informed about PTMM work being performed in their
10		area?
11	A64.	Customers interested in seeing if PTMM work is being performed in their respective
12		area can visit the Company's website at
13		https://dte.maps.arcgis.com/apps/webappviewer/index.html?id=5d9dc2eb1244456189
14		59ce788086e00e. These maps are regularly updated to inform our customers of the
15		reliability work the Company is performing on their behalf, to visually display work
16		completed in the last 6 months, and work scheduled to be completed within the next 12
17		months. Please note that the PTMM and 4.8kV Hardening Programs are called
18		"Upgrading Existing Infrastructure" in the map provided on this website. This map also
19		shows Tree Trimming, Customer Excellence (called "Rapid Response") and Circuit
20		Conversion (called "Rebuilding Significant Portions of the Grid"). A current example
21		of this map showing only the "Upgrading Existing Infrastructure" layer can be seen in
22		Figure 15.
23		



Figure 15.

5. Upgraading Existing Infrastructure Map

DTE Electric Reliability Improvements Map

Trimming Trees - Historically, equipment damage from failen tree limbs and brancher is responsible for nearly 50% of the time customers spend without power. That's why we've accelerated our efforts to trim trees away from our power lines and poles to reduce damage to our equipment during

Strengthening the existing utility poles,
 power lines and electrical equipment the

deliver your power to better withstand extreme weather. **Rapid Response** - Trimming trees away from our poles and wires and repairing or replacing the equipment on our poles to quickly improve reliability in communities experiencing issues in between planned

maintenance work. Rebuilding Significant Portions of the Grid - Removing and replacing electrical substation equipment and the underground and overhead infrastructure that delivers power, including installing new poles and wiring. Necessary tree trimming will be completed in advance of pole replacement



2

3 Substation Risk

4 Q65. What are Substation Risk projects?

5 A65. Projects in this category are designed to remediate failures of substations that have 6 already occurred, or to prevent catastrophic substation failures in the future. Because 7 a substation typically supports several circuits, substation catastrophic failure events 8 often impact a large number of customers. The events typically are caused by 9 significant equipment failure such as a transformer or switchgear, fires, or flooding 10 events. In addition to affecting a large amount of customers, they can result in lengthy 11 outages because an entire substation is difficult to restore, with methods often limited

1 to Mobile Fleet Program assets such as diesel generators and portable substations, or 2 switching load to adjacent substations with available jumpering capacity. The amount 3 of adjacent substation jumpering that can be achieved, and how quickly it can be 4 implemented, is dependent on several factors such as same circuit voltage class, 5 adequate existing capacity and cable/conductor size, and sufficient operating devices Substation Risk projects often target replacing at-risk 6 already installed in field. switchgear within the substations in order to reduce the risk of major outages. 7 8 Switchgear is an enclosure with breakers, relays, and wiring, and a breaker or cable 9 failure inside a switchgear can take out multiple circuits at once.

10

Line

No.

11 These Substation Risk projects are prioritized utilizing the Global Prioritization Model 12 (GPM) as discussed in more detail in Company Witness Kryscynski's testimony, at 13 substations where deployment of Mobile Fleet Program assets cannot restore the entire 14 substation load; in other words, customers will be out for more than 24 hours in the 15 event of a failure. Details of the projects included in this instant case can be found 16 below and in Exhibit A-23, Schedule M5.

- 17
- 18 **Q66.** Please describe the drivers of the Substation Risk: McGraw project.

A66. Record heavy rains in June 2021 led to significant, catastrophic flooding in the McGraw substation. The sub-grade part of the substation was engulfed in storm water, which caused the failure of position breakers, busses, transfer busses, and house service panels. As a result, the substation experienced a total loss of load carrying ability that caused 6,000 customer outages lasting between 16 hours to 5 days based on the ability to restore power.



Figure 16. Flooding Near McGraw Substation

2

3

4

5

6

Line

<u>No.</u> 1

> The Company's initial emergency response included a mix of jumpering load away from McGraw to adjacent substations, and use of the Mobile Fleet Program portable generation equipment. All customers were placed back on utility power within two weeks after the flooding event by means of station jumpering and breaker replacement,

7





Figure 17. McGraw Substation Flooding – Example 1

2



Figure 18. McGraw Substation Flooding – Example 2



2

3

4

5

6

however, the substation has continued using some Mobile Fleet Program equipment and a temporary overhead circuit (pole farm) constructed on City of Detroit and MDOT property to bypass damaged and inoperable substation equipment, until a permanent solution is constructed on DTEE property. While the current temporary configuration

1 supports load day-to-day, it is higher risk than standard utility construction, and there 2 have been subsequent outage impacts for these customers. For example, the portable 3 substation in the field was struck by a vehicle and taken out of service, which caused 4 additional outages to customers until a replacement could be installed. The temporary 5 configuration also poses a safety risk due to the lack of automatic ground detection alarms to indicate a downed 4.8kV wire. Substation field personnel visit the substation 6 daily to manually check for grounds at McGraw until the permanent facilities can be 7 built. Additionally, customers have expressed concerns about the continued presence 8 9 of the large temporary mobile equipment located in residential neighborhoods. 10 After the initial emergency response, the Company's engineers and field personnel 11 12 assessed the substation's condition, as well as the long-term plans of the McGraw 13 substation and surrounding circuits. The Substation Risk: McGraw project was created after these assessments with the goals of preventing future failures due to flooding and

15

14

- 16
- 17

Q67. What is the scope of the Substation Risk: McGraw project?

returning customers to normal utility service.

A67. The scope of the Substation Risk: McGraw project is to: 18

19 i) Install new substation equipment on the second level including a new circuit feeder, 20 transformer and ATO breakers, new relay and voltage control panels, and 21 network/SCADA capabilities are being installed to increase reliability. 22 Additionally, while all critical equipment has been moved out of the lower level, 23 sump pumps and a manual diversion valve have been installed to improve response 24 to any potential flooding in the basement.

<u>No.</u>		
1		ii) Acquire land parcels and vacated right-of-way from the City of Detroit and MDOT
2		to allow exterior expansion for equipment to be removed from the basement.
3		iii) Construct exterior expansion of substation equipment including two 24-4.8kV
4		10/12 MVA transformers with circuit switcher protection and a 9-position PDC,
5		and network/SCADA capabilities installed to increase reliability.
6		iv) Decommission and remove failed substation equipment in the basement.
7		
8		More details of this project can be found in Exhibit A-23, Schedule M5.
9		
10	Q68.	What are the customer benefits of the Substation Risk: McGraw project?
11	A68.	This work will return customers fed from the McGraw substation to normal utility
12		service, removing the necessity for the continued use of the mobile generation
13		equipment, and the temporary pole farm, thus improving the reliability of service for
14		all affected customers. This project will also greatly reduce or eliminate future
15		flooding risk to the McGraw substation as all equipment necessary to serve customers
16		will be located on the second floor of the substation or outside of the building (rather
17		than the basement). The project is anticipated to be completed in 2024. Additionally,
18		the permanent utility infrastructure will allow for the removal of the large temporary
19		equipment that has been a customer concern.
20		
21	Q69.	Should the Commission approve investment in Substation Risk: McGraw project

22

Line

in this instant case?

A69. Yes. This project is necessary to serve the customers fed by the McGraw substation in
 a reasonable and prudent manner. This project will return McGraw back to full
 operability, remove all mobile generation equipment, eliminating the need for the

temporary pole yard, build switching and redundancy for these circuits, and restore service to the customers with long-term utility equipment rather than the current temporary solution.

Figure 19. McGraw Substation – Temporary Pole Farm



6

7

Line

No.

1

2

3

4

5

Q70. Why was the Substation Risk: Flood Defense Program created?

8 A70. The Substation Risk: Flood Defense Program was created as a response to heavy 9 rainfalls and flooding events that have been experienced in recent years at the 10 Company's substations.

11

110	<u>•</u>	
1		Class C and D substations ⁹ were constructed in the 1930s and 1940s and were designed
2		to contain critical distribution assets underground in their basements. These older
3		substation designs rely on water-cooled equipment that requires a sewer connection,
4		making them vulnerable to catastrophic failures due to abnormally heavy rains that can
5		cause rapid flooding events.
6		
7		The Company performed a detailed updated flooding risk analysis after the 2021
8		flooding events, and determined that five substations (Walker, Orchard, Madison,
9		Frisbee, and Scotten) serving approximately 17,000 customers were at elevated risk
10		and required flood mitigation measures.
11		
12	Q71.	What is the scope of the Substation Risk: Flood Defense Program?
13	A71.	The scope of the Substation Risk: Flood Defense Program is to limit or prevent water
14		intrusion in vulnerable substations by performing the following work at five Class C/D
15		substations:
16		
17		• Install one-way backflow prevention valves on existing sewer connected

dewatering systems;

backup events; and

•

Line

No

18

19

20

21

22

⁹ A Class C substation is a general-purpose substation with three or more radially-fed 24 to 4.8kV transformers, a 4.8kV transformer bus, a 4.8kV transfer bus, and a 4.8kV linkage bus, operated together to provide a paralleloperated service with a maximum degree of continuity. A class D substation is designed to include the installation of one or more 120 to 40/24kV transformers and several 40/24kV circuits. Class D substations are usually designed for two or more 120kV buses, 120 to 40/24 kV transformers, and 40/24kV buses. The design may also include 345 and 230kV buses and switching and associated transformation to 120kV.

Seal conduit to help prevent water penetration into the substation.

Install emergency dewatering pumps to discharge at ground level during sewer

Line <u>No.</u>		U-21534
1		This work will significantly reduce the risk of catastrophic failure at five substations to
2		ensure that the 17,000 associated customers have a more reliable, resilient grid. The
3		program is anticipated to be completed in 2024.
4		
5		More details of this program can be found in Exhibit A-23, Schedule M5.
6		
7	Q72.	What are the customer benefits of the Substation Risk: Flood Defense Program?
8	A72.	The Substation Risk: Flood Defense Program investments will reduce the risk of
9		catastrophic failure of five at-risk substations, thus reducing the risk of extended
10		outages for approximately 17,000 customers.
11		
12	Q73.	Should the Commission approve investment in Substation Risk: Flood Defense
13		program in this instant case?
14	A73.	Yes, in my opinion the MPSC should approve the Flood Defense program for cost
15		recovery in the instant case because these investments are reasonable and prudent. As
16		discussed in this section of my testimony, this project is necessary to respond to the
17		substation flood analysis performed by installing back-flow prevention valves,
18		emergency water pumps, and sealing conduit to reduce the risk of flooding causing
19		catastrophic failure at the five identified substations which serve approximately 17,000
20		customers.
21		
22	Q74.	Why was the Substation Risk: Apache project created?
23	A74.	A breaker position inside switchgear failed at the Apache Substation in 2015 which
24		resulted in a significant area-wide outage affecting nearly 11,000 customers with 81%
25		of affected customers being restored within 16 hours. The downtown business district

1 of Troy, as well as surrounding commercial and residential areas were without 2 electrical service for a prolonged period of time.

23

Line

No.

4 An assessment was performed after emergency repairs were made, which identified the 5 remaining switchgear breakers were at-risk of a similar failure. A second catastrophic 6 failure could result in the loss of all switchgear positions, and up to 16 MVA of stranded load. Stranded load occurs when customers cannot be restored by 7 8 jumpering/transferring customers to an adjacent circuit or substation leading to 9 prolonged customer outages across the entire substation area. In the example of 10 Apache, while some load can be transferred to adjacent circuits, up to 16 MVA cannot 11 The Substation Risk: Apache project was initiated to invest in appropriate be. 12 replacements to prevent this potential second catastrophic failure.

13

16

17

18

14 Q75. What is the scope of the Substation Risk: Apache project?

15	A75.	The scope	of the	Substation	Risk: A	pache	project	is to

- Replace (1) at-risk 19-position switchgear with (2) new 12-position switchgear
 - Replace (3) circuit switchers with S&C 2020 circuit switchers
 - Build system cable termination on new switchgear for all 13 circuits
- Decommission the existing at-risk 19 position switchgear once load is cut over
 to new switchgear
- Install 12-5" conduit supporting substation exits
- Build (1) two-way manhole
- Build (9) three-way manholes
- Remove ~8,584 feet of old EPR and XLPE cable
- Install ~9,333 feet of new EPR cable

	M. ELLIOTT ANDAHAZY U-21534
	• Replace (19) disconnect switches with pole-top switches at the station cable poles
Q76.	What are the customer benefits of the Substation Risk: Apache Project?
A76.	The new switchgear will reduce the risk of catastrophic substation failures and
	extended duration area-wide customer outages. The replacement of one at-risk 19-
	position switchgear with two new 12-position switchgear will also provide load relief
	to Apache circuits that exceed day-to-day limits. The project is anticipated to be
	completed in 2024.
Q77.	Should the Commission approve investment in the Substation Risk: Apache
	project in this instant case?
A77.	Yes. This project is necessary to reduce the risk of another catastrophic switchgear
	breaker failure at the Apache substation potentially resulting in an extended duration
	outage for the nearly 11,000 customers served by the Apache substation.
Q78.	Why was the Substation Risk: Chestnut project created?
A78.	The Chestnut substation has a single 19-position switchgear that is a single point of
	failure. A switchgear failure could result in the loss of all switchgear positions and a
	potential stranded load of 35 MVA with limited jumpering options, which would affect
	approximately 6,000 customers across three cities. This type of potential failure is

Line

No.

lure is similar to the Apache substation failure described earlier in my testimony, which would result in a long-duration outage for the affected customers. The switchgear itself was evaluated to be at high risk of failure based on a combination of years in service (53 years) and an equipment type that has experienced issues (GE air breaker). The

Line <u>No.</u>		U-21534
1		Chestnut project was initiated to mitigate the combination of high equipment risk and
2		up to 15 MVA of stranded customer load by replacing the single at-risk 19-position
3		switchgear with two new 12-position switchgear.
4		
5	Q79.	What is the scope of the Substation Risk: Chestnut project?
6	A79.	The scope of the Substation Risk: Chestnut project is to:
7		• Replace (1) at-risk 19-position switchgear with (2) 12-position switchgear
8		• Replaced and relocate (3) capacitor banks
9		• Install ~500 feet of 15-5" concrete encased duct bank
10		• Install ~10,000 feet of EPR cable and associated branch and straight joints
11		• Install (17) OMNI-Rupters
12		
13		More details of this project can be found in Exhibit A-23, Schedule M5.
14		
15	Q80.	What are the benefits of the Substation Risk: Chestnut project?
16	A80.	The new switchgear will reduce the risk of catastrophic substation failures and
17		extended duration area-wide customer outages, and will provide increased capacity to
18		serve 18 distribution circuits, while the old configuration was only capable of serving
19		12 distribution circuits. The project is anticipated to be completed in 2025.
20		
21	Q81.	Was investment in the Substation Risk: Chestnut project requested in previous
22		rate cases?
23	A81.	Yes. The Substation Risk: Chestnut project was included in Exhibit A-12, Schedule
24		B5.4 and Exhibit A-23, Schedule M4 exhibits for Case Nos. U-21297, U-20836, U-

Line <u>No.</u>		U-21534
1		20561, and U-20162. Substation Risk projects were not included in my direct testimony
2		in any prior rate cases before this instant case.
3		
4	Q82.	Should the Commission approve investment in the Substation Risk: Chestnut
5		project in this instant case?
6	A82.	Yes. Per the responses provided above, this project is necessary to reduce the risk of a
7		catastrophic switchgear breaker failure at the Chestnut substation potentially resulting
8		in an extended duration outage for the 6,000 customers served by the Chestnut
9		substation.
10		
11	Q83.	Why was the Substation Risk: Savage Stranded Load project created?
12	A83.	Following the fire at Apache substation, DTEE engineering teams assessed similar
13		switchgear across its service territory for risk potential. Savage substation was
14		identified as having a high-risk switchgear that did not have connections to adjacent
15		substations that would allow for jumpering of the load in the event of a failure of the
16		switchgear. This lack of jumpering capabilities created the risk of stranded load in the
17		event of failure which was determined to be approximately 30MVA of load.
18		
19	Q84.	What is the scope of the Substation Risk: Savage Stranded Load project?
20	A84.	The scope of the Substation Risk: Savage project was to:
21		• Extend conduit and cable to feed (7) new primary switch cabinets
22		• Establish tie points to adjacent circuits and substations
23		
24		More details of this project can be found in Exhibit A-23, Schedule M5.
25		

1	Q85.	What are the customer benefits of the Substation Risk: Savage Stranded Load
2		project?
3	A85.	Installing switch cabinets and establishing underground connections in the area
4		accomplish the primary goal of mitigating stranded load but also provided future
5		benefits. The new switch cabinets offer spare positions for future load growth as well
6		as operating flexibility between Savage, Lochdale, and Apache circuits in the event of
7		failures on these circuits. The project was completed in 2023.
8		
9	Q86.	Should the Commission approve investment in the Substation Risk: Savage
10		Stranded Load project in this instant case?
11	A86.	Yes. This project was necessary to reduce the risk of a catastrophic switchgear breaker
12		failure at the Savage substation potentially resulting in an extended duration outage for
13		the 3,000 customers served by the Savage substation.
14		
15	Q87.	Why was the Substation Risk: Belleville Switchgear Decommission project
16		created?
17	A87.	In the beginning of 2020, DTE's Engineering team identified the 4.8kV Belleville
18		switchgear as at end of life. Breakers inside the switchgear required multiple repairs
19		over the course of 5 years and there are no breakers replacements if they were to fail.
20		Control wiring inside the cubicle also required re-wiring which involved extended
21		planned shutdowns. The Belleville substation did experience a switchgear failure in
22		2022 which led to the condemnation of Bus 11 and limited operability. The Company's
23		equipment engineers determined that the switchgear at Belleville substation is at-risk
24		of further failures and needs to be fully decommissioned.
25		

Line <u>No.</u>		U-21534
1	Q88.	What is the scope of the Substation Risk: Belleville Switchgear Decommission
2		project?
3	A88.	The scope of the Substation Risk: Belleville Switchgear Decommission project is to:
4		• Bypass Belleville's 4.8kV switchgear by installing an overhead NOVA triple-
5		single reclosers just outside of the substation
6		• Convert the 4.8kV portion of Belleville substation from a Class A to a Class T
7		substation
8		• Reconfigure the (3) load-carrying circuits and throw-over circuit into (2) load-
9		carrying circuits
10		
11		This project is expected to be completed in 2024. More details of this project can be
12		found in Exhibit A-23, Schedule M5.
13		
14	Q89.	What are the benefits of the Substation Risk: Belleville Switchgear Decommission
15		project?
16	A89.	Decommissioning and removing the partially failed, at-risk 4.8kV switchgear at
17		Belleville substation and then reconfiguring the distribution circuits has enabled
18		continued service for approximately 1,300 customers. This work has reduced the risk
19		of extended outages for these customers if the switchgear were to experience another
20		failure in the future.
21		
22		A future 4.8kV Conversion project at Belleville substation is discussed in Witness
23		Deol's testimony which will convert these circuits to 13.2kV and remove any
24		remaining 4.8kV equipment at Belleville substation.
25		

1 Q90. Should the Commission approve investment in the Substation Risk: Belleville 2 Switchgear project in this instant case? 3 A90. Yes. This project is necessary to reduce the risk of a catastrophic switchgear breaker 4 failure at the Belleville substation potentially resulting in an extended duration outage 5 for the 1,300 customers served by the 4.8kV Belleville substation. 6 7 Q91. Why was the Substation Risk: Voyager project created? 8 A91. Voyager is an industrial substation serving Stellantis. Stellantis has experienced 9 several interruptions due to the at-risk high side motor disconnects at Voyager 10 substation. 11 12 Q92. What is the scope of the Substation Risk: Voyager project? 13 A92. The scope of the Substation Risk: Voyager project was to: Install (4) piers for future circuit switcher installation 14 Install anchor bolts for future circuit switcher installation 15 • Above grade work to replace the motor disconnects with new circuit switchers 16 • will be scheduled at a later time with the customer 17 18 19 More details of this project can be found in Exhibit A-23, Schedule M5. 20 21 **O93**. What are the benefits of the Substation Risk: Voyager project? 22 A93. The below grade work was completed during a planned customer shutdown to avoid unnecessary customer outages. This below grade work will enable quicker replacement 23 of the at-risk equipment during a future project to replace this equipment and improve 24 reliability and operability at Voyager substation. This project was completed in 2023. 25

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		
2	Q94.	Should the Commission approve investment in the Substation Risk: Voyager
3		project in this instant case?
4	A94.	Yes. This project was necessary to complete below grade work during a planned
5		customer shutdown and this below grade work enables a future project to replace the
6		at-risk equipment.
7		
8	Q95.	Why was the Substation Risk: Drexel project created?
9	A95.	Position I at Drexel substation experienced a failure in July 2016 which resulted in a
10		fire and damaged several positions in the Drexel switchgear. Approximately 7,500
11		customers are normally served by Drexel substation and over 3,000 customers were
12		transferred to adjacent substations to restore service. Replacing the switchgear and
13		restoring customers to their normal point of service will restore operability and reduce
14		loading constraints in the area.
15		
16	Q96.	What is the scope of the Substation Risk: Drexel project?
17	A96.	The scope of the Substation Risk: Drexel project is to:
18		• Install (1) 9-position switchgear
19		• Install (1) 15/20/25 MVA transformer to feed new switchgear
20		• Install 6,900 feet of EPR system cable from new switchgear lineup to existing
21		cable poles
22		• Decommission and remove the damaged existing switchgear lineup
23		• Restore circuits to pre-fire configurations
24		
25		More details of this project can be found in Exhibit A-23, Schedule M5.

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		
2	Q97.	What are the benefits of the Substation Risk: Drexel project?
3	A97.	Completing the Drexel switchgear replacement project will restore the area to its
4		normal configuration which reduces load on adjacent circuits and substations that have
5		been temporarily serving Drexel customers since 2016. Decommissioning and
6		removing the partially failed switchgear mitigates the risk of additional failures and
7		extended outages for the area. This project will be completed in 2024.
8		
9	Q98.	Should the Commission approve investment in the Substation Risk: Drexel
10		project in this instant case?
11	A98.	Yes. Per the responses provided above, this project is necessary to mitigate the risk of
12		additional failures and extended outages for customers in this area.
13		
14	Q99.	Why was the Substation Risk: Savage Switchgear Replacement project created?
15	A99.	The Savage substation has a single 16-position switchgear that is a single point of
16		failure. A switchgear failure could result in the loss of all switchgear positions and a
17		potential stranded load of 30 MVA with limited jumpering options, which would affect
18		approximately 3,000 customers throughout Troy. This type of failure would result in a
19		long-duration outage for the affected customers. The switchgear has been determined
20		to be at-risk of failure based on a review by the Company's equipment engineers. The
21		combination of high equipment risk and high stranded customer load was why the
22		Savage project was initiated. By splitting the existing single 16-position switchgear
23		into two new separate 9-position switchgears, the equipment risk is reduced and the
24		amount of stranded load (15 MVA) due to a single point failure.
25		

1	Q100. What is the scope of the Substation Risk: Savage Switchgear Replacement						
2	project?						
3	A100. The scope of the Substation Risk: Savage Switchgear Replacement project is to:						
4	• Remove existing parking area north of existing substation fence –						
5	approximately 7,800 sq. ft.						
6	• Extend substation fence approximately 300 feet						
7	• Perform site preparation and below grade for expanded substation yard						
8	• Install concrete pads for new switchgear and three (3) 6 MVAR bus capacitor						
9	banks						
10	• Install two (2) 9-position 2-high switchgear						
11	• Install conduit and system cable to existing circuit cables feeding Savage						
12	circuits and neighboring circuits to enable jumper contingency						
13	• Extend overhead 770 feet to establish two (2) portable ready locations						
14	• Install two (2) sets of 3-333KVA regulators						
15	• Decommission and remove existing 1960's vintage continuous line-up of one						
16	(1) 16-position switchgear at Savage substation						
17							
18	This project will be completed in 2024. More details of this project can be found in						
19	Exhibit A-23, Schedule M5.						
20							
21	Q101. What are the benefits of the Substation Risk: Savage Switchgear Replacement						
22	project?						
23	A101. The new switchgear will reduce the risk of catastrophic substation failures and						
24	extended duration area-wide customer outages. It will also provide increased capacity						

Line <u>No.</u>		U-21534
1		to serve 12 distribution circuits while the old configuration was only capable of serving
2		10 distribution circuits. The project is anticipated to be completed in 2027.
3		
4	Q102.	Was investment in the Substation Risk: Savage Switchgear Replacement project
5		requested in previous rate cases?
6	A102.	No. The Substation Risk: Savage Switchgear Replacement project is new and was not
7		included in any prior rate cases.
8		
9	Q103.	Should the Commission approve investment in the Substation Risk: Savage
10		Switchgear Replacement project in this instant case?
11	A103.	Yes. Per the responses provided above, this project is necessary to mitigate the risk of
12		a switchgear failure at Savage substation which would result in a potential 30 MVA of
13		stranded load affecting 3,000 customers throughout Troy.
14		
15	Q104.	Why was the Substation Risk: Seville project created?
16	A104.	Position B at Seville experienced a failure in 2023 and after a review by the Company's
17		engineers was determined unrepairable. Approximately 1,500 customers have been
18		temporarily transferred to adjacent circuits to continue service. No spare positions
19		currently exist at Seville substation to restore the area to normal configuration;
20		therefore, switchgear replacement is necessary.
21		
22	Q105.	What is the scope of the Substation Risk: Seville project?
23	A105.	The scope of the Substation Risk: Seville project is to:
24		• Replace one (1) failed 7-position switchgear with one (1) 9-position switchgear
25		• Install new transformer secondary cables

		M. ELLIOTT ANDAHAZY
Line No.		U-21534
1		• Perform load transfers to re-establish Seville circuits to normal configuration
2		
3		More details of this project can be found in Exhibit A-23, Schedule M5.
4		
5	Q106.	What are the benefits of the Substation Risk: Seville project?
6	A106.	Restoring the area to normal configuration will allow the Company to return all circuits
7		to normal operating condition and restore system redundancy in the event of future
8		outage events. Additionally, the new standard 9-position switchgear will provide two
9		spare circuit positions for future use to support customer growth as necessary.
10		
11	Q107.	Should the Commission approve investment in the Substation Risk: Seville project
12		in this instant case?
13	A107.	Yes. Per the responses provided above, this project is necessary to restore the Seville
14		substation to a normal operating condition and return all circuits to loads that are within
15		an acceptable range.
16		
17	Q108.	Why was the Substation Risk: Imlay project created?
18	A108.	The Substation Risk: Imlay project is driven by safety concerns including:
19		• Substation equipment is within arm's reach when walking through the substation
20		posing a safety hazard;
21		• Imlay substation has poor lighting conditions;
22		• Imlay substation has a transformer that operates vertically by lifting which poses a
23		safety risk as it could result in a flashover during operation;
24		• Imlay substation is not built to DTEE standards;

Line <u>No.</u>		U-21534					
1		• Imlay substation lacks necessary space to rebuild equipment on the existing					
2		120x140ft site;					
3		• Imlay substation is built on differing elevations which make retrofits or upgrades					
4		difficult;					
5		• Imlay substation has a high 5-year average SAIDI of 549 minutes.					
6							
7	Q109.	What is the scope of the Substation Risk: Imlay project?					
8	A109.	The scope of the Imlay Substation Risk project is:					
9		• Replace OTSGO substation equipment to increase capacity and establish (2) new					
10		distribution circuits.					
11		• Rebuild 30 miles of overhead conductor					
12		• Convert 30 miles of 4.8kV to 13.2kV					
13		• Transfer ~4.9MVA of load from IMLAY substation to OTSGO substation					
14		• Decommission (1) 40-4.8kV substation (IMLAY).					
15		• Pre-convert and convert about 30 miles (includes part of IMLAY and OTSGO).					
16		• Transfer ~4.9MVA of load from Imlay Substation to OTSGO Sub					
17							
18		More details of this project can be found in Exhibit A-23, Schedule M5.					
19							
20	Q110.	What are the benefits of the Substation Risk: Imlay project?					
21	A110.	This project will eliminate the substation electrical hazards at Imlay substation and					
22		improve the reliability for customers by rebuilding portions of the overhead circuits.					
23							
24	Q111.	Should the Commission approve investment in the Substation Risk: Imlay project					
25		in this instant case?					

- Line No. 1 A111. Yes. Per the responses provided above, this project is necessary to mitigate the safety 2 risks posed by its current configuration. 3 Frequent Outage Programs (CEMI) 4 5 Q112. What programs are included in Frequent Outage Programs? 6 A112. In addition to strategic programs and projects to support grid reliability, the Company has shorter term programs to address pockets of the grid where customers have 7 8 experienced multiple outages. There are two primary programs under Frequent Outage 9 Programs: the Customer Excellence (CE) Program and the Strategic Reliability 10 Improvement Program (SRIP).
- 11

12 The CE program was established to provide rapid solutions to small pockets of 13 customers experiencing poor reliability. These customers are identified as experiencing four sustained outages (SAIFI > 4.0), or nine momentary outages (MAIFI > 9.0) per 14 year. The prioritization method for the CE program relies on Advanced Metering 15 Infrastructure (AMI) data to identify these customers on a rolling 12-month basis to 16 address issues more rapidly than other programs which rely on the annual analysis of 17 18 reliability events. In addition to reliability event data, the prioritization also includes an 19 evaluation of the time since the area's last tree trim was completed, any other planned 20 work on the circuits, as well as customer complaints.

21

22 Upon identification of a circuit that meets the CE prioritization criteria and is selected 23 for construction, the Company conducts a field patrol to assess both equipment and tree 24 conditions impacting reliability. After the patrol, the scope of work is developed for the identified equipment and tree-related problems. In addition to the damaged or failed 25

No.

1		equipment replacements and tree trimming, the scope of work also includes checking
2		operating equipment to ensure it is functioning properly, conducting fault studies to
3		ensure fuses are properly sized, and installing additional equipment, such as reclosing
4		devices and animal guards, to prevent future outages. On average, the solutions require
5		investments between \$60,000 and \$80,000 per circuit to implement.
6		The SRIP Program performs improvements to either portions of a circuit (customer
7		pockets), or entire circuits as appropriate. The primary distinctions between the CE and
8		the SRIP Programs are that circuits are normally selected for the SRIP Program based
9		on both a 12-month and a three-year average circuit SAIDI and SAIFI performance,
10		MPSC complaints, and regional expertise on customer needs. In addition, the scope of
11		work performed under the SRIP Program is more comprehensive, and typically
12		requires investments between \$250,000 and \$300,000 per circuit to implement.
13		
14	Q113.	What is the Company's Pre-Summer Storm Strengthening (PS3) process?
15	A113.	Beginning in 2021 after a summer with a high number of storms and associated
16		customer outages, the Company began an annual process of analyzing the performance
17		data of all circuits following each summer storm season. This analysis identifies circuits
18		expected to have the worst reliability performance. The PS3 process allocates circuits
19		to multiple programs such as Tree Trim, PTMM, CE, SRIP, and 4.8kV Hardening to
20		ensure they receive improvements before the subsequent summer storm season.
21		
22	Q114.	Has the Company continued the Pre-Summer Storm Strengthening process of

24

23

identifying circuits that are at higher risk during storms and performing investments on them?

A114. Yes. The Company has continued this process. For 2023, work was performed on 255
 circuits within the Frequent Outage (CEMI) Programs and the program plans to
 perform work on 160 circuits in 2024 and 215 circuits in 2025 (Table 13).

- 4
- 5

Table 13.	Frequent Outage Programs (CEMI) 2023-2025
-----------	---

	2023 Forecast	2024 Forecast	2025 Forecast
CE Circuits	183	100	130
SRIP Circuits	72	60	85
Total Frequent Outage (CEMI) Program Circuits	255	160	215
Capital Investment (\$ thousands)	\$63,963	\$48,050	\$62,504

12 13

14

7 Q115. How do Frequent Outage Programs (CEMI) benefit customers?

A115. Frequent Outage Programs (CEMI) perform circuit improvements that increase electric
service reliability for customers who have experienced recent poor reliability. The
Company measures the reliability of the circuits selected for the Frequent Outage
(CEMI) Program before and after the work is completed (Figures 20 and 21).

Figure 20. Frequent Outage Programs (CEMI) All Weather



MEA - 80

⁶

Although weather is variable year to year and can impact comparisons of circuit performance, Figure 20 shows that customers on circuits where Frequent Outage (CEMI) work was performed experienced a 35.2% improvement in All Weather SAIFI and a 14.0% improvement in All Weather SAIDI when comparing 2023 to 2022.



Line

No.

Figure 21. Frequent Outage Programs (CEMI) Excl. MEDs



7

8

9

10

11

12

When excluding the weather impacts of major event days, Figure 21 shows that customers on circuits where Frequent Outage (CEMI) work was performed experienced even greater reliability improvements, a 55.2% improvement in SAIFI excluding MEDs and a 45.9% improvement in SAIDI excluding MEDs when comparing 2023 to 2022.

13

Q116. How can customers stay informed about Customer Excellence work being performed in their area?

16A116. Customers interested in seeing if Customer Excellence work is being performed in their17respective area can visit the Company's external website at18https://dte.maps.arcgis.com/apps/webappviewer/index.html?id=5d9dc2eb1244456189

1 59ce788086e00e. These maps are regularly updated to inform our customers of the 2 reliability work the Company is performing on their behalf, to visually display work 3 completed in the last 6 months, and work scheduled to be completed within the next 12 months. Please note that the Frequent Outage (CEMI) Program is called "Rapid 4 Response" in the map provided on this website. This map also shows Tree Trimming, 5 4.8kV Hardening and PTMM (called "Upgrading Existing Infrastructure"), and Circuit 6 Conversion (called "Rebuilding Significant Portions of the Grid") A current example 7 8 of this map showing only the Rapid Response layer can be seen in Figure 22.

9

Line

No.

10

DTE Electric Reliability Improvements Map

Trimming Trees - Historically, equipment damage from fallen tree limbs and branches is responsible for nearly 50% of the time customers spend without power. That's why we've accelerated our efforts to trim trees away from our power lines and poles to reduce damage to our equipment during storms.

storms. Upgrading Existing Infrastructure -Strengthening the existing utility poles, power lines and electrical equipment that deliver your power to better withstand extreme weather. Inflapid Response - Trimming trees away from our seaters.

Rapid Kesponse - Imming trees away from our poles and wires and repairing or replacing the equipment on our poles to quickly improve reliability in communities experiencing issues in between planned maintenance work.

Rebuilding Significant Portions of the Grid - Removing and replacing electrical substation equipment and the underground and overhead infrastructure that delivers power, including installing new poles and wiring. Necessary tree trimming will be completed in advance of pole replacements.





11

Line <u>No.</u>

1 Cable Replacement Program

Q117. What is Underground (UG) System Cable, and how is it different from Underground Residential Distribution (URD) Cable?

A117. System cable is a specific type of cable designed and used for underground distribution
and subtransmission on the Company's primary electric system. System Cable consists
of large diameter cable surrounded by various types of insulation, and it is installed
underground in vaults and ducts that run between manholes (Figure 23 and 24).

8 System cable is used for a different purpose than URD cable. System cable is used to 9 transmit higher voltage electricity from substation to substation and to feed primary 10 circuits, while URD cable is designed to provide lower voltage electricity directly to 11 residential neighborhoods. URD is discussed in more detail later in my direct 12 testimony.

13

14 Q118. What are the key drivers of the Company's Cable Replacement program?

A118. System cable is a critical component of the distribution and subtransmission system, and while system cable provides high resiliency to storms, system cable failures do happen, and can interrupt a large number of customers for an extended period of time due the longer amount of time it typically takes to locate and replace a failed cable. System cable replacement is an industry standard program to reduce system risk and support reliability.

21

When a system cable fails, the customers fed from that circuit are typically jumpered to a redundant, or back-up cable, to restore power, and remain on the alternate circuit until the original cable is replaced and back in service. The process to replace the cable includes locating the fault, de-energizing the circuit, cutting the failed section(s), 1 pulling the failed cable out of the conduit, installing new cable, reconnecting (splicing) 2 the new cable to the existing circuit, and re-energizing the circuit. During the time it 3 takes to find and repair the cable, the system has lost redundancy and has increased risk for longer duration outages (if a failure occurs on the redundant circuit). System cable 4 5 failures can also cause failures in other equipment, including adjacent cables and 6 switchgear, which can then impact an even larger number of customers for a longer 7 period of time. The Company has had an average of 234 system cable failures per year 8 over the last six years (Table 14).

9

Line

No.



Failures by Cable Type	2018 Actual	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Actual
PILC	200	193	161	180	202	171
EPR	20	24	24	17	24	37
VCL	11	4	6	5	8	16
Gas	11	9	5	3	3	12
XLPE Post-1990	1	-	-	-	-	-
XLPE Pre-1990	9	3	7	5	1	16
Butyl Rubber	3	2	-	3	2	3
Total Cable Failures	255	235	203	213	240	255

Table 14.System Cable Failures by Cable Type and Year

11	PILC: system cable that is insulated with paper and lead
12	EPR: system cable that is insulated with ethylene propylene rubber
13	VCL: system cable insulated with varnished cambric
14	Gas: system cable that is insulated with nitrogen gas under pressure
No. 1 **XLPE:** system cable that is insulated with cross-linked polyethylene 2 Butyl Rubber: system cable that is insulated with butyl rubber 3 4 During system cable emergent restoration, the crews may experience multiple 5 challenges, which can complicate the work or slow progress on remediation of the 6 failure. In some instances, field crews find underground ducts have collapsed on the cables, making the cable extremely difficult, or in some cases impossible to replace 7 8 without repairing the ducts (Figure 23). Safety concerns during restoration sometimes 9 cause other intact cables near the failed cable to require a shutdown, meaning they must 10 be de-energized from the substation to make the site safe for work. Other examples of 11 safety concerns include pumping water out of the manholes and managing the 12 wastewater, ensuring the air quality is safe for entry, and often including remediation 13 of contaminants. Once the manholes can be entered safely, the work includes inspecting and testing long stretches of cable to find the fault, and identification of adjacent 14

16 above, which can be difficult during an emergent failure and restoration situation.

hazards. Finally, the crews typically pull (Figure 25) and splice the cable as described

17

15

Line





Figure 23. System Cable – UG Collapsed Duct





Figure 25. System Cable Pulling (Removal)



3

4

5

6

7

8

Line

No.

1 2

> In addition to aging issues, different types of cables are known to have specific failure modes. As an example, XLPE (cross-linked polyethylene) system cable manufactured before 1990 has a design defect that leads to premature insulation breakdown and failures (also called "treeing") and has contributed to switchgear failures. For another example, gas cable which is designed to have cavities within the insulating layer that

1 are filled with nitrogen gas under pressure is an obsolete design, prone to mechanical 2 damage that leads to leaks and failures, as well as costly repairs. As detailed in the 3 DGP, Exhibit A-23, Schedule M8 (as supported by Company Witness Kryscynski), 4 section 4.3.6 on page 46, approximately 63% of the Company's system cable is beyond 5 useful life expectancy. Useful life is a standard industry term that does not represent 6 the actual life of an asset, but rather the age at which an installed asset is expected to 7 require increasing maintenance and reduced performance such that it is often more 8 prudent to replace than to continue to repair and maintain. While age is not the only 9 factor to determine a need for replacement, based on the Company's experience, failure 10 rates increase with age as older cable is typically exposed to more fault currents and 11 has longer water exposure.

12

Line

No.

13 Table 15 shows the average age of the different types of the approximately 3,100 miles 14 of system cable that are within the scope of the Cable Replacement Program. The 15 typical useful life expectancy of system cable is 35 to 40 years, although actual useful life varies depending on cable type and field conditions. Based on its asset health 16 17 assessment for system cable, the Company has determined that approximately 28% of its system cable is at-risk cable and a candidate for replacement, including XLPE cable 18 19 manufactured before 1990, gas cable, VCL (varnished cambric lead), and paper-20 insulated-lead cable (PILC) cable greater than 60 years in age. The Company replaces 21 system cable because of the high number of customers who experience an outage when 22 system cable fails without available redundancy and the time it takes to locate and 23 replace the failed system cable.

Table 15. (

5. Cable Types - Average Age and Life Expectancy

Cable Type	PILC	EPR	VCL	Gas	XLPE Pre-1990	XLPE Post- 1990	Butyl
Miles	2,069	748	95	47	58	48	31
% of Total Population	66.8%	24.2%	3.1%	1.5%	1.9%	1.5%	1.0%
Average Age	55	18	64	59	40	23	57
Useful Life Expectancy	40	35	40	40	25	40	25

2

Planned replacement of UG system cable allows the Company to proactively target
cable at high risk of failure. This allows for a more strategic, and more efficient process
to replace large portions of cable in order to reduce the risk of failures and increase
redundancies in a given area.

7

8

Q119. What is the scope of the Cable Replacement Program?

A119. The Cable Replacement program exists to identify and replace at-risk system cable.
System cable replacement prioritization is based on multiple factors including
insulation type, failure history, system impacts, and cable loading. These cables are
installed in conduit and spliced together in manholes. When replacing system cable,
the Company will also replace failed/collapsed conduit, ducts, and manholes, upgrade
substation cable positions, and rebuild cable poles as necessary.

15

16 Q120. Was the Cable Replacement Program in the prior rate cases?

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1	A120.	Yes, the Cable Replacement Program was included in Case Nos. U-21297, U-20836,
2		U-20561, and U-20162.
3		
4	Q121.	Did the Commission support investments for the System Cable Replacement
5		program in prior rate cases?
6	A121.	Yes. The Commission stated in its Order for Case No. U-21297,
7		"The Commission finds that the company's requested funding should be
8		approved for inclusion in rate base with the Staff's proposed 10% reduction to
9		protect against over-projections. The Commission recognizes that regular
10		maintenance is necessary and that faulty cables should be replaced, and DTE
11		Electric provided evidence that multiple factors are considered in determining
12		where replacements are necessary including vintage, number of failures, and
13		number of affected customers, as well as safety improvements. 3 Tr 531-542,
14		581-582 Finally, the Commission disagrees with the ALJ and does not find
15		that it is necessary to separate expenditures by project for this program."
16		
17	Q122.	What is the Company's policy for system cable replacement and how are circuits
18		selected?
19	A122.	The Company's equipment engineers review all system cable on DTEE's underground
20		system and prioritize cable for replacement based on insulation type, quantity of
21		failures, circuit loading, and age of cable. From these factors, a composite score is
22		calculated and the circuits with the highest risk are replaced.
23		
24		
25		

1	Q123. What sections of cable are replaced by the Cable Replacement Program?
2	A123. The Cable Replacement Program replaces all sections of cable that are deemed at-risk
3	based on their composite score as discussed above. If there are sections of cable on a
4	circuit that are not deemed to be at-risk, they are not replaced by the program.
5	
6	Q124. How much system cable was replaced in 2023 and prior years?
7	A124. The Company replaced 8 miles of system cable in 2023 and has replaced 41.4 miles of
8	system cable over the last six years (Table 16).
9	

Table 16. System Cable Program 2018-2025

	2018 Actual	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Actual	2024 Forecast	2025 Forecast
Cable Miles Replaced	5	10	6	7.4	5	8	10.3	11.3
Capital Investment (\$ thousands)	\$9,213	\$10,945	\$12,139	\$14,984	\$27,746	\$22,832	\$15,001	\$16,501

11

10

Line

No.

12 Q125. How much system cable replacement is planned for 2024-2025?

A125. The Company plans to replace approximately 10 miles in 2024 and 11 miles in 2025 13 14 (Table 16).

15

16 Q126. How does the Cable Replacement program benefit customers?

17 A126. Replacing at-risk system cable supports continued reliability for customers. The underground cable system is designed with multiple redundancies to ensure customer 18 19 reliability. While single cable failures do not normally result in customer outages, if the primary and redundant cables fail at the same time, it results in prolonged outages 20 21 for customers. Some types of industrial class customers such as hospitals, aren't able

1		to tolerate the risk of running with a single cable, and therefore reduce or shut down
2		some functions when this happens. This program reduces overall risk to customers and
3		the grid by proactively replacing cables before they fail, in order to ensure necessary
4		redundancies for this critical part of the system as designed.
5		
6	Under	ground Residential Distribution (URD) Replacement Program
7	Q127.	What is Underground Residential Distribution (URD) Cable, and why does the
8		Company replace it?
9	A127.	URD is a specific type of cable designed for underground residential use on the
10		Company's secondary electric system. URD consists of small diameter cable
11		surrounded by polyethylene insulation and is either directly buried into the ground or
12		less frequently is installed inside conduit (Figure 26). Because underground repairs can
13		take significant amounts of time to locate and repair when compared to overhead
14		infrastructure, URD systems are typically looped so that there are two paths to feed
15		customers in case one URD cable fails.
16		

Figure 26. URD Cable – Example



3 4

5

6

7

8

9

10

2

As mandated by Michigan Administrative Code R. 460,512, all residential subdivisions in the Company's service territory built since January 1, 1971 are served with URD cable. There are two primary types of URD cable, differentiated by manufacture date. Pre-1985 URD cable has XLPE (non-tree retardant) insulation, while post-1985 the insulation has TR-XLPE (tree-retardant) insulation. In cable insulation, "treeing" refers to the tree-like pattern of insulation breakdown. The breakdown typically originates at an impurity or defect in the solid insulation and grows gradually over time to resemble the branches of a tree, ultimately leading to a cable failure. There are nearly 11,000 total miles of URD cable on the system, with approximately 2,068 miles (24%) being pre-1985 non-tree retardant vintage (Table 17).

3

Line

No.

1

2

4

URD Type	Pre-1985	1985+
URD Cable Miles	2,068	8,512
% of Total Population	24%	76%
Average Age (Years)	46	20
Life Expectancy (Years)	40	40

 Table 17.
 URD Cable Types - Average Age and Life Expectancy

5

6 In addition to failures caused by treeing described above, in general, the rate of URD 7 cable failures increases with the age of the cable, and the rate further increases once a 8 cable experiences its first failure. Manufacturer expected useful life for URD cable is 9 approximately 40 years. Useful life is a standard industry term that does not represent 10 the actual life of an asset, but rather the age at which an installed asset is expected to 11 experience increasing failure rates and reduced performance such that it is often more 12 prudent to replace than to continue to repair and maintain. For the six-year period from 2018 through 2023, there were on average approximately 930 URD cable failures per 13 14 year as seen in Table 18.

1

	2018	2019	2020	2021	2022	2023	2018-2023 Average
URD Cable Failures	1,039	755	1,036	986	900	864	930

URD Cable Failures

²

3	Q128.	What is the scope	of the URD	Replacement	Program?
	-	1		1	0

A128. There are two primary types of work performed by the URD Replacement Program:
 prioritizing and replacing existing URD cable and replacing live-front UG transformers
 (described below) with dead-front UG transformers.

Table 18.

7

8 The program prioritizes and replaces URD cable based on multiple factors including 9 number of failures on the circuit, and number of customers affected by those failures, 10 and URD cable type. The program also includes the replacement of live-front transformers with dead-front transformers. Some URD cable is fed from live-front 11 transformers, which is an obsolete design that does not include protective coverings 12 13 over energized equipment, and therefore poses a potential safety risk to crews in the field while performing operating work once the external transformer covering is 14 15 removed.

16

17 Single URD cable faults (outages) are typically restored quickly after an UG splicing 18 crew arrives and bypasses the URD failure by back feeding the customers from another 19 source on the URD loop. However, once the customers are restored, there is follow-up 20 work required to locate and repair the URD fault that caused the original outage, and 21 to restore the system to normal operating conditions. This follow-up work is called an 1 open loop. These open loops leave the system without redundancy, such that if a second URD failure occurs on the same URD loop, a new long-duration outage (4+ hours) will 2 3 result for the customers as there is no redundancy to back feed the customers as described above, while replacing the failed URD cable. Second URD failures within 4 5 six months of the original failure have occurred on average 49 times annually over the 6 last six years (Table 19).

7

Table 19. URD Double Cable Failures Within 6 month
--

	2018	2019	2020	2021	2022	2023	2018-2023 Average
URD Double Cable Failures	32	18	37	59	32	115	49

8

9 In addition, planned replacements are more cost effective than repairing failures, as the 10 Company can strategically plan to replace entire circuits of URD and live-front transformers, rather than reactively fixing smaller sections of the circuit following a 11 12 failure.

13

Table	20.	URD	ſ
Lanc	40.		L

Double Cable Failure Outage Data

URD Double Failures w/in 6 months	2018	2019	2020	2021	2022	2023
Customers Impacted	1,491	965	1,923	2,542	1,749	5,415
Outage Duration	137 hours	85 hours	182 hours	370 hours	187 hours	791 hours
Average Outage Duration	4.3 hours	4.7 hours	4.9 hours	6.3 hours	5.9 hours	6.9 hours
Total Customer Outage Minutes	356,604	265,151	484,347	837,078	683,363	2,574,899

URD Replacement Program investments include design for the following year's program, remediation of identified hazards to streamline execution of the following year's plan, the replacement of the targeted URD miles, and the replacement of live-front transformers with dead-front transformers (Figures 27 and 28).



Figure 27. Live-front UG Transformer

Line

No.

1

2

3

4



Figure 28. Dead-front UG Transformer

~
ʻ)
/
_

3 Q129. Was the URD Replacement Program included in prior rate cases?

A129. Yes, the URD Replacement Program was included in Case Nos. U-20162, U-20561,
U-20836, and U-21297.

6

7 Q130. Were URD Replacement Program investments supported in prior rate cases?

8 A130. Yes. The Commission stated in its Order for Case No. U-21297,

9 "The Commission finds that the company's requested funding should be 10 approved for inclusion in rate base with the Staff's proposed 10% reduction to 11 protect against over-projections. The Commission recognizes that regular 12 maintenance is necessary and that faulty cables should be replaced, and DTE 13 Electric provided evidence that multiple factors are considered in determining

<u>No.</u>	
1	where replacements are necessary including vintage, number of failures, and
2	number of affected customers, as well as safety improvements. 3 Tr 531-542,
3	581-582 Finally, the Commission disagrees with the ALJ and does not find
4	that it is necessary to separate expenditures by project for this program."
5	
6	Q131. How much URD cable was replaced in 2023?
7	A131. The URD Replacement Program replaced 75.3 miles of URD cable in 2023 and has
8	replaced approximately 223 miles of URD cable from 2018-2023 (Table 21).
9	

10

Line

Table 21.URD Cable Miles and Transformers Replaced 2018-2023

	2018 Actual	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Actual
URD Miles Replaced	71.6	3.6	3.6	24.5	44.7	75.3
Live-front Transformers Replaced	-	-	1	63	110	111
Capital Investment (\$ thousands)	\$10,915	\$362	\$964	\$4,705	\$7,043	\$13,750

11

Q132. Why is the planned investment in Exhibit A-12, Schedule B5.4 for URD Replacement shown as \$0 in 2024 and 2025?

A132. Because the Commission approved the Company's Infrastructure Recovery
Mechanism (IRM) in Case No. U-21297, and URD Replacement investments are
addressed through that mechanism, the investments for URD Replacement have been
moved from Exhibit A-12, Schedule B5.4 to the IRM Exhibit A-33 Schedule X1 for
2024 and 2025.

1	Q133.	How does the URD Cable Replacement Program benefit customers?
2	A133.	The program will improve reliability by reducing the number of residential customer
3		interruptions experienced by URD cable failures in the areas in which this program has
4		completed work. This will also benefit customers by reducing the risk of multiple
5		failures and long duration outages due to pre-existing open loops as described above.
6		
7	<u>Break</u>	er Replacement Program
8	Q134.	What are substation breakers and substation reclosers, and what purpose do they
9		serve?
10	A134.	The path electricity travels across the system can be subjected to interruptions due to a
11		variety of factors (e.g., a tree falling on an overhead electrical line), which can cause
12		outages and potentially dangerous situations for customers and employees. Electrical
13		switches, most commonly breakers or reclosers, are in place at points along the network
14		to recognize and isolate these interruptions (also known as electrical faults) from the
15		rest of the distribution system. These switches help to minimize equipment damage
16		from electrical faults and allow power to continue flowing to as many customers as
17		possible while restoration is completed for the damaged circuits.
18		
19		At the subtransmission and distribution levels, there are large breakers (switches) at
20		stations and substations that interrupt the current flow when a fault is detected to
21		minimize equipment damage and to isolate the faulted equipment from the rest of the
22		system.
23		
24		Downstream from the substation breakers, located on distribution circuits, are
25		substation reclosers. Substation reclosers perform similarly to a breaker. When they

detect faults, they open and isolate the interruption to a smaller area, impacting fewer
customers. Substation reclosers can prevent the substation breaker from opening,
avoiding a larger circuit level outage. Additionally, these reclosers can be used to tie
two circuits together so that, in the event of an outage, one circuit can provide power
to the other. Reclosers have a key role to play in improving reliability and are the
foundation of the automation program. **Q135. What is included in the Breaker Replacement Program?**

A135. The Company has approximately 6,000 breakers on the electrical distribution and
subtransmission systems with approximately 60% of those breakers at an age beyond
their life expectancy. The breakers included in the replacement program have an
obsolete design, typically utilizing insulation oil for fault extinguishing.

13

Breakers replaced by the Breaker Replacement Program are classified into four 14 categories: distribution breakers, subtransmission breakers, H-breakers, and substation 15 reclosers. In addition to replacing breakers, the program also replaces relays and 16 controls to make the equipment SCADA-ready. SCADA (supervisory control and data 17 18 acquisition) utilization on equipment, will provide the Electric System Operations Center (ESOC) greater visibility to system performance, which will allow ESOC 19 20 personnel to remotely reconfigure the grid to restore customers by isolating faults 21 and/or transferring load to adjacent circuits during both planned and unplanned 22 outages.

23

24 Q136. Was the Breaker Replacement Program in the prior rate cases?

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1	A136.	Yes, the Breaker Replacement Program was included in Case Nos. U-20162, U-20561,
2		U-20836, and U-21297.
3		
4	Q137.	Were Breaker Replacement Program investments supported in prior rate cases?
5	A137.	Yes. The Commission stated in its Order for Case No. U-21297,
6		"The Commission finds that the replacement of obsolete circuit breakers is the
7		type of work, like the removal of arc wire, that is necessary and lends itself to
8		few alternatives. The Commission disagrees with the ALJ and approves DTE
9		Electric's requested funding for inclusion in rate base but adopts the Staff's
10		proposed 10% reduction to the company's test year request as a check on the
11		potential for over-projections. The company provided evidence that 60% of
12		breakers in the distribution and subtransmission systems (including substation
13		reclosers) are beyond their life expectancy. DTE Electric provided the criteria
14		used for selecting which breakers to replace and indicated that it plans to replace
15		35 breakers in 2023 and 36 in 2024. 3 Tr 543-544. While the evidentiary
16		showing could have been more robust, the Commission believes that this is
17		important work that needs to be done and approves the requested funding with
18		the 10% reduction."
19		
20	Q138.	What are the customer benefits from the Breaker Replacement Program?
21	A138.	The benefits of breaker replacement and enhanced relaying and controls include

A138. The benefits of breaker replacement and enhanced relaying and controls include
 enhanced safety, reduction of substation outage risk caused by breaker failures,
 improved customer reliability, reduction in reactive expenditures due to breaker
 failures, added ability to utilize SCADA controls, and the reduction of outage duration
 due to enhanced fault location and event analysis provided by SCADA capability.

2

Installation Decade	2019 Actual	2020 Actual	2021 Actual	2022 Actual	2023 Actual	Total
Unknown	-	1	-	-	-	1
1930s	5	1	3	1	1	11
1940s	4	2	2	8	2	18
1950s	36	38	35	55	48	212
1960s	17	24	7	15	9	72
1970s	33	19	16	29	17	114
1980s	13	10	7	7	17	54
1990s	27	34	22	34	26	143
2000s	14	6	6	10	21	57
2010s	6	6	32	1	19	64
2020s	-	-	-	-	1	1
Total Breakers Failures	155	141	130	160	161	747

Table 22.

Breaker Failures 2019-2023

3

11

4 Q139. How are breakers selected for replacement?

flammable; and

5 A139. The candidates for breaker replacements are chosen by the Company's equipment 6 engineers who review all breakers on the system. Breakers are prioritized based on the 7 following criteria:

- Breakers with known performance issues;
 Breakers with no or limited availability of spare parts;
 Breakers with insulation oil for fault interrupting medium which is
- Breakers that require short inspection cycles compared to the rest of the
 breakers on our system.

Line <u>No.</u>					M. ELLIC	D TT ANDAH U-2	IAZY 21534
1	0140 Can you prov	ido o gracifi	avamula of	an abaalata b	analyan turna	that is puice	itizad
2	Q140. Can you prov	ide a specific	example of	an obsolete i	breaker type	that is prior	itizeu
3	for replaceme	ent by the Br	eaker Repla	cement Prog	ram?		
4	A140. Yes. H-breake	ers are an obs	olete oil brea	iker design, a	amongst the o	oldest in the	utility
5	industry, datin	g back to at le	east the 1920s	. H-breakers	are no longer	manufacture	d, and
6	replacement pa	arts are not av	vailable in the	market for th	nem. The Cor	npany has rep	placed
7	twenty-six obs	olete H-break	kers with mod	lern breakers	over the last	six years.	
8							
9	Q141. How many H	Breakers hav	ve been rep	laced throug	gh the Brea	ker Replace	ement
10	program in 20	023 and prio	r years?				
11	A141. Please see Tab	le 23.					
12							
13		Table 23.Breakers Replaced 201				023	
	Breaker Type	2018	2019	2020	2021	2022	2023
	Distribution Breakers	31	19	20	22	15	16
	Subtransmission Breakers	14	9	7	4	12	6
	H-Breakers	5	7	6	3	2	3
	Substation Reclosers	6	7	4	10	5	4
	Total Breakers	56	42	37	39	34	29

Capital Investment (\$ thousands)

\$9,919

\$10,931

\$17,365

\$14,415

\$13,161

\$9,148

1

2

Q142. Why is the forecasted amount in Exhibit A-12, Schedule B5.4 for Breaker Replacement \$0 in 2024 and 2025?

- A142. Because the Commission approved the Company's Infrastructure Recovery
 Mechanism (IRM) in Case No. U-21297, and URD Replacement investments are
 addressed through that mechanism, the investments for Breaker Replacement have
 been moved from Exhibit A-12, Schedule B5.4 to the IRM Exhibit A-33 Schedule X1.
- 7

8 Mobile Fleet Program

9 Q143. What is the Mobile Fleet Program?

10 A143. These investments expand the fleet of mobile generation which is used to quickly 11 restore power to customers during major events such as substation failures. These assets 12 include portable generators, portable switchgear, portable substations, portable ISO 13 equipment, portable poles, energy storage trailers and the controls that allow these assets to work together cohesively during planned and emergency events. This mobile 14 15 equipment offers multiple operational benefits including decreasing restoration time during substation failures for substation load that can't be fed from adjacent 16 substations/circuits, supporting substations on a single contingency to avoid outages, 17 18 and providing the ability to facilitate the repairs of the failed equipment inside the 19 substation while customers remain energized. Mobile Fleet Program equipment is also 20 used to support customers during planned construction work when field crews must 21 deenergize electric equipment to allow for work to be performed in a safe manner.







3

Line

No.

1 2

4 Q144. How does the Mobile Fleet Program benefit customers?

5 A144. Since the beginning of 2022, DTEE has experienced 96 major events on the system. 6 These events have caused loss of power for anywhere from a few hundred customers to over 10,000 customers. One example of a major event in 2023 occurred at Snover 7 substation, a single transformer, two circuit substation. The single substation 8 9 transformer failed, resulting in loss of load for nearly 1,100 customers for 10 approximately 13 hours. The load of the circuits could not be transferred to neighboring 11 circuits due to the configuration of adjacent DTEE circuits and because the other 12 adjacent circuits are owned by other electric providers. The Company's short-term 13 solution was to deploy portable distributed generators to serve the load of the two 14 circuits. The medium-term solution required the Company to install a portable substation while permanent repairs were made at Snover substation. This example 15 highlights both the significant challenges to addressing a major event failure and the 16 17 important role the Mobile Fleet Program plays in restoration of service to customers.

Line <u>No.</u>		U-21534
1		In addition, the mobile fleet equipment allows the Company to perform planned work,
2		such as preventative maintenance on single-tap substations, without requiring
3		customers to experience an outage while the work is being performed.
4		
5	Q145.	What Mobile Fleet Program equipment is the Company planning to purchase in
6		this instant case?
7	A145.	The Company began building the infrastructure around the engine and generator for
8		PDG1 (Portable Distributed Generator), constructed small switching trailers,
9		performed controls work on portable switchgear, and installed controls enhancement
10		on PDG3 units in 2023.
11		
12		The Company plans to complete the building of PDG1, perform the integration of
13		portable generator controls to enhance functionality, complete portable switchgear, and
14		install synchrophasor time-based trips for generators in 2024.
15		
16		The Company plans to perform integration of portable controls, purchase of additional
17		connection skids, convert hybrid DC generator to a low carbon generator, and phase
18		balance controls in 2025.
19		
20	<u>Pontia</u>	ac Vaults
21	Q146.	What is the current state of the Company's infrastructure that provides service
22		to the City of Pontiac?
23	A146.	DTEE acquired the electrical system that services the main portion of the City of
24		Pontiac in the 1980s from Consumers Energy. Pontiac is served by an 8.3kV system
25		fed by four substations (Barlett, Paddock, Rapid Street, and Stockwell) and 18

distribution circuits. This portion of the system is surrounded entirely by 13.2kV circuits, so that in the event of a major failure, the Company is unable to quickly restore customers by transferring load to adjacent DTEE circuits.

4

Line

No.

1

2

3

5 The 8.3kV system uses a non-standard voltage that the Company does not use in any 6 other area of its service territory and is an obsolete system. Replacement parts are no longer available for 8.3kV breakers and other substation equipment due to their 7 8 obsolescence, leading to extended customer interruptions, and leaving the system in an 9 abnormal state for longer durations when work must be completed (preventative or 10 reactive). Additionally, the City of Pontiac has seen a gradual increase in load demand 11 over the past several years. In response to these factors, the Company has created a 12 plan to convert the four 8.3kV substations (and corresponding distribution circuits) to 13 13.2kV, as detailed in Company Witness Deol's testimony.

14

The Pontiac 8.3kV system includes underground vaults which contain electrical equipment, such as sectionalizing equipment and service transformers, since the footprint necessary for this infrastructure is not available above ground. These vaults primarily house the equipment that provides service to the downtown business district, which includes hospitals and City of Pontiac official buildings.

20

21 Q147. What is included in the Pontiac Vaults program?

A147. The Pontiac Vault Program performs upgrades on the existing underground equipment with modern equipment that is submersible and arc sealed. This work includes replacing damaged vaults, replacing at-risk and end-of-life equipment in the vaults, Line No. 1 replacing 7 miles of existing non-standard cable, and installing SCADA monitoring 2 equipment. 3 4 Q148. How does the Pontiac Vault Program benefit customers? A148. The customers benefit from this investment because it is an integral part of the greater 5 8.3kV conversion initiative that will improve reliability, allow for faster outage 6 restoration, and increase electric capacity available to serve the City of Pontiac. 7 8 Additionally, the Pontiac Vaults program replaces at-risk, aging, non-standard 9 equipment that poses a reliability risk to downtown Pontiac and a safety hazard to the 10 Company operators and to the public in the vicinity of the vaults. 11 12 Q149. What work is the Company planning to complete in this instant case? 13 A149. In 2023, the Company completed the following construction: Installed conduit and cable, made appropriate repairs to the vault structures, installed a light post and radio, 14 and the loads transfer to energize the Cesar-Chavez Vault; and installed cable between 15 the Huron Vault and the -3 transformer. 16 17 18 40kV: Automatic Pole-Top Switch 19 Q150. What are Automatic Pole-Top Switches (APTS)? 20 A150. The function of the APTS is to sectionalize, isolate, or connect portions of the 21 subtransmission system. Failure of one of these switches has the potential to interrupt 22 thousands of customers or result in significant operational constraints. The Company has identified APTS currently installed in the distribution system that are no longer 23 working properly or at risk of failure, and where replacement parts are no longer 24

available due to obsolescence. 25

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		
2	Q151.	How does the 40kV: APTS Program benefit customers?
3	A151.	When customer outages occur on the system, if one of these APTS devices is not
4		working properly, it can cause an extended outage for thousands of customers. This
5		program ensures the APTS in the field will operate properly when necessary, so that
6		these devices can reduce the size and impact of multiple customer outages and increase
7		reliability the customers experience.
8		
9	Q152.	How many APTS is the Company planning to replace for the investments included
10		in the instant case?
11	A152.	In 2023, the Company replaced 10 APTS. The Company plans to replace 12 APTS in
12		both 2024 and 2025.
13		
14	Discor	nect and Switcher Replacement
15	Q153.	What are Disconnects and Switchers?
16	A153.	Subtransmission disconnect switches ("Disconnects") are used to sectionalize and
17		provide isolation points on the electrical system for operational reasons and/or to enable
18		service and maintenance. Failures of disconnects during operation, when operators
19		attempt to open or close a disconnect manually, can lead to safety concerns, reduce
20		system operability, and force additional equipment to be taken out of service to allow
21		critical work to continue.
22		
23		Circuit switchers ("Switchers") connect the transmission system (120kV) and the
24		subtransmission system (40kV) to the primary side of a substation power transformer.
25		The purpose of circuit switchers is to protect substation equipment from damage caused

MEA - 110

No. by excess fault current. Circuit switchers are a smaller, less expensive alternative to circuit breakers. The Company uses circuit switchers exclusively for transformer protection when performing new construction except in situations that require breakers, such as when reclosing function is required, and if the available fault current exceeds

the capacity of switchers.

6

5

Line

1

2

3

4

Q154. How does the Disconnects and Switchers Program benefit customers? 7

8 A154. The Company replaces disconnects and switchers that have been identified as at-risk, 9 and/or have been identified as being undersized compared to the current fault currents, 10 making them no longer capable of providing proper protection to transformers. These 11 replacements help to protect the Company's operators while manually operating the 12 equipment, allow the Company to sectionalize the system (thus reducing the size and 13 impact of customer outages) when performing work, and to protect the other substation equipment from damage when excess fault current occurs. 14

15

Q155. How many disconnects and switchers is the Company planning to replace in this 16 instant case? 17

18 A155. The Company replaced 24 disconnects in 2023 and plans to replace 23 disconnects in 19 both 2024 and 2025.

- 20
- 21 The Company replaced 4 switchers in 2023 and plans to replace 6 switchers in both 22 2024 and 2025.
- 23

24 **Steel Pole Highway Crossings**

Q156. What is the Steel Pole Highway Crossings Program? 25

1	A156.	The Company has experienced incidents where wood poles have failed and fallen into
2		highways and caused shutdowns. The Steel Pole Highway Crossing program identifies
3		current wood pole locations where the overhead wire crosses a highway and have a
4		high risk of failure, and replaces these at-risk wood poles with steel poles to reduce the
5		likelihood of pole failures that can impact traffic and public safety and cause customer
6		outages.
7		
8	Q157.	How does the Steel Pole Highway Crossings Program benefit customers?
9	A157.	This program was developed to replace high-risk wood poles with steel poles, primarily
10		to reduce the risk of overhead equipment falling and disrupting the highway system of
11		southeastern Michigan, however this also provides an ancillary reliability benefit as
12		failed poles can result in customer outages.
13		
14	Q158.	How many Steel Pole Highway Crossings does the Company plan to complete in
15		this instant case?
16	A158.	In 2023, the Company installed 4 Steel Pole Highway Crossings, and plans to complete
17		6 crossings in both 2024 and 2025.
18		
19	Batter	ries and Chargers Replacement Program
20	Q159.	What are Batteries and Chargers?
21	A159.	The Company's substations utilize batteries and chargers to provide reliable power
22		necessary to trip equipment such as breakers during fault conditions. Failures of
23		batteries and chargers would result in significantly longer duration faults, greater
24		damage to system equipment, larger outages, and increased hazards due to the inability
25		to clear electrical faults.

Line <u>No.</u>		M. ELLIOTT ANDAHAZY U-21534
1		
2	Q160.	How does the Batteries and Chargers Program benefit customers?
3	A160.	Batteries and chargers have a finite lifespan and eventually require replacement with
4		new units. The Company identifies batteries and chargers that are at-risk of failure and
5		at end of useful life and selects them for replacement. These devices ensure that
6		substation equipment is protected during fault conditions and can continue to operate
7		properly to maintain reliability.
8		
9	Q161.	How many Batteries and Chargers does the Company plan to replace in this
10		instant case?
11	A161.	In 2023, the Company replaced 54 batteries and 30 chargers. The Company plans to
12		replace 48 batteries and 27 chargers in both 2024 and 2025.
13		
14	<u>SCAD</u>	A Pole-Top Device Replacement
15	Q162.	What are SCADA Pole-Top Devices?
16	A162.	SCADA-enabled pole-top devices, such as overhead three-phase reclosers, are
17		sectionalizing devices that are located at key points on overhead distribution circuits.
18		These devices act like a circuit breaker, opening under detection of high current due to
19		a downstream fault, such as a tree branch across two phases. These devices allow the
20		Electric System Operations Center (ESOC) to remotely reconfigure the grid to restore
21		customers by isolating faults and/or transferring load to adjacent circuits during both
22		planned and unplanned outages.
23		
24	Q163.	How does replacing SCADA Pole-Top Devices benefit customers?

1	A163.	This program replaces devices that have experienced high rates of failure such as Eaton
2		Form 3 reclosers and Bridges pole-top switches (PTS). Failure of these devices reduces
3		system operability, thus increasing the amount of extended duration outages for
4		customers. Replacing these identified devices allows the ESOC to operate the system
5		more effectively, reducing the number and duration of outages experienced by
6		customers.
7		
8	Q164.	How many SCADA Pole-Top Devices does the Company plan to replace in this
9		instant case?
10	A164.	In 2023, the Company replaced 19 SCADA pole-top devices. The Company plans to
11		replace 20 SCADA pole-top devices in both 2024 and in 2025.
12		
13	<u>Substa</u>	ntion Regulator Replacement
14	Q165.	What are Substation Regulators?
15	A165.	Substation regulators are devices that ensure voltages stay within the normal ranges for
16		which Company and customer equipment is rated to perform. Voltage regulation is
17		critical to maintaining the health of electric equipment and helps to maintain the service
18		life of this equipment.
19		
20	Q166.	How does replacing Substation Regulators benefit customers?
21	A166.	Voltage regulation is essential to maintain the health and operability of electrical
22		equipment and prevents the premature damage and failure of this equipment, thus
23		reducing outages customers experience.
24		

<u>NO.</u>		
1	Q167.	How many Substation Regulators does the Company plan to replace in this instant
2		case?
3	A167.	In 2023, the Company replaced 4 substation regulators. The Company plans to replace
4		3 substation regulators in both 2024 and 2025.
5		
6	<u>Portal</u>	ole Generators
7	Q168.	What is the Portable Generator Program?
8	A168.	The Portable Generator Program is an investment the Company is undertaking to help
9		reduce the length of extended outages to single customers during storm events. In
10		short, the Company has purchased portable generators that can be dispatched and
11		serviced to single customers to help energize critical devices such as refrigerators,
12		freezers, personal medical devices, and sump pumps in the event they are expected to
13		be out of service for an extended period during large storms. This program is discussed
14		in more detail in Company Witness Hill's testimony.
15		
16	Q169.	Does this complete your direct testimony?

17 A169. Yes, it does.

Line No

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

KEEGAN O. FARRELL

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF KEEGAN O. FARRELL

Line No.

<u>INU.</u>				
1	Q1.	What is your name, business address and by whom are you employed?		
2	A1.	My name is Keegan O. Farrell (he/him/his). My business address is: One Energy		
3		Plaza, Detroit, Michigan 48226. I am employed by DTE Electric Company (DTE		
4		Electric or Company) as the Manager of Demand Response.		
5				
6	Q2.	On whose behalf are you testifying?		
7	A2.	I am testifying on behalf of DTE Electric.		
8				
9	Q3.	What is your educational background?		
10	A3.	I graduated from Michigan State University with a Bachelor of Arts Degree in		
11		Communication. In addition, I received a Master of Science Degree in Decision		
12		Technologies from the University of North Texas.		
13				
14	Q4.	What is your work experience?		
15	A4.	From 2008 until 2012, I was employed by DTE Gas Resources, LLC in Fort Worth,		
16		Texas where I held positions of increasing responsibility, ultimately serving as a		
17		Decision Support Analyst. In this role, I was responsible for assisting with		
18		calculating reservoir economics, monitoring daily oil and natural gas production,		
19		and overseeing the compliance and emission calculations for the Environmental		
20		Protection Agency's Greenhouse Gas Reporting Program (Subpart W). In 2012, I		
21		joined DTE Energy as a Senior Business Financial Analyst - Load Research. In		
22		2014, I was promoted to Principal Financial Analyst - Load Research. In this		
23		position, I was responsible for developing and implementing statistical sampling		
24		programs used to evaluate customer class usage characteristics, developing		

1		allocation schedules for use in cost-of-service studies and rate design, and for
2		measuring and evaluating demand response programs offered by the Company. In
3		2018, I accepted the position of Supervisor Program Management - Demand
4		Response (DR).
5		
6	Q5.	What is your current position?
7	A5.	In 2021 I was promoted to Manager of DR. In this position I am responsible for
8		overseeing DTE Electric's DR portfolio, which includes short- and long-term
9		strategic development, marketing and management of DR programs and pilots.
10		
11	Q6.	Do you hold any certifications or are you a member of any professional
12		organizations?
13	A6.	Yes. I am the course coordinator for the Association of Edison Illuminating
14		Companies (AEIC) Fundamentals for Load Data Analysis course. In addition, I
15		represent DTE Energy on the board of the Peak Load Management Alliance
16		(PLMA).
17		
18	Q7.	Have you received industry related training?
19	A7.	Yes. I have completed the AEIC Fundamentals of Load Data Analysis course. I
20		have also attended various courses at Michigan State University Institute of Public
21		Utilities Annual Regulatory Studies Program as well as the Demand Response
22		Fundamentals and Evolution Course presented by the PLMA.
23		
24	Q8.	Have you previously sponsored testimony before the Michigan Public Service
25		Commission (MPSC or Commission)?

Line
No.

1	A8.	Yes. I have sponsored testimony and exhibits before the MPSC in the following				
2		DTE Electric cases:				
3		Case No.	Description			
4		U-18014	DTE Electric 2016 General Rate Case			
5		U-18255	DTE Electric 2017 General Rate Case			
6		U-20162	DTE Electric 2018 General Rate Case			
7		U-20471	DTE Electric 2019 Integrated Resource Plan (IRP)			
8		U-20521	DTE Electric 2017-2018 Demand Response Reconciliation Case			
9		U-20793	DTE Electric 2019 Demand Response Reconciliation Case			
10		U-21044	DTE Electric 2020 Demand Response Reconciliation Case			
11		U-20836	DTE Electric 2022 General Rate Case			
12		U-21242	DTE Electric 2021 Demand Response Reconciliation			
13		U-21193	DTE Electric 2022 IRP			
14		U-21297	DTE Electric 2023 General Rate Case			

1	<u>Purpa</u>	arpose of Testimony			
2	Q9.	What is the purpose of your testimony?			
3	A9.	The purpose of my direct testimony is to discuss the demand response efforts that			
4		DTE Electric	is conducting a	and provide support for the expenditures and activities	
5		associated with the continuation of programs and pilots, as well as briefly discuss			
6		the evolving DR landscape. I also discuss the development, future plans, and related			
7		expenditures associated with the DTE Insight Program.			
8					
9	Q10.	Are you sponsoring any exhibits in this proceeding?			
10	A10.	Yes. I am sponsoring in whole, or in part, the following exhibits:			
11		Exhibit	Schedule	Description	
12		A-12	B5.6	Capital Expenditures – Demand Response Portfolio	
13				and DTE Insight	
14		A-12	B5.6.1	C&I Battery Storage Pilot Document	
15		A-12	B5.6.2	Residential Generator Pilot Document	
16		A-12	B5.6.3	Vehicle-to-Home Pilot Document	
17		A-12	B5.6.4	Smart Charge Pilot Document	
18		A-13	C5.9	Demonstrating and Selling Expenses-DR (line 9)	
19					
20	Q11.	Were these exhibits prepared by you or under your direction?			
21	A11.	Yes, they were.			
22					
23	Q12.	How is your testimony organized?			
24	A12.	My testimony consists of the following seven parts:			
25		Part I Demand Response Overview			
<u>No.</u>					
------------	---------------	----------------------	--		
1		Part II	Regulatory Framework		
2		Part III	DR Portfolio		
3		Part IV	DR Portfolio Investments		
4		Part V	Evolving DR Landscape		
5		Part VI	DTE Insight Program		
6					
7	<u>Part I</u>	: Demand Re	<u>sponse Overview</u>		
8	Q13.	What is the j	purpose of Demand Response (DR)?		
9	A13.	DR is designed	ed to reduce or shift enrolled customers' energy usage during periods		
10		of high dema	nd. DR programs provide an opportunity for customers to reduce or		
11		shift their ele	ectricity usage during periods of high energy demand in response to		
12		rates or other	forms of incentives.		
13					
14	Q14.	What are the	e benefits to customers for participating in DR programs?		
15	A14.	DR programs	allow electric customers to play a role in the operation of the electric		
16		grid and sup	port the clean energy transition. Customers participating in DR		
17		programs or	tariffs can benefit from lower bills and/or incentives when utilizing		
18		these program	ns. All customers, whether they participate or not, benefit from the		
19		cost savings t	hat DR provides. This is because as the demand for power decreases,		
20		less efficient	or more expensive forms of generation are not needed.		
21					
22	Q15.	What are the	e benefits of DR to the utility?		
23	A15.	The reduction	n or shift in customer usage from DR programs can provide value to		
24		the utility by	reducing the need for additional generation, resulting in lower energy		
25		costs and sup	porting the Company's generation transformation. If DR programs are		

Line

Line No.

less costly than other capacity resources, the utility and all customers can benefit
 from displacing or deferring the need for new generation resources. In addition,
 reducing electricity usage when demand is the highest can result in lower wholesale
 energy prices.

5

6 Part II: Regulatory Framework

Q16. What is the regulatory framework adopted by the Commission to approve, recover, and reconcile expenditures in the Company's DR portfolio?

9 A16. In the September 15, 2017, Order in Case No. U-18369, the Commission approved 10 a 'three-phase' approach for the approval, recovery, and reconciliation of DR 11 expenditures. In the first phase, DR proposals are evaluated in the context of an 12 integrated resource plan (IRP). In the second phase, DR plans that were approved 13 as part of the IRP are considered pre-approved and the associated costs are included 14 in rates in the utility's future general rate cases. The utility can also propose changes 15 or modifications to DR programs or pilots at this time. The IRP DR proposed 16 programs and pilots, as well as any changes, are then evaluated and approved in 17 rate cases and can be considered for inclusion in the next IRP. The third phase 18 involves a reconciliation of DR costs, participation rates, and demand savings 19 achieved on an annual basis. The Commission also stated that during the 20 reconciliation proceedings, actual capital spending in the examination period will 21 be reconciled against the amount approved in the IRP and recovered in a rate case 22 while Operation and Maintenance ("O&M") spending will be reconciled against 23 the amount approved and recovered in a general rate case.

24

In addition, the Company can earn a financial incentive through a financial
 incentive mechanism (FIM) calculated in each annual reconciliation case. The FIM
 methodology was agreed upon in the settlement of the 2019 DR Reconciliation
 (Case No. U-20793).

5

Q17. What DR capital costs were pre-approved through settlement in the Company's most recent IRP?

A17. Table 1 shows the capital costs that were pre-approved through settlement in the
Company's last IRP Order, Case No. U-21193, issued July 26, 2023.

- 10
- 11

 Table 1 U-21193 Pre-approved DR Capital Expenditures

Program	2024	2025
CoolCurrents	\$500,000	\$500,000
SmartCurrents	\$2,500,000	\$2,500,000
Commercial & Industrial Dashboard	\$350,000	\$350,000
Interruptible Water Heating	\$1,000,000	\$1,000,000
Total	\$4,350,000	\$4,350,000

12

13 Part III. DR Portfolio

14 Q18. Could you describe the Company's current DR portfolio?

A18. Yes. DTE Electric develops and manages its DR programs offering customers a
 range of options consisting of products, customer incentives, tariff structures, and
 education based on their profiles and willingness to curtail or shift energy usage
 during peak hours. As part of the development process, the DR organization

Line <u>No.</u>		U-21534
1		evaluates customer behavior, program acceptance and validates technologies that
2		can deliver benefits to its customers.
3		
4		The Company's current DR portfolio is made up of eleven tariffs and programs and
5		four pilots that are available to residential, commercial and industrial customers.
6		The goal of the Company's DR portfolio is to deliver measurable peak demand
7		reduction by effectively engaging customers to manage and reduce or shift their
8		energy consumption.
9		
10	Q19.	What measurable value does the DR portfolio provide?
11	A19.	The Company currently registers DR as Load Modifying Resources (LMR) at
12		MISO and receives capacity credit for its established DR portfolio.
13		
14	Q20.	What programs and tariffs are included in the Company's current DR
15		portfolio?
16	A20.	The Company's DR portfolio is made up of CoolCurrents TM , SmartCurrents TM ,
17		Smart Savers, Interruptible Water Heating, Dynamic Peak Pricing (DPP) and
18		multiple interruptible tariff rates for Commercial and Industrial (C&I) customers.
19		The participants in the DR programs or on the tariffs receive a discounted rate or
20		incentive in exchange for reducing their load during DR events.
21		
22	Q21.	What is a DR event?
23	A21.	A DR Event is a period of high energy demand when programs are activated to
24		relieve stress on the grid.
25		

Line No.

1 Q22. What is the CoolCurrents Program?

A22. CoolCurrents is the program name for the Interruptible Space Conditioning tariff
(Rate D1.1) that is available to residential and commercial customers. Customers
who enroll in CoolCurrents are equipped with a direct load control device (LCD)
on their air conditioning unit(s) or central heat pump that allows the Company to
cycle the associated appliance in exchange for a discounted rate. The cycling of the
appliance is limited to no more than eight hours in any 24-hour period and events
can be called year-round in any of the four MISO seasons.

9

10 Q23. What is the SmartCurrents Program?

11 A23. The SmartCurrents Program, commonly referred to as the Programmable 12 Communicating Thermostat (PCT) Program, is a DR offering where residential and 13 commercial customers receive a free ecobee premium thermostat. By enrolling in 14 SmartCurrents and installing their free thermostat, customers agree to allow the 15 Company to adjust the thermostat setpoint by up to four degrees during 16 SmartCurrents events. SmartCurrents events can occur on non-holiday weekdays 17 between the hours of 12:00 pm and 8:00 pm, can last no more than four hours and 18 are limited to 64 total hours each calendar year, and available year-round.

19

20 Q24. What is the Smart Savers program?

A24. The Smart Savers program, which is a Bring Your Own Device (BYOD) program,
is available to residential and commercial customers who have an existing and
eligible PCT installed at their residence or business. In this program, customers
enroll their eligible thermostat in the program and agree to let the Company adjust
the setpoint on the thermostat up to four degrees during Smart Savers events. Smart

Line <u>No.</u>		U-21534
1		Savers events last no more than four hours and can be called between 12:00 pm and
2		8:00 pm on non-holiday weekdays. The Smart Savers season runs from June 1st
3		through September 30 th and events are limited to 56 total hours annually.
4		
5	Q25.	What is the Interruptible Water Heating rate?
6	A25.	The Interruptible Water Heating rate (D5) is available to both residential and
7		commercial customers that use hot water for sanitary purposes or other uses subject
8		to the approval of the Company. An LCD is installed at the customer's location that
9		turns off the heating element of the water heater for up to four hours in any 24-hour
10		period during any MISO season. Participating customers receive a discounted rate
11		on the associated water heating usage.
12		
13	Q26.	What is the DPP rate?
14	A26.	The DPP rate (D1.8) is a rate that is offered to residential and commercial
15		customers. It is a three-tiered Time of Use rate (On-Peak, Mid-Peak, and Off-Peak),
16		with a critical peak pricing (CPP) rate component. During a CPP event, which are
17		available year-round in any of the four MISO seasons, the price per kilowatt of
18		electricity increases to \$0.95 per kilowatt hour. CPP events occur between 3:00 pm
19		and 7:00 pm on non-holiday weekdays and are limited to no more than 56 hours
20		per year.
21		
22	Q27.	What additional interruptible tariffs does the Company offer to C&I
23		customers to promote participation in demand response?
24		

A27. The Company offers C&I customers six tariffs at a discounted rate in exchange for
 agreeing to interrupt a portion of their electric load during DR events. Unless

1 2

3

Interruptible General Service Rate (D3.3): Commercial secondary customers can
 elect to have separately metered service that is subject to interruption or establish a
 portion of their load as firm through the product protection feature. This rate is not
 available to customers whose loads are primarily off-peak. Company interruptions
 may include interruptions for, but not limited to, maintaining system integrity,
 economic reasons, or when available system generation is insufficient to meet
 anticipated system load.

otherwise noted, these tariffs are available for interruption year-round in any of the

four MISO seasons. The tariffs that are available to C&I customers are as listed:

Interruptible Supply Base Service Rate (D8): Primary voltage customers who desire
 separately metered service for a specified quantity of demonstrated interruptible
 load of not less than 50 kW at a single location can take service under this rate.
 Customers may be ordered to interrupt only when the Company finds it necessary
 to do so either to maintain system integrity or when the existence of such loads will
 lead to a capacity deficiency.

Alternative Electric Metal Melting (Rider 1.1): Customers who operate electric
 furnaces for the reduction of metallic ores and/or electric use consumed in holding
 operations who provide special circuits can have that load separately metered,
 making it subject to interruption. The Company may order an interruption to
 maintain system integrity.

4. Electric Process Heat (Rider 1.2): Customers who use electric heat as an integral
 manufacturing process, or electricity as an integral part of anodizing, plating, or a
 coating process and who provide special circuits can have that load separately

Line

1

2

No.

metered, making it subject to interruption. The Company may order an interruption to maintain system integrity.

3 5. Interruptible Supply Rider (Rider 10): Rider 10 allows customers to elect the 4 amount of interruption they are willing to take under a separate meter. Program 5 participation is capped at a total of 650 MW of enrolled load. Rider 10 is designed 6 for customers of greater than 50 MW at a single location, although at the 7 Company's discretion, and with available capacity, the minimum site requirements 8 can be waived. The Company may order an interruption to maintain system 9 integrity.

10 6. Capacity Release (Rider 12): Customers are provided a capacity release payment 11 by subscribing at least 100 kW of load per site location for interruption. The 12 Company may order an interruption to maintain system integrity. The program is 13 only available during the MISO summer season from June 1 – August 31 although 14 the Company is evaluating customer reception for Rider 12 to be made available for the other seasons as well. 15

16

17 **Q28.** How much capacity does the Company's existing DR portfolio account for in 18 meeting MISO's resource adequacy requirements?

19 A28. The 2023/2024 MISO Plan Year was the first year that MISO used a seasonal 20 construct, as opposed to yearly, in establishing resource adequacy requirements. 21 This change is discussed further in Part V. MISO's resource adequacy construct 22 has four seasons; Summer (June, July and August), Fall (September, October, 23 November), Winter (December, January, February) and Spring (March, April, 24 May). DTE Electric registered 831 MWs (installed capacity or ICAP) of demand 25 response for the summer season, equating to 912 Zonal Resource Credits (ZRCs).

Line No.					K. O. FARRELL U-21534
1		The seasonal breakdowr	n of ICAP MWs and	ZRCs used to meet a	resource adequacy
2		requirements in Plannin	g Year 2023/24 is in	n Table 2.	
3					
4		Tabl	e 2 2023/24 ICAP	MWs (ZRCs) by Se	ason
		Summer	Fall	Winter	Spring
		831 (912)	368 (431)	363 (465)	318 (403)
5					
6	Q29.	How does the Company	y's DR portfolio co	mpare to other utili	ty DR portfolios?
7	A29.	In 2022, the U.S. Energy	y Information Admi	nistration (EIA) rank	ed DTE Electric's
8		DR portfolio the fifth l	argest in the countr	ry in terms of Potent	tial Peak Demand
9		Savings. EIA also ranke	ed the Company's po	ortfolio as the largest	in MISO in terms
10		of Potential Peak Deman	nd Savings.		
11					
12	Q30.	What is the intent of th	ne DR pilot offering	gs?	
13	A30.	Pilots are potential prog	grams focused on ur	nderstanding technol	ogy or design and
14		determining whether the	hey can become f	full-scale programs	that will deliver
15		accountable peak dem	and reductions or	shifts in energy c	consumption. The
16		Company will determin	e which pilots may	become programs in	the DR portfolio
17		on a case-by-case basis.			
18					
19	Q31.	Why is it important to	continue to invest	in DR pilots?	
20	A31.	Continued investment in	n DR pilots allows t	he Company to stay	at the forefront of
21		new or emerging DR	technologies and e	evaluate whether the	e technologies or
22		program design will prov	vide benefits to the C	Company and its cust	omers. Investment

KOF-13

Line <u>No.</u>		U-21534
1		in DR pilots also can shape future designs of programs and provide valuable
2		learnings as the DR landscape changes.
3		
4	Q32.	What DR pilots is the Company developing or conducting to continue to
5		diversify the portfolio as well as offer more options for potential DR
6		customers?
7	A32.	The Company is conducting pilots that include an electric vehicle (EV) DR pilot
8		(Smart Charge), a residential home generator pilot, and a C&I Battery storage pilot.
9		The Company is also developing a Vehicle-to-Home (V2H) pilot. These pilots will
10		be discussed in detail later in my testimony.
11		
12	Q33.	What is the overall purpose of continued investment in DR?
13	A33.	DR programs are, and will continue to be, an important part of DTE Electric's
14		integrated resource portfolio and are part of a utility system framework within the
15		comprehensive context of an IRP process. The Company has been managing and
16		investing in a diverse range of programs and pilots that serve as resources in the
17		Company's IRP.
18		
19		Changes have been occurring in the energy landscape including energy legislation,
20		regulatory framework, and environmental regulations. These changes, coupled with
21		a shift from fossil fuel-based generation to cleaner energy resources, are driving
22		investment in a DR portfolio to help meet the Midcontinent Independent System
23		Operator's (MISO) resource adequacy requirements. A portfolio of pilots and
24		programs enables the Company to continue providing secure, reliable, and

Line <u>No.</u>		U-21534
1		sustainable energy supply to its customers under a changing generation capacity
2		and energy landscape.
3		
4	<u>Part I</u>	V: DR Portfolio Investment
5	Projec	eted Capital
6	Q34.	How much capital is the Company forecasting to invest in the DR portfolio
7		during the bridge year, January 1, 2023, through December 31, 2024, and the
8		forecasted test year, January 1, 2025, through December 31, 2025?
9	A34.	As shown in Exhibit A-12 B5.6 p1, during the bridge period the Company is
10		forecasting to invest \$2.2 million on the CoolCurrents Program, \$8.3 million on the
11		SmartCurrents program, and \$6.9 million on other DR programs and pilots. In
12		addition, during the forecasted test year the Company is forecasting to spend \$0.5
13		million on CoolCurrents, \$2.5 million on SmartCurrents and \$1.4 million on other
14		DR programs and pilots. In total, the Company is forecasting DR capital
15		investments of \$17.4 million during the bridge period and \$4.4 million during the
16		forecasted test year.
17		
18	Q35.	What is the status of the Company's CoolCurrents LCD replacement
19		program?
20	A35.	As of December 31, 2023, approximately 260,000 residential customers and over
21		800 commercial customers take service on the D1.1 rate. The Company began
22		replacing outdated legacy Radio Control Units (RCUs) in 2015 after identifying

23 that the legacy RCUs were in need of repair, prone to malfunctioning, and difficult 24 to service as some units were installed as early as the 1980's. Since then, the Company has successfully replaced an estimated 170,000 legacy RCUs with a two-25

1

2

3

4

5

way communicating 24v LCD. The replacement LCD provides the Company with increased flexibility to interrupt based on geographic area or other subgroups as well as determine whether devices are online and available for interruption or offline.

6 Throughout 2023, the Company focused on continuing to replace RCU devices as 7 well as investigating previously installed LCDs that are offline. Nearly 25,000 8 previously installed replacement LCDs (out of 170,000) are no longer joined to the 9 electric meter and thus not available for interruption. Based on the field 10 investigations conducted in 2022 and 2023, around 70% of the replacement LCDs 11 investigated are due to the customer wiring no longer supplying the required 24v. 12 Other reasons for offline devices are unrecorded meter changes or a device reset 13 required due to a meter firmware upgrade. Making better use of data analysis and 14 procedures for upgrading meters, DTE Electric is working to reduce the need for 15 field investigations of offline devices.

16

17 Q36. Could you explain the status of the remaining CoolCurrent customers?

A36. Yes. Approximately 90,000 CoolCurrent customers still have legacy RCUs
primarily due to not having the proper wiring in place to power a replacement LCD.
Without the proper wiring available to provide power to the 24v LCD, the LCD
will not be installed. To address this issue the Company is evaluating the
installation of an alternative new LCD.

- 23
- Q37. How does installing an alternative new LCD provide a solution to customers
 that do not have the proper wiring needed to support a replacement LCD?

1	A37.	The replacement LCD, like the older RCUs, relies on a 24v line that is run from the
2		customer's furnace for power. The Company has found that when a customer
3		services or replaces their heating, ventilation, and air conditioning (HVAC) unit,
4		this line is often not reattached or is simply removed. To replace or repair the 24v
5		line, it is estimated that a customer would have to pay a contractor, on average,
6		between \$80 to \$200 to make the replacement LCD functional. This is also
7		comparable to what a customer with a legacy RCU would spend to ensure the
8		proper wiring is in place for a replacement LCD.
9		
10		The alternative 240v LCD connects directly to the customer's HVAC unit and pulls
11		its power from the unit making the 24v line no longer necessary. By offering this
12		alternative LCD, CoolCurrents customers can remain enrolled in the program
13		without any additional cost, as the device is not dependent on a dedicated, customer
14		supplied separate 24v line.
15		
16	Q38.	Has the Company worked with any other utilities to gather learnings about
17		the alternative 240v LCD?
18	A38.	Yes. The Company had discussions with Consumers Energy (CMS), who use a
19		similar 240v LCD, to better understand how the alternative LCD is installed and
20		operates. This included an installation go and see by the Company's field personnel
21		with CMS field installers. The go and see allowed the Company's field personnel
22		to see the alternative LCD installation process as well as learn what type of
23		equipment and components are needed and to ask questions directly to experienced
24		installers. In addition, the CoolCurrents Program Manager discussed the alternative
25		LCD with the CMS Program Manager to gather further learnings from their

LCD with the CMS Program Manager to gather further learnings from their

Line

1		experiences. After the collaborative field events conducted with CMS installers,
2		DTE Electric field service personnel determined that similar devices could be
3		installed by the Company's personnel. DTE Electric field service trainers are
4		currently developing a training course which all field service representatives are
5		anticipated to complete in the second quarter of 2024.
6		
7	Q39.	Has the Company ordered any alternative LCDs that do not require a 24v
8		line?
9	A39.	Yes. In 2023, the Company ordered and accepted delivery of nearly 5,000
10		alternative LCDs that are targeted to be installed in 2024. In addition, the Company
11		has ordered the various components that are necessary for the installations. The
12		installation of the alternative LCD devices will be used to gauge whether this is a
13		viable solution for customers who do not have the proper 24v wiring. Assuming
14		that there is a willingness on the part of customers to have the alternative 240v LCD
15		installed on their appliance, and DTE Electric field service executes requested
16		installations as anticipated; this device will likely provide a satisfactory alternative
17		to the 24v device.
18		
19	Q40.	How is the Company selecting which CoolCurrents customers may receive the
20		alternative LCD?
21	A40.	These alternative devices will initially be offered to customers that are currently
22		enrolled in the CoolCurrents program, allowing them to remain in the program
23		without the need to hire a contractor to repair their 24v line. As per the D1.1 rate,
24		CoolCurrents customers have a separate meter to record AC or heat pump
25		consumption. In January 2024, the Company initially targeted approximately 200

KOF-18

1		customers, located on the Fisher substation, who were contacted in 2022 to repair
2		the 24v wiring and do not currently have the 24v connection required to support the
3		replacement LCD. This initial 200 customer targeted effort supports the Non-Wires
4		Alternative (NWA) pilot in collaboration with DTE Electric's Distribution
5		Operations team. Beginning in March 2024, the Company will contact
6		approximately 4,000 customers, and more if needed, in two batches of around 2,000
7		customers, who do not have a 24v connection.
8		
9	Q41.	How will the Company determine if the alternative LCD provides a solution
10		to customers that are offline and/or without the proper voltage?
11	A41.	To determine if the alternative LCD is a viable solution the Company will consider
12		customer acceptance, ease of installation, and functionality of the alternative LCD.
13		
14	Q42.	What actions will the Company take if a CoolCurrents customer refuses the
15		alternative LCD and does not have the proper wiring?
16	A42.	If a customer continues to be non-compliant even after being offered an alternative
17		LCD, they will be removed from the tariff and other DR programs, such as Smart
18		Savers or SmartCurrents, will be marketed as alternative DR programs to maintain
19		their support of DR programs.
20		
21	Q43.	Could you describe the capital investment of \$2.2 million in the CoolCurrents
22		program during the bridge year and of \$0.5 million in the forecasted test year?
23	A43.	The capital investment through 2025 will be used to order and install alternative
24		LCDs to address customers who do not have the proper wiring in place. In addition,
25		the investment will support continued investigations into offline devices, install

K. O. FARRELL Line U-21534 No. 1 new or replacement LCDs and program operation costs. The capital investment for 2 the CoolCurrents Program can be seen on Line 1 of Exhibit A-12, Schedule B5.6. 3 4 **O44**. Why is the Company continuing to make these improvements? 5 A44. The Company identified that replacing the outdated infrastructure results in a higher 6 capacity value through increased capabilities and effectiveness. The LCDs are two 7 way communicating devices providing the Company the capability to determine whether devices are available for interruption. They also provide flexibility to 8 9 interrupt at substation or circuit level. With continued investment in the 10 CoolCurrents program, DTE Electric can extend the equipment life and continue to 11 provide an additional DR program option for residential and commercial 12 customers. In addition, the CoolCurrents program is a direct load control DR 13 program that doesn't allow for customer opt outs adding additional value to the 14 Company's DR portfolio and further supports resource adequacy. 15

16 Q45. What changes has the Company made to the SmartCurrents program?

A45. In August of 2023, SmartCurrents was relaunched with changes to the program.
One of the changes included the separation of the program from the DPP rate. Other
changes included upgrading the thermostat to an ecobee Premium Thermostat,
providing an annual participation incentive to increase retention, and revising the
DR event parameters to increase the flexibility and availability of SmartCurrents as
a MISO LMR resource. While the program was being redesigned to incorporate
these changes, program recruitment was paused.

24

Q46. Why did the Company think separating the SmartCurrents program from the DPP rate was necessary?

3 A46. Separating the SmartCurrents program from the DPP rate responds to feedback 4 heard directly from customers in an ad hoc quantitative survey to understand how 5 they would rate select attributes of the SmartCurrents program. In addition, this 6 change allows customers to select the rate that best fits their household and lifestyle. 7 Removing the tariff requirement also opened eligibility to customers who 8 previously may have been denied enrollment due to tariff incompatibilities. In 9 addition, this change allowed the Company to make the necessary changes to the 10 event parameters to better align with the Company's other DR programs.

11

Q47. Have the program changes had an impact on customer enrollment since the relaunch in August of 2023?

A47. Yes. Since relaunch, the program has enrolled a net 7,820 customers as of December 31, 2023, which is 29% of all program enrollees currently active as of the same date.

17

Q48. Could you describe the \$8.3 million bridge year capital investment and \$2.5 million test year capital investment into the SmartCurrents Program?

A48. The Company is projecting to grow the cumulative number of enrolled thermostats from approximately 27,000 as of December 31, 2023, to 35,000 enrolled thermostats at the end of 2024 and 40,000 at the end of 2025. Towards the end of 2022 and through the first half of 2023, the Company redesigned the SmartCurrents program. As noted above, the redesign included the removal of the DPP rate requirement, as well as adjusting the callable event hours and adding an annual

	incentive to the program. The multitude of changes in the redesign required updates
	to program management, IT processes, data transfers, marketing materials, and
	installation training, thus contributing to the increased costs over the bridge period.
	The Company also chose to update the thermostat offering to a newer model, the
	ecobee Smart Thermostat Premium. The new ecobee Smart Thermostat Premium
	comes with a smart sensor and offers additional functionality such as indoor air
	quality monitoring and can deliver personalized energy recommendations.
	In 2024, the Company is projecting to spend approximately \$4.0 million primarily
	on contractor costs and materials. Beginning in 2025, the Company is forecasting
	to spend \$2.5 million to support the SmartCurrents Program. The continued
	investment in the SmartCurrents program will ensure the continued success of the
	program, support the Company's program enrollment goals and increase the MW
	capacity. The capital investment in the SmartCurrents Program can be seen on Line
	2 of Exhibit A-12, Schedule B5.6.
Q49.	Can you provide a further breakdown of the SmartCurrents capital costs?
A49.	Capital costs associated with the SmartCurrents Program consist of primarily of
	contract labor and materials. Contract labor is provided by ICF and EnergyHub,
	and materials consists of the ecobee device costs and associated API license. In
	addition, there is internal DTE Electric labor to support the program, that includes
	program management, internal IT labor and digital assistance. ICF assists in the
	management of the SmartCurrents program in many facets including, but not
	limited to, thermostat scheduling, installation and reporting, program management,
	recordkeeping, IT support, customer communication and marketing development,
	Q49. A49.

KOF-22

<u>NO.</u>		
1		as well as coordinating thermostat purchases. ICF supported the program redesign.
2		EnergyHub is the third-party integrator and their platform that is used communicate
3		with the enrolled thermostats which includes determining if the thermostat is online
4		and dispatching event notifications to host thermostats and making the temperature
5		offset when a DR event is called.
6		
7	Q50.	What changes has the Company made to the SmartCurrents program in an
8		effort to reduce program costs?
9	A50.	Some of the changes made to reduce program costs include:
10	•	When a customer selects professional installation at the time of enrollment, rather
11		than shipping the thermostat to the customer, the installer brings the thermostat to
12		the customer's residence during the installation appointment. This eliminates the
13		shipping costs and materials for customers selecting professional install at the time
14		of enrollment. Since relaunch through the end of 2023, approximately 54% of
15		customers elected professional installation.
16	•	The Company added virtual installation as a new installment option which saves,
17		on average, \$80 compared to an in-person professional installation appointment.
18		This provides a virtual agent to help walk through thermostat installation with the
19		customer, ensuring proper connection and not requiring or reducing an in-person
20		installation. Since relaunch, 7% of customers opt for virtual installation at the time
21		of enrollment as of year-end 2023.
22	•	A new installation scheduler tool is offered that provides customers with the ability
23		to schedule their own installation appointment, rather than having to contact the
24		call center to do so. This tool also has a chat function that provides customers with

No. 1 troubleshooting support, reducing the need for service calls. As of December 31, 2 2023, customers have scheduled 40% of their own appointments since the relaunch. 3 • When a customer returns a thermostat, they are provided a return label via email 4 versus being mailed a return label, reducing postage costs. 5 6 Q51. Has the Commission been supportive of the SmartCurrents Program in 7 previous filings? 8 A51. Overall, yes. While MPSC Staff generally supports the program, it was agreed upon 9 in the 2021 DR Reconciliation settlement, Case No. U-21242, to disallow 10 \$1,672,895 in capital expenses associated with the SmartCurrents Program. The 11 MPSC Staff recommended the disallowance citing that the program was only 12 preapproved for \$3 million in 2021 through Case No. U-20471 (the Company's 13 2019 IRP). The disallowance (~\$1.7 million) is the difference between the actual 14 spend on SmartCurrents in 2021 and \$3.3 million (\$3 million plus 10%). 15 16 Q52. What reasons did Staff cite in recommending the disallowance? 17 A52.

The Staff did not find the overspend to be reasonable because of the lack of value 18 of these costs demonstrated by the Utility Cost Test. The SmartCurrents spend over 19 the authorized amount was primarily attributed to creating a new webpage to 20 redesign, enhance, and streamline the potential and existing participant customer 21 journey. Specifically, the webpage and platform allowed for self-service 22 enrollment, unenrollment and management of DPP event communication 23 preferences. At the time of the 2021 DR reconciliation filing, the Company could 24 not correlate increased enrollments and event participation to the development of the new webpage. 25

Line

		K. O. FARRELL
Line No		U-21534
1		
2	Q53.	Is the Company requesting recovery for the \$1,672,895 that was originally
3		disallowed in the 2021 DR reconciliation?
4	A53.	Yes. Although the Company properly eliminated the disallowed capital from the
5		balance sheet Exhibit A-2, Schedule B6.1, the Company believes there are benefits
6		from these costs and that it should be allowed to recover them. If the Commission
7		approves the Company's request for recovery, \$914,448 ¹ should be added to the
8		projected test year rate base.
9		
10	Q54.	Does the Company have any updated metrics that can be directly attributed
11		to the 2021 spend on the platform and webpage development for the
12		SmartCurrents program?
13	A54.	Yes. The Company did recognize an increase in conversion rate from 14% to 46%
14		and the average time to process enrollments decreased from an average of seven
15		days to one day. Looking back, the number of customers who enrolled in
16		SmartCurrents from August 21, 2020, through August 20, 2021, was 6,736. After
17		the webpage went live in 2021, 10,120 customers enrolled within the same
18		timeframe over the next year, resulting in a 50% increase in enrollments. Since the
19		program's 2023 relaunch, 98% of customers have enrolled through the self-service
20		channel that was set up in 2021. This supports the investments the Company made
21		in 2021 to the SmartCurrents program, specifically to the platform and the webpage
22		development, provided value to the program and the \$1,672,895 of disallowed
23		capital should be considered reasonable and prudent and therefore recoverable.
24		

¹ The amount is based on a January 1, 2025, balance of \$1,081,737 and December 31, 2025, balance of \$747,158; \$334,579 should be added to depreciation expense.

1	Q55.	How much capital is the Company forecasting to invest in Other Demand
2		Response Programs and Pilots?
3	A55.	As can be seen on Exhibit A-12, B5.6, the Company is forecasting to spend \$6.9
4		million in capital during the 24-month bridge period ending December 31, 2024,
5		and \$1.4 million during the forecasted test year ending December 31, 2025, in Other
6		Demand Response Programs and Pilots.
7		
8	Q56.	What capital investments are included in Other Demand Response Programs
9		and Pilots?
10	A56.	The Other DR Programs and Pilot category on Exhibit A-12, Schedule 5.6, line 3
11		includes both pre-approved programs from DTE Electric's most recent IRP
12		settlement, Case No. U-21193, and existing on-going pilots. In the Company's
13		settlement of Case No. U-21193, the capital associated with C&I Dashboard and
14		Interruptible Water Heating replacement programs were pre-approved and are
15		included in this capital investment amount. The current pilot that the Company is
16		evaluating that has associated capital spend beyond what was included in the IRP
17		for pre-approval is the C&I Battery Pilot.
18		
19	Q57.	What is the C&I Dashboard that was pre-approved in Case No. U-21193?
20	A57.	The Company issued a Request for Proposal in 2023 and is successfully partnering
21		with Enel X North America, Inc. as a result to provide certain C&I interruptible
22		customers, likely customers taking service under D8, R10 or R12, with technology
23		to help improve their DR performance during called events. These tariffs represent
24		439 MW (80% of the MWs available during the MISO 2023/24 summer season) so
25		their performance is critical to reliability. The technology provides customers with

Line <u>No.</u>

<u>No.</u>		
1		near real-time telemetry meter data so that a DR event can be monitored prior to,
2		during, and after it occurs. The data is displayed on a dashboard that is accessible
3		by both the customer and the Company. Providing customers with near real-time
4		telemetry will better equip them to curtail load during DR events in accordance
5		with their contracted load reduction value. The technology also provides the
6		Company analytics for better DR forecasting and post-event analysis. Initially, the
7		Company plans to provide the dashboard to interested customers for up to 55
8		customers' sites, and add up to 10 new sites in 2025, although it is anticipated that
9		the number of sites may increase as the Company gains hands-on experience with
10		the dashboard. It is anticipated that the first customers will have the necessary
11		equipment installed and access to the dashboard in the first half of 2024.
12		
13	058.	How much capital does the Company anticipate spending on the C&I

Q58. How much capital does the Company anticipate spending on the C&I
 Dashboard over the bridge period ending December 31, 2024, and the
 forecasted test period ending December 31, 2025.

A58. The Company anticipates spending \$1.0 million during the bridge period to support
the setup of the customer sites and provide access to the dashboard and \$350,000
during the forecasted test period to continue access to the dashboard for current
customers and add additional customer sites.

20

Line

Q59. Could you describe the capital investment in the Interruptible Water Heating
 program?

A59. Yes. Similar to the CoolCurrents Program, the Company's LCDs that operate the
Interruptible Water Heating program and reside in customers' homes are no longer
functioning as intended and are due for an upgrade. The Company plans to begin

Line
No.

1		replacing water heating LCDs for customers taking service on D5 (approximately
2		45,000) in 2024. The Company purchased 864 new water heating LCDs in 2023
3		with plans to purchase an additional 864 LCDs in 2024, equating to a total of 1,728
4		new units. The Company will leverage the learnings from the CoolCurrents LCD
5		replacement program including notifying customers of the work that will be
6		performed, educating customers on the rate discount as well as preemptively
7		reaffirming customers desire to remain in the program prior to sending a field
8		service installer to perform the work. If a customer does not wish to remain in the
9		Interruptible Water Heating program, they will be removed from the rate and a new
10		LCD device will not be installed in their home. After the initial targeted
11		replacements are performed in 2024, the results will be evaluated with the
12		expectation that installations will increase in subsequent years.
13		
14	Q60.	Is 24v wiring required, similar to the Company's CoolCurrents replacement
15		LCDs?
16	A60.	No. There is no need for a separate 24v power supply with interruptible water
17		heating services. The control unit is wired directly to the power source in the
18		dedicated meter enclosure and therefore does not need a separate power source.
19		
20	Q61.	How much is the Company forecasting to spend on this program during the
21		bridge period ending December 31, 2024, and during the forecasted test period
22		ending December 31, 2025?
23	A61.	The forecasted capital investment associated with the Interruptible Water Heating
24		program is included in the Other Demand Response Programs and Pilots category
25		on Line 3 of Exhibit A-12, Schedule B5.6. The Company is forecasting to spend

<u>No.</u>		
1		\$345,197 in capital during the bridge period and \$500,000 in capital to support
2		customer LCD installations during the forecasted test period, which is less than the
3		\$1,000,000 that was pre-approved in the IRP settlement as the Company ramps up
4		the replacement LCD installations.
5		
6	Q62.	What is the C&I Battery Storage pilot?
7	A62.	The C&I battery storage pilot is a behind-the-meter (BTM) lithium-ion phosphate
8		battery energy storage system (BESS) that will be located at two customers' sites.
9		It is designed to test the ability to achieve peak demand shaving or shifting during
10		DR events. The Company is targeting a two-year pilot period following installation
11		and commissioning of the batteries. Refer to Exhibit A-12, B5.6.1 for additional
12		detail on this pilot.
13		
14	Q63.	Can you discuss the main objectives of the C&I Battery Storage pilot?
15	A63.	Yes. The main objectives of the pilot are as follows:
16		• Engage with customers to better understand their interest in hosting and
17		potentially operating a BESS;
18		• Gain operational experience on battery installation, management, and
19		control interfaces when the system is located at a customer's site as opposed
20		to a Company site;
21		• Assess feasibility for sharing asset control between customer and the
22		Company; and
23		• Evaluate the effectiveness of the BESS to achieve system peak demand
24		reduction when a demand response event is called by the Company;

Line

1

2

3

4

5

6

- No.
- Assess customer's actions to achieve demand charge and overall bill ٠ reductions;
- Facilitate the understanding of multiple energy storage values, compensation models, and the integration of battery storage in wholesale markets to support tariff development as contemplated by the Commission's Order in MPSC Case No. U-21032.
- 7

8 Q64. Could you describe the status and progress of the C&I battery pilot?

9 A64. Both batteries have been ordered, shipped from China, and have arrived in the US. 10 The switchgear component, which has an approximate 38-week lead-time, was 11 approved in December 2023, and both switchgears were ordered on December 27, 12 2023. Hitachi will be working on the detailed design portion of the project in the 13 first quarter of 2024.

14

15 As part of the implementation plan, the Company has identified one customer. The 16 Company intends to leverage the commercial agreement developed and agreed 17 upon by the first participant as a template for the agreement between the second 18 participant. Due to lead time of major equipment, installation at the first customer's 19 site has taken longer than anticipated, although is targeted for Q2 2025. The 20 Company is confident that a second participant will be identified in partnership with 21 Company's MAS group in the first half of 2024 and that the second battery will be 22 installed shortly after the first. Once the second customer has been identified and 23 the first installation is underway, the installation of the second battery will begin. 24 The Company plans for both batteries to be operational by the end of 2025. The 25 initial proposed event schedule includes no more than 30 planned DR events per

10.		
1		year and five emergency DR events, with a least one-hour customer notice, per
2		year. However, per the order in Case No. U-21297, the Company will meet with
3		the MPSC Staff to discuss an appropriate number of required test events each year.
4		
5	Q65.	Did the Commission approve all capital costs related to the C&I battery pilot
6		in Case No. U-21297?
7	A65.	No. In Case No. U-21297, the Commission excluded approximately \$2.0 million
8		(\$1,990,360) of the capital spend on the C&I battery pilot because the Company
9		did not intend on signing up a second customer until the first battery was installed
10		and did not provide a timeline; thus, Staff did not believe that half the capital would
11		be used and useful in the projected test year. In 2022, the Company spent \$2.5
12		million in capital to procure the equipment for the C&I battery pilot which was
13		partially recovered in Case No. U-21403 2022 DR Reconciliation. The exclusion
14		included \$1.25 million related to half of the procured equipment which was spent
15		during the bridge period (2022) and \$0.75 million in forecasted test year (2023)
16		spend.
17		
18	Q66.	Does the Company believe that Staff's concern remains in this instant case?
19	A66.	No. As stated above, the Company expects to have a second customer secured in
20		the first half of 2024 with both batteries operational by the end of 2025, and as such
21		is requesting the previously excluded costs as mentioned above.
22		
23	Q67.	How much capital does the Company anticipate spending on the C&I Battery
24		pilot over the bridge period ending December 31, 2024, and the forecasted test
25		period ending December 31, 2025.

<u>NO.</u>		
1	A67.	The Company anticipates spending \$1.4 million during the bridge period to procure
2		and install equipment and \$0.6 million in the forecasted test year to primarily
3		support final installation costs. Capital spend was moved from 2023 to 2024 and
4		2025 due to lead time of major equipment critical for progression of both batteries.
5		
6	<u>Projec</u>	eted O&M
7	Q68.	How much O&M is the Company forecasting to spend in 2025 on DR?
8	A68.	The Company is forecasting to spend \$5.9 million in 2025 to support the
9		development and execution of its Demand Response Portfolio. This represents a
10		\$3.2 million increase from 2022 levels (a \$0.2 million increase to account for
11		inflation and \$3 million for specific adjustments). This can be seen on Line 9 of
12		Witness Bennett's Exhibit, A-13, Schedule C5.9.
13		
14	Q69.	How much O&M is needed to support the Company's Smart Savers Program
15		going forward?
16	A69.	The Company is projecting to grow the cumulative number of enrolled thermostats
17		from nearly 64,000 as of December 31, 2023, to more than 90,000 enrolled
18		thermostats by the end of 2025. In 2024, the Company is projecting to spend
19		approximately \$2.5 million on anniversary device fees for devices that were
20		enrolled prior to 2024. In 2024, the Company is forecasting to enroll 12,000 new
21		devices which result in additional devices fees. Beginning in 2025, the Company is
22		forecasting to spend \$3.3 million to support the Smart Savers Program. The
23		requested O&M spend is necessary to support the continued successful growth of
24		the program the Company has experienced since its inception including the annual

Line <u>No.</u> No. 1 portal fee and annual device fees, with annual devices fees increasing each year 2 based on the projected increase in enrollments. 3 4 Q70. How much O&M is the Company forecasting to spend in Pilots and Other 5 **Projects?** 6 A70. The Company is forecasting to spend \$2.6 million in O&M to support various DR 7 pilots, programs and projects. The pilots in this spend include the Smart Charge, 8 V2H, Residential Generator and the Non-Wires Alternative (NWA) efforts. 9 Programs such as the Company's CoolCurrents and SmartCurrents and the 10 replacement of the LCDs for the Interruptible Water Heating customers will also 11 be supported by O&M Spend. O&M spend for these programs and pilots supports 12 labor, marketing and communication efforts as well as portal, dispatch, program 13 incentive and platform fees. Other DR projects are included in this category as well.

14 The \$2.615 million in O&M is broken out by the various projects in Table 3.

15

16

Table 32025 Forecasted Spend

Pilot/Program/Project	Forecasted Spend
SmartCurrents	\$105,000
CoolCurrents	\$136,000
Smart Charge	\$767,000
Interruptible Water Heating	\$62,000
Residential Generator	\$161,000
Vehicle to Home	\$96,000
Non-Wires Alternative	\$18,000
Other Projects	\$1,270,000
Total	\$2,615,000

<u>No.</u>

Line

1

2

3

4

5

6

Q71. Could you describe the electric vehicle (EV) DR or Smart Charge pilot?

A71. The initial design of Smart Charge, which launched in 2019, was to assess the effectiveness of Open Vehicle Grid Integrated Platform (OVGIP) concept to integrate EV charging with grid objectives through demand response. This initial design ran until May of 2023.

7

8 After completion of the initial design, the Company, modified the focus of the pilot 9 to incorporate managed charging, starting in July 2023. One of the main reasons 10 the Company transitioned to managed charging was due to the mandatory roll out 11 of residential electric time of use (TOU) rates in March 2023. In this phase of the 12 pilot, the Company's managed charging approach ties each participant's enrollment 13 to their specific TOU rate schedule and automatically initiates charging to occur 14 during their off-peak rate period when it's the lowest cost for them and most 15 beneficial to the system. In addition, the Company is interested to learn if there's 16 an impact of the Company scheduling participant's daily charging automatically 17 through vehicle telematics and managed charging participation for them, or if EV 18 users are already scheduling their charging during off-peak time periods without 19 the Company's assistance. Refer to Exhibit A-12 B5.6.4.

20

Throughout 2023, the Company continued its partnership with Ford, General Motors (GM), and BMW through the OVGIP while adding a new partnership with WeaveGrid. WeaveGrid is a platform that connects utilities, original equipment manufacturers (OEMs), and EV drivers and is the platform that is used to enroll

- No. 1 eligible Tesla drivers into the Smart Charge pilot. The pilot will continue through 2 the end of 2024. 3 While the OVGIP is funded through the DR O&M budget, the partnership with 4 5 WeaveGrid was made available through the Emerging Technology Fund (ETF) that was approved in Case No. U-20836². The OVGIP forecasted spend will be subject 6 7 to future DR reconciliation while the spend associated with WeaveGrid will not be 8 subject to future DR reconciliations. 9 10 072. Could you describe the status and progress of the Smart Charge pilot? 11 A72. Yes. In 2019, the Company worked with Electric Power Research Institute (EPRI), 12 Sumitomo, Ford, and GM. The first phase of the pilot concluded after six months 13 in August 2019 after calling 12 events with approximately 165 Ford and GM 14 employee EV drivers. The second phase of the pilot expanded beyond automotive 15 employees to any Ford and GM drivers in the Company's service territory, 16 increasing to 370 participants. DTE Electric dispatched DR events for the eight months ending December 2021, resulting in 1.7 MWh of avoided energy 17 18 consumption during called events. 19 20 In May 2022, BMW joined the next phase with Ford and GM, which grew to 663
- participants and called 44 DR events over the 12-month period ending May 2023.
 The Company and OEMs identified an aggregate avoided energy total of 14 MWh
 across all 44 events. The DR events were all two hours in length and were called
 during different days of the week (weekdays only) and different times of the day to

² As described in Q/A 111 of Burns' Testimony (Case No. U-20836)

9

1 test customer participation levels and to understand how much avoided energy the 2 Company could expect to achieve based on the number of participants enrolled. 3 The Company observed the best avoided energy results during the 12am-2am time 4 periods, since most EV owners typically charge their EV overnight, presumably 5 due to more prevalent daytime work hours and cheaper off-peak rates. The average 6 aggregated avoided energy per enrolled EV during the 12am-2am event window 7 was 1.33 kWh. The average aggregated avoided energy per participating EV during 8 the 12am-2am event window was 9.04 kWh.

10 Beginning in July 2023, after the conclusion for the 2022/23 pilot year, the 11 Company and OEMs had to re-recruit customers. The expansion of the pilot to 12 support managed charging required a charge in terms and conditions by the OEMs. 13 As of December 31, 2023, there were 1,224 EVs enrolled in the Smart Charge pilot. 14 GM, Ford, and Tesla began enrolling customers in 2023, while BMW began 15 enrolling customers in Q1 of 2024. The Company will continue to recruit 16 customers for this pilot through 2024. Once a participant enrolls, Smart Charge 17 automatically schedules daily charging to meet their charging needs during their 18 off-peak rate times. This scheduled charging occurs on the weekdays only. The 19 Company also plans to call up to five DR events, June through September, to 20 evaluate how much demand and energy savings can be achieved.

21

Q73. Is the Company planning to make Smart Charge a program within the DR portfolio?

A73. Yes. The Company believes that the Smart Charge pilot should become part of the
Company's DR portfolio beginning in 2025. With continued allocated O&M

1		resources, along with the forecasted increased adoption of EVs, Smart Charge is
2		expected to continue expanding. Transitioning Smart Charge to a program also
3		allows for more customers to participate in the program above the current pilot
4		customer cap of 2,000. In addition, with this commitment, the Company will remain
5		at the forefront of developing technologies and continue to collaborate with
6		important OEMs within the service territory as EV adoption continues to grow.
7		
8	Q74.	How much is the Company forecasting to invest in O&M in the Smart Charge
9		Program?
10	A74.	The Company is forecasting to spend \$0.8 million to support the expansion of the
11		Smart Charge Program. The investment in Smart Charge will allow the Company
12		to transition to a program and support increased participant enrollment. The costs
13		are associated with platform fees, marketing and customer participation incentives.
14		
15	Q75.	Has the Commission and MPSC Staff been supportive of the Company's
16		efforts in pursuing a Smart Charge?
17	A75.	Yes. The MPSC Staff and Commission have supported the Smart Charge pilot in
18		several cases including the 2019 IRP (Cast No. U-20471), 2022 Electric Rate Case
19		(Case No. U-20836), 2023 Electric Rate Case (Case No. U-21297), as well the DR
20		Reconciliation Cases beginning with Case No. U-20521 filed in 2019.
21		
22	Q76.	Could you describe the vehicle-to-home (V2H) EV pilot?
23	A76.	The Company is partnering with two leading OEMs to evaluate V2H technology.
24		This pilot, as detailed in Exhibit A-12, B5.6.3, is one of the first in the country and
25		expands the DR team's EV portfolio and collaboration with leading OEMs. The

Line	
No.	

1	Company finalized a preliminary agreement in December 2023 and is targeting a
2	completed Statement of Work in the first half of 2024 that will be used as the basis
3	for this pilot. Similar to the WeaveGrid portion of Smart Charge, the funding for
4	the software components and the monthly EV fees of the participating OEMs was
5	made available through the Emerging Technology ETF that was approved in Case
6	No. U-20836 ³ . The O&M requested in this instant case will support the incentives
7	associated with customer enrollment and participation and will be funded by
8	Demand Response. The forecasted incentive spend will be subject to future DR
9	reconciliation while the spend associated with software and monthly fees will not
10	be subject to future DR reconciliations.
11	
12	Initially, the pilot is scheduled to run for 12 months after the completion of the
13	SOW. In this pilot, the Company and OEMs will manage the discharge of energy
14	from eligible EVs that are owned or leased by eligible participants. Participants
15	must be DTE Electric residential customers, with a bi-directional charging station
16	already installed at their home to allow the Company to dispatch events and
17	evaluate the feasibility, cost, and customer interest and behavior. Some of the
18	benefits of a V2H type of pilot include:
19	• Providing backup power to a home in the event of an outage or periods of
20	high strain on the electric grid;
21	• Reducing customers' electric bills by signaling the EV to use its battery
22	power during on-peak demand times when electricity from the grid is most
23	costly.
24	

³ As described in Q/A 111 of Burns' Testimony (Case No. U-20836)

1	Q77.	Can you describe the objectives of the V2H pilot?
2	A77.	Yes. The Company is initially targeting up to 400 eligible participants in its first
3		pilot year to ensure any issues (i.e., communication or signal issues) are resolved
4		prior to the potential expansion to the Company's broader electric customers with
5		eligible EV models. The Company plans to evaluate the success of the pilot as it
6		relates to:
7		• Targeting and recruitment efforts needed to enroll in this type of pilot;
8		• Determining the appropriate time and length to dispatch events based on the
9		most optimal time to charge and discharge the EV for the participant and the
10		Company;
11		• Understanding what incentive structure prompts customer participation;
12		• Determining how much demand (kW) and energy (kWh) savings the Company
13		could expect to achieve with the pilot's current participants as well as future
14		potential as additional eligible EV models are available in DTE Electric's
15		service territory;
16		• Assessing customer receptiveness and the value to the participants and the
17		Company for this type of V2H pilot;
18		• Identifying and processing new learnings that could be applied to current and
19		future DR V2H offerings; and
20		• Assess the viability of this resource acting as a year-round DR asset responding
21		on short-term notice for peak events.
22		
23	Q78.	Can you describe the residential home generator pilot?
24	A78.	Yes. The Company is conducting a residential customer-owned natural gas
25		generator pilot. The pilot leverages Generac Grid Services' platform and utilizes

Line <u>No.</u> No. 1 telemetry to shift customers' electric load to the customers' generator in real-time 2 during Company called DR events. Customers were prescreened for eligibility to 3 participate in the pilot and were targeted accordingly. One qualifier to participate 4 was, "owner has a premium or dealer managed subscription to Mobile Link." The 5 premium or dealer managed Mobile Link subscription allows the Company to 6 operate a switch-free program capable of remote operations such as responding to 7 demand response events. Through benchmarking with CMS, the Company learned 8 switch programs are more expensive due to the cost of physical LCDs and the 9 associated truck roll for the installation of the LCD. Customers have the options to 10 opt-out of up to two events per calendar year, throughout the duration of the 11 program. Events can occur on any non-holiday weekday between the hours of 8:00 12 am and 8:00 pm within any MISO season, can last no more than four hours and are 13 limited to 40 hours in total each calendar year. The pilot will conclude in December 14 2025. Refer to Exhibit A-12, B5.6.2 for details. 15 16 Q79. Can you describe the main objectives in pursuing a residential home generator

17 **pilot?**

19

20

Line

- 18 A79. Yes. The main objectives of the residential generator pilot are as follows:
 - Determine whether customers would be willing to actively participate and allow for real-time telemetry to control their generators during an event;
- Assess the viability of a pilot that can act as a year-round DR asset
 responding on short-term notice for peak events;
- Assess customer receptiveness and the value customers receive from a
 residential generator pilot; and
- Line
- No.
- Identify and process new learnings that could be applied to current and ٠ future demand response offerings.
- 3

1

2

4 Q80. Is the Commission and MPSC Staff supportive of the Company's efforts in 5 pursuing a residential home generator pilot?

6 A80. Yes. However, when the pilot was first introduced in Case No. U-20836, it was 7 argued by the MPSC Staff that the Commission should disallow the O&M spending 8 associated with the residential generator pilot as there was a concern that the pilot 9 was not well developed. The Commission ultimately agreed with the MPSC Staff. 10 Since that order, the pilot has been further developed. The Company took the 11 recommendation from Staff to benchmark with CMS on their residential generator 12 pilot and leverage their learnings and experience. In the Company's latest general 13 rate case, Case No. U-21297, both MPSC Staff and Commission supported the 14 O&M spend associated with the residential generator pilot, citing the progress the Company has made in the pilot development. 15

16

17 Could you describe the status of the residential home generator pilot? **Q81**.

18 A81. Yes. In 2023 the Company launched a 200-participant cap residential customer-19 owned natural gas generator pilot, Demand Response Home Generator Program, in 20 partnership with Generac Grid Services. Recruitment efforts began in July 2023 21 and continued through September 2023, resulting in successful enrollment of 197 customers. The Company called its first pilot event on November 28th, 2023. 22

23

<u>No.</u>

1

2

3

In 2024 the Company is considering a second phase of recruitment to target up to 200 additional participants. This second phase of recruitment would provide the opportunity to offer the pilot to a larger subset of different customers.

4

5 Q82. Are there Other DR Projects that are included in the Pilots and Other Projects 6 Category?

7 A82. Yes. Other DR projects include initiatives that may not necessarily be tied to a 8 specific program or a pilot. The Company plans to set up a dedicated DR call and 9 is exploring partnering with an external party to do so. With a dedicated call center, 10 representatives will be specially trained to inform customers of DR program 11 offerings and benefits and answer customer inquiries on DR programs improving 12 their experience. In addition, the Company is considering partnering with a third-13 party evaluator to measure the performance of its DR portfolio. This partnership 14 will look at the portfolio holistically and potentially identify improvements to its 15 DR programs. The Pilots and Other Projects category also includes necessary costs 16 to support the competitive DR procurement process that was agreed to in the IRP 17 settlement in Case No. U-21193.

18

Q83. Can you explain the competitive DR procurement that was part of the settlement of Case No. U-21193?

A83. Yes. In the settlement of the Company's 2022 IRP, DTE Electric agreed to procure
DR-related MISO Zonal Resource Credits (ZRCs) through a competitive bidding
process. Specifically, the Company agreed to issue two 25 MW solicitations, one
for the 2025/26 Planning Year (PY) and one for the 2026/2027 PY as well as a 100
MW solicitation for the 2027/28 PY. The Company plans to spend O&M to contract

Line <u>No.</u>		K. O. FARRELL U-21534
1		with a third-party to assist the Company with developing and supporting the
2		procurement process. The O&M to support this DR procurement effort is expected
3		to be spent in 2024 through 2027.
4		
5	Q84.	Can you summarize the Capital and O&M investment amounts for the
6		Company's DR Portfolio?
7	A84.	Yes. The Company is forecasting to invest \$17.4 million in capital during the bridge
8		period beginning January 1, 2023, and ending December 31, 2024, and investing
9		\$4.4 million in capital during the forecasted test period ending December 31, 2025.
10		In addition, the Company forecasts O&M spend of \$5.9 million. This overall level
11		of investment will support the Company's current program offerings such as
12		CoolCurrents, Smart Savers, SmartCurrents, and Smart Charge as well as allow the
13		Company to conduct and evaluate pilots to determine if they can become a valuable
14		resource within the portfolio. This spend also supports other DR related projects.
15		
16	Forec:	asted MWs
17	Q85.	What are the forecasted MWs in the DR portfolio as a result of continued
18		investment in the programs and pilots?
19	A85.	The Company is forecasting a decrease in the portfolio from 786 MWs in 2022 to
20		712 MWs in the 2025/2026 PY as shown in Table 4. The primary drivers of the
21		projected decrease are the CoolCurrents program and the C&I tariffs. The
22		Company has reduced the MWs associated with the CoolCurrents program to more
23		appropriately reflect the customers who can be successfully interrupted. In addition,
24		the MWs associated with the C&I tariffs was reduced to reflect current customers
25		and their associated operations. This decrease is offset by additional MWs

KOF-43

Line No.

> 1 associated with the Smart Savers program primarily due to increased participants 2 in the program. The Company also recognizes that as MISO continues to explore 3 short-term and long-term accreditation changes there will likely be impacts to the 4 amount of MWs available in the Company's DR Portfolio. The Company is 5 committed to continued growth of the portfolio and prudent spending to assure the 6 Company and its customers are receiving the maximum benefits of demand 7 response. However, the Company will need to remain flexible and understands that 8 the changing customer preferences and evolving DR landscape can change the MW 9 makeup of the portfolio.

10

Program	Projected 2025 MWs
Smart Savers	108
SmartCurrents	48
CoolCurrents	130
Legacy Tariffs ⁴	345
Rider 12	56
DR Procurement	25
Total	712

Table 4 Projected 2025/2026 PY MWs (ICAP)

11

12 Part V: Evolving DR Landscape

13 Q86. What changes has MISO implemented or are being proposed?

14 A86. Beginning with the planning resource auction (PRA) for the 2023/24 PY, MISO

15 changed its resource adequacy construct from an annual to a seasonal format. The

16 premise of the construct, where MISO establishes a planning requirement to serve

⁴ Includes D3.3, D8, R1.1, R1.2 and R10

1		load during peak times, and this requirement is fulfilled with resources accredited
2		based on performance, remain unchanged. However, with the change to a seasonal
3		construct, MISO has moved from setting a single annual planning requirement and
4		accrediting resources with a yearly value, to establishing a planning requirement
5		and assigning accreditation to resources for each season (spring, summer, fall and
6		winter). Lastly, MISO is exploring various short-term and long-term accreditation
7		and registration changes for LMRs.
8		
9	Q87.	Could you describe the seasonal construct that MISO implemented?
10	A87.	Yes. MISO implemented a seasonal construct where capacity is valued differently
11		in each MISO Season and resources are accredited based on the capacity value and
12		performance of that resource in each season. The MISO Seasons are as follows:
13		• Summer: June, July, August
14		• Fall: September, October, November
15		• Winter: December, January, February
16		• Spring: March, April, May
17		
18	Q88.	Has the Company made any changes to its DR portfolio in response to the
19		seasonal capacity construct?
20	A88.	Yes. The Company is focused on pilots that can be available year-round and is
21		evaluating what changes, where appropriate, could be made to programs in its
22		current portfolio to expand their availability to other seasons.
23		
24	Q89.	What short-term accreditation and registration changes is MISO exploring?

1	A89.	On a short-term basis, MISO is exploring accrediting LMRs based on actual historic
2		availability. MISO is also exploring enhancing the auditability of its LMR
3		availability data by asking for more frequent MISO data submittals from market
4		participants. It is important to note that while MISO is considering making these
5		changes, no tariff changes have been made and nothing has been filed with the
6		Federal Energy Regulatory Commission (FERC) as of this filing.
7		
8	Q90.	What long-term accreditation and registration changes is MISO exploring?
9	A90.	The long-term change that MISO is exploring is separating LMRs into emergency
10		only and non-emergency categories. MISO is currently indicating that emergency
11		only LMRs would require a 30-minute lead time for notification and non-
12		emergency LMRs would have to participate in the energy market, but this proposal
13		is subject to change as it moves through the MISO stakeholder process. Currently
14		the Company's LMRs do not participate in the energy market. Much like the short-
15		term accreditation and registration changes, no tariff changes have been made and
16		nothing has been field with FERC to date.
17		
18	Q91.	What is the Company doing to prepare for potential MISO changes that may
19		impact its DR portfolio?
20	A91.	The Company will continue to keep abreast of these proposals through stakeholder
21		meetings and will remain flexible when it comes to its DR Portfolio, understanding
22		that these changes, if filed and approved, could change the way the Company
23		manages and designs its DR Portfolio. As these proposals become better understood
24		and possibly implemented, the Company will include in future DR filings any
25		potential impacts to the Company's DR Portfolio. In addition, the Company will

KOF-46

1 examine the potential to adjust current programs, where possible, to provide 2 capacity for additional seasons beyond summer. The Company will also evaluate 3 the likely LMR accreditation changes and determine if any program adjustments, 4 such as number of events or event timing, would improve the capacity credit of its 5 programs. Continued investment in DR is important to ensure the Company can 6 make quick decisions regarding its programs and pilots and can, where possible, 7 position the Company and its customers the best possible outcome as changes occur 8 as DR resources continue to be valuable resources within MISO's capacity 9 construct.

10

11 Part VI: DTE Insight Program

12 Q92. Can you please describe the DTE Insight program?

13 A92. Yes. DTE Insight is a comprehensive program that centers on a mobile application 14 (DTE Insight App) integrated with the Advanced Metering Infrastructure (AMI) to 15 help residential customers monitor and manage their energy use. Customers using 16 the DTE Insight mobile application view their prior day's energy usage on an hour-17 by-hour basis, allowing customers to assess how recent weather and activities can 18 impact their home energy usage. Customers can combine the DTE Insight App with 19 an Energy Bridge (EB) device and obtain real-time energy information and manage 20 connected smart devices.

21

Q93. How has the Company been developing and implementing the DTE Insight program since its inception?

A93. The Company has been investing in the DTE Insight program, including the
additional offering of EB devices, since 2014. In 2018, the Company enhanced the

Line
No.

1		program into a more robust platform, including both an updated application and an
2		improved EB device. Starting in 2019, the Company began offering a combination
3		of smart home features to all DTE Insight customers with the EB. With the
4		expanded functionality of the EB device, participating customers can also control
5		other connected smart devices (i.e., thermostats, lightbulbs, switches, plugs, and
6		outlets). These smart devices can report energy consumption to the users and allow
7		the users to set activities-based rules. DTE Insight is a program that aims at driving
8		customer behavior with the goals of reducing both overall energy (gas and
9		electricity) consumption and electricity demand at peak hours.
10		
11	Q94.	Has the Commission been supportive of the DTE Insight program?
12	A94.	Yes. The Commission approved expenditures for this program in Case Nos. U-
13		18255, U-20162, U-20561, and U-20836.
14		
15	Q95.	Did the Commission approve all capital costs related to the DTE Insight
16		program in Case No. U-21297?
17	A95.	No. The Commission disallowed \$1.4 million of 2022, \$0.7 million for 2023 and
18		\$0.6 million for 2024.
19		
20	Q96.	What was the Commission's reason for not approving the DTE Insight
21		capital?
22	A96.	The Commission agreed with the ALJ and Staff. "The Staff argued that capital
23		expenditures for this program should be fully disallowed based on low engagement
24		and participation in a nine-year-old program that the company began investing in
25		in 2014. In this regard, the Staff averred that DTE Electric should boost engagement

Line <u>No.</u>		K. O. FARRELL U-21534
1		and participation in the application and in the use of EB devices before investing
2		more money into the program." (U-21297 order, page 141)
3		
4	Q97.	Are you seeking recovery of the capital costs in this proceeding?
5	A97.	Yes.
6		
7	Q98.	What has changed since the prior case to address the Commission and Staff's
8		concerns with the DTE Insight capital?
9	A98.	Unlike the prior case, the Company is not seeking recovery of capital costs related
10		to additional energy bridges or expansion of the program. Additionally, in the prior
11		case, "the Staff averred that DTE Electric should boost engagement and
12		participation in the application and in the use of EB devices before investing more
13		money into the program." (U-21297 order, page 141). As reported in Table 5
14		below, in the 12 months between December 31, 2022, to December 31, 2023, the
15		DTE Insight program saw an increase of over 110,000 in authenticated household
16		downloads and over 18,000 authenticated household with energy bridges. The 47%
17		and 48% increase in these metrics shows customers continue to gravitate to the
18		DTE Insight Program. To keep the program available for existing customers, the
19		Company is seeking to recover costs related to app maintenance, software licensing,
20		and customer support.
21		
22	Q99.	What are the most updated metrics regarding the development and
23		implementation of the DTE Insight program?
24	A99.	The Company has been focusing on increased EB utilization rate and increased
25		customer participation and engagement while it has continued the development and

KOF-49

Line No.			K. O. FARRELL U-21534	
1	implementation of the overall DTE Insight program. As shown in Table 5 below,			
2	the following metrics reflect the co	ontinuous and increasi	ng customer engagement	
3 4	and participation in the program:			
5 6	Table 5	5 – DTE Insight Metr	rics	
		Cumulative Data as of Dec 31, 2022	Cumulative Data as of Dec 31, 2023	
Αι	thenticated Household Downloads	233,384	343,461	
1	Authenticated Household Energy Bridges	38,093	56,519	
9 10 A100. 11 12 13 14 15 16 17 18	 Q100. What are the Company's planned efforts with respect to the DTE Insight program? A100. The DTE Insight program continues to evolve from providing simple usage data to delivering actionable communications and educational content to its users. Not only does the DTE Insight App provide energy data visualization and coaching, but it also provides a comprehensive customer experience hub for energy insights, intelligence, and automations. While the DTE Insight program has been primarily utilized by energy waste reduction (EWR) customers, DTE Insight has the potential to become an effective educational tool for customers in other Company programs such as Advanced Customer Pricing Pilot, MIGreenPower, and Charging Forward. With the increasing interest, the Company expects the number of DTE Insight App 			
	With the increasing interest, the Co	ompany expects the nur	nber of DTE Insight App	

Q101. How much is the Company forecasting to invest in the DTE Insight program during the bridge period of January 2023 through December 2024, and in the projected test year ending December 31, 2025?

4 A101. The Company is forecasting to invest \$1.4 million in capital expenditures during 5 the bridge period of January 1, 2023, through December 31, 2024, and \$1.6 million 6 in capital expenditures for the projected test year from January 1, 2025, through 7 December 31, 2025. The Company is requesting this level of investment as it is 8 necessary to complete the plans described above, which include continued 9 enhancement of the customer experience in the use of the program as an educational 10 tool to support the growing participation from customers in other Company 11 programs mentioned above. Examples of expenditures include ongoing app 12 maintenance, software licensing, and phone and field technical support for customers. The associated projected capital expenditures are shown in Exhibit A-13 14 12, Schedule B5.6, page 1 of 2, line 5, column (c) through (f).

15

Q102. Is the DTE Insight program included as part of the Company's DR programs and pilots and subject to the three-phase framework?

A102. No. The DTE Insight program is not subject to the evaluation and assessment
 established by the DR three-phase framework. General rate cases remain the
 appropriate regulatory proceedings for the Commission to evaluate the Company's
 proposed execution work and associated capital expenditures for the DTE Insight
 program. Therefore, the Insight program is not subject to future DR reconciliation.

23

24 Q103. Does this complete your direct testimony?

A103. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)
its rate schedules and rules governing the distribution and supply of electric energy, and for miscellaneous accounting authority.)) _)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

NEAL T. FOLEY

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF NEAL T. FOLEY

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Neal T. Foley (he/him/his). My business address is One Energy Plaza,
3		Detroit, Michigan 48226. I am employed by DTE Energy Corporate Services, LLC,
4		a subsidiary of DTE Energy Company as Director, Regulatory Affairs.
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric or Company).
8		
9	Q3.	What is your educational background?
10	A3.	I received a Bachelor of Science in Aerospace Engineering and a Bachelor of
11		Science in Mechanical Engineering from the University of Michigan. I also
12		received a Master of Science in Systems Engineering from Johns Hopkins
13		University and a Master of Business Administration from Georgetown University.
14		
15	Q4.	What is your work experience?
16	A4.	In 2007 I was employed by Lockheed Martin Corporation as a Satellite Operations
17		Engineer. In 2008, I was hired by Booz Allen Hamilton as an Associate Consultant
18		in its Federal consulting practice. In 2012, I was hired by Deloitte as a Manager of
19		Financial Analysis in its Federal consulting practice. In 2014, I was hired by
20		McKinsey & Company as an Associate Consultant, ultimately being promoted to
21		Engagement Manager before my departure in 2017. In 2017 I was hired by DTE
22		Energy Company as Manager of Corporate Strategy. In this role I was broadly
23		responsible for tracking and assessing utility industry trends, executing analyses to
24		better understand the economic impacts of emerging technologies and business

Line		1	N. T. FOLEY U-21534
<u>No.</u>			
1		models, and leading strategic initiatives for the Company. I was pro-	omoted to my
2		current role as Director of Regulatory Affairs in 2020.	
3			
4	Q5.	What are your current duties and responsibilities?	
5	A5.	My responsibilities broadly include the management of regulat	ory activities
6		relative to DTE Electric's Load Research, Tariffs, Pricing, and Rate	Design.
7			
8	Q6.	Have you previously sponsored testimony before the Michigan P	ublic Service
9		Commission (MPSC or Commission)?	
10	A6.	Yes. I have sponsored testimony in the following cases:	
11		U-20836 DTE 2022 Electric Rate Case	
12		U-21376 DTE 2023 Distributed Generation Tariff Options	
13		U-21297 DTE 2023 Electric Rate Case	

1	<u>Purpose of Testimony</u>			
2	Q7.	What is the purpo	se of your testimony	in this proceeding?
3	A7.	The purpose of my	testimony is twofold:	
4		• Describe an	d support the key con	nponents of a proposal that the Company
5		is putting f	forth in this case re	elated to the scope and duration of its
6		Distribution	Infrastructure Reco	overy Mechanism (Distribution IRM or
7		IRM)		
8		• Describe an	d support the key con	nponents of a proposal that the Company
9		is putting fo	orth in this case to es	tablish a Storm Restoration Cost Sharing
10		Mechanism (SRCSM).		
11				
12	Q8.	Are you sponsoring any exhibits in this proceeding?		
13	A8.	Yes. I am sponsorir	g the following exhi	bit:
14		<u>Exhibit</u>	Schedule	Description
15		A-33	X1	Distribution IRM Proposed
16				Investment and In-Service Levels
17				
18	Q9.	Was this exhibit p	repared by you or u	nder your direction?
19	A9.	Yes, it was.		
20				
21	<u>Distri</u>	ibution IRM		
22	Q10.	Can you please su	mmarize the history	of the Company's current Distribution
23		IRM?		
24	A10.	Yes. In Case No.	U-21297 the Com	pany proposed the establishment of a
25		Distribution IRM th	nat would be effective	e starting concurrent with the forward test

Line <u>No.</u>	U-21534
1	year in that case (i.e., December 1, 2023) and ending after roughly three years at
2	the end of 2026. More specifically, the Company proposed the following IRM Plan
3	Years:
4	• IRM Plan Year 1: December 1, 2023 to December 31, 2024
5	• IRM Plan Year 2: January 1, 2025 to December 31, 2025
6	• IRM Plan Year 3: January 1, 2026 to December 31, 2026
7	
8	The Company proposed that IRM treatment be authorized for the following five
9	capital programs focused on safety and reliability:
10	• Conversions
11	Subtransmission Redesign & Rebuild
12	Breaker Replacement
13	• Underground Residential Distribution (URD) Replacement
14	• 4.8 kV Circuit Automation
15	
16	For each capital program and IRM Plan Year, the Company proposed investment
17	levels with associated maximum in-service amounts that would be authorized for
18	IRM treatment. Based on these investment and in-service amounts, the Company
19	proposed an IRM revenue requirement and associated IRM surcharges for each
20	IRM Plan Year. Importantly, the Company proposed that if it were to invest and
21	place into service less capital than authorized, it would trigger a credit to customers.
22	If the Company were to invest and place into service more capital than authorized,
23	it could seek recovery of the additional investment in a future general rate case.
24	
25	Finally, the Company proposed two new stakeholder processes:

1	• IRM Planning Process occurring before the start of each IRM Plan Year
2	whereby the Company would make its investment plans for the upcoming
3	IRM Plan Year available to Staff, such that Staff could raise any questions
4	or concerns before execution of the investment plan. The investment plans
5	would be submitted to Staff no later than two months prior to the start of
6	each IRM Plan Year.
7	• IRM Reconciliation Process occurring after the conclusion of each IRM
8	Plan Year whereby the Company would describe its actual investments,
9	report its performance against a series of program execution metrics, and
10	calculate any over-recovery to be returned to customers based on actual
11	investment and plant in-service.
12	
13	In its proposal the Company highlighted four benefits that would be immediately
14	realized with the establishment of the IRM; specifically:
15	• Certainty of investment in key distribution capital programs;
16	• Greater transparency into both the Company's investment plans and its
17	execution of those plans;
18	• Additional opportunities for Staff to review and provide input on the
19	Company's investment plans; and
20	• Increased accountability for the Company through the reporting of new
21	program execution metrics.
22	
23	Further, the Company highlighted that a potential future benefit of the IRM is to
24	extend the time between contested rate cases.

Line

<u>No.</u>

Line
No.

1	In its December 1, 2023 order in that case (December 2023 Order), the Commission
2	stated that it "finds that there is value in the company's proposal, with some
3	limitations." (page 289). As such, it elected to approve the Company's proposed
4	IRM with modifications. Specifically, the Commission ordered the following
5	modifications to the Company's proposal:
6	• The Company shall submit its annual IRM Investment Plan no later than
7	four months prior to the start of each IRM Plan Year and it shall be
8	submitted to all intervening parties in the Company's most recently filed
9	general rate case.
10	• The Company shall schedule and provide a forum, no later than two months
11	before the start of the IRM plan year, for Staff and intervening parties to
12	raise any questions or concerns that they have before execution of the plan
13	begins.
14	• The annual IRM reconciliation shall be filed as a contested case proceeding,
15	noting that:
16	"a contested reconciliation process will provide additional opportunities
17	for input from interested parties. Further, developing a record in a
18	contested proceeding will provide even greater transparency and
19	opportunity for review of the reasonableness and prudence of the
20	company's expenditures, as well as accept input to address equity concerns
21	such as those raised by the DAAOs to avoid racialized disparities in
22	service." (page 290)
23	• The Company shall remove any allocation of IRM costs from transmission

		N. T. FOLEY
Line <u>No.</u>		U-21534
1		Finally, the Commission elected to approve only IRM Plan years 1 and 2. In
2		declining to approve the Company's proposed IRM Plan Year 3, the Commission
3		provided the following guidance:
4		
5		"there is ongoing discussion regarding [Performance Based Ratemaking] in
6		Case No. U-21400 and an ongoing audit in Case No. U-21305. Therefore, the
7		Commission finds that limiting the approval to the first two years will allow the
8		company to move forward with the IRM without precluding the incorporation
9		of any potential insights gained from those proceedings to better inform the
10		potential continuation of the IRM." (page 289)
11		
12	Q11.	What is the current status of the Company's Distribution IRM?
13	A11.	As discussed above, the Commission's December 2023 Order established the IRM
14		effective starting on December 1, 2023 (with surcharges being implemented on
15		December 15, 2023). In that Order, the Commission acknowledged the challenged
16		timing of IRM Plan Year 1, stating:
17		
18		"Regarding the time constraints for the first investment recovery mechanism
19		plan year recognized in this order, the company shall use best efforts to provide
20		its investment recovery mechanism plan as soon as practicable that will in turn,
21		allow the company to schedule the forum as soon as practicable." (page 375)
22		
23		As such, the Company submitted its IRM Year 1 Investment Plan to stakeholders
24		on February 7, 2024, and subsequently presented the plan during a stakeholder
25		forum on February 23, 2024.

1	Q12.	What is the Company proposing in this case related to its Distribution IRM?
2	A12.	The Company is proposing to extend the IRM through calendar years 2026 and
3		2027. The Company's proposal does not include any modifications to what was
4		previously approved for 2024 and 2025, although it does offer an alternative
5		scenario for 2025 that would increase the amount of capital authorized for IRM
6		treatment during that year, as described later in my testimony.
7		
8		As part of the extension, the Company is proposing two adjustments to the capital
9		programs previously authorized for IRM treatment. Specifically, the Company is
10		proposing:
11		• Starting in 2026, Pole and Pole Top Maintenance and Modernization
12		(PTMM) be authorized for IRM treatment. Company Witness Elliott
13		Andahazy provides additional support for this proposed modification in her
14		testimony; and
15		• Starting in 2026, the scope of the automation program be modified from
16		"4.8 kV Circuit Automation" to "Distribution Automation." Company
17		Witness Hartwick provides additional support for this proposed
18		modification in her testimony.
19		
20		For 2026 and 2027, the Company is proposing a level of capital investment and
21		maximum in-servicing amount for each program and year. The full detail of the
22		Company's proposed investment and in-service levels for 2026 and 2027 is
23		captured in Exhibit A 33, Schedule X1, and is summarized in Table 1 below.

Line <u>No.</u> 1

	Previously Approved Investment		Proposed Investment	
Capital Program	2024	2025	2026	2027
Conversions	1.6	185.8	190.0	240.0
Subtransmission Redesign & Rebuild	5.5	53.8	55.0	65.0
Breaker Replacement	13.7	12.6	15.0	15.0
URD Replacement	14.6	13.5	15.0	20.0
Distribution Automation ¹	26.4	24.4	105.0	180.0
Pole & Pole Top Maintenance & Modernization	n/a	n/a	150.0	200.0
Total	61.9	290.1	530.0	720.0

Table 1 – Proposed IRM Investment Levels (\$M)

2

3

4

5

6

The Company is not proposing any modifications to the annual planning process, annual reconciliation process, or underlying mechanics of the Distribution IRM approved by the Commission through its December 2023 Order.

In their testimony, Company Witness Vangilder supports the revenue requirement
associated with the Company's proposed IRM investments, Company Witness
Maroun supports the cost-of-service treatment, and Company Witness Willis
supports the rate design of the surcharges to collect the allocated revenue
requirement.

¹ Previously 4.8 kV Circuit Automation

Line <u>No.</u>		N. T. FOLEY U-21534
1	Q13.	How is the Company's proposed extension in this case different than the 2026
2		IRM investment proposed in Case No. U-21297?
3	A13.	In Case No. U-21297, the Company proposed 2026 IRM investment of \$532.7
4		million, including the following program-specific investments:
5		• Conversions: \$371.6 million
6		• Subtransmission Redesign & Rebuild: \$107.6 million
7		• Breaker Replacement: \$14.0 million
8		• URD Replacement: \$15.0 million
9		• 4.8 kV Circuit Automation: \$24.4 million
10		
11		In the current case, the Company's proposed total investment for 2026 is similar at
12		\$530.0 million, although the investment mix is different. More specifically, the
13		Company's proposal in this case reflects increasing emphasis on Distribution
14		Automation and PTMM for the IRM. Company Witnesses Hartwick and Elliott
15		Andahazy further support the increasing emphasis on these programs in their
16		testimonies.
17		
18	Q14.	Are there other issues before the Commission that impacted the Company's
19		decision to propose an extension of its Distribution IRM?
20	A14.	Yes. The Company is proposing an extension of its Distribution IRM to ensure its
21		continued and efficient operation while pending Case No. U-21400 related to
22		Performance Based Ratemaking (PBR) and pending Case No. U-21305 related to
23		the Company's Distribution System Audit can progress and ultimately conclude.
24		Absent an extension granted in this case, the existing IRM will cease at the end of
25		2025 and could only be re-established through a Commission order in a future case.

1	Such stopping and restarting of the IRM and its associated processes could lead to
2	inefficiencies and reduce the ability to improve upon the process through
3	stakeholder feedback. Importantly, the proposed extension will ensure that the
4	customer and stakeholder benefits realized through the IRM do not lapse.
5	
6	With that said, the Company also acknowledges the Commission's desire for future
7	iterations of the IRM to potentially incorporate the findings of pending Case No.
8	U-21400 related to PBR and pending Case No. U-21305 related to the Company's
9	Distribution System Audit. The Company supports the Commission's desire to
10	incorporate findings from these cases into future iterations of the IRM as discussed
11	later in my testimony.
12	
13	At the same time, to make the IRM successful there must be robust, transparent,
14	and repeatable processes in place that give all stakeholders confidence that the IRM
15	is working as planned and the intended benefits are being realized. Given that many
16	of these processes are new, including the IRM planning and reconciliation
17	processes, having the IRM and its associated processes lapse at the end of 2025
18	would challenge the ability of stakeholders to gain experience with the IRM and
19	identify opportunities for improvement.
20	
21	For example, absent an extension approved in the current case, the Company will
22	not submit an IRM Investment Plan for 2026 (otherwise due no later than August
23	31, 2025) or hold a stakeholder forum on its 2026 plans since the IRM will not yet
24	have been authorized for 2026.

Line <u>No.</u>		U-21534
1		As such, an extension is appropriate to avoid a lapse in the IRM and its associated
2		benefits, while allowing for the cases related to PBR and the Company's
3		Distribution System Audit to conclude.
4		
5	Q15.	What is the status of Case No. U-21400 related to PBR?
6	A15.	In its April 24, 2023 Order in Case No. U-21400 (April 24 Order), the Commission
7		directed Staff to convene a Financial Incentives and Disincentives Workgroup to
8		study PBR and to file a report of the workgroup's investigations and findings by
9		December 31, 2023. Among other things, the Commission directed that:
10		
11		"an initial focus of the Financial Incentives and Disincentives workgroup
12		shall include developing appropriate metrics relating to reliability including,
13		but not limited to, SAIDI (including and excluding MEDs), SAIFI, CEMI,
14		CAIDI, and resilience, including, but not limited to, downed wire response and
15		the frequency and duration of outages during extreme weather, and shall use
16		the recently updated Service Quality rules as a baseline." (page 12)
17		
18		and
19		
20		"After developing metrics around distribution performance, the workgroup
21		shall explore rate structures and the methods by which incentives and
22		disincentives may be applied. " (page 12)
23		
24		In its August 23, 2023 Order in the same case, the Commission released its initial
25		PBR straw proposal and invited comments from interested stakeholders to be

T in a	N. T. FOLEY
Line <u>No.</u>	0-21554
1	submitted by September 22, 2023 with reply comments to be submitted by October
2	20, 2023. The Commission also directed Staff to convene a stakeholder session
3	following the initial comment period to discuss the straw proposal and alternative
4	approaches.
5	
6	In response, the Company submitted initial comments on September 22, 2023 and
7	reply comments on October 20, 2023. The Company also participated in the
8	stakeholder session that was held on October 10, 2023, including presenting its
9	perspectives related to the initial straw proposal.
10	
11	On November 29, 2023, the Commission released a revised straw proposal and held
12	a stakeholder session on November 30, 2023 to discuss the revised proposal and
13	gather any initial feedback from attendees. The Company attended the November
14	30, 2023 stakeholder session.
15	
16	On December 19, 2023 Staff filed in the same docket its status report required by
17	the Commission's April 24 Order. In its report Staff recommended that the
18	Commission formally invite comments on its revised straw proposal and indicated
19	it would hold an additional stakeholder session on February 12, 2024.
20	
21	In its December 21, 2023 Order in the same case, the Commission adopted the
22	Staff's recommendation and invited comments from interested stakeholders on the
23	revised straw proposal to be submitted by February 2, 2024 with reply comments
24	to be submitted by March 1, 2024. The Commission further directed Staff to submit

.		N. T. FOLEY
Line <u>No.</u>		U-21534
1		a status report on the workgroup's investigations and findings no later than May 3,
2		2024.
3		
4		In response, the Company submitted comments on the revised straw proposal on
5		February 2, 2024, participated in the stakeholder session on February 12, 2024, and
6		submitted reply comments on March 1, 2024.
7		
8		At the time of this filing, the Company is awaiting the release of Staff's second
9		status report and any additional guidance from a Commission order in the case.
10		
11	Q16.	How is the Company planning to incorporate the findings from Case No. U-
12		21400 into potential future iterations of its Distribution IRM?
13	A16.	If an order in Case No. U-21400 is received in mid-2024, and barring any future
14		guidance from the Commission to the contrary, the Company plans to propose a
15		PBR mechanism in its first general rate case after the current case. Given that IRM
16		proposals are made during general rate cases, the Company believes that a general
17		rate case is the most appropriate venue to establish PBR such that it can be
18		considered together with a potential future IRM proposal. In that rate case filing,
19		the Company could address how a potential future IRM proposal is informed and/or
20		complimented by an application of PBR.
21		
22		This approach is consistent with Staff's December 19, 2023 status report in which
23		it stated:

Line <u>No.</u>		N. T. FOLEY U-21534
1		"This revised proposal anticipates that a contested case proceeding would
2		follow this workgroup process. The final decision in the contested case would
3		implement performance metrics for each utility. " (page 6)
4		
5	Q17.	What is the status of Case No. U-21305 related to the Company's Distribution
6		System Audit?
7	A17.	The Distribution System Audit was formally launched in August 2023 with the
8		awarding of a contract to Liberty Consulting Group for the comprehensive
9		independent audit of Consumers Energy and DTE Electric.
10		
11		On December 20, 2023, The Liberty Consulting Group submitted its "Utility
12		Distribution Audit Status Report" in compliance with the terms of its contract. The
13		report summarized its progress to date on the audits of Consumers Energy and DTE
14		Electric but did not include any preliminary findings or recommendations.
15		
16		At the time of the filing of this case, the audit is ongoing. A final report is expected
17		in late summer or early fall of 2024.
18		
19	Q18.	How is the Company planning to incorporate the findings from Case No. U-
20		21305 into potential future iterations of its Distribution IRM?
21	A18.	The Company anticipates that at the conclusion of the Distribution System Audit
22		there will be a series of recommendations from Liberty Consulting Group. The
23		Company plans to carefully consider these recommendations and, as determined
24		appropriate by the Company, incorporate them into future Distribution Grid Plans
25		(DGPs) and capital investment plans.

1		Likewise, future IRM proposals would incorporate the recommendations from the
2		Distribution System Audit where appropriate. For example, while the Company
3		cannot predict what those recommendations will be, it is possible that the Company
4		may propose changes to either the programs or the investment levels authorized for
5		IRM treatment based on Liberty Consulting Group's findings.
6		
7		If a final report is submitted by Liberty Consulting Group in late summer or early
8		fall of 2024, the Company anticipates that there would be sufficient time to
9		incorporate the recommendations from the audit where appropriate into an IRM
10		proposal in the first rate case filed after the current rate case.
11		
12	Q19.	Given the timing of these other proceedings, why is the Company proposing a
13		two-year extension of the IRM?
14	A19.	The Company believes a two-year extension is most appropriate to (1) avoid a lapse
15		in the IRM and its associated benefits, (2) provide greater certainty related to use
16		of the IRM as a regulatory mechanism, and (3) maintain the ability to incorporate
17		findings from the pending cases related to PBR and the Distribution System Audit
18		into future iterations of the IRM.
19		
20		While a one-year extension would likely allow the pending cases related to PBR
21		and the Distribution System Audit to conclude, it would also create additional
22		uncertainty as to the long-term disposition of the IRM. As discussed previously, to
23		make the IRM successful there must be robust, transparent, and repeatable

25 planned and the intended benefits are being realized. Uncertainty related to the

ne U-21534
1 ongoing use of the IRM challenges the establishment and evolution of the IRM and
2 its associated processes as stakeholders cannot effectively plan for its long-term
3 use.
4
5 Q20. In addition to the proposal described above, would the Company support an
6 increase in the amount of capital authorized for IRM treatment in 2025?
7 A20. Yes. As described previously, the Company's proposed IRM extension does no
8 impact the authorization for IRM treatment previously granted by the Commission
9 for 2024 and 2025.
.0
1 However, increasing the amount of capital authorized for IRM treatment in 2023
2 would also increase the benefits associated with the IRM. For example, increasing
3 the amount of capital authorized for IRM treatment will also increase the certainty
4 of investment of this incremental IRM capital for its intended purpose, with any
5 under-investment triggering a refund to customers.
.6
As such, the Company would support increasing the amount of capital authorized
8 for IRM treatment in 2025 beyond what was previously authorized as a way to also
9 increase the benefits associated with the IRM. If the Commission were to find such
an approach appropriate, the Company's request for recovery of 2025 capita
expenditures through base rates could be reduced by an amount equal to the
22 additional IRM authorization.
23

1	Q21.	Has the Company identified investments it believes would be appropriate for
2		IRM treatment if the Commission were to expand IRM authorization beyond
3		what was previously approved for 2025?
4	A21.	Yes. The Company has identified four areas of capital investment it believes are
5		appropriate for IRM authorization in 2025 (beyond what was previously
6		authorized):
7		• Distribution Automation - \$125.6 million of proposed 2025 investment ²
8		• PTMM - \$121.0 million of proposed 2025 investment ³
9		• 4.8 kV Hardening - \$125.0 million of proposed 2025 investment ⁴
10		• Frequent Outage Program (CEMI) - \$62.5 million of proposed 2025
11		investment ⁵
12		
13		As mentioned above, if the Commission were to authorize, either in full or in part,
14		the above capital programs and investment amounts for IRM treatment in 2025,
15		that capital could be removed from the Company's base rate recovery request.
16		
17	<u>Storm</u>	n Restoration Cost Sharing Mechanism (SRCSM)
18	Q22.	How are storm restoration O&M costs currently projected and recovered?
19	A22.	Company Witness Kryscynski supports the calculation of projected storm
20		restoration O&M expenses in his testimony and Exhibit A-13, Schedule C5.6, Page
21		2 of 2, Lines 1-8.

² Company Witness Hartwick (Exhibit A-12, Schedule B5.4, Page 17 of 26, Line 2); this represents automation investment beyond what was previously approved for IRM treatment for 2025

 ³ Company Witness Elliott Andahazy (Exhibit A-12, Schedule B5.4, Page 13 of 26, Line 13)
 ⁴ Company Witness Elliott Andahazy (Exhibit A-12, Schedule B5.4, Page 13 of 26, Line 12)
 ⁵ Company Witness Elliott Andahazy (Exhibit A-12, Schedule B5.4, Page 13 of 26, Line 15)

1		As described by Company Witness Kryscynski, projected storm restoration O&M
2		expenses are based on a five-year trailing average (i.e., historical test period and
3		preceding four years), adjusted for inflation. Based on the five-year trailing average
4		methodology, for the forward test period in this case, the Company is projecting
5		\$64.5M of storm restoration O&M expenses. These projected expenses are
6		proposed to be recovered though base rates as they have been historically.
7		
8	Q23.	Does the Company have any concerns with the current method for storm
9		restoration O&M expense recovery?
9 10	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not
9 10 11	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not address the uncertainty and variability of these expenses in any given year and
9 10 11 12	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not address the uncertainty and variability of these expenses in any given year and therefore puts both customers and the Company at risk of either over-recovering or
9 10 11 12 13	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not address the uncertainty and variability of these expenses in any given year and therefore puts both customers and the Company at risk of either over-recovering or under-recovering storm restoration O&M costs.
9 10 11 12 13 14	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not address the uncertainty and variability of these expenses in any given year and therefore puts both customers and the Company at risk of either over-recovering or under-recovering storm restoration O&M costs.
 9 10 11 12 13 14 15 	A23.	restoration O&M expense recovery? Yes. The current approach to storm restoration O&M expense recovery does not address the uncertainty and variability of these expenses in any given year and therefore puts both customers and the Company at risk of either over-recovering or under-recovering storm restoration O&M costs.



Figure 1 - Actual Storm Restoration O&M Expense (\$ million)⁶

2

3

4

5

6

As can be seen in the chart, year-over-year changes to actual costs are volatile, ranging from a 17% decrease in costs between 2021 and 2022 to an 85% increase in costs between 2020 and 2021.

In years when actual costs are less than what was authorized for recovery, customers would pay more in rates than the actual storm restoration costs incurred in that year. In years when actual costs are greater than what was authorized for recovery, the Company must absorb any difference. Either way, the current approach to storm restoration O&M cost recovery risks misalignment between what is recovered from customers and the actual expenses incurred by the Company.

13

14 Q24. Does the Company expect storm restoration O&M expenses to remain 15 uncertain and volatile?

<u>No.</u> 1

Line

⁶ Exhibit A-13, Schedule C5.6, Page 2 of 2, Line 2

1	A24.	Yes. Storm restoration expenses are impacted by the frequency and duration of
2		extreme weather events. Figure 2 below captures data from the National Oceanic
3		and Atmospheric Administration (NOAA) on the Upper Midwest ⁷ Climate
4		Extremes Index (CEI) ⁸ . The Upper Midwest CEI measures the portion of time that
5		the Upper Midwest was subject to extreme weather during a given year. A CEI
6		value of 0% indicates that no portion of the Upper Midwest was subject to any of
7		the extreme conditions considered in the index during the year. In contrast, a value
8		of 100% would mean that the entire Upper Midwest had extreme conditions
9		throughout the year. The CEI analysis considers:
10		• Maximum and minimum temperature
11		Daily precipitation

• Monthly Palmer Drought Severity Index (PDSI) 12

Line <u>No.</u>

⁷ Upper Midwest includes Michigan, Wisconsin, Minnesota, and Iowa ⁸ https://www.ncei.noaa.gov/access/monitoring/cei/







3

4

5

6

7

8

As can be seen in the chart, not only is there is a clear trend toward more extreme weather in the Upper Midwest, but there can be significant variation from year to year in the amount of extreme weather experienced in the region. For example, just considering the last five years (i.e., 2019-2023) the Upper Midwest CEI has fluctuated from a high of 42.3% in 2021 to a low just one year later of 8.8% in 2022.



Simply put, the amount of extreme weather experienced by the Company cannot be
accurately predicted in advance and therefore there will continue to be uncertainty
related to the level of storm restoration O&M expense for any given year.



1	Q25.	What is the Company proposing related to storm restoration O&M expense
2		recovery in this case?
3	A25.	The Company is proposing that the Commission authorize the Storm Restoration
4		Cost Sharing Mechanism (SRCSM), becoming effective at the start of the projected
5		test year in this case (i.e., January 1, 2025).
6		
7		The Company proposes that the SRCSM operate as follows:
8		• The calculation of projected storm restoration O&M expenses continues to
9		follow the five-year trailing average methodology as supported by
10		Company Witness Kryscynski in this case; likewise, these projected
11		amounts continue to be authorized for recovery from customers through
12		base rates.
13		• At the conclusion of each calendar year, actual storm restoration O&M
14		expenses are compared to the amount authorized to be recovered from
15		customers in base rates; for years in which the amount authorized for
16		recovery through base rates changes (e.g., a general rate case order is
17		received and becomes effective mid-year), the authorized recovery amount
18		would be calculated on a prorated basis to reflect the timing and amount of
19		the updated authorization.
20		• Any difference between actual storm restoration O&M expenses and those
21		authorized for recovery is equally shared between the Company and its
22		customers; specifically:
23		• If actual storm restoration O&M expenses are less than projected,
24		the Company returns 50% of the difference to customers by
25		recording that amount as a Regulatory Liability.

.		N. T. FOLEY
Line <u>No.</u>		0-21534
1		• If actual storm restoration O&M expenses are more than projected,
2		the Company recovers 50% of the difference from customers by
3		recording that amount as a Regulatory Asset.
4		• Regulatory Assets and/or Liabilities accumulate between general rate cases
5		until a subsequent general rate case when any net Regulatory Liability or
6		Regulatory Asset is addressed.
7		
8		For example, if the Company's projected costs for 2025 of \$64.5M were to be fully
9		approved, but actual 2025 storm restoration O&M expenses were only \$40.0
10		million, then the Company would record a Regulatory Liability of \$12.3 million to
11		be returned to customers in a subsequent rate case. The \$12.3 million is 50% of the
12		difference between approved costs included in base rates (i.e., \$64.5 million) and
13		actual costs (i.e., \$40.0 million).
14		
15	Q26.	Has the Commission provided any recent guidance on the use of alternative
16		storm restoration expense recovery mechanisms?
17	A26.	Yes. In its most recent electric rate case (Case No. U-21389), Consumers Energy
18		proposed the Symmetric Performance Incentive Mechanism (SPIM). As described
19		by Consumers Energy Witness Houtz in her direct testimony, the SPIM "would
20		return service restoration costs below what is set in rates back to customers and
21		cover costs for the Company in excess of base rates." (page 24) Importantly,
22		Witness Houtz describes the use of a "deadband" in the proposed SPIM. According
23		to Witness Houtz, if expenses are below what is set in rates a portion would be
24		returned to customers "with the Company retaining the first 10%." (page 24) If
Line <u>No.</u>		U-21534
--------------------	------	---
1		expenses are above what is set in rates, a portion would be recovered from
2		customers "with the first 10% being offset by the Company." (page 24)
3		
4		In its March 1, 2024 Order in that case (March 2024 Order), the Commission
5		declined to adopt Consumers Energy's proposed SPIM. In doing so, the
6		Commission provided in part the following guidance:
7		
8		"the Commission finds that [Consumers Energy] has not demonstrated
9		that the SPIM will sufficiently control service restoration expenses as
10		claimed by [Consumers Energy]." (page 174)
11		
12		and
13		
14		"the SPIM does not incentivize [Consumers Energy] to reduce service
15		restoration expenses more than 10% below that approved in rates.
16		Furthermore, there is no evidence demonstrating that the 10% offset would
17		adequately deter [Consumers Energy] from passing through large cost
18		increases to customers. Finally, the Commission finds that approval of the
19		mechanism is premature given the ongoing audit in Case No. U-21305."
20		(page 175)
21		
22	Q27.	Is the Company's proposed SRCSM responsive to the Commission's guidance
23		in Case No. U-21389?
24	A27.	Yes. As the Commission pointed out in its March 2024 Order, the use of a deadband
25		could result in the utility only having an incentive to control costs when inside the

1 deadband. If actual costs are outside the deadband then the utility's financial 2 incentive to control costs could be diminished because costs will either be returned 3 to customers (in the event that actual costs are less than authorized in base rates) or recovered from customers (in the event that actual costs are greater than authorized 4 5 in base rates). 6 7 Given the Commission's guidance, the Company is not proposing the use of a 8 deadband. Instead, the Company is proposing the equal sharing of costs that differ 9 from those authorized for recovery in base rates. The sharing of costs ensures that 10 the Company has a strong incentive to control costs regardless of what actual costs 11 are for a given year. Specifically, if actual costs are greater than projected, the Company is incentivized to control costs because it must absorb 50 cents of every 12 13 incremental dollar that is spent. If actual costs are less than projected, the Company 14 is still incentivized to control costs because it is allowed to retain 50 cents of every 15 incremental dollar that is saved. 16 17 Q28. Would the establishment of the SRCSM impact the Company's ability or 18 incentive to act on any future recommendations resulting from the 19 **Distribution Audit?** 20 No. The approval of the SRCSM would not prevent the Company from acting on A28. 21 any future recommendations resulting from the Distribution Audit. As discussed 22 previously, the proposed SRCSM incentivizes the Company to control storm 23 restoration O&M costs regardless of what total costs are for a given year. As such, 24 the proposed SRCSM encourages the Company to implement any appropriate 25 actions faster such that it can better control costs.

NTF-26

- 1 **Q29.** Does this complete your direct testimony?
- 2 A29. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

MARGARET E. GUILLAUMIN

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF MARGARET E GUILLAUMIN Line

<u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Margaret E. Guillaumin (she/her/hers). My business address is One
3		Energy Plaza, Detroit MI, 48226. I am employed by DTE Electric Company (DTE
4		Electric or Company) as Plant Director in the Energy Supply organization.
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	My formal education consists of a Bachelor of Science degree in Chemical
11		Engineering from Michigan Technological University. I have also completed
12		several Company sponsored courses and have attended various seminars to further
13		my professional development with DTE Electric.
14		
15	Q4.	What work experience do you have?
16	A4.	I began my employment with DTE Electric in July 2003 in the engineering
17		department at River Rouge Power Plant. Throughout my career with DTE Electric
18		I have received various promotions with increasing levels of responsibility. These
19		positions included several engineering roles at the St. Clair Power Plant beginning
20		in November of 2003, Supervisor of Chemical Engineering for DTE Electric's
21		fossil power plants in 2010, Manager of Laboratory and Field Support in 2012, Fuel
22		Supply Manager at St. Clair Power Plant in 2014, and St. Clair Power Plant
23		Maintenance Manager in 2016. In October of 2017, I was promoted to Plant
24		Manager, Greenwood Energy Center, responsible for all day-to-day operation,
25		maintenance, and engineering for the facility. In April 2019, I was given additional

> 1 responsibilities that included Peakers and Ludington. In this expanded role I added 2 to my responsibilities the operation, maintenance, and engineering of DTE 3 Electric's natural gas and fuel oil Peakers as well as responsibilities for DTE 4 Electric's interest in the Ludington Pumped Storage facility. In April of 2022, I 5 was appointed Plant Manager, Blue Water Energy Center, where I was responsible 6 for transitioning the newly constructed facility through final commissioning 7 activities to commercial operation. Following the commercial operation date, I was 8 responsible for the day-to-day operation, maintenance, and engineering of the 9 facility.

10

11 Q5. What are your current duties and responsibilities?

A5. In April 2023, I was promoted to Plant Director, Operations Performance. In this
role my responsibilities include periodic outage planning and execution for DTE
Electric's fossil power plants, strategic planning and long-term generation strategy,
asset maintenance planning, and oversight of the St. Clair, Trenton Channel and
River Rouge Power Plants during decommissioning. I also have responsibilities
for approving capital projects as a voting member of the Capital Governance Board.

1 **Purpose of Testimony**

2 Q6. What is the purpose of your testimony?

3 A6. The purpose of my testimony is to support the reasonableness and prudency of the 4 operations and maintenance (O&M) and capital expenditures for Energy Supply 5 steam power generation, hydraulic power generation (Ludington), and other power 6 generation for the historical test year ended December 31, 2022, the 24-month 7 bridge period ending December 31, 2024, and the 12-month projected test period 8 ending December 31, 2025. Although Energy Supply currently operates and 9 maintains DTE Electric's fleet of wind and solar assets, costs of these assets are 10 managed in other regulatory proceedings. Therefore, throughout my testimony 11 when I refer to Energy Supply assets, I am referring to the fossil and energy storage 12 assets, including hydraulic storage and Battery Energy Storage Systems (BESS). 13 No part of my testimony includes Energy Supply renewable generation wind and 14 solar assets as they are handled in other regulatory filings as noted above. I also 15 address the following additional topics in my testimony:

I explain forecasted changes affecting generation ratings on a yearly basis for 10
 years looking forward (2022 through 2032). The changes are associated with
 projected retirements of current generating assets, the addition of new Energy
 Supply assets, as well as changes to existing units.

20 2) I provide a review of Energy Supply coal-fired and combined cycle unit
 availability for the most recent five years of actual performance and the next five
 years projected. In addition to discussing availability, I will also discuss the
 planned and unplanned outage performance for these same timeframes.

Line
No.

20

21

- For capital expenditures, I discuss how the Environmental Protection Agency's
 (EPA) Steam Electric Effluent Limitation Guidelines (ELG) Rule affects
 required coal-fired generation investments.
- 4) I then provide details of the historical 2022 level of expenditures on a plant level 4 5 basis and provide forecasts of expenditures to be incurred from January 1, 2023 through December 31, 2025. This data shows the levels of expenditures related 6 7 to routine maintenance, environmental compliance requirements, and 8 expenditures related to safety and general reliability that have been and will be 9 made over the timeframes of this case. These discussions on capital 10 expenditures cover the Energy Supply generation and hydraulic plants including 11 the coal-fired and gas-fired steam units, the Ludington pumped storage units, the 12 Blue Water Energy Center combined cycle unit, the peaking units, and new 13 energy storage to be added.
- 14 5) I discuss significant reductions to capital expenditures planned for Monroe Units
 15 3 and 4 in light of their accelerated retirement dates.
- 16
 6) I support the multiple known and measurable changes in Energy Supply's O&M
 17 expenses that will span the timeframe from the 2022 historic test year in this
 18 case to the projected test year, ending December 31, 2025. These known and
 19 measurable changes include:
 - Retirements of St. Clair and Trenton Channel Power Plants
 - Blue Water Energy Center commercial operations
 - Slocum BESS commercial operations
- Retirements of Northeast 11-1, River Rouge 11 1-4, Slocum 11 1-5, and St.
 Clair 12 1-2 peakers and suspension of operation of Fermi 11-3 and Fermi 11-4 peakers

Line <u>No.</u>				
1		• Corpo	rate membersh	ips excluded from rates.
2				
3	Q7.	Are you spo	nsoring any ex	chibits in this proceeding?
4	A7.	Yes. I am spo	onsoring the fol	llowing exhibits:
5		<u>Exhibit</u>	Schedule	Description
6		A-6	F1	Planned Long Range Generation Changes (Steam,
7				Hydraulic & Other)
8		A-6	F2	Energy Supply Coal and Combined Cycle Unit
9				Performance
10		A-12	B5.1	Projected Capital Expenditures – Steam, Hydraulic,
11				and Other Power Generation
12		A-12	B5.1.1	Commission-requested Monroe FGD Asset
13				Preservation Project Report
14		A-13	C5.1	Projected Operation and Maintenance Expenses -
15				Steam Power Generation
16		A-13	C5.4	Projected Operation and Maintenance Expenses -
17				Hydraulic Power Generation
18		A-13	C5.5	Projected Operation and Maintenance Expenses -
19				Other Power Generation
20				
21	Q8.	Were these of	exhibits prepa	red by you or under your direction?
22	A8.	Yes, they we	re.	
23				
24	Q9.	How is your	testimony org	anized?
25	A9.	My testimon	y consists of the	e following three (3) parts:

M. E. GUILLAUMIN U-21534

Line <u>No.</u>					
1		Part I	Energy Supply Plan	t Capacity and Availability	
2		Part II	Energy Supply Capit	tal Expenditures	
3		Part III	Energy Supply Oper	ration and Maintenance Exper	nses
4					
5	<u>Part I</u>	– Energy Sup	ply Plant Capacity a	and Availability	
6	Energ	y Supply Net	Summer Installed C	apacity	
7	Q10.	Can you prov	vide an overview of]	DTE Electric's Energy Supp	oly assets?
8	A10.	As of January	1, 2022, the Compan	y's owned fossil and hydraulic	e generation based
9		on installed su	ummer capacity rating	gs totaled 9,565 MW and was	comprised of:
10			Rated Capacity (Sur	mmer) as of 1/1/2022	
11		Fossil Steam		6,445 MW	
12		Peaking Plant		2,032 MW	
13		Pumped Stora	ige	<u>1,088 MW</u>	
14		Total Fossil/H	Iydraulic System	<u>9,565 MW</u>	
15					
16		The Company	y's 6,445 MWs of fo	ossil steam plant includes co	al-fired units that
17		provided 5,66	0 MW of capacity and	l a gas-fired unit that provided	an additional 785
18		MW of capac	ity as shown below:		
19					
20			Rated Capacity as o	<u>f 1/1/2022</u>	
21		Coal-fired Ste	eam Plants	Net Summer Capability	<u>No. Units</u>
22		Belle River (I	DTE ownership)	1,034 MW	2
23		Monroe		3,066 MW	4
24		St. Clair		1,065 MW	4
25		Trenton Chan	nel	<u>495 MW</u>	<u>1</u>

Line <u>No.</u>			
1	Total Coal-fired Capacity (steam)	<u>5,660 MW</u>	<u>11</u>
2			
3	Gas-fired Steam Plants	Net Sumer Capability	<u>No. Units</u>
4	Greenwood	<u>785 MW</u>	<u>1</u>
5	Total Gas-fired Capacity (Steam)	<u>785 MW</u>	<u>1</u>
6			
7	The Michigan Public Power Agency	(MPPA) is joint owner of	Belle River Power
8	Plant and its ownership entitlement is	18.61% (236 MW) of the	plant. The MPPA
9	ownership of Belle River Power Pla	nt is not included in the	1,034 MW shown
10	above.		
11			
12	DTE Electric's peaking plants, along	with DTE Electric's own	ership share of the
13	Ludington Pumped Storage facility,	jointly owned with Consu	umers Energy, are
14	shown below:		
15	Rated Capacity	<u>v as of 1/1/2022</u>	
16	Peaking and Pumped Storage	Net Summer Capability	<u>No. Units</u>
17 18	Gas/Oil Combustion Turbines (11 locations)	1,904 MW	37
19	Diesel Generators (10 locations)	<u>128 MW</u>	<u>46</u>
20	Total Peaking Capacity	2,032 MW	83
21			
22	Ludington Pumped Storage	<u>1,088 MW</u>	6
23	Total Pumped Storage/Peaking Capac	bity <u>3,120 MW</u>	<u>89</u>
24			

Line	
<u>No.</u>	

<u>NO.</u>		
1	Q11.	Can you provide a summary of Exhibit A-6, Schedule F1 titled "Planned Long
2		Range Generation Changes (Steam, Hydraulic, & Other) Years 2022 through
3		2032"?
4	A11.	Exhibit A-6, Schedule F1 provides the 2022 actual generation rating changes and a
5		10-year projection of the forecasted changes at Energy Supply units through 2032.
6		Changes are based on the forecasted timing of upcoming unit retirements,
7		development of new Energy Supply assets, and modifications to existing assets.
8		This exhibit does not include new or existing renewable resources.
9		
10	Q12.	Can you please explain the yearly generation facility changes shown on Exhibit
11		A-6, Schedule F1 for 2022-2032?
12	A12.	The changes for 2022 are shown on lines 1 through 6 of Exhibit A-6 Schedule F1.
13		In 2022, the Company retired St. Clair Units 2, 3, 6, and 7, representing a combined
14		1,065 MW of coal-fired summer-rated capacity. Trenton Channel Unit 9, a coal-
15		fired unit with a summer capacity rating of 495 MW, also retired. The Blue Water
16		Energy Center, a combined cycle gas turbine (CCGT) power plant with a summer-
17		rated capacity of 1,127 MW, commenced commercial operations in June of 2022.
18		The Ludington Unit 3 upgrade for an additional 34 MW of generation capacity was
19		also completed.
20		
21		The changes for 2023 are shown on lines 8 and 9 of Exhibit A-6 Schedule F1.
22		Northeast 11-1 peaker (15 MW) experienced significant in-service damage in 2019
23		and was formally retired in 2023. Additionally, the Slocum peakers (14 MW) were
24		retired in 2023 to facilitate the construction of the new Slocum Battery Energy
25		Storage System (BESS).

1	
2	The forecasted changes for 2024 are shown on lines 11 through 13 of Exhibit A-6
3	Schedule F1. The Company plans to retire the River Rouge 11 peakers and the St.
4	Clair 12 peakers, representing 16 MW of summer peaking capacity. Additionally,
5	the Slocum Battery Energy Storage System (BESS), with a rating of 14 MW, is
6	projected to be completed in 2024, replacing the peakers previously located at the
7	site that were retired in 2023.
8	
9	The forecasted changes for 2025 are shown on lines 15-16 of Exhibit A-6 Schedule
10	F1. The Company plans to suspend the operations of the Fermi 11-3 and 11-4
11	peakers, representing 25 MW of summer peaking capacity, and Belle River Unit 1
12	is projected to convert from coal-fired to natural gas-fired operations.
13	
14	The forecasted changes for 2026 are shown on lines 18-19 of Exhibit A-6 Schedule
15	F1. In 2026, the Trenton Channel 220 MW BESS is projected to commence
16	operation and Belle River Unit 2 is projected to convert from coal-fired to natural
17	gas-fired operations.
18	
19	No changes are forecasted for 2027 in Exhibit A-6 Schedule F1.
20	
21	The forecasted changes for 2028 are shown on lines 23-24 of Exhibit A-6 Schedule
22	F1. In 2028, consistent with the final Order dated July 26, 2023, in the Company's
23	2022 IRP, Case No. U-21193, the Company projects retiring Monroe Units 3 and
24	4, representing a combined 1,535 MW of coal-fired summer-rated capacity and
25	commencing operation of a 275 MW BESS.

1 2 No changes are forecasted in Exhibit A-6 Schedule F1 from 2029 through 2031. 3 4 The forecasted change for 2032 is shown on line 32 of Exhibit A-6 Schedule F1. 5 In 2032, consistent with the final Order dated July 26, 2023, in the Company's 2022 6 IRP, Case No. U-21193, the Company projects retiring Monroe Units 1 and 2, 7 representing a combined 1,531 MW of coal-fired summer-rated capacity. 8 9 **Energy Supply Plant Performance** 10 013. How is the Company's Energy Supply plant performance monitored and 11 calculated? 12 A13. Energy Supply utilizes Equivalent Availability Factor (EAF), Planned Outage 13 Factor (POF), and Random Outage Factor (ROF) to monitor overall unit 14 performance. EAF is equal to 100 minus the POF minus ROF. Equivalent 15 availability is equal to total possible megawatt-weeks minus planned outage 16 megawatt-weeks minus random outage megawatt-weeks (including full and partial 17 derates) divided by total possible megawatt-weeks. Total possible megawatt-weeks 18 are calculated by multiplying the net demonstrated capacity of the unit by the weeks 19 in the time-period (52 weeks per year). Planned outage megawatt-weeks refers to 20 the equivalent number of weeks in the time-period that the unit is not available due 21 to scheduled maintenance multiplied by the capacity that is out of service. Random 22 outage megawatt-weeks is the number of weeks of unit unavailability caused by an 23 outage or derate that is not planned or scheduled, multiplied by the capacity that is 24 out of service.

Line
<u>No.</u>

1	Q14.	What are the major drivers of unit unavailability?
2	A14.	There are three major drivers of unit unavailability: (1) planned full unit or periodic
3		maintenance outages, (2) unplanned or random unit outages, and (3) derates or
4		partial unit outages which can be planned or unplanned.
5		
6		Planned full unit outages and planned derates are those outages for which the
7		Company has developed long range maintenance plans designed to sustain unit
8		performance, install required environmental systems, and proactively address
9		emerging reliability issues. Unplanned unit outages and unplanned derates are
10		those that occur due to either reliability issues common across the industry or
11		unusual events which are unique to a specific DTE Electric plant or unit.
10		
12		
12	Q15.	Can you explain the Company's 2022 total Energy Supply plant availability
12 13 14	Q15.	Can you explain the Company's 2022 total Energy Supply plant availability performance?
12 13 14 15	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets
12 13 14 15 16	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the
12 13 14 15 16 17	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included
12 13 14 15 16 17 18	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included Belle River, Blue Water, Greenwood, Monroe, St. Clair, Trenton Channel,
12 13 14 15 16 17 18 19	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included Belle River, Blue Water, Greenwood, Monroe, St. Clair, Trenton Channel, Ludington, and peaker power plants. Energy Supply availability for 2022 was
12 13 14 15 16 17 18 19 20	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included Belle River, Blue Water, Greenwood, Monroe, St. Clair, Trenton Channel, Ludington, and peaker power plants. Energy Supply availability for 2022 was reduced by several planned major overhaul maintenance outages completed on
12 13 14 15 16 17 18 19 20 21	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included Belle River, Blue Water, Greenwood, Monroe, St. Clair, Trenton Channel, Ludington, and peaker power plants. Energy Supply availability for 2022 was reduced by several planned major overhaul maintenance outages completed on Belle River Unit 1, Monroe Unit 2, and multiple peaker units. Less comprehensive
12 13 14 15 16 17 18 19 20 21 22	Q15. A15.	Can you explain the Company's 2022 total Energy Supply plant availability performance? The EAF for Energy Supply steam, hydraulic, and other power generation assets was 74.1% for the 2022 historic period. The 74.1% equivalent availability was the result of a 13.2% ROF and a 12.6% POF. In 2022, Energy Supply assets included Belle River, Blue Water, Greenwood, Monroe, St. Clair, Trenton Channel, Ludington, and peaker power plants. Energy Supply availability for 2022 was reduced by several planned major overhaul maintenance outages completed on Belle River Unit 1, Monroe Unit 2, and multiple peaker units. Less comprehensive planned outages were completed on many units to prepare units for or recover from

Line	
<u>No.</u>	

1	Q16.	What was the equivalent availability specific to the coal-fired and combined
2		cycle units within Energy Supply in 2022?
3	A16.	As shown on line 4 of Exhibit A-6, Schedule F2, coal-fired and combined cycle
4		plants had an equivalent availability of 72.7% in 2022 as a result of a 14.7% ROF
5		and a 12.6% POF for those units. Coal-fired plants included the Belle River,
6		Monroe, St. Clair, and Trenton Channel power plants. The Blue Water Energy
7		Center combined cycle plant is also included in the availability metrics.
8		
9	Q17.	How does the forecasted future coal-fired and combined cycle unit availability
10		compare to the actual historical availability?
11	A17.	As shown in Exhibit A-6, Schedule F2, the average coal-fired and combined cycle
12		unit availability for 2019-2023 was 73.4% while the forecast of average coal-fired
13		and combined cycle unit availability for 2024-2028 is 80.0%. The older and less
14		reliable coal-fired power plants were retired by 2022, resulting in an increase in
15		availability for 2023 and beyond.
16		
17	<u>Part l</u>	<u>I – Energy Supply Capital Expenditures</u>
18	Q18.	Can you please provide an overview of your Part II discussion?
19	A18.	Yes. In this section of my testimony, I will discuss the following:
20		Capital Planning Process
21		ELG Rule Compliance
22		2022-2025 Capital Projects Summary
23		Non-Routine Capital Expenditures
24		Routine Capital Expenditures

Line <u>No.</u>		
1		• Reductions to Monroe Unit 3 and 4 Capital Expenditures and Updates to the
2		Capital Projects Planned
3		Allowance for Funds Used During Construction (AFUDC) Estimate
4		• Removal Costs, Plant in Service and CWIP schedule
5		
6	<u>Capit</u>	al Planning Process
7	Q19.	Can you explain Energy Supply's capital planning process?
8	A19.	Yes. Capital projects are initiated to support safety, regulatory requirements,
9		environmental compliance, plant-level reliability plans, Original Equipment
10		Manufacturer (OEM) recommendations, or the engineering recommendations of
11		Energy Supply's equipment and system experts. Capital expenditure requests
12		require the development of a plant management approved project request that
13		includes a detailed explanation of the project and an initial estimate of the costs and
14		customer benefits associated with the project. Projects are then further developed
15		including work scope identification and ranking based on customer-centric
16		economic considerations and other important drivers such as safety requirements,
17		environmental regulations, and outage timing opportunities. The planned outage
18		schedule heavily influences capital project timing since many capital projects are
19		implemented during longer duration planned outages to minimize implementation
20		impact on plant availability. During these planned outages, inspections are
21		completed on critical systems to ensure that the outage being executed addresses
22		the work needed to sustain future unit reliability. These inspections can reveal
23		unanticipated damage because many systems cannot be thoroughly inspected or
24		evaluated until they are disassembled during an outage.

Line
No.

1 Once capital project requests are fully developed, they are prioritized and presented 2 for management review and approval. The review process focuses on ensuring that 3 the projects utilize the best solution to address the issue at hand and represent the 4 most cost-effective method for accomplishing the proposed work. Projects are 5 approved if they are required to meet safety requirements and/or environmental 6 compliance, are justified by an economic evaluation or represent normal/routine 7 plant component replacements required for continued plant operations that are 8 capitalized per authorized accounting policy.

9

In summary, the capital spending and approval process is designed to identify the optimal allocation of capital resources to meet safety requirements and environmental compliance while maintaining overall reliability performance and minimizing costs.

14

15 Q20. What do you mean by projects being justified by economic evaluation?

16 A20. The prioritization of economic projects is based on an internal rate of return (IRR) 17 analysis performed comparing the costs of implementing the new project to its 18 customer benefits. Included in the analysis are projected capital expenditures, 19 future avoided outages, heat rate (efficiency), and fuel blending capabilities. Future 20 avoided plant outage impacts include the value of avoiding events such as boiler 21 tube failures, condenser or feedwater heater leaks, and turbine blade failures. The 22 IRR of the project is based on the anticipated O&M, capital expenditures, and 23 energy and capacity market value of the unit's operations with and without the 24 project being implemented over its useful life.

1	Q21.	What would be the consequences of not completing the capital projects
2		requested in the instant case?
3	A21.	Failure to complete the approved capital projects described in this case could
4		negatively affect plant reliability, environmental compliance, customer
5		affordability, and/or safety.
6		
7	Q22.	Can you explain the governance process for approval of Energy Supply's
8		capital projects?
9	A22.	The capital governance process includes the documentation of project assumptions,
10		calculation of costs and customer benefits, and a rigorous internal review. Projects
11		costing less than \$250,000 are approved by plant management, utilizing a project
12		appropriation form, within a budget established based on historic plant
13		expenditures. These projects generally do not require engineering and often reflect
14		replacement-in-kind.
15		
16		Projects that cost greater than \$250,000 but less than \$10 million and/or projects
17		that require engineering are approved by the Energy Supply Capital Governance
18		Board (CGB) which consists of plant directors, the Director of Engineering, and
19		the Vice President of Energy Supply. A Project Approval Team (PAT) form is
20		utilized to record CGB approvals.
21		
22		Projects greater than \$10 million require senior corporate executive approval, while
23		projects greater than \$50 million require approval by the Finance Committee of
24		DTE Energy's Board of Directors. All projects greater than \$10 million must be

Line <u>No.</u>		
1		authorized by a Capital Appropriations Request Form (CARF) approved by the
2		appropriate Company representatives.
3		
4	<u>ELG</u>	Rule Compliance
5	Q23.	How does the EPA's Steam Electric ELG Rule affect the Company?
6	A23.	As discussed in more detail by Company Witness Lee, the EPA's ELG Rule
7		regulates how electric utilities must manage certain wastewaters. On October 13,
8		2020, the EPA finalized the ELG Reconsideration Rule which revised some
9		requirements from the 2015 ELG Rule and added time-based options for complying
10		with the updated requirements for Bottom Ash Transport Water (BATW) and Flue
11		Gas Desulfurization (FGD) wastewater. Subsequently, on May 30, 2023, the EPA
12		published a Direct Final Rule which extended the deadline for units to opt-in to the
13		cessation of coal compliance subcategory from the 2020 ELG Rule, which allows
14		for operation of a unit until end of 2028 in lieu of installing a technology-based
15		compliance option. Bottom ash transport water cannot be discharged to the
16		environment after December 31, 2025, from a coal-fired power plant unless the
17		plant committed to ceasing coal-fired operations by the end of 2028, by opting into
18		the cessation of coal compliance subcategory. Regarding FGD wastewater streams,
19		plants with FGD systems can comply with one set of limits by December 31, 2025
20		or comply with a set of more stringent limits by December 31, 2028 if the plant
21		plans to continue coal-fired operations past 2028. Fly ash transport water (FATW)
22		discharge limitations were not altered in the Reconsideration Rule and Direct Final
23		Rule and continued to have a December 31, 2023 compliance date.
24		

25 Q24. Did the Company submit any filings under the ELG Reconsideration Rule?

Line	
No.	

1	A24.	Yes. To utilize the ELG Reconsideration Rule's time-based options, companies
2		were required to submit a Notice of Planned Participation (NOPP) to their state
3		permitting agency. The Company filed NOPPs for Monroe and Belle River Power
4		Plants. Please refer to additional testimony for Monroe and Belle River Power
5		Plants below, as well as Company Witness Lee's testimony, for more information.
6		
7	Q25.	Has the Company made a formal commitment regarding how Belle River
8		Power Plant will comply with ELG Rules?
9	A25.	Yes. The NOPP that DTE Electric filed with the Michigan Department of
10		Environment, Great Lakes, and Energy (EGLE) on October 13, 2021 indicated a
11		commitment to cease coal-fired operations at Belle River Power Plant. The fuel
12		conversion at Belle River qualifies for ELG compliance as it results in ceasing coal-
13		fired operations. This decision allows the Company to avoid installing new ELG-
14		compliant bottom ash transport technology by the end of 2025.
15		
16	Q26.	How did the Company comply with the FATW-portion of the ELG Rule at
17		Monroe Power Plant?
18	A26.	The FATW-portion of the ELG Rule required companies to cease water discharges
19		related to the transport of fly ash by the end of 2023. A project to install piping and
20		silos and other infrastructure for the dry transport of fly ash from Monroe Power
21		Plant boilers to a permitted storage area was completed in 2023, meeting the
22		required compliance date.
23		
24	Q27.	How will the Company comply with the BATW-portion of the ELG Rule at
25		Monroe Power Plant?

Line	
<u>No.</u>	

1	A27.	Monroe Units 1 and 2 are required to comply with the BATW-portion of the ELG
2		Rule by the end of 2025. The Company plans to terminate the use of water for
3		bottom ash transport on Monroe Units 1 and 2. In place of water conveyance, a dry
4		drag chain conveyor system will be installed. This project was approved by the
5		Company in 2022 and is fully underway and will meet the required compliance
6		date.
7		
8		Monroe Units 3 and 4 will not be required to terminate the use of water for bottom
9		ash transport by the end of 2025. The Company submitted an NOPP for BATW on
10		Monroe Units 3 and 4 and will comply with the BATW-portion of the ELG Rule
11		by retiring Monroe Units 3 and 4 by the end of 2028, thereby eliminating their
12		production of BATW and the need and expense to install a new transport system.
13		
13 14	Q28.	How does the Company plan to comply with the FGD wastewater-portion of
13 14 15	Q28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant?
13 14 15 16	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the
13 14 15 16 17	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary
13 14 15 16 17 18	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows
13 14 15 16 17 18 19	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more
 13 14 15 16 17 18 19 20 	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more stringent FGD wastewater effluent limitations. The Company filed a VIP NOPP in
 13 14 15 16 17 18 19 20 21 	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more stringent FGD wastewater effluent limitations. The Company filed a VIP NOPP in October 2021, allowing it to evaluate alternative compliance technologies for
 13 14 15 16 17 18 19 20 21 22 	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more stringent FGD wastewater effluent limitations. The Company filed a VIP NOPP in October 2021, allowing it to evaluate alternative compliance technologies for Monroe Units 1 and 2.
 13 14 15 16 17 18 19 20 21 22 23 	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more stringent FGD wastewater effluent limitations. The Company filed a VIP NOPP in October 2021, allowing it to evaluate alternative compliance technologies for Monroe Units 1 and 2.
 13 14 15 16 17 18 19 20 21 22 23 24 	Q28. A28.	How does the Company plan to comply with the FGD wastewater-portion of the ELG Rule at Monroe Power Plant? Monroe Power Plant is required to comply with the FGD wastewater-portion of the ELG Rule by the end of 2025, unless the Company participates in the Voluntary Incentives Program (VIP) contained in the 2020 ELG Rule. The VIP allows compliance to be achieved by the end of 2028 if the Company agrees to meet more stringent FGD wastewater effluent limitations. The Company filed a VIP NOPP in October 2021, allowing it to evaluate alternative compliance technologies for Monroe Units 1 and 2.

Line <u>No.</u>		
1		FGD wastewater treatment systems on those units. Consequently, the Company
2		filed a cessation of coal compliance subcategory NOPP in April 2023.
3		
4	<u>2022-</u> 2	2025 Capital Projects Summary
5	Q29.	Can you provide a high-level discussion of the routine and non-routine capital
6		expenditures being made by the Company for steam, hydraulic, and other
7		power generation during the historical year 2022, the bridge period and the
8		projected test period ending December 31, 2025?
9	A29.	The Company's Energy Supply group makes routine ongoing expenditures across
10		its existing generation fleet (steam, hydraulic, and other power generation) to
11		maintain safe, environmentally compliant, reliable, and efficient operations. Most
12		of these routine expenditures are primarily for Monroe and Belle River Power Plant
13		projects. To a lesser degree, there are routine capital expenditures for the remaining
14		assets including Blue Water Energy Center, Greenwood Energy Center, and
15		peakers.
16		
17		Non-routine capital project expenditures are driven by steam power generation unit
18		upgrades with a heavy focus on environmentally mandated work at Monroe Power
19		Plant. Other major non-routine capital projects included in the instant case are
20		related to decommissioning and environmental remediation projects at retired coal
21		plants, construction of Blue Water Energy Center, and new utility scale energy
22		storage systems.
23		
24	Q30.	Can you explain Exhibit A-12, Schedule B5.1 entitled, "Projected Capital
25		Expenditures Steam, Hydraulic and Other Power Generation" in more detail?

15	Q31.	Can you provide additional details concerning Exhibit A-12, Schedule B5.1,
14		
13		assumptions included in the capital forecast.
12		expenditures. Finally, page 9 summarizes the plant in service and CWIP
11		Page 8 summarizes AFUDC included in the routine and non-routine capital
10		with expenditures of greater than \$1 million for 2022 through December 31, 2025.
9		Pages 4 through 7 provide additional detail for the routine maintenance projects
8		Other Power Generation capital expenditures by plant site and major category.
7		and Other Power Generation. Page 3 summarizes routine Steam, Hydraulic, and
6		additional detail for major non-routine capital expenditures for Steam, Hydraulic,
5		(Ludington Pumped Storage), and Other Power Generation. Page 2 provides
4		projected test period) for Steam Power Generation, Hydraulic Power Generation
3		through the bridge period and the 12 months ending December 31, 2025 (the
2		and "non-routine" capital expenditures for 2022 (the historical actual test period)
1	A30.	Exhibit A-12, Schedule B5.1 is a 9-page exhibit. Page 1 summarizes both "routine"

17

16

page 1 of 9 entitled, "Projected Capital Expenditures Steam, Hydraulic, and Other Power Generation"?

18 A31. Yes. Line 2, Routine Steam Power Generation, includes capital expenditures 19 necessary to operate and maintain Energy Supply's fossil steam power plant sites. 20 Included are projects related to safety, boiler and turbine work, cables and controls, 21 balance of plant projects and maintenance of environmental control systems. 22 Safety expenditures include the capital projects necessary to maintain a safe work 23 environment and meet applicable safety regulations and standards. Boiler and 24 turbine work include the capital expenditures intended to maintain boiler or turbine 25 operations, replace unreliable systems or equipment, support heat rate (efficiency),

Line
No.

and/or address operating and maintenance problems related to the boiler and turbine 1 2 systems. Examples of these projects include replacement of worn or damaged 3 turbine blades, air heater baskets, and boiler tube sections such as waterwalls, 4 reheaters, superheaters, and economizers. Cables and controls expenditures include 5 the capital expenditures to replace or improve distributed control systems, large 6 power cables, main unit transformers, and electrical switchgear. The balance of 7 plant area expenditures includes the capital associated with mobile equipment, station air compressors, general service water systems, fuel handling equipment and 8 9 systems, and plant vehicles and computers. Routine environmental expenditures 10 include the capital necessary to maintain operations of existing environmental 11 control and monitoring equipment. An example of routine environmental 12 expenditures is the ongoing replacement of the Selective Catalytic Reduction 13 (SCR) catalyst beds installed at Monroe Power Plant to comply with nitrogen 14 oxides (NOx) emissions limits. These routine environmental capital expenditures 15 associated with existing environmental systems differ from the non-routine 16 environmental capital expenditures required to install any future new 17 environmental systems.

18

Line 3, Non-Routine Steam Power, includes capital expenditures related to environmental compliance projects, site decommissioning, environmental remediation, and required equipment modifications related to retired power generation assets, as well as other plant level projects such as physical and cyber security at generation sites.

<u>No.</u>	
1	Line 6, Routine Hydraulic Power Generation, includes the Company's share of the
2	routine capital expenditures necessary to operate and maintain the Ludington
3	Pumped Storage facility.
4	
5	Line 7, Non-Routine Hydraulic Production Plant, includes the Company's share of
6	the capital expenditures related to the efficiency upgrade project at the Ludington
7	Pumped Storage facility. This multi-year project included installation of new
8	higher efficiency hydraulic turbines, main unit transformers, and upgraded
9	generators on all six units.
10	
11	Line 10, Routine Other Power Generation, includes capital expenditures related to
12	maintaining peaker and combined cycle operations, including routine overhauls.
13	
14	Line 11, Non-Routine Other Power Generation, primarily includes capital
15	expenditures related to the development and construction of the Blue Water Energy
16	Center (a 1,127 MW (summer-rated capacity) CCGT plant) and the development
17	of new BESSs.
18	
19	Lines 15 and 16 include Monroe regulatory asset routine and non-routine capital
20	expenditures. Consistent with the Order in the Company's 2022 IRP filing, Case
21	No. U-21193, the Company is including 2025 and all future Monroe capital
22	expenditures in the regulatory asset.

Line

T	•	
L	Jine	,
•	Ŧ	

Ν	0.

1	<u>Non-F</u>	Routine Capital Expenditures
2	Q32.	Can you summarize Exhibit A-12, Schedule B5.1, page 2 of 9 entitled,
3		"Projected Capital Expenditures Steam, Hydraulic, and Other Power
4		Generation – Non-Routine"?
5	A32.	Page 2 of Exhibit A-12, Schedule B5.1 provides project level detail for non-routine
6		capital expenditures completed and planned for Steam Production, Hydraulic, and
7		Other Power Generation from 2022 through December 31, 2025.
8		
9	Q33.	Can you explain line 2 of Exhibit A-12, Schedule B5.1, page 2 of 9?
10	A33.	Line 2 (Belle River Fuel Conversion) represents a project to convert the Belle River
11		Power Plant's fuel source from coal to natural gas, consistent with the Company's
12		approved 2022 IRP in Case No U-21193. The Order in Case No. U-21193 also
13		included preapproval of the Belle River Fuel Conversion project.
14		
15		In 2022, \$1.4 million was spent on this project. The Company approved the funding
16		and execution of this project in September 2022. An Owner's Engineer (OE) firm
17		was contracted to provide engineering support, bid specification support, and
18		technical review for the duration of the project. A request for proposal (RFP) to
19		develop project scope, schematic design, and budgetary pricing was issued to
20		support 2025 and 2026 gas conversions on Belle River Units 1 and 2, respectively.
21		
22		For 2023, the project planned expenditures are \$2.2 million and includes selection
23		of an engineering, procurement, and construction (EPC) contractor for the fuel
24		conversion of Belle River Units 1 and 2 that can meet the planned timelines. Work
25		includes the development of an EPC bid specification that included the engineering

Line
<u>No.</u>

1		design, material procurement, and installation of the natural gas systems for both
2		units. Material procurement includes components for burner and ignitor
3		modifications, ductwork modifications, air heater modifications, low and high-
4		pressure gas reducing skids, a gas detection monitoring system, gas yard
5		equipment, and components for associated electrical and controls upgrades.
6		Additionally, a limited notice to proceed was issued in December 2023 to the
7		selected EPC contractor.
8		
9		In 2024, \$39.3 million is projected to continue material procurement and complete
10		detailed design, including erection arrangements and the controls upgrade
11		requirements.
12		
13		In 2025, \$41.8 million is projected to be spent on this project. 2025 work scope
14		includes installation of a natural gas pipeline from a nearby high-pressure interstate
15		pipeline to the power plant, constructing the in-plant gas piping system, and
16		controls systems for Belle River Unit 1, and retrofitting Belle River Unit 1 with
17		natural gas burners in its fall periodic outage.
18		
19		In 2026, which is beyond the projected test year in the instant case, the in-plant gas
20		piping system and controls systems for Belle River Unit 2 will be constructed and
21		the unit will be retrofitted with natural gas burners in its fall periodic outage.
22		
23	Q34.	Can you explain line 3 of Exhibit A-12, Schedule B5.1, page 2 of 9?
24	A34.	Line 3 (Belle River Bottom Ash Basin Modification (CCR)) represents a project to
25		rate of it the north and couth bottom ash basing at Dalla Diver Dower Dient with CCD

Line
No.

1		Rule-compliant liner systems and to close the diversion basin by removal of all ash
2		from the basin. The removed ash was transported to and disposed of at the Range
3		Road Landfill. The Company spent \$60 thousand in 2022 for project engineering.
4		Project construction was initiated and was completed in 2023 for \$3.4 million. This
5		project was required by the EPA's CCR Rule as discussed in Witness Lee's
6		testimony.
7		
8	Q35.	Can you explain line 4 of Exhibit A-12, Schedule B5.1, page 2 of 9?
9	A35.	Line 4 (Monroe Dry Fly Ash Conversion (ELG)) represents a project to convert the
10		existing wet fly ash handling system at Monroe Power Plant to a dry system on all
11		four Monroe Power Plant units. The EPA's fly ash ELG rule promulgated in 2015

- 12 required all liquid discharges to the environment from fly ash transport systems to 13 cease by December 31, 2023. Conversion to a dry fly ash handling system required 14 installation of new equipment to pneumatically transport ash from each generating 15 unit's precipitator to new storage silos. The project included installation of 16 transport piping from the unit precipitator hoppers to the local unit silos and 17 installation of transport piping from the local unit silos to two central storage silos. 18 Blowers were installed to convey the fly ash to the respective ash silos. The 19 Company approved the funding and execution of this project in March 2020.
- 20

In 2022, \$20.0 million was spent to engineer and construct a local ash silo for each of the four units, receive all long lead material, and complete the silos and interconnection piping systems for the four Monroe units. The equipment tie-in was completed on Monroe Unit 2 during an outage that ended in December 2022.

Line <u>No.</u>		
1		In 2023, \$20.8 million was spent to tie-in new fly ash handling systems on Monroe
2		Units 1 and 3 in spring 2023 and Monroe Unit 4 in fall 2023.
3		
4		In 2024, \$1.2 million is projected for final site work, project demobilization, and
5		performance testing. As required under the ELG Rule, the new fly ash handling
6		systems were operational by the end of 2023.
7		
8	Q36.	Can you explain lines 5 and 47 of Exhibit A-12, Schedule B5.1, page 2 of 9?
9	A36.	Lines 5 and 47 (Monroe Bottom Ash Conversion (ELG)) represent a project to
10		install an ELG-compliant bottom ash transport system that must be completed at
11		Monroe Power Plant Units 1 and 2 by the December 31, 2025 EPA deadline. The
12		Company approved the funding and full execution of this project in December
13		2022. The project scope includes removal of the wet bottom ash collection systems
14		and major modifications to the boiler bottom hopper areas to permit installation of
15		dry drag chain conveyor systems for ash removal. Project scope also includes the
16		integration of the economizer ash handling systems into the dry fly ash handling
17		systems utilizing dry flight conveyors. Once removed from the individual boilers,
18		the bottom ash is moved outside the plant wall and into bunkers that function as the
19		feed point for loading trucks with bottom ash to be sold or disposed of off-site.
20		
21		The Company spent \$4.2 million in 2022 to engineer ELG-compliant systems and
22		procure long-lead materials.
23		
24		For 2023, \$11.4 million was projected to be spent to perform final engineering, bid
25		project construction, and continue material procurement in support of the Unit 1

Line	
<u>No.</u>	

10.	
1	and Unit 2 new bottom ash transport systems. In the Company's previous electric
2	rate case, Case No. U-21297, the forecast had included the completion of
3	engineering, bidding and award of project construction, and tie-in of new systems
4	on Monroe Unit 3 and Unit 4 for converting the economizer ash transport systems.
5	This work scope was not executed because the EPA ELG Direct Final Rule issued
6	in May 2023 allowed Monroe Unit 3 and Unit 4 to retire by the end of 2028 without
7	installing the new bottom ash handling systems otherwise required under the ELG
8	Rule.
9	
10	In 2024, \$26.1 million is projected to award project construction and complete the
11	installation of a common Unit 1-2 bunker and drag chain conveyor system. The
12	new bottom ash handling system tie-in outage and connection to the new dry
13	economizer ash transport system on Monroe Unit 2 will also be done in a fall 2024
14	outage.
15	
16	In 2025, \$23.1 million is projected to be spent for the new bottom ash handling
17	systems that will be connected to Monroe Unit 1 in the fall of that year.
18	Additionally, the new economizer ash transport system will be installed on Monroe
19	Unit 1 in the fall. Included in this \$23.1 million is \$4.3 million of project costs that
20	were prudently incurred prior to issuance of the May 30, 2023 EPA Direct Final
21	Rule which extended the deadline for plants to opt-in to the 2028 early retirement
22	provision promulgated in the 2020 ELG regulation. In the Company's previous
23	electric rate case, Case No. U-21297, Staff Witness Kindschy acknowledged that
24	the Company "may have incurred some capital expenditures in 2023 for this project
25	prior to being able to opt-in to a 2028 retirement, and those capital expenditures can

Line	
<u>No.</u>	

1		be included in the Company's next rate case for review and recovery." ¹ The \$4.3
2		million that was prudently incurred prior to issuance of the Direct Final Rule is
3		included in line 5 of Exhibit A-12, Schedule B5.1, page 2 of 9 as a credit to the
4		conversion project and is included in line 47 of Exhibit A-12, Schedule B5.1, page
5		2 of 9 for recovery through the regulatory asset. In accordance with the Company's
6		2022 IRP Order, recovery of Monroe Power Plant capital investments on this
7		project made after January 1, 2025 will be processed through a regulatory asset,
8		shown on line 47 of Exhibit A-12, Schedule B5.1, page 2 of 9.
9		
10		As required under the ELG Rule, all the new dry bottom ash and economizer ash
11		handling systems on Monroe Units 1 and 2 will be operational by the end of 2025.
12		This work is required to maintain environmental compliance and allow the units to
13		continue to provide power for customer benefit.
14		
15	Q37.	Can you explain lines 6 and 48 of Exhibit A-12, Schedule B5.1, page 2 of 9?
16	A37.	Lines 6 and 48 (Monroe FGD Wastewater (ELG)) represent a project to develop an
17		ELG-compliant flue gas desulfurization (FGD) wastewater discharge treatment
18		system at Monroe Power Plant. The Company spent \$0.3 million in 2022 to
19		perform technology evaluations and initial site engineering scoping efforts. In
20		2023, \$0.5 million of expenditures were projected to evaluate compliance
21		technologies for Monroe Units 1 and 2 and this evaluation will continue in 2024
22		and 2025 for \$1.0 million each year. In accordance with the Company's 2022 IRP
23		Order, recovery of Monroe Power Plant investments on this project made after

¹ Case No. U-21297 Kindschy, 7T 4512

Line <u>No.</u>		
1		January 1, 2025 will be processed through a regulatory asset, shown on line 48 of
2		Exhibit A-12, Schedule B5.1, page 2 of 9.
3		
4	Q38.	Can you explain line 7 of Exhibit A-12, Schedule B5.1, page 2 of 9?
5	A38.	Line 7 (Monroe Dry Fly Ash Haul Road) represents a project that constructed a
6		new asphalt road from Waters Edge Drive to the Monroe Power Plant vertical
7		extension landfill. The Company spent \$0.3 million to complete the new road in
8		the first quarter of 2022. The new road reduces heavy truck traffic on public roads
9		traversing residential areas and additionally minimizes related fugitive dust
10		emissions.
11		
12	Q39.	Can you explain lines 8-13 of Exhibit A-12, Schedule B5.1, page 2 of 9?
13	A39.	Lines 8-13 (Site Security Projects and NERC Compliance Projects) represent
14		projects required to improve power plant security. General site access security
15		improvements as well as security enhancements for critical equipment are being
16		implemented to mitigate security threats. In addition to physical security, North
17		American Electric Reliability Corporation Critical Infrastructure Protection
18		(NERC-CIP) compliance requires the Company to protect its cyber assets to
19		minimize the risks to the electrical grid. The need for increased physical and cyber
20		security for our electric assets are increasingly evident as seen in recent events at
21		other utilities. NERC-CIP-003 was originally issued in 2010 and has undergone
22		updates in 2014, 2016, and 2020 to include additional standards the Company needs
23		to meet. NERC-CIP-003 requires the Company to control and track physical access
24		to any NERC sensitive site. In order to be compliant with the CIP standard, the
25		Company reviewed physical access at all power plants and developed projects to

Line No.

1

2

3

4

mitigate risks. Risks to the bulk electric system continue to increase. As a result, some project information, most noticeably site locations, must be tightly restricted to maintain the integrity of these measures. Project major work efforts, timelines, and expenditures are being provided as discussed below.

- Line 8 (Site Security Project 11504) represents a project to install a security 5 6 station at a power plant site. The work includes modifying utilities, adding 7 road lanes and signage, and installing security barriers and a security 8 building. In 2022, \$2.8 million was spent to complete engineering, procure 9 long lead materials, and bid and award construction. For 2023, \$2.2 million 10 was projected to be spent to continue material procurement and initiate 11 construction including relocation of transmission lines and Company 12 primary utility lines from the power plant site to an adjacent right-of-way. In 2024, \$5.4 million is the projected expenditures required to complete 13 14 construction of project.
- Line 9 (Site Security Project 18700) represents a completed project that
 installed badge card readers at a power plant in January 2023. In 2022, \$15
 thousand was spent on door locks. In 2023, \$52 thousand was spent on
 procuring badge readers and installation of the equipment to complete the
 project.
- Line 10 (Site Security Project 18906) represents a project to install a site
 entrance security building at a power plant. The Company spent \$1
 thousand in 2022 and planned to spend \$0.8 million in 2023 for engineering,
 design, and procurement of the security building and to begin concrete
 foundation construction. The Company plans to spend \$0.3 million in 2024

1		to complete the installation of the security building and tie-in of building
2		utilities.
3		• Line 11 (Site Security Project 20061) represents a project to install a site
4		security fence at a satellite property supporting power plant operations.
5		Prior to the installation of the fence, there was no physical barrier to prevent
6		trespassers from accessing the property. The Company spent \$0.2 million
7		in 2023 to complete this work.
8		• Line 12 (NERC Compliance Project 18885) represents a project to install a
9		NERC-compliant perimeter fence at a power plant for expenditures of \$0.6
10		million in 2022 and \$1.1 million in 2023. The need for the new fence was
11		triggered by the recent retirement and decommissioning of a power plant
12		which was previously providing site security within its protected area.
13		• Line 13 (NERC Compliance Project 19895) represents a project that
14		restored a NERC-compliant perimeter fence in 2023 for \$7 thousand.
15		
16	Q40.	Can you explain lines 14-17 of Exhibit A-12, Schedule B5.1, page 2 of 9?
17	A40.	Lines 14-17 (Sibley Quarry Landfill Modification (CCR), Sibley Quarry Conveyor
18		Installation (CCR), Sibley Quarry Infrastructure Modification (CCR), and Sibley
19		Quarry Landfill Dewatering and Discharging Line) includes costs associated with
20		site improvements required to allow safe and efficient acceptance of the significant
21		quantities of coal combustion residuals (CCR) waste material that are being
22		removed from Monroe Power Plant. Approximately 1 million cubic yards of
23		bottom ash from the Monroe Power Plant inactive bottom ash basin is being
24		transported to Sibley Quarry to meet the EPA's CCR regulation. The improved

Line No.

1

- system will continue to be used after the completion of the Monroe Bottom Ash Basin Closure (CCR) project for continuing waste disposal activities.
- 3 • Line 14 (Sibley Quarry Landfill Modification (CCR)) – The Company spent 4 \$5.6 million in 2022 to install a drain piping shaft (chimney drain) and 5 create a new landfill operation fill plan. In 2023, \$1.8 million was spent to 6 complete the project by installing a filtration system around the drain piping 7 shaft and to relocate equipment to the current ash waste elevation. 8 Approximately 23,000 cubic yards of material had to be moved so that stone 9 could be placed for the chimney drain. Approximately 125,000 cubic yards of course aggregate limestone and approximately 40,000 cubic yards of 10 11 crushed limestone was installed for the 18-ft diameter, 105-ft high chimney 12 drain construction. The Company plans to spend \$8 thousand in 2024 for 13 final project closeout including final paperwork and as-built drawings. This 14 project is required to allow continuing acceptance of bottom ash removed 15 due to the closure of the Monroe bottom ash basin while continuing 16 compliance with the provisions of Part 115, Solid Waste Management, of 17 the Natural Resources and Environmental Protection Act, 1994 PA 451, as 18 amended, and its Solid Waste Disposal Area Operating License number 19 9602.
- Line 15 (Sibley Quarry Conveyor Installation (CCR)) The Company spent
 \$0.4 million in 2022 to complete engineering and installation of a new
 conveyor system that transports material from the designated truck
 unloading area to the bottom of the quarry.
- Line 16 (Sibley Quarry Infrastructure Modification (CCR)) The Company
 spent \$1.8 million in 2022 to engineer and construct a road, truck unloading
| Line | |
|------------|--|
| <u>No.</u> | |

1		pad, and temporary office to support the increasing levels of activity the site
2		will experience in support of the Monroe ash removal tasks supporting CCR
3		and ELG requirements. The Company spent \$9 thousand in 2023 for final
4		project close out costs.
5		• Line 17 (Sibley Quarry Landfill Dewatering and Discharging Line) – The
6		Company spent \$1.8 million in 2022 to replace a portion of the piping that
7		transports accumulated ground water out of the Sibley Quarry to the Detroit
8		River in compliance with its National Pollutant Discharge Elimination
9		System (NPDES) permit. The replaced portion of pipe is approximately
10		4,400 linear feet. The previous discharge piping was failing and required
11		replacement. The Company spent \$32 thousand in 2023 for project closeout.
12		
13	Q41.	Can you explain line 20 of Exhibit A-12, Schedule B5.1, page 2 of 9?
14	A41.	Line 20 (Monroe Bottom Ash Basin Closure (CCR)) represents a project to remove
15		all bottom ash from the inactive bottom ash basin at Monroe Power Plant to meet
16		an obtion ash non the mactive bottom ash bash at wombe I ower I fait to meet
		the EPA's CCR regulation. This project includes the removal of approximately 1
17		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe
17 18		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project
17 18 19		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project typically utilizes up to 10 trucks per day, each able to transport approximately 40
17 18 19 20		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project typically utilizes up to 10 trucks per day, each able to transport approximately 40 tons of bottom ash per load. Each truck averages five loads per day for the 46-mile
 17 18 19 20 21 		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project typically utilizes up to 10 trucks per day, each able to transport approximately 40 tons of bottom ash per load. Each truck averages five loads per day for the 46-mile roundtrip commute between Monroe Power Plant and Sibley Quarry. The trucks
 17 18 19 20 21 22 		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project typically utilizes up to 10 trucks per day, each able to transport approximately 40 tons of bottom ash per load. Each truck averages five loads per day for the 46-mile roundtrip commute between Monroe Power Plant and Sibley Quarry. The trucks only operate from March to November because cold winter weather is not suitable
 17 18 19 20 21 22 23 		the EPA's CCR regulation. This project includes the removal of approximately 1 million cubic yards, equal to over 1 million tons, of bottom ash from the Monroe inactive bottom ash basin and its transportation to Sibley Quarry. This project typically utilizes up to 10 trucks per day, each able to transport approximately 40 tons of bottom ash per load. Each truck averages five loads per day for the 46-mile roundtrip commute between Monroe Power Plant and Sibley Quarry. The trucks only operate from March to November because cold winter weather is not suitable for bottom ash material dewatering required for transport.

Line
<u>No.</u>

<u>NO.</u>		
1		The project received Company approval in December 2019. The final EPA CCR
2		Rule requires closure to be initiated as soon as technically feasible, but no later than
3		April 11, 2021 and be completed within five years. Closure was initiated on
4		October 21, 2020.
5		
6		In 2022, \$15.4 million was spent to complete the transport of 0.6 million cubic
7		yards of bottom ash from Monroe Power Plant that began in 2021.
8		
9		For 2023, \$14.6 million was projected to be spent to continue bottom ash material
10		removal from the Monroe basin and its transportation to Sibley Quarry.
11		
12		In 2024, \$11.9 million is projected to be spent to complete the bottom ash removal
13		and transportation. The closure of the Monroe bottom ash basin is expected in the
14		summer of 2024. Company Witness Lee describes the Company's closure plans
15		for multiple CCR sites in further detail in his direct testimony.
16		
17	Q42.	Can you explain lines 21 and 49 of Exhibit A-12, Schedule B5.1, page 2 of 9?
18	A42.	Lines 21 and 49 (Monroe Fly Ash Basin Closure (CCR)) represent a project
19		required by federal and state regulations. The existing Monroe Power Plant fly ash
20		basin will cease operations and be closed in place by dewatering the pond, grading
21		the existing fly ash, and installing an impervious synthetic membrane cover. The
22		existing fly ash basin utilizes a 400-acre pond with water depths up to 40 feet to
23		contain approximately 25 million cubic yards of fly ash. The Company spent \$0.5
24		million in 2022 to complete studies for conceptual compliance with the regulatory
25		requirements and selection of the detailed engineering and design contractor.

Line
No.

1	For 2023, \$4.5 million was projected to be spent to begin engineering and design.
2	During 2023, the engineering and design contractor initiated the dewatering system
3	design and capping plan, existing site documents were updated, field sampling of
4	soils was performed, site topography was surveyed, and a site grading plan was
5	established. Significant work effort was required to prepare the large number of
6	permits required by various municipalities, agencies, and authorities including U.S.
7	EPA, Michigan EGLE, Monroe County Drain Commission, Monroe County Road
8	Commission, and Monroe Township. The operating plan license agreement for the
9	basin closure project was prepared and filed with Michigan EGLE in 2023.

In 2024, \$5.0 million will be spent to continue engineering and design and develop a request for proposal to perform the basin closure. Engineering and design scope in 2024 will include fly ash basin dewatering and a water treatment system that complies with all applicable environmental limits. Additionally, the engineering and design contractor will develop an RFP to solicit bids from construction management firms for project execution. The RFP will be issued in the fourth quarter 2024.

18

In 2025, \$25.0 million is projected to award the ash basin closure construction contract and begin project construction. In accordance with the Company's 2022 IRP Order, recovery of Monroe Power Plant investments for this project made after January 1, 2025 will be through a regulatory asset, shown on line 49 of Exhibit A-12, Schedule B5.1, page 2 of 9. This project is required by the EPA's CCR Rule as discussed in Witness Lee's testimony.

25

Line <u>No.</u>

1 Q43. Can you explain line 22 of Exhibit A-12, Schedule B5.1, page 2 of 9? 2 A43. Line 22 (St. Clair Bottom Ash Basin Closure (CCR)) represents a project to clean 3 and close the St. Clair bottom ash basins by removal of all the CCR material, 4 decontamination, disposal, and basin backfill. The St. Clair bottom ash basins were 5 subject to forced closure per the CCR Rule requiring them to cease receipt of waste 6 and initiate closure as soon as technically feasible but by no later than April 11, 7 2021. As discussed in Witness Lee's testimony, the Company submitted a Part A 8 Rule demonstration for the St. Clair bottom ash basins, requesting an alternative 9 closure deadline based on cessation of coal-fired generation operations in spring of 10 2022, and a commitment to complete closure of the basins by October 17, 2023. 11 The Company initiated closure on September 1, 2022 and withdrew the requested 12 approval for a Part A Rule demonstration. 13 14 In 2022, \$7.9 million was spent to complete the detailed engineering, analysis of soil borings, and elimination of source lines, followed by removal and 15 16 transportation of bottom ash from the basins to Range Road Landfill and backfill 17 the basins. 18 19 In 2023, \$0.4 million was spent on final project closure costs, including final 20 disposal of bottom ash, final backfilling, and issuance of a closure report. Basin 21 closure was completed in the first quarter of 2023. 22 23 Can you explain lines 23-28 of Exhibit A-12, Schedule B5.1, page 2 of 9? **Q44**. 24 A44. Lines 23-28 detail steam plant removal costs associated with the retirement and 25 decommissioning of power generation assets at Harbor Beach, Conners Creek,

Line	
No	

<u>INO.</u>		
1		River Rouge, St. Clair, and Trenton Channel Power Plants. Removal of retired
2		steam generating units involves three primary activities, namely decommissioning,
3		decontamination, and demolition. Decommissioning activities include the cost to
4		isolate all unit systems and equipment to prepare them for removal from the site.
5		This includes electrical, mechanical, plant controls, water and gas service
6		shutdown, and electrical isolation from the transmission system. Decontamination
7		includes disposing of hazardous materials (including draining oils, chemicals, and
8		other fluids), cleaning tanks and pipelines, and removal of batteries and battery
9		systems. Demolition includes asbestos and lead abatement, tearing down buildings,
10		and removing and remediating the coal pile, ash basins, and ponds.
11		
12	Q45.	Can you explain line 23 of Exhibit A-12, Schedule B5.1, page 2 of 9?
13	A45.	Line 23 (Harbor Beach Decommissioning) is a project that finalized all site
14		activities associated with the decommissioning and subsequent demolition of the
15		Harbor Beach Power Plant. The Company spent \$17 thousand in 2022 for
16		monitoring the site developer's compliance to the sales contract terms.
17		
18	Q46.	Can you explain line 24 of Exhibit A-12, Schedule B5.1, page 2 of 9?
19	A46.	Line 24 (Conners Creek Seawall) was a project that restored the integrity of the
20		seawall at the Conners Creek Power Plant site through installation of new sheet
21		piling and associated shoreline repairs. The work was required to restore the
22		integrity of the site waterfront to address rising water levels and the existing
23		seawall's deteriorating condition that included separated tiebacks, undulating

25 sloughing into and impacting the Detroit River. The project was completed with

MEG-37

pilings, and corroded piles. Without this work the shoreline was at risk for

I	j	n	e
_			

<u>No.</u>

an expenditure of \$8.1 million in 2022 while fulfilling the permitting requirements
 of the US Army Corps of Engineers and Michigan EGLE.

3

4 Q47. Can you explain line 25 of Exhibit A-12, Schedule B5.1, page 2 of 9?

5 A47. Line 25 (River Rouge Decommissioning) is a project to fully decommission and 6 remove all plant structures including waste products from the site that has been in 7 operation for approximately 70 years. In the instant case, capital expenditures for 8 the River Rouge Power Plant decommissioning project support achieving a cold, 9 dark, and dry status by the end of 2024. This terminology refers to a state in which 10 the facility does not require heat or power, and all fluids have been removed from 11 their respective tanks, reservoirs, and piping systems. Project approval was 12 received from the Company in January 2023. The Company will address and 13 request the remaining decommissioning expenditures beyond achieving a cold, 14 dark, and dry state in a future rate case.

15

In 2022, \$13.0 million was spent to complete work that began in 2021 involving environmental and site assessments. The Company also began plant electrical grid isolation, removed plant natural gas feeds, performed industrial cleaning that included removal of coal, oil, and chemicals from the site. The Company began work in 2022 towards achieving a cold, dark, and dry state for the plant. Additionally, plant utilities, such as city water and natural gas supply, have been separated from the power plant proper and site outbuildings.

23

In 2023, \$21.1 million was spent to start asbestos abatement, environmental clean up, equipment removal, and continue electrical isolation of the power plant and site

Line <u>No.</u>

3

outbuildings. Independence Demolition of Michigan was selected for initial work
 activities.

In 2024, \$12.8 million is projected to be spent to complete electrical isolation of the power plant and outbuildings by end of second quarter of 2024 and establish a construction power feed for construction and various plant assets. Electrical isolation of the plant will complete the process of making the plant cold, dark, and dry.

9

10 Q48. Can you explain line 26 of Exhibit A-12, Schedule B5.1, page 2 of 9?

- 11 Line 26 (St. Clair Decommissioning) is a project to decommission St. Clair Power A48. 12 Plant, which was in operation for approximately 70 years. The St. Clair 13 decommissioning was originally planned as a single project to achieve site 14 demolition and final site grading. Due to the fact that coal handling equipment, 15 boat unloading, firefighting, and control systems located on St. Clair property and 16 within the St. Clair Power Plant proper must be kept in-service until Belle River 17 Power Plant ceases coal-fired operations at the end of 2026, it was decided to 18 perform the St. Clair demolition project in two phases. Full Company authorization 19 for the first St. Clair decommissioning project to achieve cold, dark, and dry status 20 by the end of 2024 was received on March 22, 2023. The project scope discussed 21 below is associated with the first project. The Company will address and request 22 the second project in a future rate case.
- 23

In 2022, \$9.9 million was spent to sample for asbestos, lead, and PCBs, and to
 define site conditions. The Company also performed decontamination work,

Line
<u>No.</u>

10.		
1		including the draining of oils, vacuuming of ash, washdown of boilers, and removal
2		of chemicals, and started evaluating the work required to electrically separate the
3		plant from the electrical grid. Engineering of systems to isolate plant water
4		connections to the environment was also completed, while still maintaining
5		operations of environmental systems, such as wastewater monitoring and oily waste
6		treatment.
7		
8		For 2023, \$21.9 million was projected to be spent to continue work to achieve a
9		cold and dry state in the plant and start asbestos abatement. Environmental clean-
10		up and equipment removal in exterior outbuildings along with their demolition will
11		be initiated. All basins will also be emptied, cleaned and filled in 2023.
12		
13		In 2024, \$13.0 million is projected to be spent to complete electrical isolation of
14		the plant from the electrical grid and continue abatement and demolition of exterior
15		outbuildings, namely structures associated with cooling water outfalls. Completion
16		of the electrical isolation work will place the plant in a dark state, completing all
17		cold, dark, and dry scope in the first project to decommission the St. Clair Power
18		Plant.
19		
20	Q49.	Can you explain line 27 of Exhibit A-12, Schedule B5.1, page 2 of 9?
21	A49.	Line 27 (Trenton Channel Decommissioning) is a project to fully decommission
22		and remove all plant structures including waste products from the Trenton Channel
23		Power Plant site that has produced power for approximately 100 years.
24		

Ι	Jir	ıe
N	Jo	

2

3

4

5

6

7

In 2022, \$10.0 million was spent to perform industrial cleaning, remove coal, oil, chemicals, lead, and asbestos, and initiate electrical isolation of the power plant. Additionally, the plant's natural gas feed was removed. All of these efforts were required to reach a cold, dark, and dry state for the plant. The Company also completed environmental and site assessments and developed a bid specification for site demolition and grading.

For 2023, \$48.7 million was projected to be spent to continue decommissioning efforts. Work completed in 2023 included awarding of a demolition contract to Independence Demolition of Michigan, initiation of asbestos abatement and environmental clean-up. Equipment removal in plant outbuildings along with their demolition and the plant's electrical isolation was initiated. Electrical isolation of the plant was completed and the plant reached a cold, dark, and dry state. The project received full project approval by the Company in January 2023.

15

In 2024, \$35.0 million is projected to be spent to continue asbestos abatement, removal of equipment inside the plant, and removal of stacks and the main turbine house through explosive demolition. Filling of all basins will be initiated along with the demolition of plant outbuildings in 2024. The stacks are scheduled to be demolished in March 2024 and the main turbine house will be demolished in May 2024. The Company will also begin final site grading and soil remediation activities.

23

Line <u>No.</u>		
1		In 2025, \$6.9 million is projected to be spent to conclude soil remediation and
2		complete final site grading. Performing these activities in the second quarter of
3		2025 will complete the decommissioning process.
4		
5	Q50.	Can you explain line 28 of Exhibit A-12, Schedule B5.1, page 2 of 9?
6	A50.	Line 28 (Trenton Channel Sea Wall) represents a project to restore the integrity of
7		the seawall at the Trenton Channel Power Plant and the installation of a pedestrian
8		greenway path along the Detroit River while meeting the permitting requirements
9		of the US Army Corps of Engineers, Michigan EGLE, and the City of Trenton. The
10		work includes removal of deteriorated sheet piles, maintenance of existing piles and
11		installation of new piles along the Detroit River and Slocum Canal shorelines.
12		Without this work, the shoreline was at risk for sloughing into and contaminating
13		the Detroit River and Slocum Canal. Development of the pedestrian greenway path
14		was stipulated in the approved demolition permit and will be installed along the
15		Detroit River riverfront after the power plant is demolished and site grading is
16		finalized.
17		
18		In 2023, \$0.4 million was spent to begin engineering and design of the seawall,
19		natural shoreline, and greenway path.
20		
21		In 2024, \$1.0 million is projected to be spent to complete engineering and design
22		of the seawall and begin engineering and design of the greenway path.
23		

Line
<u>No.</u>

2

3

In 2025, \$9.5 million is projected to be spent to complete construction of the seawall for the riverfront and canal and complete engineering, design and construction of the greenway path by the end of 2025.

4

5

Q51. Can you explain line 32 of Exhibit A-12, Schedule B5.1, page 2 of 9?

6 A51. Line 32 (Ludington Upgrades) represents an efficiency upgrade project at the 7 Ludington Pumped Storage Facility that was being managed by Consumers Energy, 8 Ludington's majority owner. The projected expenditures represent DTE Electric's 9 49 percent share of project costs. The upgrades of the six Ludington generating 10 units began in 2013. Ludington Unit 3, the final unit upgraded, had its work 11 completed for \$10.0 million in 2022 and \$1.5 million in 2023. Ludington Unit 3 12 returned to service on 2022, with a 34 MW increase of rated capacity now at 187 13 MW (DTE Electric's ownership percentage).

14

15 Q52. Can you explain line 35 of Exhibit A-12, Schedule B5.1, page 2 of 9?

16 A52. Line 35 (Blue Water Energy Center (CCGT)) represents a project to build a 1,127 17 net MW (summer-rated capacity) CCGT generating plant on 40 acres of Company 18 property adjacent to the existing Belle River Power Plant. This location was 19 strategically selected due to its proximity to transmission lines and high-pressure 20 natural gas pipeline infrastructure. The plant completed construction and became 21 commercially operational in June of 2022. The unit generated 4,593 GWh during 22 its first seven months of operation at an ROF less than 5% and a net heat rate of 23 only 6,492 BTU/kWh.

24

Line <u>No.</u>		
1		On April 27, 2018, the MPSC issued an Order in Case No. U-18419 approving DTE
2		Electric's construction of this plant and authorized the Company to recover up to
3		\$951.8 million in costs for the plant through future rates.
4		
5		In 2022, \$11.8 million was spent to support plant startup, testing, and
6		commissioning.
7		
8		For 2023, the Company expected a net credit to the project in the amount of \$4.5
9		million, primarily driven by a \$1.4 million credit in March 2023 for a refund from
10		ITC that came in higher than anticipated due to an interest rebate and a \$3.2 million
11		credit in June 2023 for a Canadian tax refund on natural gas purchased to support
12		startup testing.
13		
14		In 2024, \$6.0 million is projected to be spent to complete punch list items and as-
15		built drawings.
16		
17		Final project costs are awaiting completion of final punch list items and as-built
18		drawings in 2024. The Company currently projects total project costs of \$946.5
19		million, which is below the \$951.8 million approved by the Commission. This is
20		an outstanding outcome, especially given the fact the project was constructed in the
21		midst of the COVID-19 pandemic.
22		
23	Q53.	Can you explain line 36 of Exhibit A-12, Schedule B5.1, page 2 of 9?
24	A53.	Line 36 (BWEC Transmission Upgrades) represents transmission upgrades
25		required for BWEC to acquire MISO generator interconnection rights. Since

<u>No.</u>		
1		transmission network upgrades were excluded from the \$951.8 million approved
2		for the construction of BWEC in MPSC Case No. U-18419, this project is distinct
3		from line 35 (Blue Water Energy Center (CCGT)).
4		
5		In 2022, \$5.5 million was booked for ITC transmission tower modifications. Due
6		to the transmission line routing from the plant's electrical mat to the ITC substation,
7		existing ITC transmission towers and their connecting transmission lines were
8		raised to accommodate the installation of the dedicated BWEC transmission lines
9		crossing under them.
10		
11		In 2023, a refund of \$4.8 million was credited back against the \$9 million paid in
12		2021 for the Benton Harbor transformer project. This credit was received after new
13		generating projects completed by other companies requested rights to and
14		compensated the Company for utilizing part of the grid transmission capabilities
15		previously funded by the Company through this project.
16		
17	Q54.	Can you explain line 37-39 of Exhibit A-12, Schedule B5.1, page 2 of 9?
18	A54.	Lines 37-39 (Blackstart Projects 1-3) represent projects that support the North
19		American Electric Reliability Corporation (NERC) black start plan. Each region
20		designates certain generating plants as black start units. A black start unit is one
21		that can startup utilizing only its own internal power without support from the grid
22		in the event of a major grid blackout, such as the 2003 blackout. This capability is
23		critical to reestablishing grid integrity and restarting non-black start capable power
24		plants following a grid blackout. In the Company's previous rate case, Case No.
25		U-21297, ITC explained, "NERC requires each transmission operator to have a

Line

Line	
<u>No.</u>	

1	system restoration plan (SRP) and that a black start unit is an SRP" and that, "it is
2	critical to the safety and reliance of the grid." ² ITC further cautioned that black
3	start resources are being lost through conventional generation retirements and that
4	the Company's investments in the black start resources will ensure a resilient SRP.
5	The black start unit project details disclosed are limited to maintain the integrity of
6	these critical sites. ITC echoed this need for limited disclosure in the previous rate
7	case, explaining, "the fact that some people outside the Company may have
8	information regarding the black start resource projects (and [are] required to
9	safeguard such information) does not vitiate the need for confidentiality and
10	sensitive treatment of these projects." ³ The Commission was persuaded of the
11	importance of these projects in maintaining grid security in their Final Order dated
12	December 1, 2023 ⁴ , in Case No U-21297. Project major work efforts, timelines,
13	and expenditures are discussed in detail below.
14	

- Line 37 (Blackstart Project 10570 & 20255) represents a project that
 provides fuel and controls systems capabilities to enable a peaker site to
 startup without power from the grid. The project received Company
 approval in 2021.
- 19

In 2022, \$20.7 million was spent to complete design and initiate construction of fuel system modifications, develop, award, and initiate execution of mechanical erection contracts, and finalize the electrical erection specifications.

² December 1 order, page 42

³ December 1 order, page 43

⁴ December 1 order, page 43

Line <u>No.</u>	
1	
2	For 2023, \$10.4 million was projected to be spent to complete the fuel
3	system modifications and testing and to install major electrical components.
4	
5	In 2024, \$2.2 million is projected to be spent to complete all construction
6	activities, commission the installed equipment, and perform final project
7	closeout activities including drawing updates.
8	
9	• Line 38 (Blackstart Project 17611) represents a project that provides an
10	existing site new equipment and controls that enable the peaker site to
11	startup without power from the grid. The project received Company
12	approval in June 2022.
13	
14	In 2022, \$0.1 million was spent on project management activities.
15	
16	In 2023, \$2.0 million was spent to bid and procure switchgears and two
17	generators and to complete engineering efforts.
18	
19	In 2024, \$6.1 million is projected to be spent to complete all construction
20	activities and commission the installed equipment.
21	
22	• Line 39 (Blackstart Project 18320) represents a project that provides an
23	existing site equipment and controls that enable the peaker site to startup
24	without power from the grid. The project received Company approval in
25	January 2023.

Line <u>No.</u>		
1		In 2022, \$1.1 million was spent to initiate the project, bid and award
2		engineering, and procure the diesel generators and automatic transfer
3		switch.
4		
5		For 2023, \$4.0 million was projected to be spent to bid and award equipment
6		installation, receive project materials, perform the equipment installation,
7		and commission the installed equipment. This allows the unit to return to
8		service until final long lead material is received in 2024.
9		
10		In 2024, \$0.4 million is projected to be spent to receive final long lead
11		transfer switch, complete equipment installation, commission, and close out
12		the project.
13		
14	Q55.	Can you explain line 40 of Exhibit A-12, Schedule B5.1, page 2 of 9?
15	A55.	Line 40 (Slocum Battery Pilot) represents a project to replace the diesel-fueled
16		peakers at the Company's Slocum peaker site located in the City of Trenton with a
17		14 MW / 56 MWhr lithium-ion (Li-ion) BESS. The BESS will store excess energy
18		that is generated on the grid during off-peak hours. This energy will then be
19		available for dispatch during higher-priced peak hours.
20		
21		In 2022, \$7.6 million was spent for vendor selection and initial engineering work.
22		These work activities included a bid specification and RFP for major equipment.
23		Vendors for major equipment were selected and progress payments for long lead
24		materials (i.e., batteries and transformer) were initiated. Those progress payments
25		included two payments to the transformer supplier and one payment to the battery

Line <u>No.</u>		
1		supplier. Delivery of all major equipment is scheduled to occur between the first
2		quarter and third quarter of 2024.
3		
4		In 2023, \$10.1 million was spent to finish engineering, continue the procurement
5		of materials, complete the construction bid package, and issue and award an RFP
6		for construction. Additionally, the existing diesel peakers and their supporting
7		equipment were decommissioned and removed from the site.
8		
9		In 2024, \$26.8 million is projected to be spent to support a 2024 installation and
10		startup of BESS commercial operations in November 2024.
11		
12		In 2025, \$0.1 million is projected to be spent for final project closeout costs.
13		
14	Q56.	What is the Slocum Battery Pilot anticipated total project cost?
15	A56.	The Slocum Battery Pilot project costs are projected to be \$44.7 million. That
16		amount has increased from prior projections primarily due to increases in lithium
17		costs and actual construction bids received. Despite the cost increases, the Slocum
18		battery pilot continues to provide the Company valuable insights and learnings on
19		a small-scale project which will help the Company, contractors, and local
20		municipalities succeed on the planned larger scale upcoming projects.
21		
22	Q57.	Can you explain line 41 of Exhibit A-12, Schedule B5.1, page 2 of 9?
23	A57.	Line 41 (Trenton Channel Energy Center BESS) represents expenditures associated
24		with a 220 MW / 880 MWhr Li-ion BESS build, consistent with the build plan
25		approved in the Company's 2022 IRP Order. The forecast includes the

Line <u>No.</u>	
1	expenditures needed for engineering and long lead material procurement to support
2	a 220 MW BESS starting commercial operations in 2026. The project received full
3	internal Company approval in October 2023.
4	
5	In 2023, \$5.3 million was spent to bid and award equipment, and procure long lead
6	materials (i.e., electrical breakers and transformer).
7	
8	In 2024, \$120.7 million is projected to be spent to take delivery of major electrical
9	equipment and begin site preparation and construction in the fourth quarter of 2024.
10	The Company executed contracts with the EPC contractor and battery vendor in
11	January 2024, and these were submitted to the MPSC as noted below.
12	
13	In 2025, \$291.9 million is projected to be spent to take delivery of batteries and
14	electrical collection equipment for the battery inverters and complete construction
15	of the substation and BESS electrical switchyard.
16	
17	As required in the Company's 2022 IRP Case No. U-21193, contracts totaling \$334
18	million, which represents nearly 80% of the total projected spend for this project,
19	were approved by the Commission in March 2024 in Case No. U-21566. The
20	remaining 20% of project costs, totaling \$89 million, include interconnection costs
21	and permits (\$23 million), BESS commodities and environmental remediation (\$10
22	million), subgrade stabilization and fire suppression (\$10 million), auxiliary
23	transformer (\$2 million), DTE labor (\$3 million), owner's engineer and expert
24	support costs (\$6 million), project overheads (\$16 million), and AFUDC (\$19
25	million). The Company plans for the Trenton Channel Energy Center BESS to

Line
<u>No.</u>

10.		
1		reach commercial operations in March 2026. Therefore, it is classified as
2		construction work in progress (CWIP) through the projected period of this case. As
3		explained by Witness Uzenski, projects in CWIP with an AFUDC offset do not
4		impact the revenue requirement.
5		
6	Q58.	Can you explain line 42 of Exhibit A-12, Schedule B5.1, page 2 of 9?
7	A58.	Line 42 (Northeast 11-1 Decommissioning) represents a project to decommission
8		the Northeast 11-1 peaker unit that retired in 2023.
9		
10		For 2023, \$0.3 million was projected to be spent to electrically disconnect the
11		generator from the electrical grid, drain lube oil from the generator, and begin
12		engineering of the decommissioning project. Engineering work will include
13		environmental protections, isolation of fuel source, disabling of the fire protection
14		system, and plant controls systems modifications.
15		
16		In 2024, \$0.3 million is projected to be spent to complete engineering of the
17		decommissioning and execute the separation work needed on the peaker unit.
18		
19	<u>Routi</u>	ne Capital Expenditures
20	Q59.	What information is provided on page 3 of Exhibit A-12, Schedule B5.1?
21	A59.	Page 3 provides a summary of the routine capital expenditures for steam power,
22		hydraulic power (Ludington), and other power generation facilities from the
23		beginning of 2022 through December 31, 2025, broken down by site and by major
24		spending category. Routine capital projects include projects to maintain plant
25		reliability, maintain environmental compliance, provide safe operation of

<u>NU.</u>		
1		equipment, and improve efficiency, all with a focus on providing the customer
2		affordable, low-cost generation. The Company has included all Monroe routine
3		2025 expenditures in a regulatory asset shown on Exhibit A-12, Schedule B5.1,
4		page 3, line 13, consistent with the Commission's final Order in the Company's
5		2022 IRP filing, Case No. U-21193.
6		
7	Redu	ctions to Monroe Unit 3 and 4 Capital Expenditures and Updates to the Capital
8	<u>Proje</u>	cts Planned
9		
10	Q60.	What types of work do typical Monroe Power Plant major periodic outages
11		include?
12	A60.	Monroe units are brought offline once every four years for approximately three
13		months to perform major periodic outages. During these outages, major
14		maintenance is performed on the unit's systems, such as the boiler and steam
15		turbines, to ensure future safe, reliable, efficient, and environmentally compliant
16		operations.
17		
18	Q61.	As Monroe Units 3 and 4 approach retirement scheduled for the end of 2028,
19		how has the Company modified its periodic outage capital expenditure plans?
20	A61.	Prior to the Company's 2022 IRP in which the Company advanced the timing of
21		the retirement of Monroe Units 3 and 4 from 2040 to 2028, the Company was
22		anticipating investing over \$200 million of capital expenditures during the Monroe
23		Unit 3 2024 and Monroe Unit 4 2025 periodic outages to replace sections of boiler,
24		replace turbine rotors and blades, and perform other maintenance critical for
25		extended unit operation. Given the limited timeframes between the upcoming

Line
<u>No.</u>

1		Monroe Unit 3 and 4 periodic outages and their pending retirements in 2028, the
2		Company has scaled back or eliminated many capital projects previously planned
3		to support operations until 2040. The planned scope reductions will lower routine
4		large capital expenditures by approximately 50 percent, to just over \$100 million
5		for the Monroe Unit 3 and 4 periodic outages in 2024 and 2025. In addition to this
6		reduction in Monroe Unit 3 and 4 routine capital project periodic outage
7		expenditures, an additional \$100 million of regulatory-mandated non-routine ELG-
8		related investments for these units is no longer required and customers have been
9		saved the expenditures.
10		
11	Q62.	Has the Company discussed changes in capital projects on Monroe Units 3 and
12		4 under a 2028 retirement in a previous filing?
13	A62.	Yes. In the Company's 2023 electric rate case, MPSC Case No. U-21297, the
14		Company delineated the avoidable and unavoidable capital expenditures that would
15		be possible if Monroe Units 3 and 4 were to retire in 2028. Since that filing, further
16		information has come to light that has resulted in updates to the scope and costs of

and 4 periodic outages.

17

19

Q63. What routine capital project scope planned for the Monroe Unit 3 periodic outage in 2024 required updating since the last rate case, Case No. U-21297?

the unavoidable capital investment requirements for the upcoming Monroe Unit 3

A63. Since the initial filing of the last rate case, nine projects have been cancelled on
 Monroe Unit 3 with seven other projects being executed as previously planned.
 Recent unit equipment inspections and failures have also triggered the Company to
 move forward with two capital projects not previously anticipated to be required

Line	
<u>No.</u>	

1 under a 2028 retirement. These projects now deemed as required at this time 2 include the Air Heater Cold-End Basket Replacement Project and the Horizontal 3 Reheat Tube Replacement Project. Additionally, the Company has determined that 4 the turbine valve project should fully overhaul all eight governor valves based on 5 age and condition of internal parts and four throttle valves due to valve seats 6 cracking and weld failures. The original turbine valve project anticipated requiring 7 only limited inspections and repairs of some of the valves which previously made 8 that portion of the work an O&M expense instead of a capital asset replacement. 9 Finally, the Company has reduced the Unit 3 DCS project by approximately 40 10 percent to focus on only completing work scope critical for continued unit 11 operations until retirement of the unit at the end of 2028. I elaborate on these 12 project justifications and further explain these updates below.

13

14 Q64. What is the current condition of the Monroe Unit 3 air heater cold-end 15 baskets?

16 A64. The Monroe Unit 3 air heater cold-end baskets were installed in 2015 and have a 17 typical life expectancy of 7-10 years. The existing baskets are failing due to 18 material loss caused by normal operational corrosion. Recent inspections show 30 19 percent of the basket material has been lost. If the air heater baskets are not 20 replaced, continued material loss will cause air heater imbalances requiring unit 21 outages to clean and balance the air heater, while risking likely drive gear failures. 22 A gear drive failure will cause the unit to be in a multi-week forced outage until 23 repairs to the air heater(s) are completed. The plant has already experienced two 24 air heater failures in recent years on Monroe Unit 2, in which elements fell out and 25 jammed the air heater drive resulting in multi-week forced outages. Additionally,

Line No.

not performing the project would increase the heat rate of future operations.
Furthermore, the discounted payback for the project was calculated to be 2.2 years,
well within the projected operating life of the unit. Alternatively, if this project was
not completed, in addition to the costs associated with cleaning and balancing the
air heaters, the forecasted costs to customers from each air heater failure event
between 2024 and 2028 would be \$0.5 million in repair costs and over \$3 million
in purchase power expense during a 2-week forced outage repair.

8

9 Q65. What is the current condition of the Monroe Unit 3 horizontal reheater?

10 A65. The Monroe Unit 3 horizontal reheater is original to the unit and is failing due to 11 oxygen pitting corrosion and fly ash erosion. Since Monroe Unit 3's last periodic 12 outage in 2019, the unit experienced nineteen horizontal reheater tube leaks, forcing 13 the unit offline for multiple weeks to perform repairs. During inspection of the 14 failed reheater tubes, oxygen pitting damage was found. The Company plans to 15 replace 4,000 linear feet of tubes in the most heavily damaged areas to minimize 16 future horizontal reheater tube leaks until the unit's 2028 retirement. Without the 17 project, the Company anticipates at least one additional tube leak outage requiring 18 extensive repairs each year. Reheater repairs are difficult and often lengthy because 19 tight tube spacing can necessitate cutting away undamaged tubes to gain access to 20 complete required repairs and then restoring those removed tubes to complete the 21 repair effort. Additionally, such tube failures often cause collateral damage to 22 surrounding tubes. The discounted payback for the project was calculated to be 1.8 23 years, well within the projected operating life of the unit. Alternatively, if this 24 project was not completed, the forecasted costs to customers from each horizontal 25 reheater tube leak event between 2024 and 2028 would be \$0.5 million in repair

Line <u>No.</u>		
1		costs and over \$3 million in purchase power expense during a 2-week forced outage
2		repair.
3		
4	Q66.	What scope was added to the Monroe Unit 3 Turbine Valves project in the
5		2024 periodic outage since the last rate case, Case No. U-21297?
6	A66.	In 2023, further analysis of turbine valve scope was completed, leading to updated
7		repair plans for the governor valves and throttle valves.
8		
9		That further analysis included a review of age and condition of internal valve
10		components which indicated that the eight governor valves needed to have their
11		stems, bushing, and seats replaced. This scope of work will ensure proper operation
12		of this critical safety system that is required for turbine control and safe shutdown.
13		
14		Additionally, the Company plans to overhaul all four Monroe Unit 3 throttle valves
15		due to the valve seat failures observed in 2022 at Belle River Power Plant. Over
16		many years of normal operations at high temperatures (1000°F), valve seats
17		containing stellite alloys become brittle, crack, and fail, causing damage to
18		downstream turbine blades. Thus, the Company plans to proactively replace the
19		throttle valve seats before turbine damage occurs.
20		
21		Without routine overhaul of these valves, there is risk of the valves not functioning
22		properly, leading to damage to the unit's turbines or an overspeed condition
23		resulting in catastrophic turbine failure. Accordingly, this project is classified as a
24		safety project.
25		

Line <u>No.</u>

Q67. What is the status of the Monroe Unit 3 DCS and Control Room upgrade project?

3 A67. The Monroe Unit 3 DCS and Control Room project cost has been reduced from 4 \$5.0 million to \$3.1 million. In the Company's 2023 main electric rate case, Case 5 No. U-21297, the costs for this project were excluded from the approved revenue 6 requirement because the Company was reviewing the need for the upgrades and the 7 necessity for the project was less certain. During 2023, the Company reduced the project scope to one that is solely focused on critical work necessary to support 8 9 continued operations. Scope removed from the project included demolition of 10 original alarm panels, integration of a display that monitors and controls electrical 11 control positions throughout the unit, and furniture replacements. Without at a 12 minimum performing this scaled-down project, the Company expects chronic 13 controls component failures to cause derates and outages equivalent to multiple 14 outage days per year. The discounted payback for the project was calculated to be 15 2.2 years, well within the projected operating life of the unit. Additionally, the 16 project maintains consistency in the control systems design and function across all 17 four units at Monroe. This continuity of design and function is critical to avoid 18 human performance errors as operators routinely move from unit to unit.

19

20Q68. Besides scope updates to Monroe Unit 3 periodic outage projects, what21additional updates has the Company included in the filing of the instant rate22case?

A68. The Company has updated cost projections based on the latest information
available. For two projects, the Monroe Unit 3 Coal Mill Classifiers project and
the Monroe Unit 3 Waterwall Tubes project, costs to complete the projects are

Line <u>No.</u>		
1		forecasted to be approximately \$1 million more for each individual project than the
2		scaled down costs estimated in Case No. U-21297.
3		
4	Q69.	Why did Monroe Unit 3 Coal Mill Classifier project cost projections increase
5		since Case No. U-21297?
6	A69.	In Case No. U-21297, the Company inadvertently presented only contractor labor
7		costs as unavoidable costs related to the scaled down version of the Unit 3 Coal
8		Mill Classifier project and did not include materials and overheads to perform the
9		scaled down version of the project. Accordingly, project costs in the instant case
10		now include \$0.6 million for materials and \$0.7 million of overheads (indirect and
11		shared costs). The scope remains consistent with the scaled down version of the
12		project described in Case No. U-21297 and includes replacement of the upper and
13		lower bearings based on OEM recommendations, as opposed to the previously
14		planned full classifier overhaul project that was projected to exceed \$5 million.
15		Alternatively, if the bearings are not replaced, each bearing that fails will require
16		the respective coal mill to be forced offline for emergent repair and result in a
17		derated capacity for the unit. The discounted payback for the project was calculated
18		to be 2.0 years, well within the projected operating life of the unit.
19		
20	Q70.	Why did Monroe Unit 3 Waterwall Tubes project cost projections increase
21		since Case No. U-21297?
22	A70.	In 2023, the Company procured the waterwall materials and evaluated installation
23		labor bids for the Monroe Unit 3 Waterwall Tubes project. While the Commission

25 on MPSC Staff's assumptions that costs would reduce 50 percent if the square

24

excluded 50 percent of the project costs from rate base in Case No. U-21297 based

Line	
No.	

1	footage being replaced was reduced by 50 percent, the actual bids received did not
2	provide the 50 percent reduction assumed by the MPSC Staff. The cost projection
3	for the revised project now totals \$13.6 million, consisting of \$8.8 million for
4	installation labor, \$1.1 million for scaffolding, \$0.5 million for materials, \$0.7
5	million in shared costs, \$0.4 million for inspections, \$0.3 million in other contract
6	labor (including abatement, air monitoring, engineering, electrical, and industrial
7	cleaning), \$0.3 million in DTE Electric labor, and \$1.5 million for overheads. The
8	scope in the instant case remains consistent with the scaled down version of the
9	project described in Case No. U-21297 and includes replacement of 2,000 square
10	feet of waterwall panels, as opposed to a full, 4,000 square foot replacement project
11	that was projected to cost \$19 million. Based on tube thickness measurements and
12	tube wastage trends, in addition to data from other failure modes, Monroe Unit 3's
13	boiler will experience multiple tube leak forced outages annually if the scaled back
14	waterwall replacement project is not completed. The costs to customers from each
15	waterwall tube leak event between 2024 and 2028 is approximately \$0.4 million in
16	repair costs and \$1-2 million in purchase power expense during each 1-week forced
17	outage repair. The discounted payback for the project was calculated to be 2.7
18	years, well within the projected operating life of the unit.

Q71. What projects had their scope updated since the last case, Case No. U-21297, for the Monroe Unit 4 periodic outage in 2025?

A71. In 2023, the Company further reviewed and reduced the Unit 4 DCS Project scope
 to minimize scope to only that scope of work critical for continued operation to
 retirement. Additionally, the need for a reasonable amount of preventative
 maintenance continues to be validated. For example, the Monroe Unit 4 south

Line

- No.
- boiler feed pump condenser project was originally scheduled to be completed in 2025 but required execution in 2023 on an emergency basis.
- 2 3

1

4 **O72**. What is the status of the Monroe Unit 4 DCS and Control Room project?

5 A72. Consistent with the prior discussion involving the Monroe Unit 3 DCS and Control 6 Room project above (Q/A 67), the Monroe Unit 4 DCS and Control Room project 7 has been reduced to \$2.6 million which is the amount necessary to support 8 continued operation and address major reliability risks associated with obsolete 9 equipment which is no longer supported by vendors. Without performing this 10 scaled-down project, the Company expects chronic controls component failures 11 resulting in derates and outages equaling multiple outage days per year. The 12 discounted payback for the project was calculated to be 2.5 years, well within the 13 projected operating life of the unit. Additionally, the project maintains consistency 14 in the control systems design and function amongst all four units at Monroe. This 15 continuity of design and function is critical to mitigating the risk of human 16 performance errors for the operators running the units.

17

18 Q73. Why did the Monroe Unit 4 south boiler feed pump turbine (SBFPT) 19 condenser require retubing in 2023?

20 A73. The south boiler feed pump turbine condenser required retubing in 2023 because in 21 February of 2023 a large number of condenser tubes developed leaks in this 22 equipment which was original to Monroe Unit 4. Over time, the condenser required 23 39 percent of its cooling water tubes to be plugged to stop leaks caused by ammonia 24 grooving, erosion, and stress corrosion cracking. After tubes are plugged, water 25 velocities through the remaining tubes increase causing additional wear. The old

Line	
<u>No.</u>	

	condenser was not capable of providing the heat transfer required to operate the
	boiler feed pump turbine at full capacity without causing turbine blade damage due
	to increased back-pressure. Without the condenser in-service, the unit is limited to
	half load operations. The discounted payback for the project was calculated to be
	1.5 years, well within the projected operating life of the unit.
<u>Routi</u>	ne Capital Expenditures - Steam Power Generation
Q74.	What were the Company's routine capital expenditures completed in 2022 for
	Steam Power Generation?
A74.	During 2022, the Company's Energy Supply group routine capital expenditures
	related to Steam Power Generation were \$219.0 million as shown on Exhibit A-12,
	Schedule B5.1, page 3 of 9, line 7, column (b). These expenditures included the
	following projects that individually exceeded \$1 million as detailed on page 4 of
	Exhibit A-12, Schedule B5.1:
	• The Belle River Unit 1 low pressure (LP) turbine rotors and blades were
	replaced for \$5.4 million (Exhibit A-12, Schedule B5.1, page 4, line 1).
	Inspections had identified blade erosion and rotor cracking that needed to be
	addressed to ensure continued safe and reliable operation of the LP turbines.
	• The Belle River Unit 1 turbine valve actuators were replaced for \$4.0 million
	(Exhibit A-12, Schedule B5.1, page 4, line 2). The original actuators
	provided by the OEM have been replaced across the industry due to
	maintenance issues, lack of spare parts, and an absence of qualified
	companies capable of repairing them. The replacements were required to
	ensure the continued reliable operation of this system that controls turbine
	<u>Routi</u> Q74. A74.

Line
<u>No.</u>

2

3

4

5

6

7

loading. Failure of these valves to properly operate would impact the ability to properly control unit output.

- Waterwall tubes were replaced on Belle River Unit 1 for \$3.8 million (Exhibit A-12, Schedule B5.1, page 4, line 3). The project replaced 2,100 square feet of boiler waterwall panels damaged by the ordinary wear and tear of quench cracking and soot blower erosion to support continued reliable boiler operation.
- 8 Belle River Unit 1 high pressure (HP) turbine blades were replaced for \$3.4 • 9 million (Exhibit A-12, Schedule B5.1, page 4, line 4). During disassembly 10 of the HP turbine stop valves at the start of the 2022 periodic outage, it was 11 discovered that stop valve disk wear-resistant stellite coatings had failed and 12 likely entered the HP turbine. During the previous 2016 periodic outage, the 13 valves were inspected and had shown no indications of dis-bonding failures. 14 Further turbine inspections revealed that 11 rows of rotating and stationary 15 blades of the HP Turbine were suffering from foreign object damage and 16 needed to be replaced. By addressing the damage during this periodic 17 outage, the Company was able to potentially avoid a future significant forced 18 outage likely in excess of 90 days to complete the repair.
- Underground electrical cables (each approximately 1-mile long) from Belle
 River Unit 1 to the condenser cooling water intake structure located on the
 St. Clair River were replaced for \$2.8 million (Exhibit A-12, Schedule B5.1,
 page 4, line 5). The intake structure equipment provides water from the river
 to the plant. Testing of the power feed cables following recent failures had
 indicated degradation of the cables, necessitating replacement to ensure
 continued safe and reliable operation.

Line
<u>No.</u>

1	• The Belle River Unit 1 boiler ignitor system was replaced for \$2.2 million
2	(Exhibit A-12, Schedule B5.1, page 4, line 6). The ignitor system was
3	replaced to address the operational issues that have developed into safety
4	concerns for the operators working the burner decks. The ignitors on Unit 1
5	are original equipment and have been in service since 1984. The
6	performance of the ignitor components has degraded, frequently failing to
7	insert when required, which then requires the operator to manually position
8	these components. This puts the operator at risk to mechanical and electrical
9	hazards.
10	• The Belle River Unit 1 HP turbine valves were rebuilt for \$2.1 million
11	(Exhibit A-12, Schedule B5.1, page 4, line 7) as part of the normal scheduled
12	work on these valves to ensure continued proper operations. The stellite
13	coatings on the valve seat disks were found to be delaminated, releasing
14	foreign material into the turbine requiring extensive HP turbine blade
15	repairs, as discussed above. The HP turbine stop valves and control valves
16	must operate properly to provide overspeed protection for the turbine and
17	prevent possible catastrophic failure.
18	• Belle River Unit 1 primary air heater baskets were replaced for \$2.0 million
19	(Exhibit A-12, Schedule B5.1, page 4, line 8). As air heater baskets
20	deteriorate with age, the basket plates become loose and can drop into the
21	moving ductwork and prevent the air heater from rotating. Without a
22	properly functioning air heater, the unit cannot operate. Additionally, the
23	basket replacements improve boiler efficiency.
24	• A portion of the horizontal middle reheater on Belle River Unit 1 was
25	replaced for \$1.4 million (Exhibit A-12, Schedule B5.1, page 4, line 9). The

Line
<u>No.</u>

2

3

4

5

6

horizontal reheater is located within the downdraft section of the boiler. These tubes were replaced due to preferential corrosion of original construction shop welds that were compromised by acidic corrosion taking place during boiler washes that remove ash and slag accumulations associated with utilization of low sulfur western fuel at the plant. These tubes required replacement to avoid tube failure outages.

Belle River Unit 1 generator phase bushings were replaced for \$1.2 million
(Exhibit A-12, Schedule B5.1, page 4, line 10). In early 2020, the plant
discovered that the Z-phase generator bushing (insulator) seal had failed and
was leaking hydrogen. Inspection of the remaining five (5) generator
bushings identified signs of deterioration requiring replacement to prevent a
failure that would release hydrogen into the plant and force a unit outage.

13 \$1.1 million was spent to rebuild the purple coal mill on Belle River Unit 1 14 due to service hours and lube oil analysis indications of deteriorating internal 15 components (Exhibit A-12, Schedule B5.1, page 4, line 11). Due to the 16 abrasiveness of coal, coal mill parts experience significant wear in the 17 process of converting lump coal to a fine powder consistency suitable for 18 boiler combustion and need to be disassembled, repaired, and components 19 replaced approximately every 10 years. Purple coal mill was last overhauled 20 in 2012 and was due for this work.

Two (2) induced draft (ID) fan motors on Belle River Unit 1 were replaced
 for \$1.0 million (Exhibit A-12, Schedule B5.1, page 4, line 12). These
 motors require overhaul/replacement approximately every 10 years and the
 motors were due for this work.

Line
<u>No.</u>

2

3

4

5

- In preparation for the Belle River Unit 2 planned outage in 2024, \$2.9 million was spent to engineer and procure replacement LP turbine rotors and blades (Exhibit A-12, Schedule B5.1, page 4, line 13). Inspections identified blade erosion and rotor cracking that needed to be addressed to ensure continued safe and reliable operation of the LP turbines.
- 6 The Belle River fuel supply east main coal pile project was completed for 7 \$2.3 million (Exhibit A-12, Schedule B5.1, page 4, line 14). The east main 8 coal pile was used to fuel both St. Clair Power Plant and Belle River Power 9 Plant. When St. Clair Power Plant retired in 2022, the existing equipment 10 required modification to eliminate the risk of safety hazards (fires) due to 11 combustible dust and coal accumulation stranded in the equipment no longer 12 in operation. This modification required the removal of non-operational 13 diverter gates and chutes, removal of dust collector ductwork and installation 14 of new ductwork, installing a new metal (tramp iron) detection system, 15 removal of two abandoned coal bins and four slide gates, installation of a 16 new transfer chute, new instrumentation, and a new dust suppression system. Isolating the abandoned St. Clair Power Plant conveyor systems through 17 18 installation of barriers was required to prevent coal and combustible dust 19 from entering the retired St. Clair Power Plant fuel system where it would 20 create a risk of fire or explosion.
- \$1.8 million was spent to replace the Belle River fuel supply DCS consoles
 (Exhibit A-12, Schedule B5.1, page 4, line 15). The previous system was
 obsolete and required an upgrade to ensure reliable communication and
 eliminate compatibility issues with the Belle River Power Plant DCS.

Line
<u>No.</u>

2

Additionally, this ten-year-old equipment was no longer supported by the vendor.

- 3 Belle River 3TH-8 fuel supply dust collector was replaced for \$1.7 million • 4 (Exhibit A-12, Schedule B5.1, page 4, line 16). The dust collector in the fuel 5 supply system collects dust that is inherent to the transportation of coal via 6 conveyor belts. The dust is collected from multiple points along the fueling 7 system via several large ducts that are under vacuum. The dust collector 8 filters the dust laden air, allowing the clean air to exhaust back to the 9 atmosphere, while the coal dust is transported by screw conveyors back to 10 the conveyor belts. The replacement mitigates combustible dust and 11 complies with the National Fire Protection Association (NFPA) combustible 12 dust guidelines.
- 13 \$1.7 million was spent to begin separation of St. Clair Power Plant from the 14 Fuel Supply system (Exhibit A-12, Schedule B5.1, page 4, line 17). There 15 are a number of systems in the St. Clair Fuel Supply system that are 16 interrelated with the Belle River Power Plant as all coal deliveries to Belle River are unloaded at and pass through the St. Clair Power Plant fuel supply 17 18 system. Although St. Clair Power Plant retired in 2022, these interrelated 19 systems must remain functional to continue fueling the Belle River Power 20 Plant until its ultimate conversion to operation on natural gas. The project 21 scope was to completely separate St. Clair Power Plant from the Fuel Supply 22 System that will continue to be operated in support of Belle River Power 23 Plant. The scope of the separation effort included fire protection, general 24 service water, wastewater, stormwater, low voltage electrical, and medium 25 voltage electrical switchgear systems.

Line
<u>No.</u>

1 •	The Belle River fuel supply CV2 to CV4 transfer chute was replaced for \$1.3
2	million (Exhibit A-12, Schedule B5.1, page 4, line 18). This chute was
3	replaced to prevent combustible coal and dust accumulation that would
4	become a safety hazard.
5•	In preparation of the Greenwood Unit 1 outage in 2025, \$7.6 million was
6	spent on engineering and initial material procurement efforts for LP turbine
7	rotors and blades (Exhibit A-12, Schedule B5.1, page 4, line 19). Stress
8	corrosion cracking of multiple blade root connections needs to be addressed
9	to ensure continued safe and reliable operation of the LP turbines.
10 •	The Greenwood Unit 1 north induced draft (ID) fan was overhauled for \$1.0
11	million (Exhibit A-12, Schedule B5.1, page 4, line 20). Inspections
12	conducted following an instance of abnormal vibration levels revealed
13	bearing wear beyond the operational tolerance specifications and hydraulic
14	fluid leaks. The increasing vibration needed to be addressed to ensure
15	continued reliable operations.
16 •	In preparation for the Monroe Unit 1 2023 periodic outage, \$9.6 million was
17	spent to procure material for fabrication of new LP turbine rotors and blades
18	(Exhibit A-12, Schedule B5.1, page 4, line 21). Inspections were conducted
19	and revealed the expected ordinary wear and tear on the L-0 through L-5
20	blade rows. This project also addressed stress corrosion cracking concerns
21	on the original LP turbine forgings which are an industry-wide safety
22	concern. Additionally, SCR catalyst modules for layers 1, 2, and 4 were
23	purchased for \$4.0 million (Exhibit A-12, Schedule B5.1, page 4, line 22).
24	The catalyst module replacements were required to maintain compliance
25	with air permit emission limits for NOx and ammonia slip guidelines. \$3.9

Line
<u>No.</u>

1	million was spent to begin initiation of the purchase of 4,000 square feet of
2	waterwall tubes (Exhibit A-12, Schedule B5.1, page 4, line 23). The boiler
3	tubes deteriorate due to combined effect of corrosion fatigue, fireside
4	corrosion, creep damage, and tube thinning. Thirty-seven (37) expansion
5	joints were purchased for \$2.7 million (Exhibit A-12, Schedule B5.1, page
6	4, line 24). The replacements were based on near term failure risk which
7	would affect unit reliability, efficiency, and result in a safety risk to plant
8	personnel. \$2.4 million was spent to procure replacement materials for the
9	south air heater hot and cold end baskets (Exhibit A-12, Schedule B5.1, page
10	4, line 25). The previous baskets had degraded due to corrosion and, if not
11	addressed, would become loose, cause an imbalance and lead to a drivetrain
12	failure. The replacements restored physical integrity and heat transfer
13	efficiency of the air heater. \$1.6 million was spent to procure 10,000 linear
14	feet of tubing for replacement of reheat outlet pendants (Exhibit A-12,
15	Schedule B5.1, page 4, line 26). The tubes were prone to stress-induced
16	precipitation hardening failures and required replacement to ensure reliable
17	operation. \$1.6 million was spent to engineer and procure materials for
18	rebuilding the Unit 1 north and south FGD booster fans (Exhibit A-12,
19	Schedule B5.1, page 4, line 27). Due to the corrosive environment in which
20	these fans operate, the fans require repair or replacement of the hub and
21	blades every eight (8) years to avoid component failures and damage to fan
22	internals. This maintenance was due. Engineering and material
23	procurement continued for \$1.1 million for a 1.5 MW backup generator to
24	be installed in 2023 on the Monroe Unit 1 FGD (Monroe Unit 1 FGD Asset
25	Preservation) (Exhibit A-12, Schedule B5.1, page 4, line 28). The backup
Line	

<u>No.</u>	

1	generator provides emergency power to allow stabilization of critical FGD
2	equipment during power failures. This backup generator provides dedicated
3	emergency power to the FGD equipment. This project is also detailed in a
4	new report (Exhibit A-12, Schedule B5.1.1) as requested in the Commission
5	Order in Case No. U-21297. The report demonstrates the reasonableness
6	and prudence of the FGD Asset Preservation projects, including the fact that
7	the costs of installing FGD back-up generators now are the same as installing
8	the generators during initial FGD construction 15 years ago, the risks of
9	damage associated with not having back-up generators during a loss of
10	power, and the potential future uses of the generators after the Monroe units
11	retire. Finally, \$1.1 million was spent to start engineering and procurement
12	of materials to replace the existing Monroe Unit 1 coal mill primary air duct
13	and damper (Exhibit A-12, Schedule B5.1, page 4, line 29). The previous
14	ductwork had thinned, allowing fugitive dust leaks, creating fire and other
15	safety risks.
16 •	4,000 square feet of Monroe Unit 2 waterwall tubes were replaced for \$16.8
17	million (Exhibit A-12, Schedule B5.1, page 4, line 30). The boiler tubes had

17 million (Exhibit A-12, Schedule B5.1, page 4, line 30). The boiler tubes had 18 deteriorated due to the combined effects of corrosion fatigue, fireside 19 corrosion, creep damage, and tube thinning. Boiler tubes sections were 20 replaced with material that incorporates an Inconel weld overlay protective 21 coating that is resistant to the harsh reducing atmosphere boiler combustion 22 zone conditions. Inconel protective coatings have been utilized for over 10 23 years and have proven extremely well-suited for this application.

Line <u>No.</u>	
1	• IP turbine blades were replaced on Monroe Unit 2 for \$4.3 million to
2	eliminate erosion damage on the previous blades (Exhibit A-12, Schedule
3	B5.1, page 5, line 31).
4	• Monroe Unit 2 SCR catalyst modules for layers 1, 2, and 4 were replaced for
5	\$4.1 million (Exhibit A-12, Schedule B5.1, page 4, line 32). The catalyst
6	module replacements were required to maintain compliance with air permit
7	emission limits for NOx and ammonia slip guidelines.
8	• Monroe Unit 2 coal mill primary air (PA) duct and dampers were replaced
9	for \$3.6 million (Exhibit A-12, Schedule B5.1, page 4, line 33). The
10	previous ductwork had thinned, resulting in fugitive dust leaks.
11	• Twenty (20) expansion joints were replaced on Monroe Unit 2 for \$2.7
12	million (Exhibit A-12, Schedule B5.1, page 54, line 34). The replacements
13	were required to maintain unit reliability and efficiency, while also
14	mitigating safety risks to plant personnel.
15	• Monroe Unit 2 horizontal reheater tubes (960 linear feet) were replaced for
16	\$2.6 million (Exhibit A-12, Schedule B5.1, page 54, line 35). The horizontal
17	reheater is located within the downdraft section of the boiler. These tubes
18	required replacement to avoid tube failure outages. Tube failures occur from
19	oxygen pitting corrosion, fly ash erosion, abrasive wear of closely spaced
20	horizontal reheater and primary superheater tubes, and the use of soot
21	blowers which operate to remove and prevent ash build-up.
22	• \$1.9 million was spent to replace the Unit 2 FGD absorber inlet expansion
23	joint and flanges on both upstream and downstream sides of the joint
24	(Exhibit A-12, Schedule B5.1, page 54, line 36). Flue gas and moisture

Line
<u>No.</u>

1 cause progressive deterioration to the inlet expansion joint necessitatin
2 periodic replacement to prevent forced outage failures.
• The Monroe Unit 2 north and south FGD booster fans were rebuilt for \$1
4 million (Exhibit A-12, Schedule B5.1, page 4, line 37). Due to the corrosiv
5 environment in which these fans operate, the fans require repair of
6 replacement of the hub and blades every 8 years to avoid risk of a component
7 failure and damage to other fan internals. This maintenance was due.
• \$1.3 million was spent to complete Monroe Unit 2 DCS and control room
9 modifications (Exhibit A-12, Schedule B5.1, page 4, line 38). Th
10 equipment and software were at risk from a reliability perspective, requirir
11 modifications to keep the plant's control systems reliable. The DC
12 hardware was last replaced over a decade ago and the associated software
13 dates back to the 1980's. Additionally, the equipment was no long
14 supported by the vendor.
• Monroe Unit 2 coal mill silo 2-1 (Exhibit A-12, Schedule B5.1, page 4, lin
16 41) and silo 2-7 (Exhibit A-12, Schedule B5.1, page 4, line 39) were rebuild
17 for \$1.2 million each. Monroe Unit 3 coal mill silo 3-5 (Exhibit A-1
18 Schedule B5.1, page 4, line 45) and silo 3-6 (Exhibit A-12, Schedule B5.
19 page 4, line 46) were rebuilt for \$1.2 million and \$1.1 million, respectively
20 The chemical and abrasive properties of coal within the silos resulted
21 corrosion and erosion of the silo walls and compromised the structur
22 integrity requiring repairs.
• \$1.2 million was spent for engineering, material procurement, ar
24 preliminary installation work for a 1.5 MW backup generator to b
25 completed in 2023 on Monroe Unit 2 FGD (Monroe Unit 2 FGD Ass

Line	
<u>No.</u>	

1	Preservation) (Exhibit A-12, Schedule B5.1, page 4, line 40). The backup
2	generator will provide emergency power to allow for stabilization of critical
3	FGD equipment in the event of a power failure. This project is also detailed
4	in a new report (Exhibit A-12, Schedule B5.1.1) as requested in the
5	Commission order in Case No. U-21297. The report demonstrates the
6	reasonableness and prudence of the FGD Asset Preservation projects,
7	including the fact that the costs of installing FGD back-up generators now
8	are the same as installing the generators during initial FGD construction 15
9	years ago, the risks of damage associated with not having back-up generators
10	during a loss of power, and the potential future uses of the generators after
11	Monroe units retire.
12	• Monroe Unit 2 FGD mist eliminators (1 st and 2 nd stages) were replaced for
13	\$1.0 million (Exhibit A-12, Schedule B5.1, page 4, line 42). The original
14	mist eliminator trays were plugged, damaged, and worn. They were replaced
15	to improve FGD moisture removal and emission monitoring equipment
16	reliability and accuracy.
17	• SCR catalyst modules for layer 1 on Monroe Unit 3 were replaced for \$3.2
18	million (Exhibit A-12, Schedule B5.1, page 4, line 43). The catalyst module
19	replacements were required to maintain compliance with air permit emission
20	limits for NOx and ammonia slip guidelines.
21	• \$1.6 million was spent to replace the Monroe Unit 3 FGD mist eliminators
22	(1 st and 2 nd stages) (Exhibit A-12, Schedule B5.1, page 4, line 44). The
23	original mist eliminator trays had become plugged, damaged, and worn.
24	They were replaced to improve FGD moisture removal and emission
25	monitoring equipment reliability and accuracy.

Line
<u>No.</u>

1	•	The Monroe Unit 4 generator stator rewind was completed for \$2.2 million
2		(Exhibit A-12, Schedule B5.1, page 4, line 47). The stator required a rewind
3		to maintain the generator's reliability and to address the deterioration of the
4		brazed joints and excess coil movement.
5	•	Procurement of a spare main unit transformer was continued for \$3.9 million
6		to replace the transformer that was installed on Monroe Unit 1 in the fall of
7		2021 (Exhibit A-12, Schedule B5.1, page 4, line 48). This transformer is
8		needed to provide a fleet spare that will be installed in the event of a failure
9		of one of the other main unit transformers.
10	•	Monroe fuel supply tripper car gallery J had the floor replacement (7,199
11		square feet of elevated structure) completed for \$4.1 million (Exhibit A-12,
12		Schedule B5.1, page 4, line 49). The original tripper gallery floors,
13		supporting floor beams, and floor beam top flanges had corroded over time
14		and required replacement to ensure worker safety during washdown
15		activities required to control fugitive and combustible coal dust. There are
16		9 galleries (sections) in the tripper gallery that serve all four Monroe Power
17		Plant units, designated by letters A, B, C, D, E, F, G, H, and J. Floor beam
18		inspections were conducted to determine the condition of the gallery and
19		prioritize sections based on the results. The inspection included the gallery
20		conveyor floor system, floor plates, and floor supporting structural steel.
21		Gallery J was identified as a priority area in the inspection. Support beams
22		and girders show signs of degradation and need to be replaced. This project
23		restored the structural integrity of the floor, the floor beams, girders, and
24		associated connection hardware for this gallery section.

Line
<u>No.</u>

2

3

22

 Monroe fuel supply CV-04 transfer chute was replaced for \$2.8 million (Exhibit A-12, Schedule B5.1, page 4, line 50). The new discharge chute technology minimizes combustible dust and coal spillage.

4 Monroe fuel supply tripper car gallery B started engineering of the floor 5 replacement (8,096 square feet of elevated structure) for \$1.3 million 6 (Exhibit A-12, Schedule B5.1, page 4, line 51). The original tripper gallery 7 floors, supporting floor beams, and floor beam top flanges had corroded over 8 time and required replacement to ensure worker safety during washdown 9 activities required to control fugitive and combustible coal dust. There are 10 nine (9) galleries (sections) in the tripper gallery that serve all four Monroe 11 Power Plant units, designated by letters A, B, C, D, E, F, G, H, and J. Floor 12 beam inspections were conducted to determine the condition of the gallery 13 and prioritize sections based on the results. The inspection included the 14 gallery conveyor floor system, floor plates, and floor supporting structural 15 steel. Gallery B was identified as a priority area in the inspection. Support 16 beams and girders show signs of degradation and need to be replaced. This 17 project will restore the structural integrity of the floor, the floor beams, 18 girders, and associated connection hardware for this gallery section.

The Monroe fuel supply coal pile runoff oil wastewater system began initial
engineering and material procurement for \$1.1 million (Exhibit A-12,
Schedule B5.1, page 4, line 52).

In 2017 the plant experienced a Notice of Violation on a similar system.
Remediation of soil and augmentations to the wastewater system were
required following the event. Further review of oil-containing equipment on

<u>No.</u>	
1	the Monroe property identified the areas around the coal pile run-off system
2	are at risk of a similar event. A major oil spill event into public waterways
3	could result in cleanup costs into the millions as well as fines for not
4	mitigating this potential risk.
5	
6	The current coal pile run-off wastewater treatment system has no oil removal
7	capabilities to prevent oil discharges into open waters. The coal pile
8	containment area contains over 30,000 gallons of oil stored in various
9	locations. Any loss of oil from these systems could migrate to the coal pile
10	run-off water collection system.
11	
12	Currently, discovery of oil-contaminated water in the coal pile run-off
13	wastewater system requires an operator to be at the right place at the right
14	time. Detecting small quantities of oil sheen is very difficult and heavily
15	influenced by environmental conditions, including daylight, rain, fog, etc.
16	Once the operator discovers that the contamination exists, they manually
17	intervene by deploying oil-containment booms and contracting
18	environmental clean-up firms to mitigate the event.
19	
20	The planned project installs an oily waste treatment system that has
21	automated oil removal capabilities for the coal pile run-off system. The new
22	system will not depend on visual observations and manual intervention to
23	trigger an oil clean-up response. Instead, the oily waste treatment systems

Line

24

will provide 24x7 enhanced environmental protection.

Line	
<u>No.</u>	

1 The detailed discussion above is responsive to the Final Order dated
2 December 1, 2023, in Case No U-21297 in which the Commission indicated
3 support for necessary measures to prevent environmental contamination and
4 damage, but it felt that risk analysis of an environmental spill needed furthe
5 specificity for this project.
6
7 Q75. What are the routine projects with projected capital expenditures greater than
8 \$1 million planned or completed for 2023 for Steam Power Generation?
9 A75. Planned or completed 2023 routine capital projects greater than \$1 million are
10 detailed on page 5 of Exhibit A-12, Schedule B5.1 and discussed below.
11
12 In preparation for the Belle River Unit 2 2024 periodic outage, Belle River
13 Unit 2 LP turbine rotors and blades procurement payments were projected
14 for materials at \$6.1 million (Exhibit A-12, Schedule B5.1, page 5, line 68)
15 Inspections have identified blade erosion and rotor cracking that needs to be
16 addressed to ensure continued safe and reliable operation of the LP turbines
17 This work is a permanent fix to the issues identified in 2020. Additionally
18 \$2.3 million was projected to procure materials for the replacement of the
19Belle River Unit 2 exciter (Exhibit A-12, Schedule B5.1, page 5, line 69)
20 Vibration levels have indicated structural/mechanical integrity issues with
21 the rotor components. Replacement of the exciter will maintain equipmen
reliability in the future. \$1.5 million was projected to start procurement of
23 materials for the waterwall tubes that will be replaced on Belle River Unit 2
in 2024 (Exhibit A-12, Schedule B5.1, page 6, line 70). The project wil
25 replace 2,500 square feet of boiler waterwall panels damaged by quench

Line
<u>No.</u>

2

3

4

5

6

7

cracking and soot blower erosion to support continued reliable boiler
operation. Finally, \$1.5 million was projected to procure materials for the
Belle River Unit 2 intermediate pressure (IP) turbine valves (Exhibit A-12,
Schedule B5.1, page 5, line 71). This project overhauls the four (4) IP
turbine stop valves and four (4) control valves. The valves are worn and
require overhaul to operate properly. These valves provide overspeed
protection for the turbine and prevent possible catastrophic failure.
• \$3.3 million was projected to finish the separation of St. Clair Power Plant

8 9 from the Fuel Supply system (Exhibit A-12, Schedule B5.1, page 5, line 72). 10 There are a number of systems in the St. Clair Fuel Supply system that are 11 interrelated with the Belle River Power Plant. Although St. Clair Power 12 Plant retired in 2022, these interrelated systems must remain functional to 13 continue fueling the Belle River Power Plant. The project scope was to 14 completely isolate St. Clair Power Plant from the Fuel Supply System. This 15 scope included fire protection and general service water, wastewater and 16 stormwater, low voltage electrical, and medium voltage electrical 17 switchgear.

Installation of a wet dust collector to replace three (3) dry-type dust collectors in the Belle River fuel supply 3TH-9 building was projected for \$1.8 million (Exhibit A-12, Schedule B5.1, page 5, line 73). The prior system had inadequate performance to meet current NFPA guidelines. The replacement mitigates combustible dust and complies with the NFPA combustible dust guidelines.

In preparation for the Greenwood Unit 1 2024 periodic outage, \$5.8 million
 was spent on material progress payments for procurement of the LP turbine

Line
<u>No.</u>

1	rotors and blades (Exhibit A-12, Schedule B5.1, page 5, line 74). Stress
2	corrosion cracking of multiple blade root connections needs to be addressed
3	to ensure continued safe and reliable operation of the LP turbines.
4 •	Monroe Unit 1 waterwall replacement was completed for \$15.0 million
5	(Exhibit A-12, Schedule B5.1, page 5, line 75). The project replaced 4,000
6	square feet of boiler waterwall tubes. The boiler tubes were deteriorated due
7	to corrosion fatigue combined with fireside corrosion, creep damage, and
8	tube thinning.
9 •	Monroe Unit 1 LP turbine rotors and blades were replaced to address the
10	industry-wide safety concern with known stress corrosion cracking for \$10.4
11	million (Exhibit A-12, Schedule B5.1, page 5, line 76). Prior inspections
12	revealed extensive erosion on the L-0 through L-5 blade rows. These rotors
13	will be further analyzed for the severity of stress corrosion cracking and
14	refurbished for use on the Monroe Unit 4 LP turbine in 2025 to minimize the
15	project cost needed to address stress corrosion cracking on its LP turbine
16	forgings.
17 •	Monroe Unit 1 reheat outlet pendants were replaced for \$5.4 million (Exhibit
18	A-12, Schedule B5.1, page 5, line 77). The boiler reheater tubes are critical
19	to steam turbine design and operations. Reheater tubes allow exhaust steam
20	from the HP turbine to be reheated in the boiler and reintroduced into the IP
21	and LP turbines with additional energy that adds to unit MW output at
22	improved efficiency levels. The replacements were based on near term tube
23	failure risk which would force the unit offline for repair.
24 •	Thirty-seven (37) expansion joints were replaced on Monroe Unit 1 for \$5.3
25	million (Exhibit A-12, Schedule B5.1, page 5, line 78). This project covered

Line
<u>No.</u>

1		multiple areas in the air duct and flue gas systems to accommodate thermal
2		expansion of the process ductwork. Scope of work included ash removal to
3		provide a safe workspace, confined space rescue services, scaffold for safe
4		access, lead/asbestos abatement, and replacement of the expansion joints.
5		The replacements were based on near term failure risk which would affect
6		unit reliability, efficiency, and result in a safety risk to plant personnel.
7	•	\$4.2 million was spent to complete the replacement of the Monroe Unit 1
8		coal mill primary air ductwork (Exhibit A-12, Schedule B5.1, page 5, line
9		79). The previous ductwork had thinned, resulting in fugitive dust leaks, and
10		required replacement.
11	•	\$3.9 million was spent to procure and replace blade rows 1, 3, and 8 on the
12		Monroe Unit 1 HP turbine (Exhibit A-12, Schedule B5.1, page 5, line 80).
13		The turbine blades were replaced due to solid particle erosion. The
14		replacement was required to sustain the HP turbine reliability.
15	•	Monroe Unit 1 IP turbine blades (Exhibit A-12, Schedule B5.1, page 5, line
16		81) were replaced for \$3.7 million. The turbine blades were replaced due to
17		solid particle erosion. The first stage rows on both ends (turbine-end and
18		generator-end) were replaced. The replacement was required to sustain the
19		IP turbine reliability.
20	•	Monroe Unit 1 SCR catalyst modules for layers 1, 2, and 4 were replaced for
21		\$3.3 million (Exhibit A-12, Schedule B5.1, page 5, line 82). The catalyst
22		module replacements were required to maintain compliance with air permit
23		emission limits for NOx and ammonia slip guidelines.
24	•	Monroe Unit 1 IP turbine rotor project (Exhibit A-12, Schedule B5.1, page
25		5, line 83) started progress payments of \$2.6 million to replace the rotor in

Line <u>No.</u>	
1	2025. During off-site inspection in 2023, creep void indications of cracking
2	were found in the rotor bore and the stage 1 wheel dovetail roots. The OEM
3	performed the work required to return the IP rotor to service on a short term
4	basis but also provided further analysis of the rotor that confirmed the need
5	to replace the rotor soon, concluding that it could only be safely operated for
6	an additional 30 months.
7	• Monroe Unit 1 economizer tubes were replaced for \$2.5 million (Exhibit A-
8	12, Schedule B5.1, page 5, line 84). The boiler economizers are a critical
9	component of the boiler tubing circuits that removes waste heat from the
10	combustion process and utilizes it to preheat boiler feedwater improving
11	overall cycle efficiency and heat rate. The original equipment economizer
12	had erosion and tube thinning which required approximately 2,000 linear
13	feet of tubing replacements to maintain boiler reliability.
14	• The Monroe Unit 1 reheat turbine stop valves (Exhibit A-12, Schedule B5.1,
15	page 5, line 85), control valves (Exhibit A-12, Schedule B5.1, page 5, line
16	88), and main steam stop valves (Exhibit A-12, Schedule B5.1, page 6, line
17	89) were rebuilt for \$2.4 million, \$1.3 million, and \$1.3 million,
18	respectively. All turbine valves must operate properly to provide overspeed
19	protection for the turbine and prevent possible catastrophic failure.
20	• Monroe Unit 1 SCR inlet and outlet dampers were removed for \$1.5 million
21	(Exhibit A-12, Schedule B5.1, page 5, line 86). When the SCR was
22	originally installed, these dampers and the SCR only operated during

summer months. Now, since the SCR is operated year-round due to changes

in EPA regulations, the inlet and outlet dampers are not needed and

23

24

Line
<u>No.</u>

1		contribute to draft losses leading to ID fan limitations, negatively affecting
2		the output capability of the generating unit.
3	•	The Monroe Unit 1 south air heater hot and cold end baskets were replaced
4		for \$1.4 million (Exhibit A-12, Schedule B5.1, page 5, line 87). The
5		previous baskets were degraded due to corrosion and, if not addressed,
6		would have become loose and cause an imbalance leading to an air heater
7		drivetrain failure. The replacements restored physical integrity and heat
8		transfer efficiency of the air heater.
9	•	Monroe Unit 1 coal mill silo 1-3 (Exhibit A-12, Schedule B5.1, page 5, line
10		90) and Monroe Unit 4 coal mill silo 4-1 (Exhibit A-12, Schedule B5.1, page
11		5, line 105) were projected to be rebuilt for \$1.2 million and \$1.5 million,
12		respectively. The chemical and abrasive properties of coal within the silos
13		resulted in corrosion and erosion of the silo walls and compromised the
14		structural integrity requiring repairs.
15	•	Monroe Unit 1 turning gear and bull gear were rebuilt for \$1.2 million
16		(Exhibit A-12, Schedule B5.1, page 5, line 91). The turbine turning gear
17		must engage to the bull gear as designed to rotate the turbine shaft properly
18		when the unit is offline to prevent damage to the turbine shaft. To address
19		the excessive wear on these components, the turning gear was overhauled
20		and bull gear was replaced.
21	•	Monroe Unit 1 FGD mist eliminators (1st and 2nd stages) were replaced for
22		\$1.1 million (Exhibit A-12, Schedule B5.1, page 5, line 92). The original
23		mist eliminator trays were plugged, damaged, and worn. They were replaced
24		to improve FGD moisture removal and emission monitoring equipment
25		reliability and accuracy.

Line
<u>No.</u>

1 •	\$1.1 million was spent to replace the Unit 1 FGD absorber inlet expansion
2	joint and flanges on both upstream and downstream sides of the joint
3	(Exhibit A-12, Schedule B5.1, page 5, line 93). The inlet expansion joint is
4	essential for inlet flue gas to reliably enter the absorber tower. It allows for
5	expansion and contraction of the inlet duct with changing temperatures
6	(during a shutdown/startup of the unit). The previous expansion joint was
7	deteriorated and showed visible signs of failure. Failure of this expansion
8	joint will result in flue gas leaking from the ductwork and poses a reliability
9	risk.
10 •	The Monroe Unit 1 north and south FGD booster fans were rebuilt for \$1.1
11	million (Exhibit A-12, Schedule B5.1, page 5, line 94). The FGD system for
12	each unit includes a north and south booster fan. These axial fans, with a
13	14-foot diameter impeller, are located between the outlet of the precipitator
14	and the inlet to the FGD Absorber. Failure of one of these booster fans
15	would cause the unit to be limited to half load until replacement parts could
16	be procured and installed. Due to the corrosive environment in which these
17	fans operate, the fans require repair or replacement of the hub and blades
18	every 8 years to maintain reliability. This maintenance was due in 2023.
19 •	\$1.2 million was spent to start procurement of materials in preparation to
20	replace the Monroe Unit 2 air heater cold end baskets (Exhibit A-12,
21	Schedule B5.1, page 5, line 95) in 2024. The air heater plays a critical heat
22	transfer role to boiler efficiency and flue gas equipment operational
23	performance. The Monroe units cold end baskets typically last 7-10 years.
24	The cold-end baskets on Monroe Unit 2 north and south air heaters have

been in service since 2014 and are currently in failure mode due to a

Line	
<u>No.</u>	

2

3

4

significant loss (30 percent) of element material. As this condition
progresses, so does the risk of an out of balance condition, placing high
stresses on all components of the air heater. The imbalance issue will lead
to drive train failures, resulting in unit forced outages.

5 In preparation for the Monroe Unit 3 outage in 2024, new air heater cold end 6 baskets were purchased for \$2.2 million (Exhibit A-12, Schedule B5.1, page 5, line 96). The cold-end baskets on Monroe Unit 3 north and south air 7 8 heaters have been in service since 2015 and are currently in failure mode due 9 to a significant loss (30 percent) of element material. Additionally, the 10 purchase of SCR catalyst modules for layers 2, 3, and 4 are projected for 11 \$1.5 million (Exhibit A-12, Schedule B5.1, page 5, line 97). The catalyst 12 module replacements are required to maintain compliance with air permit 13 emission limits for NOx and ammonia slip guidelines. \$1.3 million was 14 projected to start engineering and procure material to replace twelve (12) 15 Monroe Unit 3 expansion joints (Exhibit A-12, Schedule B5.1, page 5, line 16 The replacements are required to maintain unit reliability and 98). efficiency, while also mitigating safety risks to plant personnel. Finally, \$1.1 17 18 million was projected to be spent to start engineering and begin to procure 19 materials to replace the Monroe Unit 3 existing coal mill primary air 20 ductwork (Exhibit A-12, Schedule B5.1, page 5, line 99). The existing 21 ductwork is thinning, causing fugitive dust leaks, and requires replacement. 22 Monroe Unit 3 coal mill 3-6 overhaul was projected for \$1.0 million. The • 23 coal mill overhaul was due to service hours, air flow performance, and lube 24 oil analysis indications of deteriorating internal components (Exhibit A-12, 25 Schedule B5.1, page 5, line 100). Due to the abrasiveness of coal, coal mill

Line
<u>No.</u>

2

3

4

parts experience significant wear in the process of converting lump coal to a fine powder consistency suitable for boiler combustion and need to be disassembled, repaired, and components replaced approximately every 10 years.

5 In preparation for the Monroe Unit 4 2025 periodic outage, \$4.3 million was 6 spent to start procurement of long lead materials related to refurbishment of 7 the LP turbines (Exhibit A-12, Schedule B5.1, page 5, line 101). Refurbishment is needed due to the industry-wide problem of stress 8 9 corrosion cracking on the current LP turbine. The rotors being replaced on 10 Monroe Unit 1 in 2023 will be analyzed, refurbished, and installed on 11 Monroe Unit 4 to keep the project cost to a minimum while mitigating the 12 safety risk of a stress corrosion cracking catastrophic failure.

Installation of SCR catalyst modules for layer 2 for Monroe Unit 4 was
 projected to cost \$2.1 million (Exhibit A-12, Schedule B5.1, page 5, line
 102). The catalyst module replacements are required to maintain compliance
 with air permit emission limits for NOx and ammonia slip guidelines.

Monroe Unit 4 south boiler feed pump turbine condenser retubing was
projected to cost \$1.8 million (Exhibit A-12, Schedule B5.1, page 5, line
103). A significant increase in tube failures in the inlet section of the
condenser were identified resulting in thirty-nine (39) percent of the
condenser inlet section tubes being plugged, requiring the condenser to be
retubed to keep the boiler feed pump turbine in service.

In preparation for the Monroe Unit 4 outage in 2025, \$1.5 million was
 projected to be spent to start engineering and material procurement of SCR
 catalyst module layers 1, 3, and 4 that will be replaced (Exhibit A-12,

Line
<u>No.</u>

<u> </u>	
1	Schedule B5.1, page 5, line 104). The catalyst module replacements are
2	required to maintain compliance with air permit emission limits for NOx and
3	ammonia slip guidelines.
4 •	Procurement of a spare main unit transformer was completed for \$3.0
5	million to replace the transformer that was installed on Monroe Unit 1 in the
6	fall of 2021 (Exhibit A-12, Schedule B5.1, page 5, line 106). This
7	transformer is needed for fleet reliability in the event of a failure of one of
8	the other main unit transformers.
9 •	Monroe underground storage tank No. 389 (Exhibit A-12, Schedule B5.1,
10	page 5, line 107) will be removed and replaced with an above ground storage
11	tank for a projected \$2.0 million. The tank collects used oil, is constructed
12	of double-walled steel, has a capacity of 5,750 gallons and has been in
13	service since 1993. This project will mitigate the oil spill risk and ensure
14	continued environmental compliance.
15 •	The Monroe fuel supply coal pile runoff oil wastewater system replacement
16	project was projected to continue with construction at a cost of \$4.6 million
17	(Exhibit A-12, Schedule B5.1, page 5, line 108). As previously discussed
18	above in the 2022 steam routine projects section, this project enhances
19	environmental compliance by reducing the risk of oil contaminants from the
20	storm water and coal pile run-off systems reaching the lake.
•	Monroe fuel supply tripper car gallery B floor replacement (8,096 square
22	feet of elevated structure) was completed for \$3.0 million (Exhibit A-12,
23	Schedule B5.1, page 5, line 109). The original tripper gallery floors,
24	supporting floor beams, and floor beam top flanges had corroded over time
25	and required replacement to ensure worker safety during washdown

Line
<u>No.</u>

23

1	activities required to control fugitive and combustible coal dust. There are
2	9 galleries (sections) in the tripper gallery that serve all four Monroe Power
3	Plant units, designated by letters A, B, C, D, E, F, G, H, and J. Floor beam
4	inspections were conducted to determine the condition of the gallery and
5	prioritize sections based on the results. The inspection included the gallery
6	conveyor floor system, floor plates, and floor supporting structural steel.
7	Gallery B was identified as a priority area in the inspection. Support beams
8	and girders showed signs of degradation and needed to be replaced. This
9	project restored the structural integrity of the floor, the floor beams, girders,
10	and associated connection hardware for this gallery section.
11 •	Monroe fuel supply transfer chute that feeds from conveyor C4 to conveyors
12	C5 and C5A was projected to be replaced for \$2.7 million (Exhibit A-12,
13	Schedule B5.1, page 5, line 110), the transfer chutes from conveyors C10,
14	C11, and C5 that feed onto conveyor C4 were replaced for \$2.0 million
15	(Exhibit A-12, Schedule B5.1, page 5, line 111), and transfer chute from
16	conveyor C19 that feeds onto conveyor C10 was projected to be replaced for
17	\$1.5 million (Exhibit A-12, Schedule B5.1, page 5, line 113). Transfer
18	chutes are used throughout the fuel supply system to direct coal from one
19	conveyor belt to another on the path from the coal piles to the powerhouse.
20	The previous chute tended to generate significant amounts of coal dust
21	during periods of dry coal and was prone to pluggage during periods of wet

coal. The new discharge chute technology minimizes combustible dust and coal spillage and ensures compliance with NFPA guidelines.

In preparation for the Monroe fuel supply tripper car gallery C floor (Exhibit
 A-12, Schedule B5.1, page 5, line 112) being replaced in 2024, \$1.7 million

Line
<u>No.</u>

1		was spent for engineering and materials (10,750 square feet of elevated
2		structure). The original tripper gallery floor, supporting floor beams, and
3		floor beam top flanges have corroded over time and require replacement to
4		ensure worker safety during washdown activities required to control fugitive
5		and combustible coal dust. There are 9 galleries (sections) in the tripper
6		gallery that serve all four Monroe Power Plant units, designated by letters A,
7		B, C, D, E, F, G, H, and J. Floor beam inspections were conducted to
8		determine the condition of the gallery and prioritize sections based on the
9		results. The inspection included the gallery conveyor floor system, floor
10		plates, and floor supporting structural steel. Gallery C was identified as the
11		next priority area in the inspection. Support beams and girders show signs
12		of degradation and need to be replaced. This project will restore the
13		structural integrity of the floor, the floor beams, girders, and associated
14		connection hardware for this gallery section.
15		• The capping of section 1a at Sibley Quarry was projected for \$9.6 million
16		(Exhibit A-12, Schedule B5.1, page 5, line 126). This portion of the site,
17		twenty-seven (27) acres, has reached its licensed capacity and requires
18		capping per its landfill operating permit.
19		
20	Q76.	What are the routine projects with projected capital expenditures greater than
21		\$1 million planned for 2024 for Steam Power Generation?
22	A76.	Planned routine capital projects greater than \$1 million for 2024 are detailed on
23		page 6 of Exhibit A-12, Schedule B5.1 and discussed below.
24		• In preparation for the 2025 periodic outage on Belle River Unit 1,

engineering and material procurement will be initiated to replace sixty-seven

Line
<u>No.</u>

1	(67) 480-volt breakers (Exhibit A-12, Schedule B5.1, page 6, line 128) and
2	fifty-three (53) medium voltage breakers (Exhibit A-12, Schedule B5.1,
3	page 6, line 129) for \$2.0 million and \$1.9 million, respectively. The
4	breakers are original to the 1980's era unit and the reliable operation of these
5	breakers is at risk due to their age. These breakers are obsolete and no longer
6	supported by the OEM. Additionally, these breakers are an electrical safety
7	concern due to the obsolete trip device technology. Finally, \$1.3 million will
8	be spent to start material procurement for the Belle River Unit 1 east boiler
9	feed pump turbine blades and rotor (Exhibit A-12, Schedule B5.1, page 6,
10	line 130). During the 2022 Belle River Unit 1 periodic outage, the east boiler
11	feed pump turbine rotor was inspected, and heavy rubbing was found on
12	multiple stages where the blades connect to the rotor steeples. Crack
13	indications were found and removed as a temporary repair, enabling the
14	equipment to return to service with a plan for replacement during the 2025
15	periodic outage.
16 •	\$1.1 million will be spent to rebuild the white coal mill on Belle River Unit
17	1 due to service hours and lube oil analysis indications of deteriorating
18	internal components (Exhibit A-12, Schedule B5.1, page 6, line 131). Due
19	to the abrasiveness of coal, coal mill parts experience significant wear in the
20	process of converting lump coal to a fine powder consistency suitable for
21	boiler combustion and need to be disassembled, repaired, and components
22	replaced approximately every 10 years. The coal mill was last overhauled
23	in 2014 and has close to 50,000 run hours.
24 •	The Belle River Unit 2 LP turbine rotors and blades will be replaced for \$6.4
25	million (Exhibit A-12, Schedule B5.1, page 6, line 132). Inspections have

Line
<u>No.</u>

2

3

4

identified blade erosion and rotor cracking that needs to be addressed to
ensure continued safe and reliable operation of the LP turbines. This work
is a permanent fix to the issues identified and repaired on a temporary basis
in 2020.

- Waterwall tubes will be replaced on Belle River Unit 2 for \$4.3 million
 (Exhibit A-12, Schedule B5.1, page 6, line 133) to support continued reliable
 boiler operation. The project will replace 2,500 square feet of boiler
 waterwall panels damaged by quench cracking and soot blower erosion.
- \$3.3 million will be spent to replace the Belle River Unit 2 exciter with a
 static exciter (Exhibit A-12, Schedule B5.1, page 6, line 134). Vibration
 levels have indicated structural and mechanical integrity issues with the rotor
 components. Replacement of the exciter will maintain equipment reliability
 in the future.
- Belle River Unit 2 IP turbine valves will be overhauled for \$2.8 million (Exhibit A-12, Schedule B5.1, page 6, line 135). This project overhauls the four (4) IP turbine stop valves and four (4) control valves. The valves are worn and require overhaul to operate properly. These valves provide overspeed protection for the turbine and prevent possible catastrophic failure.
- The Belle River Unit 2 turbine stop valve actuators will be replaced for \$2.7
 million (Exhibit A-12, Schedule B5.1, page 6, line 136). The original
 actuators provided by the OEM have been replaced across the industry due
 to maintenance issues, lack of spare parts, and an absence of qualified
 companies capable of repairing them. The replacements are required to
 maintain continued reliable operation of this system that controls turbine

Line
<u>No.</u>

2

3

loading. F	ailure of the	hese v	alves to	properly	y operate	e wou	ld impact	t the ability
to proper	y control	unit	output.	These	valves	also	provide	overspeed
protection	for the tur	bine a	and preve	ent poss	sible cata	astrop	hic failur	e.

- In preparation for the 2026 periodic outage on Belle River Unit 2, 4 • 5 engineering and material procurement will be initiated to replace sixty-seven 6 (67) 480-volt breakers (Exhibit A-12, Schedule B5.1, page 6, line 137) and 7 fifty-three (53) medium voltage breakers (Exhibit A-12, Schedule B5.1, 8 page 6, line 138) for \$2.0 million and \$1.8 million, respectively. The 9 breakers are original to the 1980's era unit. The reliable operation of these 10 breakers is at risk due to their age. These breakers are obsolete and no longer 11 supported by the OEM. Additionally, these breakers are an electrical safety 12 concern due to the obsolete trip device technology.
- Over 400 primary superheater tube bends will be replaced on Belle River
 Unit 2 for \$1.7 million (Exhibit A-12, Schedule B5.1, page 6, line 139). The
 tubes have been compromised from soot blower erosion and require
 replacement to support continued reliable boiler operations.
- 17 In preparation for dual-unit outages in 2025 and 2026 at Belle River Power 18 Plant, engineering and material procurement will be initiated to replace 19 ninety-four (94) common system 480-volt breakers (Exhibit A-12, Schedule 20 B5.1, page 6, line 140) and fifty-seven (57) common system medium voltage 21 breakers (Exhibit A-12, Schedule B5.1, page 6, line 141) for \$2.7 million 22 and \$2.0 million, respectively. The breakers are original to the 1980's era 23 units. The reliable operation of these breakers is at risk due to their age. 24 These breakers are obsolete and no longer supported by the OEM.

2

Additionally, these breakers are an electrical safety concern due to the
obsolete trip device technology.

- 3 Underground storage tanks No. 387 and No. 388 (Exhibit A-12, Schedule • 4 B5.1, page 6, line 142) at Belle River Power Plant will be replaced for \$1.9 5 million. The tanks have been in service for over 29 years. Underground 6 storage tanks that have been in service for this many years have an increased risk of failure, potentially allowing the contents to leak, contaminating the 7 8 soil and groundwater around the tank. Tank No. 387 contains gasoline fuel 9 with a capacity of 4,000 gallons. Tank No. 388 contains diesel fuel with a 10 capacity of 1,000 gallons. Additionally, underground storage tank No. 393 11 (Exhibit A-12, Schedule B5.1, page 6, line 143) will be replaced for \$1.8 12 million. The tank contains used oil with a capacity of 2,300 gallons and has also been in service for over 29 years. 13
- \$12.1 million will be spent on engineering and material procurement for the
 Greenwood Unit 1 LP turbine rotors and blades replacement project (Exhibit
 A-12, Schedule B5.1, page 6, line 148). Stress corrosion cracking of
 multiple blade root connections is being addressed to ensure continued safe
 and reliable operation of the LP turbines.
- Materials will be procured for the 2025 replacement of the Greenwood Unit
 1 feedwater heater No. 6 (Exhibit A-12, Schedule B5.1, page 6, line 149)
 and feedwater heater No. 3 (Exhibit A-12, Schedule B5.1, page 6, line 150)
 for \$1.6 million and \$1.4 million, respectively. A leak in the shell of
 feedwater heater No. 6 was discovered in March 2023. Phased Array
 Ultrasonic Testing (PAUT) also identified an 8" long crack in the shell.
 Further PAUT testing found several smaller connected indications on the

Line
<u>No.</u>

1	inside diameter of the shell. Additional borescope inspection revealed
2	multiple internal weld cracks located between the desuperheating zone ar
3	the drain cooling zone of the feedwater heater. Feedwater heater No.
4	needs to be replaced to restore reliable service. The existing feedwate
5	heater No. 3 is experiencing an increasing number of tube leaks and require
6	replacement to restore reliability. Both feedwater heaters take waste he
7	from the LP turbines and use it to preheat boiler feedwater, improving the
8	overall efficiency of the steam power cycle. Steam turbine power cycle
9	utilize feedwater heating in this manner.
10	• \$1.5 million will be spent on Monroe Unit 1 to start material procurement
11	for the SCR catalyst modules being replaced on layer 3 in 2025 (Exhibit A
12	12, Schedule B5.1, page 6, line 151). The catalyst module replacements as
13	required to maintain compliance with air permit emission limits for NC
14	and ammonia slip guidelines.
15	• For the Monroe Unit 1 IP turbine rotor (Exhibit A-12, Schedule B5.1, pag
16	6, line 152), the Company will continue progress payments of \$1.1 millio
17	to replace the rotor in 2025. During an offsite inspection in 2023, cree
18	void indications of cracking were found in the bore and the stage 1 whe

- 19dovetail roots. The OEM performed the work required to return the unit to20service on a short-term basis but also provided further analysis of the rotor21that confirmed the need to replace the rotor soon, concluding that it could22only be returned to service for no more than 30 months.
- In preparation for the Monroe Unit 2 periodic outage in 2026, \$8.3 million
 will be spent to start procurement of material to forge new LP turbine rotors
 and blades (Exhibit A-12, Schedule B5.1, page 6, line 153). Replacement

Line
<u>No.</u>

2

is needed due to the industry-wide problem of stress corrosion cracking on
the current LP turbine forgings.

- 3 \$4.2 million will be spent to complete the replacement of the Monroe Unit 4 2 north & south air heater cold end baskets (Exhibit A-12, Schedule B5.1, 5 page 6, line 154). The air heater plays a critical heat transfer role to boiler 6 efficiency and flue gas equipment operational performance. The Monroe 7 cold end baskets typically last 7-10 years. The cold-end baskets on Monroe 8 Unit 2 north and south air heaters have been in service since 2014 and are currently in failure mode due to a significant loss (30 percent) of element 9 10 material. As this condition progresses, so does the risk of an out of balance 11 condition, placing high stresses on all components of the air heater. The 12 imbalance issue will lead to drive train failures, resulting in unit forced 13 outages.
- \$3.0 million will be spent on Monroe Unit 2 to complete the replacement of
 layer 3 SCR catalyst modules (Exhibit A-12, Schedule B5.1, page 6, line
 15). The catalyst module replacements are required to maintain
 compliance with air permit emission limits for NOx and ammonia slip
 guidelines.
- Monroe Unit 2 coal mill feeder controls will be replaced for \$1.5 million
 (Exhibit A-12, Schedule B5.1, page 6, line 156). The current coal mill
 feeder controls for all seven (7) coal mills are original equipment (1970's).
 Reliability of this equipment has diminished, causing unit derates.
 Replacing the obsolete controls is needed to address the reliability issues.
 This controls project upgrade will improve reliability, accuracy of
 measuring coal flow, and boiler efficiency.

Line
<u>No.</u>

23

1	• \$12.7 million will be spent to replace Monroe Unit 3 waterwall tubes
2	(Exhibit A-12, Schedule B5.1, page 6, line 157). This project was reduced
3	in scope based on the advanced unit retirement as previously discussed in
4	Q70. The project will now only replace approximately 2,000 square feet of
5	boiler waterwall tubes. In total, the waterwall section of a single Monroe
6	unit consists of over 42,000 square feet of tubes joined together in the
7	furnace area of the boiler. The waterwall tubes absorb heat from the
8	combustion process to convert boiler water to steam, the basic process of
9	the steam power cycle. A tube leak in any portion of the waterwall requires
10	the unit to be removed from service for repair. The boiler tubes being
11	replaced are deteriorating due to corrosion fatigue combined with fireside
12	corrosion, creep damage, and tube thinning.
13	• Replacement of the SCR catalyst modules for layers 1, 2, and 3 on Monroe
14	Unit 3 will be completed for \$6.7 million (Exhibit A-12, Schedule B5.1,
15	page 6, line 158). The catalyst module replacements are required to
16	maintain compliance with air permit emission limits for NOx and ammonia
17	slip guidelines.
18	• \$5.3 million will be spent to complete the replacement of the existing
19	Monroe Unit 3 coal mill primary air (PA) ductwork (Exhibit A-12, Schedule
20	B5.1, page 6, line 159). The existing ductwork is thinning, resulting in
21	fugitive dust leaks, and requires replacement. This project scope includes

- dampers, and expansion joints on the unit's seven coal mills.
- \$5.0 million will be spent to overhaul the Monroe Unit 3 turbine valves
 (Exhibit A-12, Schedule B5.1, page 6, line 160). Project scope includes the

MEG-94

removal and replacement of the interconnecting ductwork, slide gates,

Line
<u>No.</u>

2

3

4

5

6

7

8

four (4) throttle valves, four (4) intercept valves, eight (8) governor valves,
and two (2) reheat stop valves. The valves are worn and require overhaul
to ensure proper operation until unit retirement. These valves provide
overspeed protection for the turbine and prevent possible catastrophic
failure.

\$4.3 million will be spent to complete the replacement of Monroe Unit 3 IP turbine blades to correct erosion damage on the existing blades (Exhibit A-12, Schedule B5.1, page 6, line 161).

9 Twelve (12) Monroe Unit 3 expansion joints will be replaced for \$3.3 10 million due to leakage or being at risk of near-term leaking (Exhibit A-12, 11 Schedule B5.1, page 6, line 162). This project covers multiple areas in the 12 air duct/flue gas systems to provide a means of thermal expansion of the 13 process ductwork. Scope of work includes vacuuming of all areas to 14 provide a safe workspace, confined space rescue services, scaffold for safe 15 access, lead/asbestos abatement, and replacement of the expansion joints. 16 The replacements are based on near term failure risk which would affect 17 unit reliability, efficiency, and result in a safety risk to plant personnel.

Monroe Unit 3 reheat outlet pendants will be replaced for \$2.7 million (Exhibit A-12, Schedule B5.1, page 6, line 163). The boiler reheater tubes are critical to steam turbine design and operations. Reheater tubes allow exhaust steam from the HP turbine to be reheated in the boiler and reintroduced into the IP and LP turbines with additional energy that adds to unit MW output at improved efficiency levels. The replacements are based on near term tube failure risk which would force the unit offline for repair.

Line
<u>No.</u>

1	• \$2.7 million will be spent to complete the replacement of the Monroe Unit
2	3 north & south air heater cold end baskets (Exhibit A-12, Schedule B5.1,
3	page 6, line 164). The baskets are in failure mode with significant loss (30
4	percent) of element material. The baskets have been in service since 2015,
5	having a 7-10 year life. The integrity, reliability, and efficiency of the
6	Monroe Unit 3 north & south air heater cold-end baskets will be restored.
7	• Monroe Unit 3 horizontal reheater tubes (4,000 linear feet) will be replaced
8	for \$2.6 million (Exhibit A-12, Schedule B5.1, page 6, line 165). The
9	horizontal reheater is located within the downdraft section of the boiler.
10	These tubes require replacement to avoid tube failure outages. Tube failures
11	occur from oxygen pitting corrosion, fly ash erosion, abrasive wear of
12	closely spaced horizontal reheater and primary superheater tubes, and the
13	use of sootblowers which operate to remove/prevent ash build-up.
14	• \$2.6 million will be spent to complete the Monroe Unit 3 DCS and control
15	room modifications (Exhibit A-12, Schedule B5.1, page 6, line 166). The
16	equipment and software are at risk from a reliability perspective, requiring
17	modifications to keep the plant's control systems reliable. The DCS
18	hardware was last replaced over a decade ago and the associated software
19	dates back to the 1980's. Additionally, the equipment is no longer
20	supported by the vendor. As discussed in the preceding section, the
21	Company has scaled back this project to focus on the critical work necessary
22	to support continued operations to 2028.
23	• \$2.4 million will be spent to replace the upper and lower bearings on
24	Monroe Unit 3 coal mill classifiers (Exhibit A-12, Schedule B5.1, page 6,
25	line 167). The rebuild cycle for the classifiers is based on bearing life

Line
<u>No.</u>

2

3

4

5

6

7

8

9

expectancy, OEM recommendations, and condition of the internal wear components. The classifier bearings are recommended for replacement every 10 years, and the Monroe Unit 3 bearings have been in service since 2015.

 Monroe Unit 3 coal mill 3-7 silo will be rebuilt for \$1.5 million (Exhibit A-12, Schedule B5.1, page 6, line 168). The chemical and abrasive properties of coal within the silos resulted in corrosion and erosion of the silo walls creating coal leaks and compromised the structural integrity. Repairs are required for a safe workspace and continued reliable operation.

10 In preparation for the Monroe Unit 4 2025 periodic outage, \$6.0 million will 11 be spent to start procurement of long lead materials related to refurbishment 12 of the LP turbines (Exhibit A-12, Schedule B5.1, page 6, line 169). 13 Refurbishment is needed due to the industry-wide problem of stress 14 corrosion cracking on the current LP turbine which could result in 15 unexpected catastrophic failure. The LP rotors that were installed on 16 Monroe Unit 1 in 2001 have been replaced with new upgraded rotors in 17 2023. Due to the cost of forging new rotors or the extended outage required 18 to perform the refurbishment of the Monroe Unit 4 rotors, Unit 4's rotors 19 will be replaced with those that were removed from Unit 1. The Unit 1 20 rotors will be inspected and refurbished to provide safe and reliable 21 operation of the Unit 4 LP turbines until the projected retirement of Unit 4 22 in 2028. In addition, SCR catalyst modules for layers 1, 3, and 4 will be 23 purchased for \$3.8 million (Exhibit A-12, Schedule B5.1, page 6, line 170). 24 The catalyst module replacements are required to maintain compliance with 25 air permit emission limits for NOx and ammonia slip guidelines. \$1.8

Line
<u>No.</u>

1	million will be spent to start engineering and begin to procure materials to		
2	replace the Monroe Unit 4 existing coal mill primary air ductwork (Exhibit		
3	A-12, Schedule B5.1, page 6, line 171). The existing ductwork is thinning		
4	resulting in fugitive dust leaks, and requires replacement. \$1.4 million will		
5	be spent to procure materials for Monroe Unit 4 expansion joints to be		
6	replaced in 2025 (Exhibit A-12, Schedule B5.1, page 6, line 172). Fourteen		
7	(14) high priority Monroe Unit 4 expansion joints have been identified to		
8	be replaced due to leakage. A leak can affect unit reliability and efficiency,		
9	and result in a safety risk to plant personnel. Finally, \$1.2 million will be		
10	spent to procure materials for the Monroe Unit 4 turbine valves project		
11	(Exhibit A-12, Schedule B5.1, page 6, line 173). Project scope includes the		
12	four (4) stop valves, four (4) control valves, and 2 combined reheat stop		
13	valves. The valves are worn and require overhaul for proper operation until		
14	the projected Unit 4 retirement. These valves provide overspeed protection		
15	for the turbine and prevent possible catastrophic failure.		
16 •	Monroe underground storage tank No. 389 (Exhibit A-12, Schedule B5.1,		
17	page 6, line 174) will be replaced with an above ground storage tank for		
18	\$1.2 million. Tank No. 389 has been in service since 1993. The tank		
19	collects used oil and is constructed of double-walled steel. Tank No. 389		
20	has a capacity of 5,750 gallons. This project will mitigate the oil spill risk		
21	and ensure continued environmental compliance.		

Monroe fuel supply tripper car gallery C will have the floor replacement
 (10,750 square feet of elevated structure) completed for \$4.7 million
 (Exhibit A-12, Schedule B5.1, page 6, line 175). The original tripper gallery
 floor, supporting floor beams, and floor beam top flanges have corroded

Line
<u>No.</u>

1	over time and require replacement to ensure worker safety during
2	washdown activities required to control fugitive and combustible coal dust.
3	There are 9 galleries (sections) in the tripper gallery that serve all four
4	Monroe Power Plant units, designated by letters A, B, C, D, E, F, G, H, and
5	J. Floor beam inspections were conducted to determine the condition of the
6	gallery and prioritize sections based on the results. The inspection included
7	the gallery conveyor floor system, floor plates, and floor supporting
8	structural steel. Gallery C was identified as the next priority area in the
9	inspection. Support beams and girders show signs of degradation and need
10	to be replaced. This project will restore the structural integrity of the floor,
11	the floor beams, girders, and associated connection hardware for this gallery
12	section.

- \$3.0 million will be spent in Monroe fuel supply to replace the transfer chutes in the CV-C2 Loading Zone (Exhibit A-12, Schedule B5.1, page 6, line 176). The CV-C2 loading zone transfer chutes design and technology is obsolete. This project replaces three (3) transfer chutes (C1A to CV-C2, C1B to CV-C2 & C1C to CV-C2) that load onto CV-C2 so that the transfer point is reconfigured such that the coal stream is less susceptible to dust generation, pluggage, and spillage.
- The Monroe fuel supply coal pile runoff oil wastewater system replacement
 project will be completed for \$2.6 million (Exhibit A-12, Schedule B5.1,
 page 6, line 177). As previously discussed above in the 2022 steam routine
 projects section, this project enhances environmental compliance by
 reducing the risk of oil contaminants from the storm water and coal pile run off systems reaching the lake.

Line
<u>No.</u>

<u>IU.</u>		
1		• The capping of section 1A at Sibley Quarry will be completed for \$8.3
2		million (Exhibit A-12, Schedule B5.1, page 6, line 186). This portion of the
3		site, twenty-seven (27) acres, has reached its licensed capacity and requires
4		capping as it is no longer available for material disposal.
5		
6	Q77.	What are the routine projects with projected capital expenditures greater than
7		\$1 million to be executed in 2025 for Steam Power Generation?
8	A77.	Planned maintenance projects greater than \$1 million in 2025 are detailed on page
9		7 of Exhibit A-12, Schedule B5.1 and discussed below.
10		• \$6.3 million will be spent on Belle River Unit 1 to complete replacement of
11		waterwall tubes (Exhibit A-12, Schedule B5.1, page 7, line 188). The project
12		will replace 2,500 square feet of boiler waterwall panels damaged by quench
13		cracking and sootblower erosion to support continued reliable boiler
14		operation.
15		• \$5.3 million will be spent to replace baskets on Belle River Unit 1 secondary
16		air heater (Exhibit A-12, Schedule B5.1, page 7, line 189). The baskets of
17		the secondary air heaters have been in service for 10 years, have eroded, are
18		loose and at risk of falling out, causing a forced outage. The integrity,
19		reliability, and efficiency of the secondary air heater baskets will be restored
20		with this project.
21		• Belle River Unit 1 IP turbine valves (Exhibit A-12, Schedule B5.1, page 7,
22		line 190) will be overhauled for \$4.5 million. The four (4) IP turbine control
23		and four (4) stop valves begin to wear within 6 to 8 years of an overhaul and
24		must be disassembled, inspected, and repaired every other periodic
25		outage. The Unit 1 IP turbine control and stop valves need to operate

Line
No.

2

properly to provide overspeed protection for the turbine and prevent possible catastrophic failure.

- \$3.3 million will be spent to replace the Belle River Unit 1 duplex heater
 (No. 1 and No. 2 low-pressure feedwater heater) (Exhibit A-12, Schedule
 B5.1, page 7, line 191). The low-pressure heaters are original plant
 equipment. Eddy current testing and borescope inspections of these heaters
 identified tube wall loss damage at the support plates. Replacement of the
 duplex heater is required to maintain unit performance.
- 9 \$2.6 million will be spent to replace Belle River Unit 1 expansion joints 10 (Exhibit A-12, Schedule B5.1, page 7, line 192). This project replaces 11 sixteen (16) expansion joints on the air side of the ductwork going to the 12 boiler and on the gas side of the ductwork from the boiler. A comprehensive 13 plan to identify and replace expansion joints on the air and gas ducts was 14 developed and is being implemented to address leakage. The replacements 15 are based on near term failure risk which would affect unit reliability, 16 efficiency, and result in a safety risk to plant personnel.
- 792 linear feet of Belle River Unit 1 horizontal middle reheat tubes (Exhibit
 A-12, Schedule B5.1, page 7, line 193) will be replaced for \$2.2 million.
 Corrosion and sootblower erosion have degraded the original 1980's era
 factory tube welds in the horizontal middle reheater.
- \$2.4 million will be spent to complete the replacement of the Belle River
 Unit 1 east boiler feed pump turbine blades and rotor (Exhibit A-12,
 Schedule B5.1, page 7, line 194). During Belle River Unit 1's 2022 periodic
 outage, the east boiler feed pump turbine rotor was inspected and heavy
 rubbing was found on multiple stages where the blades connect to the rotor

Line		
<u>No.</u>		

2

3

steeples. Crack indications were found and removed as a temporary repair enabling the equipment to return to service with a plan for replacement during the 2025 periodic outage.

- \$5.0 million will be spent to cap 16 acres in Area G2 Phase 2 at the Range
 Road Landfill with a 2-foot clay cover and a 6-inch layer of friable earth
 with vegetation cover (Exhibit A-12, Schedule B5.1, page 7, line 195). This
 work complies with the site landfill license from EGLE which requires
 sections of the landfill be capped as they are filled.
- 9 Engineering and material procurement will continue for the replacement of 10 the Belle River north auxiliary boiler (Exhibit A-12, Schedule B5.1, page 7, 11 line 196) and Belle River south auxiliary boiler (Exhibit A-12, Schedule 12 B5.1, page 7, line 197) for \$1.9 million each. Both auxiliary boilers are original to the 1980's era plant. They have become unreliable due to 13 14 frequent tube leaks, resulting in multiple tubes being plugged which significantly reduces boiler efficiency. As boiler efficiency is reduced, there 15 16 is an increasing risk that the boilers will not provide sufficient steam for unit 17 startups or building heat. Without sufficient building heat, there will be 18 freezing damage to various plant systems and equipment and safety issues 19 for plant personnel.
- \$5.9 million will be spent to complete the Greenwood Unit 1 LP turbine
 rotors and blades replacement project (Exhibit A-12, Schedule B5.1, page 7,
 line 201). Stress corrosion cracking of multiple blade root connections is
 being addressed to ensure continued safe and reliable operation of the LP
 turbines.

Line
<u>No.</u>

1	•	Greenwood Unit 1 feedwater heater No. 6 (Exhibit A-12, Schedule B5.1,
2		page 7, line 202) and feedwater heater No. 3 (Exhibit A-12, Schedule B5.1,
3		page 7, line 203) will be replaced for \$2.2 million and \$2.1 million,
4		respectively. A leak in the shell of feedwater heater No. 6 was discovered
5		in March 2023. Phased Array Ultrasonic Testing (PAUT) identified an 8"
6		long crack in the shell. Further PAUT scanning found several smaller
7		connected indications on the inside diameter of the shell. Additional
8		borescope inspection revealed multiple internal weld cracks located between
9		the desuperheating zone and the drain cooling zone of the feedwater heater.
10		The feedwater heater needs to be replaced to restore reliable service. The
11		existing feedwater heater No. 3 is experiencing an increasing number of tube
12		leaks and requires replacement to restore reliability. Both feedwater heaters
13		take waste heat from the LP turbines and use it to preheat boiler feedwater
14		improving the overall efficiency of the steam power cycle. All steam turbine
15		power cycles utilize feedwater heating in this manner.
16	•	The Greenwood Unit 1 turbine valves will be rebuilt for \$1.8 million
17		(Exhibit A-12, Schedule B5.1, page 7, line 204). The valves are worn and
18		require overhaul to operate safely and properly. These valves provide
19		overspeed protection for the turbine and prevent possible catastrophic
20		failure.
21	•	The Greenwood Unit 1 north boiler feed pump turbine last row of blades will
22		be replaced for \$1.5 million to correct erosion damage on the existing blades
23		(Exhibit A-12, Schedule B5.1, page 7, line 205).
24	•	\$1.3 million will be spent to replace Greenwood Energy Center underground
25		storage tank No. 377 (Exhibit A-12, Schedule B5.1, page 7, line 206). The

Line
<u>No.</u>

2

3

4

5

tank has been in service for over 30 years. Underground storage tanks that
have been in service for this many years have an increased risk of failure,
potentially allowing the contents to leak, contaminating the soil and
groundwater around the tank. Tank No. 377 contains gasoline fuel with a
capacity of 2,500 gallons.

6	• Monroe Unit 1 IP turbine rotor (Exhibit A-12, Schedule B5.1, page 7, line
7	207) replacement will be completed for \$4.2 million. During offsite
8	inspection in 2023, creep void indications of cracking were found in the bore
9	and the stage 1 wheel dovetail roots. The OEM performed the work required
10	to return the rotor to service on a short-term basis but also provided further
11	analysis of the rotor that confirmed the need to replace the rotor soon,
12	concluding that it could only be returned to service for no more than 30
13	months.

- Monroe Unit 1 SCR catalyst modules for layer 3 will be replaced for \$2.5
 million (Exhibit A-12, Schedule B5.1, page 7, line 208). The catalyst
 module replacements are required to maintain compliance with air permit
 emission limits for NOx and ammonia slip guidelines.
- Monroe Unit 1 coal mill feeder controls will be replaced for \$1.4 million (Exhibit A-12, Schedule B5.1, page 7, line 209). The current coal mill feeder controls for all seven (7) coal mills are original equipment (1970's).
 Reliability of this equipment has diminished, causing unit derates.
 Replacing the obsolete controls is needed to address the reliability issues.
 This controls project upgrade will improve reliability, accuracy of measuring coal flow, and boiler efficiency.
| Line | |
|------|--|
| No. | |

1	• In preparation for the Monroe Unit 2 periodic outage in 2026, \$11.0 million
2	will be spent to continue procurement payments on material to forge new
3	LP turbine rotors and blades (Exhibit A-12, Schedule B5.1, page 7, line
4	210). Replacement is needed due to the industry-wide problem of stress
5	corrosion cracking on the current LP turbine forgings. In addition, Monroe
6	Unit 2 SCR catalyst modules for layers 1, 2, and 4 will be purchased for
7	\$4.4 million (Exhibit A-12, Schedule B5.1, page 7, line 211). The catalyst
8	module replacements are required to maintain compliance with air permit
9	emission limits for NOx and ammonia slip guidelines. Finally, \$3.0 million
10	will be spent to purchase materials for replacing the Monroe Unit 2 north
11	and south air heater hot-end baskets (Exhibit A-12, Schedule B5.1, page 7,
12	line 212). The baskets have significant deterioration which limits heat
13	transfer capability and impacts operational performance. The integrity,
14	reliability, and efficiency of the Monroe Unit 2 north and south air heaters
15	will be restored.
16 •	\$5.3 million will be spent to complete the replacement of the Monroe Unit 4
17	LPA and LPB turbine rotors and blades (Exhibit A-12, Schedule B5.1, page
18	7, line 213). Refurbishment is needed due to the industry-wide problem of
19	stress corrosion cracking on the current LP turbine which could result in
20	unexpected catastrophic failure. The LP rotors that were installed on
21	Monroe Unit 1 in 2001 have been replaced with new upgraded rotors in
22	2023. Due to the cost of forging new rotors or the extended outage required
23	to perform the refurbishment of the Monroe Unit 4 rotors, Unit 4's rotors

will be replaced with those that were removed from Unit 1. The Unit 1 rotors

<u>No.</u>	
1	will be inspected and refurbished to provide safe and reliable operation of
2	the Unit 4 LP turbines until the projected retirement of Unit 4 in 2028.
3	• \$4.2 million will be spent to overhaul the Monroe Unit 4 turbine valves
4	(Exhibit A-12, Schedule B5.1, page 7, line 214). Project scope includes the
5	four (4) stop valves, four (4) control valves, and 2 combined reheat stop
6	valves. The valves are worn and require overhaul for proper operation until
7	unit retirement. These valves provide overspeed protection for the turbine
8	and prevent possible catastrophic failure.
9	• Monroe Unit 4 SCR catalyst modules for layers 1, 3, and 4 will be replaced
10	for \$3.6 million (Exhibit A-12, Schedule B5.1, page 7, line 215). The
11	catalyst module replacements are required to maintain compliance with air
12	permit emission limits for NOx and ammonia slip guidelines.
13	• \$2.6 million will be spent to complete the Monroe Unit 4 coal mill primary
14	air duct and dampers project (Exhibit A-12, Schedule B5.1, page 7, line 216).
15	The existing ductwork is thinning, resulting in fugitive dust leaks, and
16	requires replacement.
17	• \$2.4 million will be spent to complete replacement of Monroe Unit 4
18	expansion joints (Exhibit A-12, Schedule B5.1, page 7, line 217). Fourteen
19	(14) high priority Monroe Power Plant Unit 4 expansion joints have been
20	identified to be replaced due to leakage. A leak can affect unit reliability,
21	efficiency, and result in a safety risk to plant personnel.
22	• \$2.1 million will be spent to replace the Unit 4 FGD inlet expansion joint
23	and flanges on both upstream and downstream sides of the joint (Exhibit A-
24	12, Schedule B5.1, page 7, line 218). The inlet expansion joint is essential
25	to reliability for inlet flue gas to enter the absorber tower. It allows for

Line
<u>No.</u>

2

3

expansion and contraction of the inlet duct with changing temperatures
(during a shutdown/startup of the unit). The existing joint and flange surface
is damaged and needs replacement to allow the joint to seal.

- 4 \$1.9 million will be spent to complete the Monroe Unit 4 DCS and control ٠ 5 room modifications (Exhibit A-12, Schedule B5.1, page 7, line 219). The 6 equipment and software are at risk from a reliability perspective, requiring 7 modifications to keep the plant's control systems reliable. The DCS 8 hardware was last replaced over a decade ago and the associated software 9 dates to the 1980's. Additionally, the equipment is no longer supported by 10 the vendor. The Company has scaled back this project to focus on the critical 11 work necessary to support continued operations to 2028.
- 12 The Monroe Unit 4 secondary heat exchanger (Exhibit A-12, Schedule B5.1, 13 page 7, line 220) will be replaced for \$1.9 million. The Unit 4 secondary 14 heat exchanger is an original piece of equipment (1970's era) and provides 15 process heat to the combustion coils that are needed for unit start-up and 16 building heating which will continue to be needed after unit retirement. The 17 existing secondary heat exchanger has become unreliable due to an 18 increasing number of tube leaks. Replacement of the secondary heat 19 exchanger will improve unit reliability and maintain building heating 20 requirements.
- \$2.1 million will be spent to install new piping within the Monroe urea to ammonia (U2A) systems (Exhibit A-12, Schedule B5.1, page 7, lines 221 and 222). The emergency cooling and condensate systems have started to leak and show heavy corrosion after 15 years of service. The U2A system is common to all four units and required to be operational at all times.

Line
<u>No.</u>

1	Shutdown of the U2A system results in forced outages to all four Monroe
2	Power Plant units. This project will install new cooling water supply and
3	condensate return lines supporting the four U2A reactors and restore reliable
4	operations to this critical environmental control equipment.
5	• Monroe fuel supply tripper car gallery D will have the floor replacement
6	(9,890 square feet of elevated structure) completed for \$7.1 million (Exhibit
7	A-12, Schedule B5.1, page 7, line 223). The original tripper gallery floor,
8	supporting floor beams, and floor beam top flanges have corroded over time
9	and require replacement to ensure worker safety during washdown activities
10	required to control fugitive and combustible coal dust. There are 9 galleries
11	(sections) in the tripper gallery that serve all four Monroe Power Plant units,
12	designated by letters A, B, C, D, E, F, G, H, and J. Floor beam inspections
13	were conducted to determine the condition of the gallery and prioritize
14	sections based on the results. The inspection included the gallery conveyor
15	floor system, floor plates, and floor supporting structural steel. Gallery D
16	was identified as the next priority area in the inspection. Support beams
17	and girders show signs of degradation and need to be replaced. This project
18	will restore the structural integrity of the floor, the floor beams, girders, and
19	associated connection hardware for this gallery section.
20 •	\$1.9 million will be spent to replace the Fuel Supply Dust Collector No. 4
21	(Exhibit A-12, Schedule B5.1, page 7, line 224). The replacement will
22	mitigate combustible dust and comply with the NFPA combustible dust

23 guidelines.

Line
<u>No.</u>

1	1 Routine Capital Expenditures - Hydraulic Power Generation	
2	Q78.	What were the Company's routine capital expenditures in 2022 for Hydraulic
3		Power generation (Ludington)?
4	A78.	During 2022, the Company's Energy Supply group's routine capital expenditures
5		for the Ludington Pumped Storage facility were \$13.0 million as shown on Exhibit
6		A-12, Schedule B5.1, page 3 of 9, line 8, column (b). Expenditures were related to
7		unit and HVAC maintenance, powerhouse roof replacement, lower penstock
8		expansion joint chamber water stop replacement, and controls upgrades and
9		replacements.
10		
11	Q79.	What will be the Company's routine capital expenditures for Hydraulic Power
12		Generation (Ludington) in the 24 months ending December 31, 2024?
13	A79.	During the 24 months ending December 31, 2024, Energy Supply routine capital
14		expenditures for the Ludington Pumped Storage facility are projected to be \$19.3
15		million as shown on Exhibit A-12, Schedule B5.1, page 3 of 9, line 8, column (e).
16		Investments will be related to the replacements of the powerhouse roof, lower
17		penstock expansion joint chamber water stop, barrier net panels, oil water separator,
18		and control relays and performing unit maintenance and upgrades to auxiliary
19		equipment.
20		
21	Q80.	What will be the Company's routine capital expenditures for Hydraulic Power
22		Generation (Ludington) in the projected test year, the 12 months ending
23		December 31, 2025?
24	A80.	During the 12 months ending December 31, 2025, the Company's routine capital
25		expenditures for the Ludington Pumped Storage facility are projected to be \$10.8

Line	
<u>No.</u>	

1		million as shown on Exhibit A-12, Schedule B5.1, page 3 of 9, line 8, column (f).
2		Investments will be related to replacements of control relays, governors, barrier net
3		panels, and oil water separator, as well as station power transformer and other unit
4		maintenance.
5		
6	<u>Routi</u>	ne Capital Expenditures - Other Power Generation
7	Q81.	What bulk electric system support is provided by the peaking units included
8		in Other Power Generation?
9	A81.	DTE Electric's fleet of peaking units are primarily valued for their capacity and
10		ability to start up quickly and reliably in response to high peak customer demand
11		and the variable circumstances on the Company's distribution system throughout
12		its 7,600 square mile service territory. The safe, reliable operation of these peaking
13		units is also an important factor in system balancing as additional intermittent
14		resources are integrated into the grid.
15		
16	Q82.	What were the Company's routine capital expenditures greater than \$1
17		million in 2022 for Other Power Generation?
18	A82.	During 2022, the Company's routine capital expenditures for Other Power
19		Generation units was \$66.7 million as shown on Exhibit A-12, Schedule B5.1, page
20		3 of 9, lines 9-10, column (b). These expenditures include the following projects
21		that individually exceeded \$1 million as detailed on page 4 of Exhibit A-12,
22		Schedule B5.1:
23		• \$6.5 million was spent to complete the Belle River 12-1 major overhaul
24		(Exhibit A-12, Schedule B5.1, page 4, line 53). This work was required for
25		continued safe and reliable operation. Major maintenance intervals for gas

Line
No.

2

turbines are established by the cumulative run hours and startup sequences experienced.

- In preparation for the Belle River 12-2 Peaker major overhaul outage in
 2023, \$2.1 million was spent to continue procurement of materials (Exhibit
 A-12, Schedule B5.1, page 4, line 54). This work was required for continued
 safe and reliable operation. Major maintenance intervals for gas turbines are
 established by the cumulative run hours and startup sequences experienced.
- \$2.0 million was spent to replace the generator field on Belle River 12-1
 (Exhibit A-12, Schedule B5.1, page 4, line 55). This work was required for
 continued safe and reliable operation. Generator field replacements for gas
 turbines are established by the years of service and the frequency of start/stop
 cycles experienced by the unit.
- 13 In preparation for combustion overhauls in 2023, material procurement was 14 completed for Belle River 13-1 (Exhibit A-12, Schedule B5.1, page 4, line 15 56) and Greenwood 12-1 (Exhibit A-12, Schedule B5.1, page 4, line 57) 16 Peakers for \$1.7 million each. The projects included the replacement of fuel 17 nozzles, support housings, combustor baskets, transition pieces, as well as 18 inner and outer transition seals. This work was required to ensure continued 19 safe and reliable operation. Major maintenance intervals for gas turbines are 20 established by the cumulative run hours and startup sequences experienced. 21 Combustion overhauls were completed on Greenwood 11-1 (Exhibit A-12, • 22 Schedule B5.1, page 4, line 58) and Greenwood 11-2 (Exhibit A-12, 23 Schedule B5.1, page 4, line 59) Peakers for \$1.5 million and \$1.2 million, 24 respectively. These projects included the replacement of fuel nozzles, 25 support housings, combustor baskets, transition pieces, as well as inner and

Line
<u>No.</u>

1		outer transition seals. This work was required for continued safe and reliable
2		operation. Major maintenance intervals for gas turbines are established by
3		the cumulative run hours and startup sequences experienced.
4	•	The Renaissance Unit 4 (Exhibit A-12, Schedule B5.1, page 4, line 60) and
5		Renaissance Unit 1 (Exhibit A-12, Schedule B5.1, page 4, line 62) Peakers
6		(163 MW each) completed major overhauls for \$13.5 million and \$7.4
7		million, respectively. These were the first major maintenance overhauls
8		since the units were installed in 2002. The overhauls were required to
9		maintain the peakers' availability and included corrective maintenance on
10		the compressor, combustion system, gas turbine blading, and hot gas path.
11	•	In preparation for the Renaissance Unit 3 Peaker (163 MW) major overhaul
12		in 2023, \$9.7 million was spent to procure materials for the overhaul (Exhibit
13		A-12, Schedule B5.1, page 4, line 61). This was the first major maintenance
14		since the unit was installed in 2002. The overhaul was required to maintain
15		peaker availability and includes corrective maintenance on the compressor,
16		combustion system, gas turbine blading, and hot gas path.
17	•	\$3.6 million was spent for engineering and material procurement of the
18		Renaissance Unit 3 Peaker exhaust cylinder and manifold replacement
19		(Exhibit A-12, Schedule B5.1, page 4, line 63). Recent exhaust system
20		inspections completed on Renaissance Unit 3 revealed degradation of
21		components and struts, material distress, and weld cracks. The integrity of
22		the exhaust turbine casing and cylinder were at risk of failure and required
23		replacement.
24	•	The exhaust silencers (baffles) on the Renaissance Unit 3 Peaker were
25		replaced for \$2.9 million (Exhibit A-12, Schedule B5.1, page 4, line 64).

<u>No.</u>		
1		The exhaust silencer baffles were degrading, and inspections identified
2		metal debris and insulation material loss. The new baffles improve sound
3		attenuation of the unit, supporting permit compliance.
4		• \$2.0 million was spent to start procurement of a Renaissance spare main unit
5		transformer (Exhibit A-12, Schedule B5.1, page 4, line 65). The previous
6		spare transformer will be installed on Renaissance Unit 1 in 2024. This
7		transformer is needed for fleet reliability in the event of a failure of one of
8		the other Renaissance main unit transformers.
9		• In preparation for replacing the exhaust silencers (baffles) on the
10		Renaissance Unit 4 Peaker in 2023, \$1.3 million of materials were procured
11		(Exhibit A-12, Schedule B5.1, page 4, line 66). The previous exhaust
12		silencer baffles were degraded, and inspections identified metal debris and
13		insulation material loss. The new baffles improve sound attenuation of the
14		unit, supporting permit compliance.
15		
16	Q83.	What are the routine projects with projected capital expenditures greater than
17		\$1 million in 2023 for Other Power Generation?
18	A83.	Planned 2023 Other Power Generation maintenance projects greater than \$1 million
19		are detailed on page 5 of Exhibit A-12, Schedule B5.1 and described below. The
20		individual projects with greater than \$1 million expenditures in 2023 for Other
21		Power Generation units include:
22		• A Belle River 12-2 Peaker major overhaul outage was completed in 2023 for
23		\$5.4 million (Exhibit A-12, Schedule B5.1, page 5, line 114). Additionally,
24		the Greenwood 11-1 Peaker will prepare for a 2024 major overhaul outage
25		with engineering for \$1.4 million (Exhibit A-12, Schedule B5.1, page 5, line

<u>No.</u>		
1	117). This work is required for continued safe and reliable operation. Major	
2	maintenance intervals for gas turbines are established by the cumulative run	
3	hours and startup sequences experienced.	
4	• During the annual borescope inspection, emergent work was found to be	
5	required for the Belle River 13-1 Peaker Modified Hot Gas Path Overhaul	
6	and is projected for \$1.4 million (Exhibit A-12, Schedule B5.1, page 5, line	
7	115). Hardware damage as the result of a failed transition piece end seal,	
8	which was found in good condition in the spring borescope inspection, was	
9	identified within the combustion and turbine sections. The transition seal	
10	will be repaired, damaged 1st stage buckets will be replaced, and minor	
11	damage on the 2nd and 3rd stage hardware will be addressed.	
12	• The generator field was replaced on the Belle River 12-2 (Exhibit A-12,	
13	Schedule B5.1, page 5, line 116) Peaker for \$1.4 million. This work was	
14	required for continued safe and reliable operation. Generator field	
15	replacements for gas turbines are established by the years of service and the	
16	frequency of start/stop cycles experienced by the unit.	
17	• The generator field was replaced on the Northeast 13-2 Peaker for \$1.6	
18	8 million (Exhibit A-12, Schedule B5.1, page 5, line 118). This work was	
19	9 required to replace failed equipment and for continued safe and reliable	
20	operation. The generator field failed in 2022 and required replacement.	
21	• The Renaissance Unit 4 Peaker (163 MW) generator stator was rewound and	
22	the rotor was replaced (Exhibit A-12, Schedule B5.1, page 5, line 119) with	
23	a projected \$9.2 million project expense. This rewind and rotor replacement	

24

25

generator. During the inspection phase of the project, the neutral side main

was required because Renaissance Unit 4 experienced a ground fault on the

Line
<u>No.</u>

1		leads were found to have flashed between two phases, damaging insulation
2		material and stator components.
3	•	The Renaissance Unit 3 Peaker (163 MW) completed a major overhaul in
4		2023 for \$7.1 million (Exhibit A-12, Schedule B5.1, page 5, line 120). This
5		was the first major maintenance since the unit was installed in 2002. The
6		overhaul was required to allow the return of the peaker to service and
7		included corrective maintenance on the compressor, combustion system, gas
8		turbine blading, and hot gas path.
9	•	During the annual borescope inspection, emergent work was found to be
10		required for the Renaissance Unit 2 Peaker (163 MW) Modified Hot Gas
11		Path Overhaul and is projected for \$3.7 million (Exhibit A-12, Schedule
12		B5.1, page 5, line 121). Significant erosion with material loss was identified
13		at the row 1 turbine vane trailing edges and at the row 1 turbine blade leading
14		edges. Replacement of the row 1 vane and blade assemblies will be
15		completed to address these issues.
16	•	The exhaust silencer baffles on the Renaissance Unit 2 (Exhibit A-12,
17		Schedule B5.1, page 5, line 122) and Renaissance Unit 4 (Exhibit A-12,
18		Schedule B5.1, page 5, line 124) Peakers were replaced for \$2.3 million and
19		\$1.7 million, respectively. The exhaust silencer baffles were degrading, and
20		inspections identified metal debris and insulation material loss. The new
21		baffles improved sound attenuation of the unit, supporting permit
22		compliance.
23	•	\$1.8 million was spent to complete the Renaissance Unit 3 exhaust cylinder
24		and manifold replacement (Exhibit A-12, Schedule B5.1, page 5, line 123).
25		Exhaust system inspections completed on Renaissance Unit 3 revealed

Line
<u>No.</u>

1		degradation of components and struts, material distress, and weld cracks.
2		The inspections indicated the integrity of the exhaust turbine casing and
3		cylinder were close to failure and required replacement.
4		• Procurement of a Renaissance unit compatible spare main unit transformer
5		was completed for \$1.2 million (Exhibit A-12, Schedule B5.1, page 5, line
6		125). This transformer was needed for fleet reliability in the event of a
7		failure of any one of the Renaissance main unit transformers.
8		
9	Q84.	What are the routine projects with projected capital expenditures greater than
10		\$1 million in 2024 for Other Power Generation?
11	A84.	Planned Other Power Generation maintenance projects greater than \$1 million in
12		2024 are detailed on page 6 of Exhibit A-12, Schedule B5.1 and described below.
13		The individual projects with greater than \$1 million expenditures in 2024 for Other
14		Power Generation units include:
15		• \$3.7 million will be spent to complete the Blue Water Energy Center
16		circulating water pumps enclosure project (Exhibit A-12, Schedule B5.1,
17		page 6, line 144). Although the plant is designed to operate at minus 24
18		degrees Fahrenheit, the weather experienced in December 2022 revealed that
19		certain wind direction and ice-forming conditions could still negatively
20		impact plant reliability. During these conditions, the motor air filters on the
21		circulating water pumps become plugged with ice which obstructs airflow
22		and causes the motors to overheat and shutdown. Additionally, the cooling
23		tower stairs, which are located immediately adjacent to the circulating water
24		pumps, also experience heavy icing. Enclosing the circulating water pump,
25		supporting systems, and the cooling tower stairs protects them from the

<u>No.</u>	
1	cooling tower plume during the winter and will prevent forced outages and
2	reduce the risk of employee injury.
3	• The Blue Water Energy Center conference room building (Exhibit A-12,
4	Schedule B5.1, page 6, line 145) will be completed for \$3.3 million. In the
5	December 1, 2023 Commission Order from the last rate case No. U-21297,
6	the Commission did not allow the inclusion of this project in rate base at that
7	time due to what it considered insufficient information. To provide the
8	further explanation and justification, the Company offers the following:
9	
10	The current office space configuration provides the fulltime employees of
11	Blue Water with 25 available workspaces for their daily use. The 25
12	workspaces are at times not sufficient because the site workforce can surge
13	to 100-plus personnel in support of routine and major maintenance activities.
14	
15	During construction of the plant, the large construction workforce used a
16	significant number of temporary trailers for this purpose. Other DTE
17	Electric power plant sites have repurposed original construction buildings
18	that were converted to functional plant conference rooms when construction
19	was completed.
20	
21	This new building will also support craft labor onboarding requirements,
22	which include safety training and onsite orientation. Due to the open-air
23	design of the Blue Water Energy Center, there are insufficient enclosed
24	spaces available to support these onboarding requirements. Conversely,
25	other DTE Electric power plant sites have historically utilized large open

Line	
<u>No.</u>	

2

3

4

spaces that are inherent in the design of the plant boiler / turbine buildings to temporarily accommodate the needs of craft labor. A drawing of the conference building layout is provided in my workpapers in support of this project.

\$1.5 million will be spent for material procurement to replace the Blue Water
Energy Center plant control system server (Exhibit A-12, Schedule B5.1,
page 6, line 146). The current version of the Windows Operating System at
Blue Water Energy Center is based on Microsoft Windows Server 2012
validated by General Electric at the time the Blue Water project was
commenced. That version has a service end date of October 2023 and needs
to be upgraded to maintain software security and reliability protocols.

- 12 \$1.1 million will be spent to start procurement of a spare Blue Water Energy 13 Center steam turbine generator transformer (Exhibit A-12, Schedule B5.1, page 6, line 147). There is no transformer available that meets the electrical 14 15 configuration requirements for the Blue Water Energy Center steam turbine 16 generator. It is both reasonable and prudent to initiate the procurement of a spare transformer at this time, especially considering the multi-year 17 18 manufacturing time requirement. A failed transformer could cause an 19 extended forced outage of 2-3 years.
- A combustion overhaul will be completed on the Belle River 13-1 Peaker
 for \$1.4 million (Exhibit A-12, Schedule B5.1, page 6, line 178). The project
 includes the replacement of fuel nozzles, support housings, combustor
 baskets, transition pieces, as well as inner and outer transition seals. This
 work is required for continued safe and reliable operation. Major

1	1 maintenance intervals for gas turbines are established by t	the cumulative run
2	2 hours and startup sequences experienced.	
3	• A blackstart peaker unit starting system will be replaced	d for \$2.8 million
4	4 (Exhibit A-12, Schedule B5.1, page 6, line 179). The unit	t starting system is
5	5 obsolete and requires replacement with an up-to-date des	sign. Components
6	6 of the existing unit starting system, installed in 1999, are no	o longer supported
7	7 by the OEM and other suppliers.	
8	8 • Greenwood 11-1 Peaker major overhaul outage will be c	completed in 2024
9	9 for \$6.8 million (Exhibit A-12, Schedule B5.1, page 6, lin	e 180). This work
10	10 is required for continued safe and reliable operation. M	lajor maintenance
11	11 intervals for gas turbines are established by the cumulat	tive run hours and
12	12 startup sequences experienced.	
13	• The exhaust silencers (baffles) on the Greenwood 11-	1, 11-2, and 12-1
14	14 Peakers will be replaced for \$2.9 million (Exhibit A-12, So	chedule B5.1, page
15	15 6, line 181). The exhaust silencer baffles are degrading	g, and inspections
16	16 identified metal debris and insulation material loss. The	e new baffles will
17	17 improve sound attenuation of the unit, supporting permit	compliance.
18	• The generator field will be replaced on the Greenwood 1	1-1 (Exhibit A-12,
19	19 Schedule B5.1, page 6, line 182) Peaker for \$1.7 milli	on. This work is
20	20 required to ensure continued safe and reliable operation	1. Generator field
21	21 replacements for gas turbines are established by the years	of service and the
22	22 frequency of start/stop cycles experienced by the unit.	
23	• The Renaissance Unit 1 (Exhibit A-12, Schedule B5.1, pa	ge 6, line 183) and
24	24 Renaissance Unit 3 (Exhibit A-12, Schedule B5.1, page 6,	, line 184) Peakers
25	25 (163 MW each) generator stator rewind and rotor rep.	lacements will be

Line <u>No.</u>

Line
<u>No.</u>

<u>10.</u>		
1		completed for \$7.4 million and \$7.0 million, respectively. Previous
2		inspections on Renaissance units revealed a high level of risk for in-service
3		faults that need to be addressed to prevent failure. Accordingly, these units
4		require a generator stator rewind and rotor replacement to avoid an in-service
5		failure.
6		• The main unit transformer on the Renaissance Unit 1 Peaker will be replaced
7		for \$1.7 million (Exhibit A-12, Schedule B5.1, page 6, line 185).
8		Transformer testing detected high internal gas levels, which is the leading
9		indicator of transformer failure requiring replacement. The spare
10		transformer utilized for this replacement was previously purchased and its
11		planned use triggered the Company to purchase a replacement spare as
12		discussed on page 116 of this testimony.
13		
14	Q85.	What are the routine projects with projected capital expenditures greater than
15		\$1 million in 2025 for Other Power Generation?
16	A85.	Planned Other Power Generation maintenance projects greater than \$1 million in
17		2025 are detailed on page 7 of 9 in Exhibit A-12, Schedule B5.1 and described
18		below. The individual projects with greater than \$1 million of expenditures in 2025
19		for Other Power Generation units include:
20		• Material procurement for a Blue Water Energy Center steam turbine
21		generator transformer (Exhibit A-12, Schedule B5.1, page 7, line 198) and

Blue Water Energy Center combustion turbine transformer (Exhibit A-12,
Schedule B5.1, page 7, line 199) will continue for \$1.9 million and \$1.8
million, respectively. There are no transformers available for the Blue Water

<u>No.</u>	
1	Energy Center combustion turbines and steam turbine generator. A failed
2	transformer could cause an extended forced outage of 2-3 years.
3	• \$1.7 million will be spent to complete the Blue Water Energy Center plant
4	control system server upgrade (Exhibit A-12, Schedule B5.1, page 7, line
5	200). The current version of the Windows Operating System at Blue Water
6	Energy Center is based on Microsoft Windows Server 2012 validated by
7	General Electric at the time the Blue Water project was commenced. That
8	version has a service end date of October 2023 and needs to be upgraded to
9	maintain software security and reliability protocols.
10	• A blackstart peaker starting system will be replaced for \$2.8 million (Exhibit
11	A-12, Schedule B5.1, page 7, line 225). The unit starting system is obsolete
12	and requires replacement with an up-to-date design. Components of the
13	existing unit starting system, installed in 1999, are no longer supported by
14	the OEM and/or other suppliers.
15	• The exhaust silencers (baffles) on the Delray 11-1 and 12-1 Peakers will be
16	replaced for \$1.9 million (Exhibit A-12, Schedule B5.1, page 7, line 226).
17	The exhaust silencer baffles are degrading, and inspections identified metal
18	debris and insulation material loss. The new baffles will improve sound
19	attenuation of the unit, supporting permit compliance.
20	• In preparation for major overhauls in 2026, engineering will begin for the
21	Greenwood 11-2 Peaker for \$1.2 million (Exhibit A-12, Schedule B5.1, page
22	7, line 227) and 12-1 Peaker for \$1.1 million (Exhibit A-12, Schedule B5.1,
23	page 7, line 228). This work is required for continued safe and reliable
24	operation. Major maintenance intervals for gas turbines are established by
25	the cumulative run hours and startup sequences experienced.

Line
<u>No.</u>

1		• \$8.7 million will be spent to complete the Renaissance Unit 4 Peaker (163
2		MW) exhaust cylinder and manifold replacement (Exhibit A-12, Schedule
3		B5.1, page 7, line 229). Exhaust system inspections completed on
4		Renaissance Unit 4 and sister units have revealed degradation of components
5		and struts, material distress, and weld cracks. The integrity of the exhaust
6		turbine casing and cylinder are at risk of failure and require replacement.
7		• The Renaissance Unit 2 Peaker (163 MW) generator rotor will be replaced
8		for \$3.2 million (Exhibit A-12, Schedule B5.1, page 7, line 230). This
9		generator work must be completed to correct the degradation of insulation
10		and copper and reduce the risk of extensive damage should a failure occur.
11		• A blackstart peaker major overhaul outage will begin for \$6.4 million
12		(Exhibit A-12, Schedule B5.1, page 7, line 231) and be completed in 2026.
13		This work is required for continued safe and reliable operation. Major
14		maintenance intervals for peakers are established by the cumulative run
15		hours and startup sequences experienced.
16		
17	<u>AFUI</u>	DC Estimate
18	Q86.	Do the capital expenditures you are supporting include an allowance for funds
19		used during construction (AFUDC)?
20	A86.	Yes, capital expenditures include an AFUDC for eligible projects that are in
21		Construction Work in Progress (CWIP). At the direction of Company Witness
22		Uzenski, AFUDC is applied to projects greater than \$50,000 and lasting more than
23		six months, except for large environmental projects which are exempt from
24		AFUDC treatment.

Line	
<u>No.</u>	

1	Q87.	How much AFUDC is assumed in the projected test period for Energy Supply?
2	A87.	AFUDC for Energy Supply is included on Exhibit A-12, Schedule B5.1, page 8 of
3		9. As shown on line 16, column (c), the AFUDC is projected to be \$21.0 million
4		for the 12-month period ending December 31, 2025. A historical trend is used to
5		estimate AFUDC on routine capital since the mix of eligible projects is consistent
6		year-to-year, while the AFUDC is calculated specifically on a project-by-project
7		basis for eligible non-routine projects. The authorized cost of capital rate used is
8		5.561% consistent with the December 1, 2023 Case No. U-21297 Order. For
9		additional details on AFUDC refer to Company Witness Uzenski's direct
10		testimony.
11		
12	Remo	val Costs, Plant in Service and CWIP Forecast
13	Q88.	What is provided on the schedule entitled Removal Costs, Plant in Service, and
14		CWIP schedule on page 9 of 9 of Exhibit A-12, Schedule B5.1?
15	A88.	This schedule provides a breakdown of plant activities which are used by Witness
16		Uzenski to forecast Plant in Service, Accumulated Depreciation, and CWIP on the
17		projected balance sheet. Capital expenditures consistent with Exhibit A-12,
18		Schedule B5.1, page 1 are summarized in columns (c) through (f). Column (b)
19		includes a corresponding in-service assumption: Annual is indicated for categories
20		of plant spend that are generally unitized within the year of spend, while a specific
21		in-service date is used for projects that remain in CWIP for more than a year before
22		moving into Plant in Service.
23		
24		Column (g) includes an estimated percentage of removal costs that are included
25		within the capital expenditures. Removal costs, as discussed by Witness Uzenski,

Line	
<u>No.</u>	

1		are charged to Accumulated Depreciation rather than Plant/ CWIP and are therefore
2		not depreciable. Removal cost of 15% based on historical trend of removals as a
3		component of capital expenditures is applied to routine expenditures on lines 2
4		through 6. 100% is applied to specific removal and decommissioning projects on
5		lines 9, 10, and 22 and 0% is applied to non-removal projects on lines 11 and 12.
6		Finally, 0% is applied to new build projects on lines 15 through 21 since there is no
7		related removal work.
8		
9		Column (h) through (j) reflect calculated removal costs based on projected Capital
10		Expenditures in columns (d) through (f) multiplied by the removal cost % in column
11		(g). The remaining Capital Expenditures will appear in Plant in Service columns
12		(k) through (m) if in-service assumption is "Annual", or CWIP columns (n) through
13		(p) until the date of in-service as indicated in column (b). At that time, cumulative
14		spend including the historical period is transferred to in-service (excluding the
15		removal cost estimate). Major projects with a long lead time also reflect spend
16		from earlier years that will be transferred out of CWIP into Plant in Service on the
17		in-service date.
18		
19	<u>Part I</u>	II – Energy Supply Operation and Maintenance Expenses
20	Q89.	What is the process used to prepare the Energy Supply operating and
21		maintenance (O&M) projected level of expense?
22	A89.	Projected O&M expense is developed by taking historical test year O&M
23		expenditure data and adjusting for any known projected period changes. Plant level
24		changes include labor and material cost increases, cost variations related to

- environmental equipment operation, non-periodic maintenance cost variations
 driven by predictive maintenance programs, and other known changes.
 The overall Energy Supply O&M projection for steam, hydraulic, and other
 generation assets is developed by adjusting the actual historic test year (2022)
 results for rate case adjustments between witnesses, normalization adjustments to
- the 2022 data, and known and measurable adjustments to handle O&M changes (up
 or down). O&M projections in this case do not include funding for Energy Supply
 renewable generation wind and solar assets that are handled in other regulatory
 filings.
- 11

Energy Supply operations expenses are those associated with day-to-day operation of the Company's generating units, including certain Account 501 fuel handling expenses. Energy Supply maintenance expenses are associated with periodic outages, non-periodic outages, and other maintenance activities. Other maintenance activities include standard day-to-day work to maintain plant equipment, such as inspections, servicing, and minor maintenance that does not require the unit to be taken offline to complete.

19

21

22

23

20 Energy Supply O&M is presented in three major cost categories as shown below:

- Steam Power Generation
- Hydraulic Power Generation
 - Other Power Generation
- 24

Line
<u>No.</u>

1	Q90.	What were Energy Supply's historical O&M Expenditures for 2022 for Steam
2		Power Generation?
3	A90.	During 2022, Steam Power Generation adjusted O&M expenses totaled \$231.5
4		million as shown on Exhibit A-13 Schedule C5.1, line 19, column (g). This was
5		comprised of \$105.2 million in operations costs and \$126.3 million in maintenance
6		costs. The \$8.3 million of Steam Power Generation O&M that relates to Fuel
7		Supply and Midwest Energy Resources Company (MERC) Fuel Handling is
8		sponsored by Company Witness Milo on Exhibit A-13, Schedule C5.2 and is
9		subtracted on line 20 (Note 1), resulting in remaining Steam Power Generation
10		adjusted O&M in the amount of \$223.2 million.
11		
12	Q91.	Can you provide an overview of Exhibit A-13, Schedule C5.1?
13	A91.	Exhibit A-13, Schedule C5.1 shows total projected test period O&M for Steam
14		Power Generation by starting with the 2022 actual O&M expenses and adjusting
15		for rate case eliminations, normalization/other adjustments, and inflation
16		adjustments. The historical adjustment is required to determine the portion of the
17		2022 O&M expenses that will reoccur in the 12-month period ending December
18		31, 2025. The normalization adjustment credit of \$0.099 million is shown in note
19		4. There are also "Other" credit adjustments of \$31.5 million required in column
20		(k) and shown in note 6 to project the O&M required in the 12-month forecasted
21		test period ending December 31, 2025.
22		
23	Q92.	What major O&M expense categories are found in Exhibit A-13, Schedule
24		C5.1?

Line No.

4

A92. The expenses shown in Exhibit A-13, Schedule C5.1 are categorized into the major
 categories of operations and maintenance consistent with FERC accounting
 guidelines.

5 Operations account 500 includes the cost of plant management for the individual 6 plant sites, their supporting staffs, and the Energy Supply Engineering Support 7 Organization. Plant management includes plant site director, area managers, and 8 administrative support. The major supporting staffs in this area are the technical 9 and engineering personnel associated with problem solving daily plant operating 10 issues, obtaining and interpreting test data, and developing long-term operating and 11 maintenance plans to maintain plant availability and efficiency.

12

Operations account 501 "Fuel Handling" includes expenses incurred for coal train and vessel unloading, ash disposal, coal pile management, and mobile equipment operations. Depending on plant site and delivery options, plants maintain and manage a coal pile inventory that can vary over many months. Larger coal pile inventories are required at the Belle River Power Plant at the end of December to ensure adequate coal supplies when vessel deliveries cannot be obtained due to winter ice on the Great Lakes.

20

Accounts 502 and 505 represent operations personnel and materials expenses associated with direct operating supervision and control of boiler, turbine, generator, water, and environmental control systems. Shift supervisor and control room supervising operators are key to the successful steam power generation unit operations that are required to ensure adequate and cost-efficient production of

Line No.

1 2

3

4

5

6

7

8

9

electrical energy for our customers. Their labor expenses are captured in these accounts.

Account 506 "Misc. Steam Power Expenses" includes Instrument and Controls personnel to troubleshoot and calibrate the vast array of complex instruments and controls found on steam generating units. Also included in this account are operations of all common equipment such as water, air, and cooling equipment systems. Plant buildings and grounds cleaning, landscaping, snow removal, and maintenance are also captured in this account.

10

Maintenance accounts 510 through 514 capture expenses associated with planned 11 12 and unplanned maintenance activities. These expenses mostly consist of the 13 planned maintenance activities that generally occur on a two to five-year interval 14 on all boiler systems and on a six to ten-year interval on turbine systems. Account 15 510 captures management of the plant maintenance area including area managers 16 and general foremen. Account 511 covers maintenance of common infrastructure 17 areas such as roofs, windows, and roads. The major area of expense captured in 18 account 512 "Maintenance of Boilers" includes maintenance expenses for internal 19 and external labor and all materials associated with planned and unplanned outage 20 work on the boilers. The boiler maintenance scope of work includes the boilers, air 21 and flue gas systems, ash handling, and fuel burning equipment. The major area of 22 expense captured in account 513 "Maintenance of Electric Plant" includes internal 23 and external labor and materials expenses associated with work on turbines. The 24 major area of expense captured in account 514 "Maintenance of Misc. Steam Plant"

Line <u>No.</u>		
1		includes internal and external labor and materials expenses for maintenance of all
2		common equipment such as water, air, and cooling equipment systems.
3		
4	Q93.	Can you provide additional detail on the O&M expenses incurred for the
5		Company's Steam Power Generation during 2022?
6	A93.	Yes. In the historic period of 2022, the Company spent \$223.2 million in Steam
7		Power Generation O&M expenses after adjustments and reclassifications. Planned
8		major periodic maintenance outages were executed in 2022 on Belle River Unit 1
9		and Monroe Unit 2. Also completed during 2022 were multiple short duration unit
10		tune-up outages on various units to allow their continued efficient operation
11		burning high percentages of lower sulfur coals. Costs for the portions of outages
12		that occur in years other than 2022 will be captured in those years.
13		
14		The other category of maintenance expenses incurred during the historic period
15		were associated with regular plant maintenance while units were in operation or
16		expenses to repair or replace equipment during a forced or unplanned unit outage.
17		These short duration unplanned maintenance outages can generally be completed
18		in three to seven days and will be experienced at varying intervals on all steam
19		power generating units depending on the severity of the service cycles and the time
20		elapsed since the last planned maintenance outage.
21		
22		During the projected 12-month period ending December 31, 2025, the Company
23		will execute major periodic maintenance outages on Belle River Unit 1, Greenwood
24		Unit 1, and Monroe Unit 4, and minor periodic maintenance on Monroe Unit 1. As

Line <u>No.</u>		
1		in the historic period, short duration unit tune-up outages will also be completed on
2		various steam power generation units to optimize continuing performance.
3		
4	Q94.	What adjustments were made to the historical test period amounts?
5	A94.	Fuel Handling O&M expenses recorded in Fuel Account 501 are added to Steam
6		Power O&M in column (d). This amount includes Fuel Supply and MERC Fuel
7		Handling for which an adjustment is made in column (e) to reclassify non-O&M
8		fuel handling sponsored by Witness Milo (Note 3). In column (f) detailed in Note
9		4, there is one (1) historical adjustment:
10		• A credit for \$99 thousand for the removal of EEI membership dues as
11		supported by Witness Uzenski.
12		
13	Q95.	Can you describe some of the benefits the Company and its customers realize
13 14	Q95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power
13 14 15	Q95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)?
 13 14 15 16 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations
 13 14 15 16 17 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and
 13 14 15 16 17 18 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities.
 13 14 15 16 17 18 19 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities.
 13 14 15 16 17 18 19 20 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities. Specifically, with respect to EPRI, the Company collaborates with other utilities to
 13 14 15 16 17 18 19 20 21 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities. Specifically, with respect to EPRI, the Company collaborates with other utilities to fund technical projects that study and resolve critical industry issues. For instance,
 13 14 15 16 17 18 19 20 21 22 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities. Specifically, with respect to EPRI, the Company collaborates with other utilities to fund technical projects that study and resolve critical industry issues. For instance, EPRI guidelines for boiler water chemistry and steam purity are commonly
 13 14 15 16 17 18 19 20 21 22 23 	Q95. A95.	Can you describe some of the benefits the Company and its customers realize through its memberships in industry associations, such as the Electric Power Research Institute (EPRI)? Yes. As discussed by Witness Crozier, memberships in industry associations provide the Company access to benchmarking/best practices, research, and networking opportunities. Specifically, with respect to EPRI, the Company collaborates with other utilities to fund technical projects that study and resolve critical industry issues. For instance, EPRI guidelines for boiler water chemistry and steam purity are commonly referenced to protect plant equipment and maintain reliable operations. In addition

Line <u>No.</u>		
1		membership is cost-effective. The costs for the Company to perform even one of
2		these projects would be greater than the cost of the membership.
3		
4	Q96.	What are the inflation factors shown in Note 5 of Exhibit A-13 Schedule C5.1?
5	A96.	Note 5 contains the inflation factors that are utilized to forecast the changes
6		necessary to transition needed O&M funding from the historic test year of 2022 to
7		the projected test year ending December 31, 2025. The labor and material inflation
8		adjustment factor of 3.20% for 2023, 2.90% for 2024, and 2.90% for 2025 is
9		supported by Witness Uzenski.
10		
11	Q97.	Can you provide a further explanation of the \$31.5 million projected test year
12		credit adjustment (reduction) shown on note 6 of Exhibit A-13, Schedule C5.1?
13	A97.	Yes. The \$31.5 million projected test year credit (reduction) adjustment shown in
14		this exhibit reflects projected test year modifications needed to transition from 2022
15		actual O&M expenses to those required in the 12 months ending December 31,
16		2025. The labor and material inflation adjustment factor of 3.20% for 2023, 2.90%
17		for 2024, and 2.90% for 2025 is supported by Witness Uzenski:
18		• The first adjustment is a credit of \$18.3 million and represents the St. Clair
19		Power Plant's operation and maintenance expenses in 2022 that will not
20		occur in the projected test period, as St. Clair Power Plant retired in 2022.
21		A portion of St. Clair Power Plant's 2022 expenses are not included in the
22		adjustment. The portion not included is \$2.7 million of fuel supply costs
23		common to St. Clair and Belle River Power Plants that were transferred to
24		Belle River Power Plant because they are necessary for providing fuel to
25		Belle River in the projected test year. The Belle River and St. Clair Power

<u>No.</u>		
1		Plants share a common coal vessel unloading facility that continues to be
2		required to support the Belle River Power Plant after the St. Clair Power
3		Plant retired.
4		• The second adjustment is a credit of \$13.1 million and represents the Trenton
5		Channel Power Plant's operation and maintenance expenses in 2022 that will
6		not occur in the projected test period, as the Trenton Channel Power Plant
7		retired in 2022. A portion of Trenton Channel Power Plant's 2022 expenses
8		are not included in the adjustment. The portion not included is \$0.4 million,
9		representing Sibley Quarry's operation and maintenance costs. Sibley
10		Quarry will continue operation beyond the date of the Trenton Channel
11		Power Plant's retirement because it provides waste disposal services to
12		Monroe Power Plant and other DTE business units.
13		
14	Q98.	Can you summarize Exhibit A-13, Schedule C5.4, entitled "Operations and
15		Maintenance Expenses - Hydraulic Power Generation"?
16	A98.	Exhibit A-13, Schedule C5.4 represents DTE Electric's share of the continuing
17		operation and maintenance expense of the Ludington Pumped Storage facility. As
18		a 49 percent owner of this facility, the Company incurs expenses for operating and
19		maintaining the facility. The forecasts for these expenses through the projected test

18a 49 percent owner of this facility, the Company incurs expenses for operating and19maintaining the facility. The forecasts for these expenses through the projected test20period are based on the historic labor and materials expenses adjusted for inflation.21The labor and material inflation adjustment factor of 3.20% for 2023, 2.90% for222024, and 2.90% for 2025 is supported by Witness Uzenski. No other historical or23projected adjustments were made to Hydraulic Power Generation Projected24Operation and Maintenance expenses.

25

Line

Line <u>No.</u>

Q99. Can you summarize Exhibit A-13, Schedule C5.5, entitled "Operations and Maintenance Expenses - Other Power Generation? A99. Exhibit A-13, Schedule C5.5 represents DTE Electric's peaker fleet O&M costs, as well as Blue Water Energy Center, which began commercial operations in June 2022. DTE Electric owns and operates a quantity of peaking units ranging from 2.5 MW diesel-fueled engines to newer 163 MW natural gas-fired combustion

turbines. The main driver of projections for these expenses through the projected test period is the labor and material required to support these peaker assets and Blue Water Energy Center. Included in this category will also be the labor expenses for the Generation Optimization and Integrated Resource Planning teams. The forecasts for these expenses through the projected test period are based on the historic labor and materials expenses as adjusted for inflation. The labor and material inflation adjustment factor of 3.20% for 2023, 2.90% for 2024, and 2.90%

- 14 for 2025 is supported by Witness Uzenski.
- 15

Q100. Did you make any adjustments to the historical test period operations and maintenance expenses for other power generation?

- A100. Yes. I eliminated \$37.7 million of total 2022 test year O&M, listed in column (d)
 of Exhibit A-13, Schedule C5.5 because these expenses are related to the renewable
 energy program which are not associated with the instant case.
- 21

Q101. What adjustments were made to the projected test period amounts for other power generation?

A101. In column (i) detailed in Note 3 of Exhibit A-13, Schedule C5.5, there is an upward
 adjustment for \$6.3 million in support of Blue Water Energy Center's operation.

1		Of the \$6.3 million total adjustment, \$4.67 million is in support of ongoing base
2		operation and maintenance, while \$1.67 million is in support of the estimated
3		levelized major periodic O&M expense not covered by the contract service
4		agreement with the OEM. The plant began commercial operations in June of 2022.
5		
6		Also, \$0.31 million is forecasted in 2025 to support of the first full year of Slocum
7		BESS operations.
8		
9		Finally, there is a decrease of \$0.2 million related to the retirement and suspension
10		of operations of peaker units (River Rouge 11, Slocum 11, and St. Clair 12
11		retirements and Fermi 11-3 and Fermi 11-4 suspension of operations).
12		
13	Q102.	What are your thoughts concerning the level of DTE Electric's historical and
13 14	Q102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony?
13 14 15	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M
13 14 15 16	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and
13 14 15 16 17	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed
13 14 15 16 17 18	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and
 13 14 15 16 17 18 19 	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and O&M expenditures. I believe that DTE Electric has fully justified as reasonable
 13 14 15 16 17 18 19 20 	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and O&M expenditures. I believe that DTE Electric has fully justified as reasonable and prudent its request for recovery of the Energy Supply plant expenses that are
 13 14 15 16 17 18 19 20 21 	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and O&M expenditures. I believe that DTE Electric has fully justified as reasonable and prudent its request for recovery of the Energy Supply plant expenses that are set forth in my testimony and associated exhibits.
 13 14 15 16 17 18 19 20 21 22 	Q102. A102.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and O&M expenditures. I believe that DTE Electric has fully justified as reasonable and prudent its request for recovery of the Energy Supply plant expenses that are set forth in my testimony and associated exhibits.
 13 14 15 16 17 18 19 20 21 22 23 	Q102. A102. Q103.	What are your thoughts concerning the level of DTE Electric's historical and projected capital and O&M expenses contained in your testimony? DTE Electric has been reasonable and prudent in past capital and O&M expenditures, and I anticipate this to continue through the projected test period and beyond. During this same timeframe, generation unit availability is managed through a rigorous process that continues to be focused on prudent capital and O&M expenditures. I believe that DTE Electric has fully justified as reasonable and prudent its request for recovery of the Energy Supply plant expenses that are set forth in my testimony and associated exhibits. Does this complete your direct testimony?

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

SHANNEN M. HARTWICK

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF SHANNEN M. HARTWICK Line

<u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Shannen M. Hartwick (she/her/hers), and my business address is One
3		Energy Plaza, Detroit, Michigan, 48226. I am employed by DTE Electric Company
4		(DTE Electric, DTEE or Company).
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	I graduated from the University of Michigan with a Bachelor of Science in
11		Engineering in 2007 and completed the Executive MBA program with the Ross
12		School of Business at the University of Michigan in April 2023.
13		
14	Q4.	Please summarize your professional experience.
15	A4.	I began my career with DTE Electric in 2008 and have been employed there since.
16		I started out as an Associate Engineer in the Performance Management group where
17		I worked on several process improvement projects across Distribution Operations.
18		Over the years, I held a number of positions with increasing leadership
19		responsibilities primarily within Distribution Operations and spent a year in DTE
20		Electric's strategy team. Within Distribution Operations I worked in areas that
21		include: Process Management Team, Substations, Asset Optimization (System
22		Operations Center, Strategy, and dispatch), Southeast Service Operations and Tree
23		Trim.

24

Line	
ЪT	

<u>No.</u>							
1		In 2014, I took a position as a Developmental Field Supervisor – Southeast Service					
2		Operations where I was responsible for leading the frontline lineman performing					
3		maintenance, operations, and construction on DTE Electric's electrical distribution					
4		system.					
5							
6		In 2015, I was promoted to Manager - Tree Trim where I was responsible for					
7		leading Operations for the Tree Trim Team, comprised of DTE Energy Employees					
8		and all six of our tree trim vendors (comprising over 1300 tree trimmers in 2022).					
9		In this role, I was responsible for safety, quality, productivity, customer					
10		satisfaction, storm and trouble restoration efforts, and relationships with					
11		municipalities.					
12							
13		In 2020, I was promoted to the Director of Tree Trim where I was responsible for					
14		the strategy and execution of the Tree Trim Program. This included contract					
15		negotiations, strategy, planning, auditing, execution, outage restoration trimming,					
16		customer satisfaction, tree trim technology, and scheduling.					
17							
18	Q5.	Do you hold any certifications or are you a member of any professional					
19		organizations?					
20	A5.	Yes. I am a Lean Six Sigma Blackbelt.					
21							
22	Q6.	What are your current duties and responsibilities?					
23	A6.	Currently, I am the Director of Automation. In this role, I am responsible for the					
24		execution of the distribution automation work. This includes overseeing					

Line <u>No.</u>		
1		automation program strategy and budget, engineering and planning, scheduling,
2		construction, and in-servicing commissioning.
3		
4	Q7.	Have you previously sponsored testimony before the Michigan Public Service
5		Commission (MPSC or Commission)?
6	A7.	Yes. I sponsored testimony in Case numbers. U-20836 and U-21297. In addition,
7		I supported the preparation of testimony on the topic of the Company's tree
8		trimming program in previous rate cases (Case Nos. U-20162 and U-20561).

Line	
<u>No.</u>	

1 **Purpose of Testimony**

2	Q8.	What is the purpose of your testimony?				
3	A8.	The purpose	The purpose of my testimony is to support, as reasonable and prudent, the historical			
4		capital expe	capital expenditures for 2022, projected capital expenditures for 2023 through			
5		December 3	1, 2025, in t	he distribution strategic investment category of the		
6		Technology	and Automat	tion Pillar, and the programs associated with the		
7		Company's l	Infrastructure F	Recovery Mechanism (IRM).		
8						
9	Q9.	Are you spo	nsoring any e	xhibits in this proceeding?		
10	A9.	Yes. I am	sponsoring po	rtions of Exhibit A-12 Schedule B5.4, Exhibit A-23		
11 12		Schedule M7	Schedule M7, and all of Exhibit A-19 as follows:			
13		<u>Exhibit</u>	<u>Schedule</u>	Description		
14		A-12	B5.4	Projected Capital Expenditures, Distribution Plant -		
15				Technology and Automation (pg. 1-2,17-26)		
16		A-23	M7	Distribution Plant Capital Project Detail –		
17				Technology and Automation		
18		A-12	B5.4.1	Pilots: NWA: O'Shea Energy Storage		
19		A-12	B5.4.2	Pilots: NWA: Battery Trailer		
20		A-12	B5.4.3	Pilots: NWA: Omega Load Relief		
21		A-12	B5.4.4	Pilots: NWA: Fisher Load Relief		
22		A-12	B5.4.5	Pilots: NWA: Port Austin Load Relief		
23		A-12	B5.4.6	Pilots: NWA: Veridian		
24		A-12	B5.4.7	Pilots: NWA: EV Charging Demonstration at ACM		
25		A-12	B5.4.9	Pilots: NWA: Adaptive Networked Microgrids		

SMH-4

Line <u>No.</u>						
1		A-19	I1.1	Telecom Reliability		
2		A-19	I1.2	Telecom Cost		
3						
4	Q10.	Were these e	xhibits prepare	ed by you or under your direction?		
5	A10.	Yes, they were	2.			
6						
7	Q11.	How is your t	estimony organ	nized?		
8	A11.	My testimony	consists of the f	following parts:		
9		Part I – Infrast	ructure Recover	ry Mechanism (IRM) Support		
10		Part II – Grid Automation				
11		A. Distribution Automation				
12		B. Grid Automation Telecommunications				
13		C. Conservation Voltage Reduction and Voltage/VAR (Volt-Amps Reactive)				
14		Optimization (CVR/VVO)				
15		D. Non-Wire Alternative (NWA) Pilots				
16		E. Grid Edge Insights and New Technology				
17		F. Distrib	oution Line Sens	ors		
18		Part III – Operational Technology				
19		G. Grid Management				
20		H. Distribution Planning				
21		I. Work Management and Scheduling				
22		J. Asset M	Management			
23		K. Mobile	e Technology			
24						
25	Q12.	Can you pleas	se describe the	Technology & Automation Pillar?		


1 Inherent to grid modernization, new technologies are becoming an increasingly A12. 2 fundamental part of the grid, improving the way modern electric grids operate and 3 resulting in improved reliability, operability, and safety. Investments in technology 4 also provide new opportunities to improve operations in ways that benefit 5 customers, such as the ability to automatically isolate outages to limit the number 6 of impacted customers. An additional critical function is to provide real-time 7 visibility for system operators and engineers into circuit and substation loading. 8 This loading data is critical to managing circuits efficiently both today and in the 9 future, and to accommodating electric vehicles and increasing numbers of 10 Distributed Energy Resources (DER) such as solar, and energy storage. A modern 11 distribution system overview can be seen in the figure below.

12

13





Line	
<u>No.</u>	

1	Q13.	What categories of investments make up the Technology and Automation
2		Pillar?
3	A13.	This pillar consists of the Grid Automation and Operational Technology categories.
4		Grid Automation covers four key areas: Distribution Automation, Grid Automation
5		Telecommunications, Conservation Voltage Reduction (CRV/VVO), and Non-
6		Wire Alternatives (NWA) pilots. Operational Technology covers five key areas:
7		Grid Management, Distribution Planning, Work Management and Scheduling,
8		Asset Management, and Mobile Technology. These are discussed later in
9		testimony.
10		
11	Q14.	Do Grid Automation and Operational Technology (OT) work independently
12		of each other?
13	A14.	No, OT is a set of enabling technologies that interact closely with Grid Automation
14		and are tailored to support its objectives where needed within the Automaton
15		roadmap.
16		
17	Infras	structure Recovery Mechanism (IRM) Support
18	Q15.	Are any of the programs you are supporting impacted by the Company's
19		Distribution Infrastructure Recovery Mechanism (Distribution IRM or
20		IRM)?
21	A15.	Yes, as described by Company Witness Foley in his testimony, in the
22		Commission's December 1, 2023 Order in Case No. U-21297 (December 2023
23		Order) it authorized IRM treatment for the 4.8 kV Circuit Automation program
24		from December 1, 2023 through the end of 2025.

Line	
<u>No.</u>	

1	Q16.	Is the Company proposing recovery of any additional automation investment
2		during the bridge and/or test years beyond what the Commission previously
3		authorized for recovery through the IRM?
4	A16.	Yes, as reflected in Exhibit A-12, Schedule B5.4, Page 17, Line 2, the Company is
5		proposing recovery on an additional \$21.2 million of Distribution Automation
6		investment in 2024 and an additional \$125.6 million of Distribution Automation
7		investment in 2025. This investment is incremental to the automation investment
8		already authorized for IRM treatment during these years and will support wholly
9		different work to avoid double recovery of the same investment.
10		
11	Q17.	Is the Company proposing recovery for any additional automation investment
12		through the IRM beyond the test year of this case?
13	A17.	Yes, as described by Company Witness Foley, the Company is proposing a two-
14		year extension of the IRM (i.e., calendar years 2026 and 2027). As part of that
15		extension the Company is proposing recovery of additional Distribution
16		Automation capital investment as captured in Exhibit A-33, Schedule X1.
17		
18	Q18.	Is the Company proposing any modifications to the scope of the automation
19		investment authorized for IRM treatment?
20	A18.	Yes, as part of the proposed two-year IRM extension described by Company
21		Witness Foley, the Company is proposing that the scope of the automation
22		investment change from "4.8 kV Circuit Automation" to "Distribution
23		Automation". This change reflects the Company's strategy to fully automate the
24		distribution grid to provide safety and reliability benefits to customers. The is
25		discussed in more detail in later in my testimony, questions 29 and 30.

Line
No.

1 Grid Automation

2 Q19. What is Grid Automation?

- A19. Grid Automation is focused on the physical technology infrastructure needed to
 support the efficient control and operation of a modern distribution grid. These
 investments include reclosers to improve safety and reliability, capacitors and
 voltage regulation for CVR/VVO, infrastructure to support NWA, DER, EVs, and
 grid telecommunications.
- 8

9 Q20. Why is investing in Grid Automation essential for the customers of DTEE?

10 A20. Grid Automation is essential for DTEE to improve grid reliability, provide an enhanced customer experience, facilitate grid planning, and support integration of 11 12 DERs. The distribution grid is increasing in complexity as the result of growing 13 bi-directional flow of power from the integration of renewable resources. Grid 14 automation improves the reliability of the power grid by enabling real-time 15 monitoring, control, and quick response to faults and abnormalities. It reduces 16 outage durations, improves fault detection, and enhances grid resilience. Grid 17 automation plays a crucial role in managing the variability and intermittency of 18 renewable energy generation. It enables the ability to balance supply and demand, 19 optimize energy flows, ensure grid stability, and facilitates the seamless integration 20 of renewable energy into the grid. Grid Automation also provides valuable data 21 and insights for grid planning and expansion. With automation, DTEE can adapt 22 to changes in energy generation and consumption patterns, better accommodate the 23 load growth from electric vehicles and integrate other new technologies into the 24 grid. This flexibility ensures the grid can meet future energy demands and 25 technological advancements.

Line	
No.	

1	Q21.	Where are the details of the capital investment in this category?
2	A21.	The details of the capital investment in this category are included in:
3		Exhibit A-12, Schedule B5.4, page 17-18
4		Exhibit A-23, Schedule M7
5		

6

Table 1 Grid Automation Exhibit Locations

Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
Distribution Automation	p. 17, line 2	pp. 46-49	pp. 136, 138-139
Grid Automation Telecommunications	p. 17, line 6	pp. 74-77	pp. 136, 140-142
CVR/VVO	p. 17, line 8	pp. 34-37	pp. 136, 142
NWA: O'Shea Energy Storage	p. 17, line 9	pp. 142-145	pp. 136, 142-143
NWA: Battery Trailer	p. 17, line 10	pp. 125-128	pp. 136, 142-143
NWA: Omega Load Relief	p. 17, line 11	pp. 138-141	pp. 136, 142-143
NWA: Fisher Load Relief	p. 17, line 12	pp. 134-137	pp. 136, 142-143
NWA: Port Austin Load Relief	p. 17, line 13	pp. 146-149	pp. 136, 142-143
NWA: Veridian	p. 17, line 25	pp. 154-157	pp. 136, 142-143
EV Charging Projects	p. 17, line 28	pp. 129-133	pp. 136, 142-143
NWA: Adaptive Networked Microgrids	p. 17, line 26	pp. 120-124	pp. 136, 142-143
Grid Edge Insights & New Technology	p. 17, line 30	pp. 78-82	pp. 137, 143
DER Control	p. 18, line 31	pp. 38-41	pp. 137, 143
NWA: Small Solar and Storage Testbed	p. 17, line 14	pp. 150-153	pp. 137, 143
Sensor, Network and Algorithm Development (Solar Deployment)	p. 17, line 15	рр. 181-184	pp. 137, 143
Distribution Sensing and Monitoring (incldg Line Sensors)	p. 17, line 7	pp. 54-57	N/A

Line	
No.	

1	А.	Distribution Automation
2	Q22.	What is Distribution Automation?
3	A22.	Distribution Automation (DA) uses digital sensors and switches with advanced
4		control and communication technologies to automate feeder switching, monitor
5		voltage and equipment health, and manage voltage and reactive power. Automation
6		improves the speed, cost, and accuracy of these key distribution functions to deliver
7		reliability improvements and cost savings to customers. This technology plays a
8		crucial role in modernizing the power grid, as evidenced by The Department of
9		Energy (DOE) report Distribution Automation: Results from the Smart Grid
10		Investment Grant Program ¹ ," published in September 2016.
11		
12	Q23.	What are the benefits of Distribution Automation?
13	A23.	The benefits include: improved distribution system resilience to extreme weather
14		which can limit the number of customer outages; improved Fault Location,
15		Isolation, and Service Restoration capabilities which improve customer restoration;
16		more effective equipment monitoring and preventative maintenance to prevent
17		equipment failures; more efficient use of repair crews; reduced repair times; and
18		improved grid integration of DER.
19		
20		The Distribution Automation technologies and Smart Grid Investment Grant
21		Projects discussed by the DOE in a 2016 report on the benefits of distribution
22		automation begin to quantify how these technologies can substantially benefit the
23		grid. After deploying distribution automation programs, five utilities reported a 50-

¹ Office of Electricity Delivery and Energy Reliability. (2016). *Distribution Automation: Results from the Smart Grid Investment Program*. U.S. Department of Energy. energy.gov/sites/prod/files/2017/01/f34/Final SGIG Report - 2016-12-20_clean.pdf

Line	
<u>No.</u>	

1		55% reduction in the number of customer interruptions and customer minutes of
2		interruptions per outage events, while three utilities reported System Average
3		Interruption Frequency Index (SAIFI) improvements of 17-58% from pre-
4		deployment baselines due to the ability to more quickly identify the location of a
5		fault and perform switching activities that allow the fault to be isolated to a smaller
6		area so that fewer customers are impacted during the repair activities. The real-
7		world examples provided by the DOE in this study demonstrate that DTE Electric
8		specific Distribution Automation circuit and program benefits, such as the SAIDI
9		reduction of 54 minutes over 2024 and 2025, covered later are achievable. ²
10		(Distribution Automation: Results from the Smart Grid Investment Grant Program
11		(energy.gov)).
12		
13		Distribution Automation, which includes automated field devices, advanced
14		protection, and SCADA, is a core component for grid modernization. Distribution
15		Automation provides immediate system reliability benefits and adds the core
16		components to support potential future grid needs.
17		
18	Q24.	What are the core investments the company is deploying to achieve these
19		benefits?
20	A24.	The Distribution Automation Program is primarily composed of pole top recloser
21		deployments. Pole top reclosers, such as the G&W Electric's Viper recloser used
22		in this program, offer a variety of capabilities needed for distribution automation
23		such as the ability to isolate outages into smaller sections and the ability to reroute
24		power around damage. Reclosers installed at midpoints on a circuit will operate

² See footnote 1.

Line
No.

1 when a fault is detected and isolate the outage to smaller area, impacting less 2 customers. Reclosers installed at a tie point on the end of a circuit provide the 3 ability to reconfigure circuits and reroute power around damaged sections by 4 connecting to adjacent circuits. This device is also used to provide advanced 5 protection capabilities, such as ground detection and isolation, which are covered 6 in more detail in question 26. The pole top devices also provide circuit level 7 SCADA monitoring and control to the System Operations Center. Beyond the pole 8 top reclosers, some general distribution construction may be needed to create tie 9 points on distribution circuits and to support capacity and voltage during 10 reconfiguration.

11

Q25. Does DTEE have any unique considerations informing the development of its Distribution Automation strategy?

DTEE has two unique considerations that were important when evaluating 14 A25. 15 Distribution Automation on the Company's distribution system. The first of these 16 is the nature of the ungrounded 4.8 kV delta system. This consideration is unique 17 as most utilities no longer have this type of lower voltage ungrounded system to 18 consider. Distribution Automation will improve ground detection and isolation, 19 thus reducing the risk of energized down wire on the ungrounded 4.8 kV system. 20 The ground detection functionality adds improved safety factors to the traditional 21 reliability improvement from Distribution Automation. The second consideration 22 is that service restoration benefits identified in Distribution Automation require a 23 level of circuit connectivity and capacity beyond what DTEE has in some areas of 24 the distribution grid. Circuits with existing connections that need only automation 25 equipment installed will be targeted earlier in this process, while circuits requiring

new connectivity or additional capacity are prioritized later in order to maximize near term benefits for customers.

3

2

1

4 Q26. What benefits can reclosers provide in terms of ground detection and isolation? 5

6 A26. A ground on a circuit is a potential indicator of an energized wire-down condition 7 that in some circumstances could pose a safety hazard to the public. The 8 Distribution Automation Program includes start of circuit reclosers that provide 9 new capability to detect when a ground occurs on a circuit as well as the ability to 10 isolate the grounded circuit. Currently, when a ground alarm appears on a circuit, 11 a substation operator is dispatched to the substation and manually identifies which 12 circuit has a ground, then a field crew is sent to locate the ground and isolate. With 13 the ability to automatically identify this condition, the hazard can be detected and deenergized much more quickly and efficiently through automated isolation, 14 15 quickly eliminating the risk associated with the downed wire. Addressing these 16 hazards automatically not only reduces the safety risk sooner but allows resources 17 previously used to isolate energized wire downs to be directed to restoration 18 activities. This grid improvement is accomplished by installing start of circuit 19 reclosers across all circuits fed from the same substation transformer and 20 programming these reclosers using timing coordination between the circuits. 21 Under this structure, when a ground occurs on one of the circuits from that 22 substation transformer, all of the circuits detect the ground. This trigger 23 programmed timing coordination of the reclosers, where each recloser operates in 24 sequence until the circuit with the ground is detected and isolates that individual 25 circuit. As a result, potentially energized wire downs are isolated and deenergized

very quickly. These benefits will apply to all circuits being automated in 2024 (95
 circuits), which currently see an average of 16 downed wires per year, and to the
 149 4.8 kV circuits being automated in 2025, which currently see an average of 17
 downed wires per year.

- 5
- 6

7

Q27. Are the technology investments for the Distribution Automation Program the same for all circuits?

8 A27. No. To achieve the service restoration capabilities associated with FLISR, an 9 alternative source of power from adjacent circuits with capacity for additional load 10 needs to be available. Approximately half (48%) of DTEE's distribution circuits already have these connection points established and have the ability to provide 11 12 sufficient capacity to allow service restoration during an outage event. An 13 additional 40% of circuits either require some investment to establish connection 14 points or require detailed evaluation to determine if investment is needed to 15 increase emergency capacity needed to support service restoration. The remaining 16 12% of circuits have physical restrictions such as lakes, rivers, freeways, or service 17 territory boundaries that may make establishing connections with adjacent circuits 18 difficult. The estimated benefits of tie locations are also adjusted to account for 19 catastrophic storm conditions during which both circuits may be impacted, thereby 20 reducing the benefits. This condition is addressed through a reduction to overall 21 benefits of the Distribution Automation Program rather than on an individual circuit 22 basis.

23

Q28. What factors inform the Company's prioritization for DistributionAutomation?

Line No.

1	A28.	Across Distribution Operations, the Global Prioritization Model (GPM) is used to
2		rank strategic investments; this topic is described further by witness Kryscynski.
3		These factors are what drives Distribution Automation's high GPM ranking: (a) the
4		safety benefits associated with de-energizing down wires, (b) the reliability benefits
5		associated with the reduced number of customer interruptions and the reduction of
6		outage durations, and (c) the improved operational efficiencies associated with
7		improved system monitoring and control. The safety benefit factor applies to all
8		4.8 kV circuits, and special weighting is given to the 4.8 kV circuits that have
9		experienced high levels of wire downs. There are also additional safety benefits
10		for completing all circuits associated with a particular substation transformer to
11		ensure ground isolation coordination. Reliability benefits are estimated at the
12		individual circuit level based on historical reliability and the existing level of
13		automation. The existing level of automation is also key to estimating costs for
14		cost/benefit circuit prioritization. Operational efficiency improvements are
15		universally applied with improvements in safety and reliability.

16

17 Q29. What is the Company's scope for Distribution Automation?

18 A29. The scope of Distribution Automation includes: (a) installation of SCADA enabled 19 reclosers on larger circuits with more than 400 customers to have at a minimum of 20 one midline recloser and a SCADA enabled tie point, (b) installation of a recloser 21 near the start of the overhead portion of a circuit for all ungrounded 4.8 kV circuits 22 to enable ground detection and isolation, (c) installation of reclosers near the start 23 of the circuit on 13.2 kV circuits that currently do not have SCADA enabled circuit 24 breakers in the substation, (d) the construction of the necessary overhead equipment 25 to create and enable load shifts between circuits, and, (e) the integration of devices

1 and technology within ADMS to allow for the application of FLISR with the new 2 and existing devices. The scope will also include ground fault detection and 3 isolation on the 4.8 kV system, SCADA monitoring and control of all general-4 purpose distribution circuits, and improved fault isolation and increased remote restoration capabilities to improve reliability. 5 6 7 **Q30.** How has this strategy evolved since the Company's previous rate case, Case 8 No. U-21297, was filed? 9 A30. Following the severe storms that impacted the Company's service territory in early 10 2023, a review of the outage events and the duration of restoration concluded that the limited deployment of automation across the electric grid was impeding the 11 12 Company's ability to restore services to customers swiftly during large storm 13 events. Based on this conclusion, the Company determined that extensive circuit 14 automation was required to improve reliability performance for our customers. 15 As part of this expanded focus, the Distribution Automation Program was 16 17 broadened to encompass the entire distribution grid, including the installation of 18 SCADA-enabled reclosers and enabling remote sectionalization of outages into 19 400-800 customer segments. Additionally, it includes establishing tie points to 20 connect circuits for efficient load shifting. 21 22 Furthermore, the Company recognized that deploying remotely operated SCADA-23 enabled reclosers on circuits will deliver most of the benefits associated with the 24 substation automation program at a significantly accelerated pace. As a result of 25 this assessment, funding for substation automation was reduced and redirected to

Line

No.

Distribution Automation investments, which also supported greater alignment and bundling opportunity with substation related asset replacement scope of work.

2 3

1

4 **Q31.** With the expanded scope of Distribution Automation and the refined ability 5 to prioritize circuits to automate, will the Company combine 4.8 kV circuit 6 automation, 13.2 kV circuit automation, substation automation, and circuit 7 rebuild for automation into a single focused distribution automation 8 program?

9 A31. Yes. The Company has developed a cost-benefit model for Distribution 10 Automation that estimates the reliability and safety impact and the investment required for every distribution circuit. This model allows the Company to prioritize 11 12 circuits across all of the previously individual automation programs. As a 13 fundamental step in the program, standards are being developed for the 14 implementation of automation associated with specific grid voltage. Investment 15 for recloser installations in 2024 will continue to focus on the 4.8 kV distribution 16 system, based on standards and design work that was completed in 2023. The 13.2 17 kV standards for automation are being developed in 2024, which will ensure the 18 2024 design and 2025 construction will be aligned with the updated circuit 19 prioritization model.

20

21 **Q32**. How are circuit level benefits estimated?

22 A32. Distribution Automation circuit level benefits were modelled by reviewing 23 historical reliability performance against expected performance based on 24 installation of Distribution Automation equipment including midpoint reclosers and 25 SCADA enabled tie points. For example, a 4.8 kV circuit without any automation

Line
No.

1 would have been modeled by reviewing the reliability data for the recent outages 2 and then reviewing what the reliability data would have been after the planned 3 installation start of circuit ground detection recloser, a midpoint recloser and a tie 4 recloser. The operational efficiency benefits provided by automation were 5 estimated and applied to those outages as well as modelled reductions in customers 6 interrupted and outage durations. These reductions were modelled based on 7 automation design requirements and are consistent with the industry performance 8 improvement data seen in the DOE Smart Grid Investment Grant Projects paper 9 discussed earlier. Benefits were not included in this analysis for circuits where 10 automation already exists. The individual circuit costs were estimated by reviewing 11 existing circuit automation and then defining the expected additional equipment 12 needed to achieve the modelled benefits.

13

14 Q33. What is the scope of the Distribution Automation Plan for 2024 and 2025?

15 A33. The 2024 Distribution Automation Plan is composed of the investments included 16 in the IRM in Case No. U-21297, which is 63 circuits and 189 reclosers, plus an 17 additional 96 reclosers that are expected to improve 32 circuits on the 4.8 kV 18 distribution system. In addition, engineering and design work will be completed 19 in 2024 for 240 reclosers covering approximately 80 circuits to be constructed in 20 2025. In 2025, 578 reclosers across an estimated 242 circuits will be constructed 21 based on the prioritization model developed in 2023 and 480 reclosers and 160 22 circuits are expected to undergo engineering and design in 2025 for 2026 23 construction.

24

Line
No.

Q34. What benefits are associated with the Distribution Automation investments planned for 2024 to 2025?

3 A34. The planned Distribution Automation work for 2024 is expected to address ground 4 detection and isolation for 63 circuits at 18 substations that is part of the IRM, and 5 an additional 32 circuits at 11 substations. It is also expected to reduce SAIDI on 6 impacted circuits by 45%, reducing system SAIDI by 9 minutes, based on the 7 circuit level benefits modeling discussed earlier. The planned work for 2025 is 8 expected to address ground detection and isolation for 281 circuits at 73 substations 9 and is expected to reduce SAIDI on impacted circuits by 47% reducing system 10 SAIDI by 45 minutes.

11

12 Q35. What progress in Distribution Automation was made in 2023?

13 A35. In 2023, DTEE completed engineering and design standards for use of the 14 Distribution Automation reclosers for 4.8 kV and initial standards for 4.8 kV 15 ground detection and isolation, ground detection and isolation standards will be 16 finalized in early 2024, based on incorporating process improvements identified 17 during initial deployments. DTEE has field installed 208 reclosers and 18 commissioned 102 more with fault isolation and remote operating capability, with 19 the balance of 106 expected to be commissioned in early 2024. DTEE has also 20 completed circuit level costs and benefits estimates, which will be used for circuit 21 prioritization and program cost benefit estimation.

22

Q36. Has the Company been able to confirm the benefits of the 2023 Distribution Automation investments?

1	A36.	The majority of the 70 reclosers that were installed in 2023 were installed in the
2		second half of the year so a full year of the performance data needed to confirm the
3		estimated benefits is not yet available. DTEE will track performance in two ways
4		to ensure expected benefits are achieved. First, in 2024, DTEE will begin using
5		actual outage data to track estimated customer outage minutes saved by automation.
6		This will ensure that automation is performing as expected during individual
7		events. Second, DTEE will track the performance of Distribution Automation
8		circuits before and after work is complete and will compare the change to the
9		control group. Variance in individual circuit performance year to year can be
10		heavily influence by weather and unique events, but comparing the performance of
11		the larger group of automation circuits relative to the rest of the system can provide
12		the validation of program level objectives.

13

14 B. Grid Automation Telecommunications

15 Q37. What is Grid Automation Telecommunications?

16 A37. Grid Automation Telecommunications refers to the use of telecommunications technology in the automation of electrical power grids. It involves the integration 17 18 of communication systems with power distribution networks to enable real-time 19 monitoring, control, and management of grid operations. The telecommunications 20 network is the backbone system that connects the distribution automation 21 equipment in the field to the ESOC, enabling two-way remote monitoring and 22 control that provides visibility into grid conditions and allowing the ESOC to remotely operate grid devices. An advanced telecommunications infrastructure 23 plays a crucial role in grid automation by providing reliable and secure 24 25 communication channels for data exchange between various grid devices such as

Line N<u>o.</u>

> 1 sensors, meters, switches, and control centers. Telecommunication networks have 2 always played an important role in supporting the safe and reliable delivery of 3 electric power. This role is becoming even more crucial in the looming industry 4 transformation, since Smart Grid represents the convergence of 5 telecommunications, computing, and energy technologies.

6

7 Q38. Can you describe the structure of a utility telecommunications network?

A 438. A utility telecommunications network structure typically consists of various
components that work together to facilitate communication and data exchange
within the utility's infrastructure. Here are some key elements of an electric utility
telecommunications network structure:

12 Backhaul network: The backhaul network serves as the central communication • 13 backbone of the utility's infrastructure, connecting different sites, such as power 14 plants, substations, and control centers. It handles high-capacity data transmission 15 and supports critical applications, for monitoring, control and device management, 16 and incorporates the highest level of cyber security controls and network 17 management. Through 2025, the Company's Grid Automation 18 Telecommunications investments are focused on expanding the backhaul network. 19 • The last mile network: The last mile network connects end-user devices, such as 20 sensors, meters, and monitoring equipment, to the backhaul network. It enables 21 data collecting, monitoring, and control and the edge of the network. It is made up 22 of wireless technology such as microwave links, radio frequency (RF) networks, 23 and cellular networks, to establish communication links between different sites. 24 Wireless infrastructure provides flexibility and scalability in extending network 25 coverage and provides a secure and manageable interface between devices and the



3

4

5

6

7

8

9

backhaul network. The Company is not making significant investments in this area
 for the time period of this instant case but plans to in the future.

The Grid telecommunications network consists of many technologies such as fiber, wireless systems, elevated structures, switches, and routers. Each of these technologies need supporting investment to create an integrated system that allows for the seamless flow of information, enabling remote monitoring and control of the grid and is the mechanism that cybersecurity threat monitoring and security updates are performed. See Figure 2 for a simplified structure of a Grid Telecommunications Network.

11

10

12

Figure 2 Simplified Structure of a Grid Telecommunications Network



13

14 Q39. Can you describe the existing state of the Company's Grid Automation
15 Telecommunication network?

Line <u>No.</u>

1	A39.	DTEE's existing telecommunication network consists of a combination of
2		equipment and technologies including fiber, microwave, leased phone lines, and
3		radio; some of these technologies being legacy end of life systems. The current
4		network does not fully connect all field devices to the ESOC, many devices
5		currently on the Company's electrical system, including some pole-top and
6		substation equipment, are either not connected for remote monitoring and control,
7		or are connected through a patchwork of communication networks and technologies
8		that have varying capabilities, are not fully integrated, and in many cases cannot
9		provide resiliency due to their architecture. At the center of the telecommunications
10		system, the Company currently relies on a fiber ring that was originally designed
11		to only connect data centers and transmission stations on towers along transmission
12		corridors. The primary purpose of that connection was to provide a backhaul
13		network enabling resiliency of data flow for critical operations. At the time the fiber
14		ring was installed, the design scope did not include the capability for connecting
15		the more modern distribution resources coming to the grid today, such as the circuit
16		automation devices discussed earlier in this testimony. This portion of the backhaul
17		network does not extend to all critical assets, which is why the Company is
18		investing in expanding the backhaul network with additional fiber. Additionally,
19		the legacy telecommunications technologies lack sufficient capability to provide
20		the bandwidth speed, capability, and reliability necessary to stabilize delivery and
21		response to the data being transmitted by those modern distribution resources and
22		is a key driver of investment in Grid Automation Telecommunications.
23		

Q40. What are the other key drivers of the Company's investment in GridAutomation Telecommunications?

A40. The increasing deployment and utilization of grid automation equipment, evolving
 grid demands, and aging telecommunications infrastructure are the other key
 drivers of DTEE's investment in grid automation telecommunications.

4 First, in direct support of our distribution automation plan, the Company is 5 increasing the deployment of Distribution Automation and smart devices in the 6 field to drive improvements in grid reliability, resiliency, optimization, and 7 efficiency through programs like Distribution Automation, Conservation Voltage 8 Reduction (CVR), Volt-Var Optimization (VVO), Advanced Metering 9 Infrastructure (AMI), and demand response. These technologies, when deployed 10 on the grid, require real-time data transmission from field devices through a secure 11 channel with sufficient, highly reliable bandwidth. Distribution automation alone 12 plans to add over 13,000 new devices to the network which is over five times more 13 distribution SCADA devices than are currently installed. As noted earlier in my 14 testimony, DTEE is investing in automation devices that are being deployed on the 15 grid to improve reliability. These devices require a telecommunications network 16 that is reliable, secure, and has sufficient bandwidth to transmit data to allow for 17 real-time monitoring and control. The investment in Grid Automation 18 Telecommunications supports DTEE's Distribution Automation devices by 19 providing the advancements in bandwidth, speed, capability, and reliability 20 necessary to operate the modern grid and enable the benefits from the automation 21 devices. These investments provide the necessary infrastructure and capabilities to 22 automate and optimize grid operations and enhance reliability. Every alarm, 23 command, and outage notification seen by the ADMS systems and System 24 Operations Center (SOC) must come through the communications network.

1 Without these investments, the Company would have to build device 2 communication capacity as automation devices are installed on the grid. 3 4 Secondly, the increasing adoption of customer owned renewable energy sources is 5 driving the need for integration and management of those sources to enable 6 operators to monitor and control the flow of renewable energy. This control 7 requires bidirectional information flow between utilities and renewable customers, 8 and real-time communication that supports coordination and optimization of the 9 electrical system. The Company's existing communications network was not 10 designed to include the modern distribution resources coming to the grid, and the 11 deployment of these resources requires additional bandwidth and reliable, quick 12 transmission of data. 13 14 Lastly, some of the existing communications equipment is targeted for replacement 15 due to obsolescence or lack of available spare parts. End of life, and legacy systems 16 that are incapable of supporting new smart grid operations need to be replaced to 17 support remote management of devices and to provide a platform to support the 18 transition of existing communications assets. 19 20 041. Company's investment plan for Grid Automation What is the 21 **Telecommunications?** 22 A41. DTE Electric's plan is to first expand the backhaul network fiber to provide 23 sufficient bandwidth and high-speed data transmission capability, and then in future 24 years outside of the timeframe of this case, to invest in the last-mile networks by

1

2

3

connecting wireless systems to the fiber network to bring the visibility and control of all devices into the network.

4 The near term primary planned investment is expansion of the fiber system through 5 the installation of a series of fiber rings that interconnect the Company's data 6 centers with its distribution and sub transmission stations, service centers, 7 communications towers, power plants, and other critical DTE Electric facilities. 8 This system is designed to provide communications to locations where they are 9 currently not deployed, have degraded service due to obsolete equipment, have 10 incompatible networks and protocols, or are subject to interference or where the bandwidth needs have increased. The investments in the current case will address 11 12 many of the critical infrastructure sites that can only be served with a fiber 13 deployment.

14

15 The near-term investments in Grid Automation Telecommunications through 2025 will build out the critical backbone of the telecommunication network that connects 16 17 the key infrastructure sites such as substations and other critical facilities to the 18 This is the foundational requirement to enable the various data centers. 19 functionality of the various operational technologies. Beyond 2025, DTE will need 20 to continue to expand the telecommunication network investments to the next tier 21 of locations that are prioritized from a resiliency perspective. Additionally, 22 investments in 2026 and beyond will be structured to support an advanced wireless 23 system that will be overlaid on the fiber backhaul to provide connectivity for pole 24 top and distributed devices including mobile assets that will not be directly 25 connected to fiber. This combined system of fiber and advanced wireless will

Line
No.

3

provide sufficient capability to support the communications needs of the electrical
 system for decades to come.

This time staged deployment of telecommunications investments will provide reliable, high bandwidth, low latency backhaul for the Distribution Automation investments described earlier in this testimony, including SCADA, AMI backhaul data concentrators, asset monitoring sensors, physical security measures and future planned devices to provide control and visibility to the system control center and engineering backend systems.

10

11 Q42. How will customers benefit from the Company's investment in Grid 12 Automation Telecommunications?

A42. 13 Customers will gain significant benefits from the capabilities that Grid Automation 14 Telecommunications will enable for Distribution Automation. Primarily, for the 15 full reliability and operational benefits of Grid Automation investments described 16 earlier in my testimony, including rapid fault location, isolation, and restoration to 17 minimize downtime during outages and ensuring swift detection and response to 18 disturbances on the grid. More details related to the benefits of fault location, 19 isolation and service restoration are described later in the FLISR section of my 20 testimony. Grid Automation Telecommunications will also provide sufficient 21 future capacity as customers add new energy devices such as DER. Additionally, 22 this solution will also improve coordination of DTEE resources by reducing the 23 number of disparate and legacy systems that must be maintained and operated.

24

Q43. What telecommunication options were considered in choosing the best
 technology investment to support Grid Automation Telecommunications
 backhaul network expansion?

4 A43. The Company employs multiple technologies in building the Grid Automation 5 Telecommunications Network and all of them have an important place in the 6 overall solution. We do not employ a one technology fits all strategy and for each 7 portion of the network we consider all of the available technologies which include 8 but are not limited to Microwave, Private mesh, Public commercial cellular, 9 WiMAX, Private and public Fiber and private Radio. we even consider options that 10 we have not yet invested in such as Private Cellular. All of these options were 11 examined and in this case for this particular portion of the project and for this usage 12 profile building our private Fiber capability was selected.

13

14 Multiple technology investment options were considered to support Grid 15 Automation Telecommunications backhaul network expansion. The full 16 implementation of communications to all end points will continue to utilize a 17 variety of the available solutions where they are best suited to provide sufficient 18 capability and reliability. Several factors were considered when selecting the 19 backhaul technology to be utilized for the telecommunications, and a qualitative 20 assessment of those factors is included here. The primary factors considered were 21 the ability of the technology to fully serve the bandwidth (amount of data) and 22 latency (delay in transmitting data) needs, and the reliability and the essential 23 cybersecurity characteristics of those systems for providing service to critical sites 24 and infrastructure. On a site-by-site basis, additional considerations for each of the 25 technologies are factored into the decision of which technology to deploy.

Line <u>No.</u>	
1	Here is a summary of the uses and characteristics of each telecommunication
2	system type evaluated:
3	
4	Public cellular:
5	Description: Cellular technology owned and operated by a third-party
6	telecommunications carrier and located on carrier owned cell phone towers or
7	leased structures.
8	
9	Current utilization:
10	• Short-term deployment where Distribution Automation is needed quickly,
11	and other options are not currently available or cost effective.
12	Key Considerations:
13	• No quality of service guarantees for uptime or performance; carriers have
14	already demonstrated they will not notify of network downtime including
15	planned maintenance, or unplanned outages. Carrier maintenance, either
16	planned or unplanned, can impact field network communications
17	availability. When these outages occur, they can result in localized or wider
18	ranging gaps service which impacts meter communications effectiveness.
19	DTEE has no input into these outages and so finds it to be prudent to invest
20	in multiple technologies to increase reliability. The timing of these service
21	interruptions has impacts in large storm restoration when DTE is relying on
22	meter information to establish which customers are restored to prioritize
23	crew dispatch. Examples of reliability issues on this type of network are
24	included in Exhibit A-19 Schedule I1.1.

included in Exhibit A-19 Schedule I1.1.

Line
No.

1

2

3

4

5

6

 As a customer vs owner, DTEE is unable to configure specific routes between devices and set data prioritization policies for utility traffic. Prioritization of data relies on a vague tier system that prioritizes traffic with no guarantee or insight to analyze the network performance. No visibility into the network routing or ability to troubleshoot network connectivity or performance problems.

Detailed cyber security logging and network traffic analysis is not available,
 requiring the layering of multiple levels of additional security on the traffic
 to encrypt the data which requires additional equipment infrastructure and
 configuration time and labor at each end point.

- Monthly fees are typically \$25 per month per location and can exceed \$175 11 12 per month for higher bandwidth plans. When considering the 40,000+ 13 planned locations for automation and AMI backhaul that will be needed for 14 Grid Automation the aggregate costs can reach into the hundreds of millions 15 of dollars over the life span of the equipment and it is very likely that 16 monthly costs will only increase as DTEE bandwidth needs increase and 17 other carrier customers demand even more data. Sites that exceed 18 bandwidth plans incur overage fees and in some cases the carriers' 19 maximum plans are insufficient to support heavy bandwidth use cases like 20 physical security cameras.
- Interference between other network tenants, in shared service areas at the
 edges of the DTEE territory or where municipal utilities have networks
 there are instances where interference has impacted network capabilities
 due to shared spectrum usage.

Line
<u>No.</u>

1	• Public carriers upgrade their system frequently, resulting in the removal of
2	older hardware. This can cause premature obsolescence of functioning
3	utility communications systems. This hardware replacement cycle is not in
4	control of the utility and carrier changes in technology have been forced on
5	the utility in some cases resulting in thousands of devices going out of
6	support well before their end of life, or a complete lack of service. For
7	example, prior to the 3G to 4G transition thousands of square miles of the
8	service territory in the thumb region were suddenly without service as the
9	networks were shut down and sold off because they were not seen as
10	profitable in 2017. Overall, the 3G to 4G technology transition required
11	DTEE to invest over \$36M to reconfigure its network and reestablish
12	communications to metering assets and device at over 2,700 locations, this
13	does not include the cost of downtime, or the opportunity cost of applying
14	that personnel time and investment to more valuable system enhancements.
15	There was nothing wrong or obsolete about the 3G radios being used from
16	a technical perspective (in some cases there were better propagation and
17	range from the 3G equipment) and those devices could have had a
18	substantially longer remaining lifetime before replacement if the network
19	backhaul had not been subject to a technology change. These
20	reconfigurations cause additional cost to troubleshoot communications
21	failures, replace radios, conduct site evaluations to evaluate the replacement
22	communication paths. This unplanned obsolescence is not a problem if the
23	technology cycle was in control of the utility.

Incapable of providing sufficient bandwidth for physical security use cases
like security cameras.

<u>No.</u>	
1	• In areas with sparse or no coverage it is at the carrier's discretion and the
2	utility cost to install new infrastructure, meaning that these network
3	extensions would have infrastructure buildout costs and additional lease
4	costs above and beyond the monthly fees for data.
5	
6	Private Long-Term Evolution (LTE) Cellular:
7	Description:
8	• Cellular equipment owned and operated by the Utility.
9	Current utilization:
10	• Not currently in use by the Company
11	Key Considerations:
12	• Best use as a last mile solution for distribution automation and DER
13	• Requires backhaul to get to data centers but can efficiently leverage the fiber
14	investment.
15	• Requires investment in radio frequencies.
16	
17	Point-to-Multipoint and Point-to-Point Microwave:
18	Current utilization:
19	• Used in spot solutions since it requires detailed pathing studies and
20	communicates between specific locations.
21	Key Considerations:
22	• Existing issues with signal interference caused by new users of the
23	frequency allowed by the deregulation of the frequency bands by the FCC,
24	limiting the technological capability substantially and exposing the systems
25	to excessive interference.

Line

Line <u>No.</u>	
1	• Microwave requires substantially more tower height that is more expensive
2	and more difficult to site and permit to allow direct paths to function given
3	the higher frequency's inability to penetrate tree cover.

<u>No.</u>	
1	Wireless mesh:
2	Description:
3	• Utility owned radio equipment
4	Current or optional utilization:
5	• Supplementing the existing wireless mesh is a short-term solution being
6	employed as part of the AMI program.
7	• The existing wireless mesh assets will be aligned to the fiber backhaul to
8	improve overall system capability and resiliency.
9	Key Considerations:
10	• Does not address the backhaul bandwidth and routing issues with the
11	system, or the requirements of grid automation.
12	• May be subject to public interference on shared frequencies and limited in
13	power levels which reduces effective range, especially in heavily treed
14	areas.
15	
16	Leased fiber:
17	Description:
18	• Fiber lines owned and operated by a third-party vendor.
19	Current utilization:
20	• In specific locations where fiber is required for out of service territory wind
21	parks, power plants, and facilities.
22	Key Considerations:
23	• Requires paying a telecom provider to build out the fiber network to provide
24	the required point to point routes for distribution automation and then
25	paying monthly lease and service fees in addition to the build out costs.

Line

Line	
No.	

1

2

3

4

5

•	Requires negotiating and maintaining many contracts with different
	providers and negotiating to build fiber linkages between different vendors
	to complete the fiber rings needed for resiliency that may not be considered
	shared or beneficial routes by the provider, resulting in the Company
	absorbing the entire cost of construction.

- Where networks need to connect to provide resiliency, the Company must
 provide the risers, electronics, and routing equipment at these locations to
 ensure isolation of traffic and cyber security, resulting in increased
 infrastructure costs for this aspect of the project over a privately owned
 system that can optimize the locations of these installations and greatly
 simplify the equipment needed.
- While there may be minor cost savings where the providers have existing
 fiber lines, the Company's experience is that this is more costly by roughly
 30% or more than building the fiber infrastructure efficiently on existing
 DTEE structures.
- 16
- 17 **Private, Company-owned fiber:**

18 **Description:**

19

21

22

• Fiber lines owned and operated by the Utility.

- 20 **Current utilization:**
 - Existing fiber ring, and previous phases of grid automation telecommunications program
- 23 Key Considerations:
- Privately owned fiber allows for efficient and optimized routes, and
 infrastructure tailored to the utility use cases.

1 Q44. Was a best investment option determined for this phase of the project?

2 A44. Yes, private fiber was determined to be the best investment for the 2024 and 2025 3 project scope for telecommunications backhaul. This does not mean that DTE will 4 be using fiber exclusively for all telecommunications needs and different 5 technology solutions will continue to be evaluated on a case by cases basis for 6 specific locations. Fiber-optic networks offer unmatched bandwidth, speed, 7 reliability, security, suitability for backhaul of other networks, and resilience to 8 interference. Fiber-optic networks provide significantly higher data transmission 9 speeds and bandwidth essential to support grid automation and scalability for the 10 evolving demands of grid modernization initiatives.

11

For example, to meet the needs of substation physical security DTEE has already reached the maximum public cellular and pool data plans at some sites on public carriers, including FirstNet. The Company receives several notices a week that specific sites are using too much bandwidth; bandwidth easily provided by fiber and a factor in prioritizing the fiber deployment.

17

18 Fiber infrastructure provides the necessary backhaul for other communications 19 networks, linking towers, base stations, and other access points to the core network. 20 This connectivity is essential for carrying the massive volumes of data generated 21 by devices to their intended destinations. Fiber infrastructure serves as the bedrock 22 for all last mile networks, playing a pivotal role in ensuring their efficiency, speed, 23 and reliability. Fiber-optic cables provide extremely high and consistent bandwidth 24 over long distances compared to traditional copper cables or wireless medium, 25 transmission capability crucial for the seamless functioning of networks. The

Line	
<u>No.</u>	

1	inherent stability and low latency of fiber-optic connections ensure consistent and
2	uninterrupted connectivity, indispensable to last mile networks. This reliability is
3	vital for applications that require real-time data transmission, such as internet of
4	things (IoT) devices, autonomous vehicles, and mission-critical communications.
5	Without a robust and extensive fiber optic infrastructure, DTEE would struggle to
6	deliver the high-speed, low-latency, and reliable connectivity demanded by today's
7	digital landscape. Fiber serves as the linchpin that supports and sustains the
8	interconnectedness and seamless operation of all connected technologies.
9	
10	A group of internal SMEs discussed the different options and ranked them

qualitatively based on several reliability, lifecycle, and initial cost factors. The
results of the qualitative analysis can be seen below.

Line <u>No.</u>

- 1	
_ 1	
	-

Figure 3 Alternatives Compared Using Reliability Factors

	Public Cellular	Private LTE	Microwave/ Wimax	Wireless Mesh	Leased Fiber	Private Fiber
Bandwidth						
Low Latency						
Network Control						
Prioritization and Quality of Service (QoS)						
Security						
Maintenance Window Scheduling	\bigcirc					
Disaster Recovery						
Control of Communications During Emergency						
Protection Against Interference and FCC Decisions						

2

Line <u>No.</u>

1	
I	

Figure 4 Alternatives Compared Using Life Cycle Factors

	Public Cellular	Private LTE	Microwave/ Wimax	Wireless Mesh	Leased Fiber	Private Fiber
Ongoing Operating Costs (Excluding Staffing)						
Staffing						
Open Standards			\bigcirc	\bigcirc		
Technology Availability						
Technology Stability						
Technology Lifespan						

2

3

Figure 5 Alternatives Compared Using Initial Cost Factors

	Public Cellular	Private LTE	Microwave/ Wimax	Wireless Mesh	Leased Fiber	Private Fiber
Control of Geography Covered						
Device Deployment Effort						
Installation Cost		\bigcirc				\bigcirc

4

5 Q45. How is fiber more resistant to interference?

A45. Fiber optic cable operates independently of the wireless spectrum, using light
 signals transmitted through glass fibers rather than the radio frequencies allocated

Line
No.

1 and regulated by the Federal Communications Commission (FCC). This technology 2 makes fiber impervious to the electromagnetic disruptions that affect wireless 3 transmissions such as electromagnetic radiation, radio waves, electronic devices, 4 and the FCC's spectrum reallocation, a process of redistributing portions of the 5 electromagnetic spectrum for different services or technologies. Immunity to 6 interference and FCC spectrum reallocation is a testament to the resilience and 7 reliability of fiber optics among communication networks, ensuring consistent, 8 high-quality data transmission and uninterrupted communication pathways critical 9 for applications such as telecommunications, internet services, and utility-owned 10 telecom systems. As a specific example, the Ann Arbor microwave was decommissioned and replaced with fiber after it was determined that a major wifi6 11 12 deployment would introduce substantial radio interference, rendering the 13 microwave system unable to sustain reliable communications. Subsequent 14 evaluation of the wireless traffic in the area indicated that this projection was 15 accurate and that if the microwave had not been replaced with fiber it would have 16 become unusable.

17

18 Q46. Why would the Company build a private network versus leasing from existing
19 fiber providers?

A46. Owning and operating telecommunication systems allows greater control and
 flexibility over the networks. Unlike relying on leased or third-party systems,
 utility-owned infrastructure offers customization, scalability, and adaptability
 tailored to specific operational needs. This level of control is pivotal in integrating
 diverse technologies including sensors, IoT devices, and advanced monitoring tools
 essential for effective Distribution Automation and Smart Grid implementations.
Line
No.

1		Utility-owned telecommunication systems provide enhanced security and
2		resilience. By internalizing these systems, utilities can implement robust
3		cybersecurity measures and ensure reliable communication channels, mitigating
4		cybersecurity vulnerabilities associated with relying on external networks.
5		Ownership of the network topology allows for efficient use of the entire network
6		and eliminates constraints on traffic routing and prioritization. Investing in utility-
7		owned telecommunication systems aligns with long-term cost-effectiveness and
8		reduced recurring lease fees. Ownership reduces dependency on leased lines or
9		external providers, minimizing ongoing operational expenses and providing greater
10		predictability in maintenance and upgrades. Utility-owned telecommunication
11		infrastructure represents a strategic move towards grid modernization and
12		resilience. Lastly, a private network protects DTEE from network blackouts caused
13		by using leased Internet Service Providers that do not build their networks with the
14		same level of resilience that the electric grid requires. This has resulted in a strategic
15		shift in recent years to build networks privately owned and maintained by DTEE to
16		enable the Company to securely control and operate reliable telecommunication
17 18		systems.
19	Q47.	What components of the Grid Automation Telecommunications investment
20		plan were completed in 2022 and 2023?
A 1		

- 21 A47. Highlights of 2022 installations include:
 - 220 miles completed.
- Fiber installations north and south of I-96 on the West side of Detroit
 and through Wayne County brought fiber to multiple service centers
 and backhaul towers, and substation locations.

Line <u>No.</u>		
1		• Installation and commissioning of a fiber route through Pontiac and
2		adjacent areas north of the city.
3		• Significant work was started on the fiber line from Dearborn to Monroe
4		and aligned with the telecommunications changes needed for the
5		Trenton Channel Power plant decommissioning work.
6		• A major route was started to close a major gap in the existing fiber ring
7		between M-53 in Macomb County and the Blue Water Energy Center.
8		2023 installations included:
9		• 239 miles completed.
10		• Completion and commissioning of the Dearborn to Monroe fiber line
11		and the connection of both Fermi and Monroe power plant stations and
12		facilities to the fiber network, including the Newport service center and
13		substation locations.
14		• Substantial completion of routes on the East side of Detroit and up the
15		I-94 corridor.
16		• Additional work nearing completion from 2023 are routes to reach
17		Howell service center and the completion of the fiber ring from Monroe
18		to Ann Arbor to provide resiliency to the Dearborn to Monroe line.
19		
20	Q48.	What investments are included in the 2024 and 2025 telecommunications
21		investment plans?
22	A48.	The major routes planned for completion in 2024 and 2025 are those in Detroit to
23		serve all substations and communications towers. This work is being coordinated
24		with the Infrastructure Resilience and Hardening Pilar as well as the City of Detroit
25		Infrastructure (CODI) program.

1	2024:	
2	•	150 miles in 2024 will provide a southern thumb ring running east to west
3		north of I-69, and a route south of I-94 and Metro Airport to connect
4		substations in the southwest region of the territory. The rest of the 2024
5		investment in fiber installation will be to install taps and entrances to
6		substations from previously constructed routes.
7	•	Installation of routing electronics to light up routes that have finished fiber
8		construction and to connect substation end point taps with the existing
9		wireless mesh network end points to improve bandwidth and reliability.
10		This work will continue into 2025.
11	2025:	
12	•	Routes for 2025 will include investments to replace leased lines in the
13		Eastern thumb and will be coordinated with sub transmission relocations.
14		Additional routes in the City of Detroit will be constructed and coordinated
15		with substation conversion and consolidation and the CODI program.
16	•	2025 will also focus on completion of critical infrastructure and resiliency
17		routes and the electronics to connect the end point substations. The program
18		will also begin to prepare for deployment of advanced wireless capabilities
19		that will reach the tens of thousands of devices that are not economical to
20		run fiber directly but will use the fiber as the high bandwidth and low
21		latency backhaul to DTEE systems. These investments will verify that the
22		communications industry marketing material contains accurate latency and
23		bandwidth and appropriate prioritization of critical traffic based on carrier
24		provided cellular build out versus an advanced wireless system supported
25		by the fiber. This evaluation will investigate methods that may be more

Line <u>No.</u>

Line
No.

2

3

4

5

economically viable options to serve the end point devices that DTEE will be using to reduce customer outages and determining whether existing communications can support loop schemes and advanced protection to restore more of the population in a time period that does not cause disruption of service beyond a normal switching transient or other short-term events.

6 A small portion of the 2025 investment is to validate last mile solutions in 7 real world conditions and to document information and data received from the various methods of communications, allowing an investment and 8 9 deployment plan for future years to be created. Testing will take into 10 account factors such as the deployment of thousands of new DER (solar, storage, EVs) and bidirectional charging, all of which may need 11 12 coordination with demand response events during times of summer and 13 winter loading. The learning gained will also prepare DTEE to support upcoming Midcontinent Independent System Operator (MISO) rules for 14 15 Federal Energy Regulatory Commission (FERC) Order 2222 and to fully 16 support the new clean energy law. This work in 2025 will determine 17 bandwidth, physical and cyber security requirements, and if a request for 18 proposal (RFP) should be issued for additional communication services or 19 infrastructure. It will determine if existing publicly or privately available 20 communications are sufficient to provide reliability, latency, and bandwidth 21 and to provide sufficient cyber security controls (which continue to increase 22 in complexity and depth) to support grid modernization and increasing 23 electrification.

24

Line	
No.	

1	Q49.	Can you describe what the Commission found in Case No. U-21297 about Grid
2		Automation Telecommunications?
3 4	A49.	The Order summarized the conclusions of the PFD stating "[t]he ALJ noted that
4		DTE Electric expanded the scope of the program from the 500 miles of fiber and
5		230 substations proposed in Case No. U-20836 to the present proposal for 630 miles
6		and 400 substations in the test year," then added that "[s]he [the ALJ] further found
7		that the company should be required to provide an analysis of alternatives when
8		requesting further extensions of the fiber network." (December 1, 2023 Order in
9		Case No. U-21297, pg. 120). Earlier in my testimony I reviewed the options the
10		Company has considered for expanding the fiber network, the rationale behind the
11		Company's decision, and the description of the Company's planned investments in
12		this area.
13		
14		Below I address the concern regarding the change in scope proposed in Case No.
15 16		U-21297 compared to the previous filing, Case No. U-20836.
17	050	What led to the change in scope from 500 miles of telecommunications fiber in
18	Q.30.	Case No. II-20836 to 630 miles in Case No. II-21297?
19	A 50	The 500 miles in Case No. U-20836 only included the scope of telecommunication
20	1001	fiber miles up through 2023 in testimony. Case No. U-21297 additionally included
21		2024 miles in testimony. The instant case also includes investment through 2025.
22		Additionally, initial estimates of routes created at the engineering level have been
23		updated for final route design, considering constructability, permitting, crossings,
24		and accessibility of the path, which results in some routes being longer and some
25		routes being shorter. Finally, the updated scope incorporated the additional fiber

2

3

4

scope from other projects into the program. For example, the Trenton Channel Power Plant decommissioning required the relocation of the legacy communication infrastructure that was served from the plant. This additional scope had synergies with work that was already planned in the downriver area in the fiber program, resulted in a more robust solution and avoided duplicated work.

6

5

7 Q51. How is DTEE controlling the investment costs for this program?

8 A51. The Company is evaluating each route in the planning process to locate the most 9 efficient path between stations, including competitively bidding the routes to 10 multiple contractors that have demonstrated they can meet the installation standards. The selected contractors can perform the make ready work as well as the 11 12 fiber stringing and splicing so it only requires one crew vs other approaches that would have to pair a line crew with a fiber crew or a 3rd party fiber crew with a line 13 14 crew. The competitive bidding has been able to reduce the per mile cost on average 15 by 35% and is expanded upon in Exhibit A-19 Schedule I1.2 A similar amount of 16 savings has been seen compared to leased fiber construction routes, with the added 17 benefit of avoiding the ongoing lease cost. Contractors have also identified 18 additional savings on bulk purchasing material and scheduling work to minimize 19 mobilization costs. This has allowed the program to maintain a design target of 20 \$55K per installed mile of fiber and, on average, consistently achieve that 21 benchmark or better.

22

Q52. Will the investments in the Grid Automation Telecommunications Program continue past 2025?

Line	
No.	

1	A52.	Yes, fiber installations are expected to continue into 2028. In 2026 and through the
2		end of the program, fiber routes will be run through a cost benefit analysis to
3		determine the appropriate future technology to be used that will support the
4		telecommunications needs of all other DTEE investments and programs. This is
5		also being done to align construction of the fiber with sub transmission relocation
6		to prevent installation of fiber in locations where the lines are planned to be moved,
7		and to complete the installation of electronics and taps into substations. Future
8		investments will also include the integration of an advanced wireless system to
9		connect to additional device locations and assets inside the service territory. This
10		proposed second phase of the grid telecommunications installation top address the
11		last mile devices is projected to run through the end of the decade.
12		
13	C.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO)
13 14	C. Q53.	<u>Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO)</u> What is Conservation Voltage Reduction and Volt-Var Optimization?
13 14 15	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO)What is Conservation Voltage Reduction and Volt-Var Optimization?Volt Var Optimization (VVO) manages system-wide reactive power flow to
13 14 15 16	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include
 13 14 15 16 17 	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters
 13 14 15 16 17 18 	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc.
 13 14 15 16 17 18 19 	С. Q53. А53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc.
 13 14 15 16 17 18 19 20 	С. Q53. А53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc.
 13 14 15 16 17 18 19 20 21 	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc. Conservation Voltage Reduction (CVR), as one of the VVO options, is designed to maintain customer voltage down to the circuit level in the lower portion of the
 13 14 15 16 17 18 19 20 21 22 	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc. Conservation Voltage Reduction (CVR), as one of the VVO options, is designed to maintain customer voltage down to the circuit level in the lower portion of the allowable voltage ranges, thus reducing system losses, peak demand and energy
 13 14 15 16 17 18 19 20 21 22 23 	C. Q53. A53.	Conservation Voltage Reduction and Volt-Var Optimization (CVR/VVO) What is Conservation Voltage Reduction and Volt-Var Optimization? Volt Var Optimization (VVO) manages system-wide reactive power flow to achieve one or more specific operating objectives. The objectives can include reducing losses, managing circuit level voltage, optimizing operating parameters and/or optimizing power factors, etc. Conservation Voltage Reduction (CVR), as one of the VVO options, is designed to maintain customer voltage down to the circuit level in the lower portion of the allowable voltage ranges, thus reducing system losses, peak demand and energy consumption.

Line	
<u>No.</u>	

1		CVR is achieved by utilizing various electrical equipment including transformer
2		load tap changers (LTC), overhead line regulators, and capacitor banks. In addition,
3		supervisory control and data acquisition (SCADA) monitoring devices and line
4		sensors are used to ensure customer voltage levels are maintained in allowable
5		voltage ranges; advanced telecommunication and optimization tools can also be
6		used to achieve optimal savings in the system.
7		
8	Q54.	What are the benefits and drivers of the CVR/VVO Program investments?
9	A54.	CVR/VVO provides both a benefit to the distribution system as well as a
10		generation alternative through reduced demand and energy consumption. Initial
11		pilots conducted in 2020 through 2022 on six circuits using local control achieved
12		peak reductions of 0.9% to 1.4% and energy savings of 0.7% to 1.0% and would be
13		expected to raise to industry standard level 1.5% to 3% with the use of ADMS based
14		CVR/VVO control. The CVR/VVO program is targeting a total peak demand
15		reduction of up to 38 MW by 2030. In addition, CVR/VVO is, and will continue
16		to be, a part of DTE Electric's integrated resource portfolio and are part of a utility
17		system framework within the comprehensive context of an integrated resource
18		planning process.

20 Q55. What work related to CVR/VVO has been completed to date?

A55. DTE Electric successfully enabled CVR/VVO technology on six pilot circuits in
two substations on the distribution system in December 2020. CVR/VVO was
enabled and measured throughout 2021 and produced demand and energy savings
that were in line with the projections in DTE Electric's 2019 IRP filing (Case No.
U-20471). CVR/VVO was enabled throughout 2022 and there have been no

Line	
<u>No.</u>	

1		additional investments related to the pilot. The program was paused in 2022 and
2		2023 to align the program with advancements in ADMS that would allow for the
3		use of ADMS CVR/VVO modules for control in place of the local electronic
4		control used in the pilot. Although the program was paused, in 2023, engineering,
5		design and the replacement of failed capacitors and capacitor controls with units
6		that support CVR/VVO was completed.
7		
8	Q56.	What is the scope of work for the CVR/VVO Program for 2024 and 2025?
9	A56.	In 2024, 22 circuits will be upgraded for \$2.5 million. Circuit upgrades include the
10		replacement of 36 capacitors and controls, four regulator control replacements, and
11		the installation of 20 voltage monitoring locations. This work will allow for ADMS
12		monitoring and control of voltage through CVR/VVO modules.
13		
14		In 2025, 22 circuits are expected to be upgraded for \$2.5 million. Circuit upgrades
15		include the replacement of 40 capacitors and controls, two regulator control
16		replacements, and the installation of 22 voltage monitoring locations. This work
17		will allow for ADMS monitoring and control of voltage through CVR/VVO
18		modules. In addition, the Company's scope of work includes a targeted capacitor
19		control replacement program to address end of life capacitor controls that rely on
20		time-based radio control. The existing radio controls have been determined to by
21		obsolete by the manufacture and spare components for the radio transmitter are at
22		risk of not being available. The capacitor control replacement program portion of
23		the 2025 scope includes \$5.6 million to replace 737 capacitor controls, bringing the
24		total cost for 2025 to \$8.1 million.

Q57. How is the Capacitor Control Replacement Program related to CVR/VVO and what are the benefits?

3 The Capacitor Replacement Program is a one-time investment to replace end of life A57. 4 and failed capacitor controls across the distribution system that could be utilized by 5 CVR/VVO. The installations will be replacing the obsolete capacitor controls with 6 the current standard control and installing sensing equipment that will allow for 7 monitoring and remote control of the capacitor through SCADA and the ADMS. 8 Replacing the existing capacitor controls with new SCADA enabled controls will 9 allow for those units to be integration into CVR/VVO program. The capacitors 10 replaced will be able to be controlled by the ADMS VVO module and provide real time optimization of the circuit voltage and reactive power. This will provide some 11 12 efficiency benefit to the circuit related to improved power factor, but the circuits 13 they are on will not have the voltage reduced to gain extra energy efficiency savings 14 from CVR. Customers will also see the benefits of reduced losses from improved power factor and voltage management on the circuit. 15

16

17 D. Non-Wire Alternatives (NWA) Pilots

18 **Q58.** What are Non-Wire Alternatives?

A58. Non-Wire Alternatives (NWA), as initially defined by the Commission on page 11
of the August 20, 2020 Order in Case No. U-20147, are, "An electricity grid
investment or project that uses distribution solutions such as distributed energy
resources (DER), energy waste reduction (EWR), demand response (DR), and grid
software and controls, to defer or replace the need for distribution system
upgrades."

25

1

Q59. Why is the Company evaluating NWA?

2 A59. The August 20, 2020 Order in Case No. U-20147 ("August 2020 Order") stated on 3 pages 43 and 44 that "the Commission expects to be presented with 'a robust suite of NWAs that may be evaluated for prudency as possible programs." Consistent 4 5 with that Order, the Company developed a set of NWA pilots utilizing different 6 technologies and addressing different grid concerns for inclusion in the 2021 DGP. 7 Since 2018, DTE Electric has been implementing those NWA pilots using 8 alternative technologies to address circuits or substations with loading concerns to 9 help delay or offset traditional system upgrades. The Company plans to continue to 10 implement the remaining pilots, as well as analyze the results of the completed 11 pilots. This is also consistent with the industry's evaluation of the opportunities that 12 NWA's present.

13

14 Q60. Did the Company present its NWA projects in its previous rate case?

A60. Yes, the Company proposed its NWA projects in Case No. U-21297. In its
December 1, 2023 Order in that case the Commission approved the following
projects: O'Shea (pg. 127); Omega (pg. 128); Mobile Battery Trailer (pg. 128);
Fisher (pg. 129); Port Austin (pg. 128); and Veridian (pg. 130).

19

20 Q61. What is the Company's objective for NWA?

A61. The Company's objective is to incorporate NWA solutions into the distribution
planning process to be considered along with traditional options to best meet the
customer needs as described in the Company's 2023 DGP, Exhibit A23, Schedule
M8, on pages 95 and 96. The pilots currently being pursued are building blocks that
will form a foundation for future NWA projects. As capabilities are confirmed,

Line <u>No.</u>		
1		multiple NWA technologies can be combined to further advance the Company's
2		utilization of NWA.
3		
4	Q62.	What are the potential customer benefits of NWAs?
5	A62.	NWA projects have the potential to become economic alternatives compared to
6		traditional infrastructure upgrades. The pilots are expected to validate customer
7		and economic benefits to help further refine the analysis of NWAs as an alternative
8		to traditional solutions. While individual participating customers benefit from
9		investment in some of the technologies used in targeted NWA solutions, such as
10		lower energy bills due to EWR, customers overall may benefit from the deferred or
11		displaced investment in infrastructure.
12		
13	Q63.	Can you please describe the NWA investments included in the instant case?
14	A63.	The Company is currently engaged with a suite of nine NWA pilots. Some of the
15		pilots are still under evaluation while others are in progress or have been completed.
16		The NWA pilots are listed in Table 2 along with the use cases and technology the
17		pilots are intended to test. The Hancock Pilot was completed and described in
18		MPSC Case No. U-20836, and the remaining planned pilots are fully described in
19		Exhibit A-12, Schedule B5.4.1 to Exhibit A-12, Schedule B.5.4.7, Exhibit A-12,
20		Schedule B.5.4.9 and Exhibit A-23, Schedule M7.

Line	
No.	

	Table 2	NWA Pilots Use Cases, Technologies, and O						bjectives	
		Technology							
Use Case	Pilot	EWR	DR	Storage	Solar	BTM DER	EV Charging	Microgrid	Objective
Voltage Mitigation	1. O'Shea			4					Test effectiveness of storage to address voltage instability due to intermittent solar
Portable Battery	2. Mobile Battery Trailer			✓					· Test use of energy storage in p traditional portable generators
Sub-transmission Loading	3. Omega			1					 Deploy storage to address subtransmission loading Install battery that can be re-lo
	4. Hancock <i>(Completed)</i>	✓							Initial pilot to test geo-targeted and develop DER Estimating too
Substation	5. Fisher	√	1						Test geo-targeted EWR/DR c Measure implementation timing
Loading	6. Port Austin			~	~			✓	Test solar and storage to addr substation capacity Test redeployment of stationar battery from Omega
Customer Load and DER Control	7. Veridian		1	~	1	~	~	1	Develop secure and effective methods to interface and contro- behind the meter (BTM) DER is conjunction with utility scale DE
EV Charging	8. EV Demonstration at ACM						~		Develop control algorithms and conduct testing on an extreme fai charger and its interfaces as well develop cyber secure smart cha management capabilities for Department of Energy
Reliability	9. Adaptive Networked Microgrids			~	~	~		~	Develop and test the use of ad networked microgrids to improv customers' reliability and increase benefits of NWA deployments

NWA Dilata Usa Casas Tashnalagias and Objectives T-11. 3

Q64. Can you elaborate on the technologies included in Table 2?

5 A64. Yes. EWR refers to replacing less efficient equipment with more efficient 6 equipment, reducing overall electrical demand. DR refers to a shift or reduction in 7 electricity usage by a utility customer to help manage demand on the electrical grid 8 during periods of peak demand. Behind-the-Meter (BTM) refers to coordinating 9 the participation of customer equipment to reduce overall demand or provide other 10 system benefits. Electric Vehicle (EV) charging refers to coordinating the charging 11 or discharging of EV equipment to provide electrical system benefits, avoid 12 electrical system issues or address loading concerns.

13

4

14 Q65. Can you provide more detail on the Company's NWA pilot projects?

Line <u>No.</u>		
1	A65.	Yes. Each pilot is described in detail in the following sections and Exhibit A-12,
2		Schedule B5.4.1 to Exhibit A-12, Schedule B.5.4.7, Exhibit A-12, Schedule
3		B.5.4.9, and Exhibit A-23, Schedule M7 provide additional details.
4		
5	<u>O'She</u>	ea la
6	Q66.	Can you briefly describe the O'Shea Pilot?
7	A66.	Yes. A 1 MW by 1 MWh Battery Energy Storage System (BESS) is being
8		interconnected at the O'Shea Solar Park. O'Shea is a DTEE owned 2MW solar
9		array installed on a circuit from the Chicago substation on the west side of Detroit
10		to address power quality concerns related to the intermittent nature of the installed
11		solar generation. The BESS is expected to address power quality for those
12		customers.
13		
14	Q67.	What progress has been made for the O'Shea Pilot?
15	A67.	DTEE has completed the below grade work at the site, poured concrete support
16		pads, and installed the battery housing. The controls have been procured and are
17		undergoing testing, and the site is ready for battery installation. The project has
18		allowed the Company to create standard designs and to develop operation
19		procedures, safety plans, and maintenance instructions. These learnings and the
20		opportunity to test compliance to standards have resulted in the creation of safety
21		policies for the installation and usage of battery systems that support not only this
22		project but other storage projects in the future as well. The O'Shea Pilot has further
23		allowed for the development of processes and practices for interconnecting battery

24 systems at renewable sites.

25

Line	
<u>No.</u>	

1	Q68.	Does the O'Shea Pilot require any additional work?
2	A68.	The tasks remaining are installing and commissioning the battery modules into the
3		battery housing and then validating the control systems, communication
4		infrastructure, new processes, standard designs, and other aspects of the pilot. The
5		capability for the battery system to demonstrate participation in the wholesale
6		market will be tested in consideration of FERC Order 841 to vet processes controls
7		and communications that can be replicated at future battery sites.
8		
9	<u>Mobil</u>	<u>e Battery Trailer</u>
10	Q69.	Can you briefly describe the Mobile Battery Trailer Pilot Project including the
11		customer benefits?
12	A69.	Adding to the Company's mobile resources supporting geo-targeted major event
13		restoration, DTE Electric has developed a mobile battery system that is capable of
14		providing temporary power to a circuit and also supporting local system voltage.
15		The mobile system consists of three separate trailers. Two trailers contain batteries
16		(DC battery trailers), and the remaining trailer contains an inverter and system
17		interconnection equipment (medium voltage trailer). The mobile battery systems
18		have zero emissions and can support customer restorations in several ways
19		including siting in place of traditional portable generators, supporting system
20		requirements during shutdowns or maintenance, or being deployed at substations
21		or on circuits to reduce peak load as part of a broader NWA project. The systems
22		are designed to operate stand alone or in conjunction with other mobile resources.
23		
24	Q70.	What progress has been made in 2023?

> 1 A70. The medium voltage and DC battery trailers have been delivered and connected at 2 the DTEE Westland training center, where the solar and storage testbed is located, 3 to allow for detailed checkouts of controls and onboard systems. Battery system 4 communications, control functions and alarm screens were implemented on the 5 trailers and run through testing. Initial documentation, procedural walkdowns, 6 safety reviews, and testing of the house service and alarming systems were 7 completed in 2023. Several modifications were identified and implemented to 8 improve the deployment time and improve safety when operating the trailers.

9

10 Q71. What work is remaining for the Mobile Battery Trailer Pilot?

11 Medium voltage testing will occur in early 2024 to validate the battery system A71. 12 control modes and communications with the System Control Center. These first 13 tests will include validating functionality for the battery system including operator-14 controlled charging and discharging, peak shaving, volt var control, and solar 15 smoothing as well as the onboard monitoring and safety systems. Procedures for 16 disconnecting, moving, and reconnecting the battery systems will be field tested to 17 allow for finalization of job units and work procedures. The systems will also be 18 tested to work with other mobile resources and DER prior to deployment for 19 support of the grid. During the testing, enhancements to functionality and control 20 modes will be integrated into the Battery Trailer System(s) to increase the number 21 of use cases the systems can support, and these enhancements will be propagated 22 to the other Battery Trailer Systems.

23

24 <u>Omega</u>

25 Q72. Can you briefly describe the Omega Pilot Project?

Line
No.

1	A72.	Yes. The Omega Pilot Project is located in the high growth area of Harrison
2		Township. Two subtransmission lines feed Omega substation and both have been
3		impeding further growth. In the near term, the placement of mobile storage
4		equipment (the same type of equipment described in the Mobile Battery Trailer
5		section) at the Omega substation will be used to reduce peak loading on the
6		transformers and substransmission lines during contingencies, validating the ability
7		of the mobile battery for peak load reduction and load shift use cases. The mobile
8		batteries will be moved to other project locations, for example, Port Austin, once
9		this capability demonstrated.

11 Q73. What work has been completed for the Omega Pilot?

A73. Engineering, design, and construction were completed for the site. Standards have also been developed to improve the efficiency of future applications of storage for the same purposes. The Company learned technical specifications and requirements to integrate battery storage equipment with the electrical system in a safe and reliable manner. The Battery Trailer Systems were delivered on site in Q4 2023 and connected to house service power.

18

19 Q74. What work is remaining for the Omega Pilot?

A74. Checkout and commissioning of the mobile battery systems is expected to be
completed by end of Q2 2024. Upon completion, the controls and protection can
be fully tested, and the medium voltage trailers can be connected to the distribution
system. Additionally, the commissioning process and operational procedures in the
control room and field for coordinating multiple battery systems at the same site
will be established.

1	Fisher	<u>:</u>
2	Q75.	Can you briefly describe the Fisher Pilot?
3	A75.	Yes. Fisher substation is located in Gibraltar and is over its firm capacity rating. In
4		addition, two circuits served by Fisher are expected to be over the design standard.
5		This poses significant risk of outages and inability to serve customers. The
6		Company originally considered adding capacity at the substation by upgrading
7		from a Class "F" substation to a Class "A" ³ substation, replacing existing substation
8		transformers with larger transformers, installing a nine position Power Distribution
9		Center (PDC ⁴), and adding two new circuits to split the load. The Company then
10		considered NWAs. The NWA scope includes targeted deployment of DR and EWR
11		to relieve a portion of the load concerns. The remaining load concerns at Fisher will
12		be addressed with the installation of an STDF (Subtransmission Distribution
13		Facility ⁵) in a 120kV corridor. This will allow one of the existing circuits to be
14		split. The combination of energy waste reduction, demand response, and the STDF
15		will address the loading concerns and return these circuits to their design capacity
16		ratings.
17		
18	Q76.	What has been the progress and results of the EWR work at Fisher?
19	A76.	The Company has been working on EWR in collaboration with the MPSC Staff and
20		the Natural Resources Defense Council. The team continues to design and plan a
21		cost-effective mix of pilot programs to deliver an estimated 300 peak-kW reduction

³ A class F is a small substation consists of two transformers and three breakers, while a Class A substation is more automated and has two or more transformers with each transformer having its own breaker

⁴ A PDC is a power feed to a bus bar that supplies the individual circuits fed from a substation. It is similar in function to a breaker panel in a home at a much larger scale. ⁵ A facility that consists of a set of equipment which creates a single circuit from a subtransmission

connection.

Line <u>No.</u>		
1		over the span of three years in the field. The pilots include geo-targeted bonus
2		incentives to deliver off peak-load relief for premises connected to Fisher circuits.
3		EWR progress for year-end 2023 is at a 139 peak-kW reduction.
4		
5	Q77.	What EWR work is still to be completed for the Fisher project and what is the
6		expected timeline for that work?
7	A77.	The field pilot programs will run for three years and are expected to be completed
8		in 2025.
9		
10	Q78.	Are the EWR costs included in Exhibit A-12, Schedule B5.4?
11	A78.	No. Energy Waste Reduction pilot costs are included as part of the Company's
12		EWR Plan in Case No. U-20876, Exhibit A-11 and Exhibit A-14.
13		
14	Q79.	What has been the progress and results of the DR work at Fisher?
15	A79.	As of Q4 2023, there is a cumulative total of 183 customers at the Fisher substation
16		enrolled in the Smart Savers program; 57 new customer enrollments can be
17		connected back to 2023 marketing initiatives. Based on a third-party forecasted
18		analysis, these customers could each provide an average of 0.62 kW in load shed
19		per event for a total of approximately 113 kW available in demand savings. As of
20		Q4 2023, there are also a total of 298 CoolCurrents customers online and
21		dispatchable at the Fisher substation. Based on the third-party forecasted analysis,
22		these customers could each provide an average of 0.53 kW in load shed per event
23		for a total of approximately 158 kW available in demand savings. In addition to the
24		298 online customers, the DR team has identified 201 CoolCurrents customers at
25		the Fisher substation who are currently offline because they do not have a proper

Line <u>No.</u>		
1		24-volt power source connection. The Company has identified a solution for this
2		and will be implementing it in 2024.
3		
4	Q80.	What DR work remains to be completed for the Fisher Pilot and what is the
5		expected timeline for that work?
6	A80.	The Fisher Pilot was launched in 2022 and is forecasted to run for three years until
7		2025. The DR team will continue to deploy enhanced marketing efforts for the
8		Smart Savers program to drive incremental enrollment. The DR team will also
9		continue efforts to restore offline CoolCurrents customers.
10		
11	Q81.	What has been the progress and next steps for the STDF?
12	A81.	Preliminary engineering and design are completed. Reconductoring is expected to
13		start in early 2024 and final construction is expected to be completed in 2024. The
14		design for the STDF installation is forecasted to start in 2024, and the STDF will
15		be installed and operational in 2024.
16		
17	Port A	Austin
18	Q82.	Can you briefly describe the Port Austin NWA Pilot?
19	A82.	Yes. The Port Austin substation, located at the tip of the thumb, is over its firm
20		rating, one circuit is over its day-to-day rating, and there are short periods of low
21		voltage at the end of the circuits during periods of peak demand. The substation
22		voltage is 4.8 kV, and the traditional method for addressing these concerns would
23		be to convert the area to the higher 13.2 kV. However, significant load growth is
24		not forecasted in this area, which makes this a lower priority for conversion
25		compared to other areas. Additionally, this area is vulnerable to severe weather and

1		experienced two tornadoes in recent years. With these considerations, the			
2		Company is piloting the application of solar generation combined with energy			
3		storage to address these concerns. Deployment of this equipment and using it to			
4		form a microgrid will benefit and supply power to a portion of the customers on the			
5		circuits if an event creates a fault that interrupts service from the substation.			
6					
7	Q83.	What progress was made from 2022 through 2023?			
8	A83.	Engineering was completed for the Port Austin project in 2022 and detailed design			
9		was completed in early 2023. The purchase of the property was completed in 2023.			
10		Project construction permits were secured from Huron County in the fall of 2023.			
11		The solar equipment was purchased in 2022 and was delivered to DTEE in 2023.			
12		Site preparation and construction started in the fall of 2023.			
13					
14	Q84.	What work remains for the Port Austin Pilot?			
14 15	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be			
14 15 16	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new			
14 15 16 17	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once			
14 15 16 17 18	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to			
14 15 16 17 18 19	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of			
14 15 16 17 18 19 20	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841.			
14 15 16 17 18 19 20 21	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841.			
 14 15 16 17 18 19 20 21 22 	Q84. A84.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841.			
 14 15 16 17 18 19 20 21 22 23 	Q84. A84. <u>Veridi</u> Q85.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841.			
 14 15 16 17 18 19 20 21 22 23 24 	Q84. A84. <u>Veridi</u> Q85. A85.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841.			
 14 15 16 17 18 19 20 21 22 23 24 25 	Q84. A84. <u>Veridi</u> Q85. A85.	What work remains for the Port Austin Pilot? Site construction needs to be completed and a mobile battery system will be delivered to the site. The control systems, communication infrastructure, new processes, standard designs, and other aspects of the pilot will be fully verified once the batteries and solar are installed, and the capability for the battery system to demonstrate participation in the wholesale market will be tested in consideration of FERC Order 841. And Can you briefly describe the Veridian NWA Pilot? Veridian is a planned residential subdivision development in Ann Arbor made up of mixed use and community buildings and approximately 150 residential units that			

Line	
No.	

1		are a combination of detached single-family homes, townhomes and multi-unit
2		dwellings. The area is served by the 4.8 kV Regent substation. While substation
3		loading is not the primary concern, the overall load of the development is expected
4		to approach 1.5 MVA, and none of the existing circuits have capacity to
5		accommodate this level of load growth. However, the developer is planning to
6		deploy customer owned solar and storage. By carefully coordinating the usage of
7		the customer deployed DER with utility controls, system upgrades can be
8		minimized yet still deliver the safe and reliable power required for this
9		development. There are three aspects of the project: installing a URD loop,
10		completing system upgrades, and developing a microgrid.
11		
11		
11	Q86.	What work remains to be completed for the Veridian Pilot?
12 13	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and
11 12 13 14	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is
11 12 13 14 15	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through
11 12 13 14 15 16	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through early 2024. The system upgrade portion of the project began construction in 2023
11 12 13 14 15 16 17	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through early 2024. The system upgrade portion of the project began construction in 2023 and will be completed in 2024. The microgrid portion of this pilot is currently in
11 12 13 14 15 16 17 18	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through early 2024. The system upgrade portion of the project began construction in 2023 and will be completed in 2024. The microgrid portion of this pilot is currently in detailed engineering study, and controls design, procurement, and construction will
11 12 13 14 15 16 17 18 19	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through early 2024. The system upgrade portion of the project began construction in 2023 and will be completed in 2024. The microgrid portion of this pilot is currently in detailed engineering study, and controls design, procurement, and construction will begin in 2024 and continue into 2025, aligning with occupancy of the development
11 12 13 14 15 16 17 18 19 20	Q86. A86.	What work remains to be completed for the Veridian Pilot? Design is underway for the underground residential distribution (URD) and reconductoring portions of the Veridian project. The URD loop construction is currently scheduled to align with the developer's project plan, extending through early 2024. The system upgrade portion of the project began construction in 2023 and will be completed in 2024. The microgrid portion of this pilot is currently in detailed engineering study, and controls design, procurement, and construction will begin in 2024 and continue into 2025, aligning with occupancy of the development and the solar/storage DER components going on-line.

22 EV Charging Demonstration at ACM

23 Q87. Can you briefly describe the NWA: EV Charging Demonstration at ACM
24 investment?

т :	
Line	
No.	

1	A87.	This project includes investments in several different EV charging technologies and
2		projects to learn how the various technologies will impact the grid. This includes
3		the Department Of Energy (DOE) DE-EE0008361 Xtreme Fast Charging demo at
4		ACM, the DOE VTO FOA-2197 EVs at RISC program, and the Electreon in-road
5		charging pilot in Corktown sponsored by MDOT. The project scope also includes
6		engineering support for transportation electrification including work with
7		automotive OEMs and suppliers, engineering support and testing for managed
8		charging pilots, engineering support for electric school buses, engineering support
9		for Vehicle to Home (V2H) charging pilots, engineering support for Vehicle to Grid
10		pilots (V2G), development of V2H and V2G interconnection requirements,
11		charging interoperability testing and the distribution engineering support, testing
12		and validation for many of the pilots initiated in the Emerging Technology Fund,
13		which is described in Witness Pina Bennett's testimony at page 61.
14		
15	Q88.	Has the Commission addressed this project in a previous order?
16	A88.	In its December 1, 2023 Order in Case No. U-21297 the Commission stated:
 17 18 19 20 21 22 23 24 25 26 27 28 		The Commission notes that in the November 18 order, pp. 159-161, the Commission approved only 10% of the requested funding for this pilot. Based on the record in the instant case, the Commission is not persuaded to approve additional funding at this time. The Commission agrees with the Attorney General's assessment of the technology as currently so experimental as to be premature for funding by ratepayers. See, 6 Tr 3680-3681. Further, it is unclear what benefits—if any— would be available to DTE Electric's customers other than ACM, making it difficult to justify the reasonableness and prudence of having all customers pay for this pilot. (MPSC, p. 131)
29	Q89.	Is the Company providing testimony to address the Commission's stated
30		concerns?

Line	
No.	

1	A89.	Yes, additional support for cost recovery of this investment is provided to address
2		the Commission's stated concerns. Furthermore, the historical project name is
3		being kept for consistency even though the investments in EV technology programs
4		addresses a broader scope of EV projects than the ACM Xtreme Fast Charging
5		Project, and the ACM project component was completed in 2022.
6		
7	Q90.	Why were other EV project investments grouped with the NWA: EV Charging
8		Demonstration Pilot at ACM?
9	A90.	Originally, when the project was created it supported multiple EV technology
10		projects that were under consideration. The project that was furthest in
11		development, (dating back to 2018) was the DE-EE0008361 Xtreme fast charging
12		demo at ACM. The pilot's name was applied to the budget category even though it
13		contained other EV projects, because at the time those other projects were still in
14		initial stages and did not have any significant investment. The project name has
15		been retained through subsequent cases for consistency even though it doesn't fully
16		describe all the investments in the category. Table 3 provides a breakdown of the
17		split between the ACM spend and that from other EV technology projects.

Table 3Cost breakdown of ACM compared to total program

	2022	2023	2024	2025
ACM	\$ 697,000	\$ -	\$ -	\$ -
EV Programs	\$ 595,000	\$ 1,292,000	\$ 920,000	\$ 2,500,000
Program Total	\$ 1,292,000	\$ 1,292,000	\$ 920,000	\$ 2,500,000

19

20 Q91. What is included in Historical funding year for NWA: EV Charging 21 Demonstration at ACM Pilot investment?

Line	
No.	

1	A91.	At the ACM site, work included site preparation, below grade cable and conduit
2		installation, foundations for equipment, installation of a medium voltage switch for
3		isolation and operating, installation of relaying and power quality meter and
4		communications and control hardware to measure and record data from charging
5		events. The Xtreme fast charger successfully completed initial charging
6		demonstrations in fall of 2022 and culminated in the demonstration to the
7		Department of Energy on Oct 13, 2022 ⁶ .
8		

9 For the other EV programs in this category, the work was primarily for the DOE 10 VTO FOA-2197 EVs at RISC program⁷ and focused on validating the data model 11 and cyber security implementations necessary to provide managed charging in a 12 multi stake holder environment where charging was dynamically controlled by grid 13 conditions. This included an initial proof of concept demonstration to the 14 Department of Energy of the system's ability to control vehicle charging locally 15 and remotely based on real time grid conditions while implementing the required 16 cybersecurity practices to maintain isolation of the utility control network. Additional work was performed on EV charging station protocol interoperability 17 18 and compatibility for managed charging and demand response and initial 19 investigations into the Electreon electric road technology and Vehicle to Grid 20 functionality and standards.

21

⁶ High-Efficiency, Medium-Voltage-Input, Solid-State-Transformer-Based 400-kW/1000V/400A Extreme Fast Charger for Electric Vehicles (Technical Report) | OSTI.GOV available at https://www.osti.gov/biblio/1987553

⁷ EVs-at-RISC: A Secure and Resilient Interoperable Smart Charge Management Control System Architecture for Electric Vehicles At-Scale : elt265 (energy.gov) available at https://www.energy.gov/sites/default/files/2021-07/elt265 woodbury 2021 o 5-14 500pm KF ML.pdf

1

Q92. What investments are included in the test and forecast year funding?

2 A92. A major portion of the investment during the test years is the technical 3 demonstration of the DOE program for DE-FOA-0002197, EVS-at-RISC (Electric 4 Vehicle Secure - Resilient Interoperable Smart Charging) This includes the initial 5 and widescale demonstration of the system controlling multiple publicly accessible chargers in and around the Michigan central campus in Corktown. This 6 7 demonstration will help the Company develop cyber-secure monitoring and control 8 capabilities with smart charge controls to ensure reliable and secure interfaces to 9 customer systems. The project will further enhance knowledge of the grid impact 10 of these new management technologies. The electric Marketing organization has initiated Smart charge management projects that will be tested in multiple phases 11 12 through 2023 and 2024 at the DTEE DER lab. Testing of vehicle protocol and 13 interoperability will continue; especially as new commercially available systems 14 integrate more directly with solar and storage and feature more complex controls 15 and the ability to operate offline. Investments in the development of V2G and 16 interconnections documentation will be completed in 2024 year. Engineering will 17 also be done on the inductive road charging project to better understand the power 18 quality impacts of wireless charging. Engineering support for Electric Vehicle 19 Emerging Technology Fund (ETF) is primarily around providing feedback to the 20 individual projects design. Work also includes supporting the implementation of 21 testing of the solution and validating the technical performance of the projects.

22

Q93. Is there investment in the ACM portion of the project in the bridge years 2023 or 2024 or in the projected test year of 2025?

A93. No, other than project close out and accounting, the specific work at ACM was
 completed in 2022 and the investments in this category are at sites other than ACM.
 DTEE continues to monitor the charger and solid-state transformer to gather
 additional data on charging events.

5

6 Q94. Can you describe the specific work for the NWA: EV Charging Demonstration 7 at ACM?

8 A94. Yes, in addition to the information provided in Exhibit A-12, Schedule B5.4.7, the 9 EV Charging Demo at ACM Project included DTE Electric supporting the 10 implementation of the Delta Power Electronics DC Xtreme 400KW fast charger and solid state transformer installation as part of the DOE project DE-11 12 EE0008361/DE-FOA-0001808. The purpose of which was to gain understanding 13 of the impacts of high-powered EV charging on power quality and operations. The 14 pilot installed a power quality meter, utility gateway, and communications portal to 15 (a) enable charge management, (b) develop control algorithms and conduct testing 16 on a Delta Extreme fast charger and its interfaces, (c) develop cyber security 17 interfaces and control, (d) install additional sensing capabilities, (e) monitor 18 performance on the charging network, and (f) develop monitoring and control 19 algorithms for in-road inductive charging at the ACM site. The DE-EE0008361 20 project began in 2018 with Delta being the prime recipient of funding to develop 21 the extreme fast charger and associated solid state transformer, where most of the 22 research and development work occurred at the Delta facility in Livonia. The 23 project team members also included DTEE, General Motors (GM), Next Energy, 24 Virginia Tech, the City of Detroit, and the Michigan Energy Office. This teaming 25 is typical of DOE grant projects where a private technology partner teams with a

<u>No.</u>	
1	university, national labs, and a utility partner to demonstrate a technology of
2	interest to the Department of Energy. The project stated goals to the DOE were:
3	AREA OF INTEREST (AOI) 1: Extreme Fast Charging (XFC) Systems for Electric
4	Vehicles:
5	• To design and test a high-efficiency, medium-voltage-input, solid-state-
6	transformer-based 400-kW Extreme Fast Charger (XFC) for electric
7	vehicles, achieving better than 96.5 percent efficiency.
8	• To demonstrate extreme fast charging with a retrofitted General Motors'
9	light-duty battery electric vehicle at 3C or higher charging rate for at least
10	50 percent increase of SOC.
11	• To achieve a 180-mile charge within 10 minutes.
12	
13	Stated benefits of the technology development were (a) a reduced amount of low
14	voltage electrical equipment, (b) reduced charging losses, (c) the allowance of more
15	direct integration of DER and storage into the system, (d) reduced space required
16	for the unit, and (e) reduced labor to install high powered charging.
17	The initial Delta fast charger prototype was available by the end of 2020 and was
18	tested electrically at the Next Energy microgrid. The second phase was field
19	demonstration and installation which took place in late 2022 with a demonstration
20	for the Department of Energy showing 400KW charging on commercially available
21	vehicles and the use of a solid-state transformer.
22	The American Center for Mobility (ACM) demonstration was a collaboration
23	between Delta, DTE Energy, and ACM. The ACM site draws directly from medium
24	voltage 13.8 kV, which was already available at the station. ACM also provides a
25	step towards "real-world" usage in a semi-controlled environment, as many ACM

Line

1

2

3

customers are running tests with electric vehicles where a fast charge will help them get back to testing quickly. The site constructed under the project closely mimics the process for fielding a medium voltage EV charger at other sites.

4

5 Q95. Is the charging technology demonstrated at ACM experimental and 6 premature?

7 A95. No, the specific charger installed at ACM contained additional testing 8 instrumentation and required more access for configuration than a final product. 9 The ACM site charger, while not available commercially, has resulted in a 10 commercial product that Delta is currently working to bring to market. The demonstration for the Department of Energy showed charging of 2023 model year 11 12 vehicles, including a GM EV Hummer at full power of 400 KW and operating at 13 the maximum of 800V, double the standard charging voltage in older EVs. This 14 showed that the system could readily perform DC fast charging of a Ford F-150 15 Lightning, Chevy Bolt, and Cadillac Lyrig at their maximum charge rate as well. 16 All these vehicles were standard production and unmodified. This technology 17 demonstration is fundamental to encouraging rapid electrification and improving 18 the charging experience for EV owners by reducing the charging time for a full 19 charge from multiple hours to just minutes. This project demonstration identified 20 best practices that can be applied to any similar high powered future charging 21 projects that would result in reduced design and construction costs and allow for 22 the early identification of potential roadblocks to installation. The scope of 23 evaluation with the Department of Energy is to demonstrate technical feasibility 24 and meet demonstration milestones. The Department of Energy Vehicle

Line

No.

- 2 technologies demonstrated.
- 3

1

4 **Q96.** Does the ACM project show a successful approach to leveraging other funding 5 sources to innovate and support electrification?

Technology Office has clear criteria to facilitate the commercialization of

6 A96. Yes. Delta, the primary recipient of the grant, funded development of the solid-state 7 transformer and extreme fast charging system and provided the equipment to the 8 project. The Company fulfilled the role of the host utility to provide engineering 9 input into the project to reach a successful integration of the grid connection and 10 engineering and operating support. ACM acted as the site host for the demonstration primarily because initial testing required vehicles that were heavily 11 12 modified to accept the high-powered charging and these vehicles were not certified 13 to drive on the open road thus requiring a test track location. Without the initial 14 testing on the closed track, there was no way to rapidly discharge the vehicle 15 batteries to perform cycle testing on the system to validate that the power 16 management and thermal management of both the vehicle and the charger was 17 performing as expected. For the final demonstrations, the test vehicles were 18 replaced with production models as GM had integrated the technology into their 19 core drivetrain platform by that time.

20

21 Q97. What benefits did the ACM Pilot have that can be applied beyond the ACM 22 site?

23 A97. By participating in Department of Energy projects that include equipment 24 manufacturers and research institutions, DTEE is able to obtain valuable 25 information on technologies such as extreme fast charging as well as on solid-state

Line
No.

14		have for customers?
13	Q98.	What benefits do the other EV charging investments beyond the ACM Pilot
12		
11		wiring.
10		efficiency gains by eliminating traditional transformation and secondary voltage
9		voltage primary system, allowing for higher charging rates and significant
8		technology where the EV charger direct current is directly coupled to the medium
7		have. The demonstration also provided experience with solid state transformer
6		that will not have on site trained electrical staff like an industrial facility might
5		the method needed for grid connection and operation at high powered charging sites
4		secondary voltage equipment and transformation. Additionally, DTEE evaluated
3		in the future by eliminating equipment and construction costs for unnecessary
2		product that would allow high power charging to be deployed more cost effectively
1		transformer technology performance. DTEE also supported Delta in developing a

A98. As EV's become more prevalent in the Company's service territory, the learnings
from these projects will support a more efficient incorporation into the grid, laying
the groundwork for EV's to be a grid-benefitting resource. There are three major
benefits for the additional investments.

Create a consistent and clear set of standards and requirements for the
 connection and operation of Vehicle to Home (V2H) and Vehicle to Grid
 (V2G) technologies and to use these as the baseline for necessary changes
 in processes and organizations that directly interface with the customer that
 is requesting those capabilities to streamline that experience.

<u>No.</u>		
1		• Define and implement the appropriate communication, cybersecurity, and
2		control architectures for managed charging to allow for greater adoption of
3		EV charging and minimizing the impact of grid constraints.
4		• Increase insight into the benefits of managed charging and the impact of EV
5		charging on system loading and power quality, especially at high
6		concentrations of charging to optimize circuit design and develop consistent
7		methods for modelling the variability of managed charging and EV
8		charging, this information will translate to projects that are better at
9		integrating electrification.
10		
11	<u>Adapt</u>	ive Networked Microgrids
12	Q99.	Are there any additional pilots proposed based on the work at O'Shea and
13		Port Austin?
14	A99.	Yes. DTE Electric has been selected by the DOE for Infrastructure Investment and
15		Liber And (IIIA) from the second stand of the Company's NIWA and the New Grief the second
		Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to
16		finalize the project award expected to continue until sometime in the second quarter
16 17		finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea
16 17 18		finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked
16 17 18 19		Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed
16 17 18 19 20		Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed assets.
 16 17 18 19 20 21 		Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed assets.
 16 17 18 19 20 21 22 	Q100.	Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed assets. Why were these sites selected?
 16 17 18 19 20 21 22 23 	Q100. A100.	Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed assets. Why were these sites selected? DTE Electric is dedicated to the deployment of renewable NWA projects, and the
 16 17 18 19 20 21 22 23 24 	Q100. A100.	 Jobs Act (IIJA) funding to expand on the Company's NWA work. Negotiations to finalize the project award expected to continue until sometime in the second quarter of 2024. DTE Electric will use this funding to grow the deployments at O'Shea Solar Park and Port Austin substation and to incorporate Adaptive Networked Microgrids (ANMs) to further increase the customer benefits from the deployed assets. Why were these sites selected? DTE Electric is dedicated to the deployment of renewable NWA projects, and the ANMs will be an extension of that work. Both sites have assets already deployed

Line

Line	
No.	

1		described earlier in my testimony, and by selecting these sites, the overall cost will
2		be lower. Furthermore, Chicago substation / O'Shea is in an urban area with a high
3		energy justice score, and Port Austin substation is in a rural area with longer
4		circuits. Between these two locations, the ANM concept can be fully developed and
5		tested for the benefits it provides customers in a range of settings. Additionally,
6		both areas are served by 4.8 kV ungrounded delta circuits. When the reclosers are
7		placed near the start of the circuit to detect and isolate grounds, the networked
8		microgrids and fault location technology that will be developed during the project
9		will further isolate the ground and continue to provide power to customers from
10		outside the isolation area.
11		
12	Q101.	Why is the Company focused on microgrid development and deployment?
13	A101.	The DOE's vision includes microgrids as a building block for the future electrical
14		system ⁸ . Microgrids provide a mechanism to bring local DER together to provide
15		solutions for resilience and reliability by becoming their natural aggregation point.
16		Microgrids form a unit that hosts loads and generation that can be connected or
17		disconnected from the rest of the grid. Additionally, multiple neighboring
18		microgrids with dynamic boundaries can form larger multi-customer dynamic
19		microgrids.

⁸ "By 2035, microgrids are envisioned to be essential building blocks of the future electricity delivery system to support resilience, decarbonization, and affordability. Microgrids will be increasingly important for integration and aggregation of high penetration distributed energy resources. Microgrids will accelerate the transformation toward a more distributed and flexible architecture in a socially equitable and secure manner." from DOE OE 2021 Strategy White Papers on Microgrids: Microgrids as a Building Block for Future Grids – Topic 4, page 5, Available at https://www.energy.gov/sites/default/files/2022-12/Topic4%20Report.pdf, Accessed on November 28, 2023.

Line	
No	

With that background, microgrids provide an opportunity to increase the benefits
 of the Company's NWA deployments and customers' DER installations. Deploying
 microgrids is directly aligned with the DOE's vision for the future electrical
 distribution system.

5

6 Q102. What are Adaptive Networked Microgrids (ANMs)?

A102. Adaptive Networked Microgrids are two or more neighboring microgrids with
controls and protection that enable them to merge based on several considerations
including but not limited to the locations of faults, load forecasts, weather forecasts,
and DER status. These microgrids can dynamically change their boundaries
through switching operations to isolate faults and improve the reliability of
customers. This vision offers a chance to increase reliability, but development and
testing are required.

14

15 Q103. What development and testing are needed?

A103. There are seven areas of focus for the development and testing leading up to the
installations at O'Shea and Port Austin. This work is needed primarily to build on
the Company's NWA pilots toward ANMs. The seven areas are Project and
Technical Management, Sensors and Data Analytics, Cybersecurity, Control and
Protection, Engineering Due Diligence, Microgrid Deployment, and Sharing
Lessons Learned. Details on these seven areas can be found in Exhibit A-12,
Schedule 5.4.9, Section 2(a).

23

24 Q104. How will the Company's customers benefit from this project?

Line	
No.	

1	A104. Benefits to the Company's customers include (a) greater resilience to extreme
2	weather conditions, (b) improved reliability for everyday operations, (c) enhanced
3	security from an evolving number of cyber-physical threats, (d) superior flexibility
4	to respond to the variability and uncertainty of conditions, and (e) increased
5	sustainability through energy efficient and renewable resources. Additionally, the
6	project will support the advancement of microgrids in general. Other technology,
7	such as fault locating and state estimation will be developed from the project, that
8	will benefit customers outside of the networked microgrid deployment. Overall,
9	this will place Michigan as a leader in Adaptive Networked Microgrid technology.
10	
11	Q105. Does the Company have any partners for this project?

A105. Yes. The Company has formed a partnership for this work called the Adaptive
Networked Microgrid Partnership (ANMP). The Company's partners include Open
Systems International (OSI), Open Energy Solutions (OES), Electric Power
Research Institute (EPRI), and the University of Michigan-Dearborn. Lawrence
Livermore National Laboratory (LLNL) and National Renewable Energy
Laboratory (NREL) are advisors for the project. The roles of each partner are
described in Exhibit A-12, Schedule B5.4.9.

19

20 Q106. Where will this new technology be deployed initially?

- A106. After a period of development and testing at the Company's Solar and Storage Lab
 in Westland, Michigan, the deployments will be at Chicago substation/O'Shea
 Solar Park and Port Austin substation.
- 24

25 Q107. What specifically will be added at Chicago/O'Shea?

Line	
No	

1	A107.	One of the batteries currently being used for the Omega Pilot will be transported to
2		a new DER site to be installed on Chicago DC 1415 in the City of Detroit.
3		Reclosers will be installed at the start of the circuit to isolate grounds, at each DER
4		site, and on the circuit to isolate or connect the two DER sites to create dynamic
5		microgrids.
6		
7	Q108.	What specifically will be completed at Port Austin?
8	A108.	A DER site with a battery only will be installed adjacent to the microgrid currently
9		being installed. Depending on equipment availability and cost, an additional DER
10		site may be built next to the substation with solar and storage like the current DER
11		being installed at Port Austin. Like the plan for Chicago/O'Shea, these DER sites
12		will all be sectionalized by reclosers to dynamically shift the microgrid boundaries.
13		There will also be sectionalizing at the beginning of the circuit for ground fault
14		indication and isolation.
15		
16	Q109.	What are the expected costs for this work?
17	A109.	The estimate for the pilot is approximately \$46 million. This includes
18		approximately \$1 million in funding from the Company's partners, and \$23 million
19		from the DOE, which leaves approximately \$22 million in funding from DTE
20		Electric.
21		
22	Q110.	What is the schedule for this networked microgrid development work?
23	A110.	The project is expected to progress over four phases that are roughly tied to the
24		calendar years from 2024 to 2027. With the Engineering Phase primarily occurring
25		in 2024, the Development Phase primarily occurring in 2025, the Deployment
Line <u>No.</u>		0-21334
--------------------	-------	---
1		Phase primarily occurring in 2026, and the Assessment Phase primarily occurring
2		in 2027.
3		
4	Q111.	How is the funding provided by the DOE and the Company's partners
5		included in the Exhibit A-12, Schedule B5.4?
6	A111.	Line 26 on page 17 of Exhibit A-12, Schedule B5.4 provide the cost for the project.
7		The funding from the DOE and the Company's partners to support the project is on
8		line 27 on page 17 of Exhibit A-12, Schedule B5.4. Line 27 reduces the total cost
9 10		of the project, which is included on Line 26.
11	Q112.	What does the Order Case No. U-21297 include about Staff involvement for
12		the NWA pilots?
13	A112.	Page 124 of the December 1, 2023, Order in Case No. U-21297 includes the Staff's
14		recommendation that "the company engage in ongoing consultation with the Staff
15		and making other recommendations for the battery technology pilots and for
16		ongoing updates that could ease the burden of litigating these pilots in rate cases."
17		The Company has continued to involve Staff with NWA pilots. As an example, for
18		the Adaptive Networked Microgrid, the Company presented the pilot to the Staff
19		on November 14 th , 2023, to ensure the Staff understands the concept and has an
20		opportunity to offer their insights on the pilot.
21		
22	Е.	Grid Edge Insights and New Technology
23	Q113.	What is Grid Edge Insights and New Technology?
24	A113.	This category of investments is a collection of projects that are designed to
25		consolidate the learnings from the Non-Wire Alternatives projects into a consistent

Line	
No.	

1	platform, and to unlock the capabilities of new equipment that is being brought to
2	market to run the grid safer, more reliably and efficiently, ultimately increasing the
3	amount of DER that can be accommodated on the grid. The projects that make up
4	this category are summarized in the following table.

Line <u>No.</u>

1 Table 4 Key Investment Highlights for Grid Edge Insights and New Technology

Key Investment	Use Case	Implementation Highlight
Grid Edge Insights	Consolidate capabilities developed in the NWA projects into a single modular platform to allow future NWA and DER installations to benefit from consistent technology, controls, communications and practices	Creation of a single interconnection gateway platform for all large interconnection and NWA projects. The platform will have a number of physical form factors to allow for deployment at small medium and large scale sites.
New Technology Evaluation	Test overhead, underground, substation and control equipment that is not currently in use at DTE to determine if it can be used to improve current operations. Create practices and procedures for the roll out of the technology into projects and programs.	All new equipment that will be operated and maintained by DTE Electric is run through the New Technology evaluation 6 gate process to ensure appropriate documentation, standards and procedures are created including installation at the Technical Training Center and field evaluations prior to broad deployment.
DER Control	Installation of standardized interconnection gateways at several DTE DER sites	Upgrades of controls and monitoring at Demille, Turril and Greenwood solar to improve remote management capabilities, integration with the control room and forecasting.
Small Solar and Storage Testbed	Testing hardware and capabilities to evaluate the performance and safety of commercially available solar and storage that customers are installing in the service territory and evaluate different configurations for interactions, safety and training for field crews.	Testing of customer DER configurations in a safe environment and enable the creation of practices and settings for smart inverter and microgrid functions for customers that install DER.
S ensor network and algorithm Development	Evaluate different remote sensing options to capture information that allows for improved forecasting and visibility into DER performance	Installation of weather network sensors and sky cameras to improve hourly forecasts of solar production in localized areas that have high solar penetration allowing the control to better understand fluctuations in loading.

2

3 Q114. What are the benefits of Grid Edge Insights and New Technology?

1	A114.	Evaluation and integration of new technology into the grid allows for technological
2		enhancements to improve grid reliability, resilience, safety, efficiency, and
3		opportunities for costs savings. The investments in Grid Edge Enablement will
4		allow for additional NWA and DER resources to be connected into the grid in a
5		safe and reliable manner by coordinating the DER controls with day-to-day grid
6		operations. By having a consistent platform for integration, per project costs and
7		time are reduced as site and controls design is limited to only those unique aspects
8		of the DER that do not follow standard protocols and interoperability. Integration
9		of Utility NWA and DER can be standardized, and interconnection of customer
10		DER can be streamlined as substantial portions of the communication and control
11		are pre-designed inside the gateway. The gateway allows for a consistent
12		configuration, communications, and cybersecurity between the utility and the
13		gateway and moves the complexity of dealing with site-by-site variation in
14		hardware and implementation to the edge of the grid rather than having to
15		accommodate the additional complexity in central IT systems like the ADMS and
16		future Distributed Energy Resource Management System (DERMS). The modular
17		nature of the gateway controls allows for expandability to accommodate new DER
18		types, control algorithms, and functionalities and the system provides the ability for
19		remote management and upgrades to reduce site visits.

- 20
- 21

Q115. What considerations inform the Company's strategy for Grid Edge Insights and New Technology? 22

A115. New technology is evaluated on several factors, with reliability and safety of the 23 product taking precedence. The new technology process allows for a structured 24 25 evaluation of all aspects of a product or functionality and for incorporation of

1 lessons learned from other utilities, industries, and research organizations like 2 EPRI. These lessons inform the determination of its readiness to be deployed into 3 the grid. Careful attention is given to operating practices, worker safety, and the 4 long-term sustainability of the product. Key aspects considered are the ability for 5 the product and its controls to be integrated into the DTEE SCADA system and the 6 cyber security of the product and its vendor support structure. This process allows 7 for products and functionalities to be accepted and operating practices to be 8 developed; it also provides the opportunity to identify any cross-cutting synergies 9 in other areas where the same product or functionality can be reused to save costs. 10 Other considerations include enabling additional capabilities for utility operations and customers to improve efficiency, reliability, and resilience. These factors can 11 12 then be tested at the Technical Training Center which includes facilities for testing 13 grid connected and the interactions of customer equipment at the Solar and Storage 14 Testbed.

15

Q116. What is the Company's strategic scope for Grid Edge Insights and New Technology?

18 A116. Ongoing investments in this category are expected as the complexity of the grid 19 and the capability of devices will continue to increase for decades to come as new 20 technology is brought to the marketplace. A rigorous technology evaluation and 21 selection program is instrumental in selecting the best technologies to construct the 22 grid and to ensuring safe, reliable, and efficient operation for customers and 23 employees. Investments in the introduction of new technology allow all projects 24 and programs to benefit from improved performance and capabilities. For example, 25 the pace of change of consumer DER products continues to increase and utility

Line	
No.	

1	practices must keep up with customer expectations. As the industry adapts to these
2	changes it is expected that there will be increased standardization in products and
3	the need for increased communication between the customer and utility; this will
4	drive additional requirements for interoperability and cyber security to unlock the
5	full potential of DER and NWA and additional testing capability for the Solar and
6	storage testbed to incorporate microgrid control functionality.
7	
8	Q117. Were all capital investments in Grid Edge Enablement and New Technology
9	described within the Distribution Automation financial exhibit?
10	A117. No. In 2022 and 2023, investment occurred under the OT program titled
11	Interconnection Process Enablement. For 2024 this is described in The Operational
12	Technology Distribution Planning section of this testimony. Investment for 2022
13	was \$1.64 million and for 2023 \$2.75 million, most of this being expansion of the
14	small solar and storage testbed site to incorporate three phase 480V and medium
15	voltage testing capability and gateway testing hardware. These investments were
16	made under that category prior to the decision to split the DER controls and
17	hardware from the backend OT functionalities needed for interconnection study and
18	processing. For 2024 onward all the control and hardware investment will be
19	included in the Grid Edge Enablement and New Technology Category. This work
20	was not duplicative and simply represents a change in classification to align the
21	projects more clearly to their focuses going forward. Work incorporated into the
22	individual NWA projects reflects site specific implementations and while it is
23	coordinated with the Grid Edge Enablement and new technology the investment is
24	not duplicated between the projects.

25

1 Q118. What progress has been made in 2022 and 2023?

A118. The solar and storage testbed has been expanded to allow for connection and testing
of the interconnection gateways and battery trailer system. This expansion included
test bays with medium voltage hookups, conduit, cable and switching equipment as
well as communication and control wiring to allow for instrumentation and
connection to the equipment.

7 The large interconnection gateway has been tested at the Solar Testbed and 8 equipment is being prepared to be deployed to NWA projects such as O'Shea, and 9 Port Austin. A variant has also been incorporated into the Battery Trailer systems. 10 Grid edge functionalities for energy storage management and coordination between 11 the utility control room and market operations were implemented into the gateway 12 functionality along with safety and operating controls that allow for monitoring 13 DER, energy storage systems, and alarms.

14 A Hardware-In-the-Loop (HIL) testing system has been installed in the testbed 15 which allows for real time and repeatable testing of control and communications 16 interactions of the actual grid control hardware while allowing for different circuit 17 configurations and scenarios to be simulated. This functionality allows testing of 18 complex control schemes leading to a high degree of confidence that the controls 19 will work when deployed to the field. It also allows for rigorous testing of scenarios 20 where changes in settings or conditions change; the tests can be rapidly rerun to 21 verify that proper system operation will occur. This type of testing is critical to 22 advanced functions such as microgrids where many devices must all operate 23 together over different networks to allow for the successful transition of customers 24 and resources onto and off the grid.

25

1 Q119. What are the benefits of the 2022 and 2023 investments?

2 A119. Having a consistent design for the interconnection gateway allowed for NWA 3 projects to incorporate the concrete pad, house service power, and communications 4 requirements into the site plan with minimal design. The modular controls 5 capability allowed each project to only focus on the unique aspect of the project 6 design and use cases, significantly reducing engineering and design time and 7 eliminating duplicated effort. The HIL system has already allowed for rapid 8 verification of control concepts for NWA projects like the microgrid NWA at Port 9 Austin.

10

11 Q120. What is the Company's plan for 2024 and 2025?

12 A120. Investments in 2024 and 2025 include integrations into the interconnection gateway 13 of functionalities for microgrid operations, networked microgrid capabilities, 14 coordination with grid automation, the inclusion of customer managed DER into 15 grid optimization, EV and V2G management and Demand Response. Additionally, 16 medium and small-scale gateway products will be evaluated and tested to allow 17 more DER and NWA sites to benefit from the integrated gateway functionality. 18 New technology evaluations will continue to expand the capabilities of grid 19 automation to allow for more integration with ADMS FLISR, circuit loop schemes 20 and distribution automation. Investment in gateways and sensor networks will 21 establish a mechanism to replace the system loading visibility that is lost in no 22 longer being able to install generation meters for specific customer classes. The 23 testbed will also be enhanced to allow for the full training capabilities on customer 24 DER configurations and testing of microgrid functionalities for NWA projects like 25 the ANM using both the HIL simulation system and the testbed electrical network.

1 Q121. What benefits are associated with the work planned for 2024 to 2025?

2 A121. New Technology evaluations in 2024 and 2025 will focus on supporting grid 3 automation deployments and the various use cases for the viper reclosers and 4 ADMS advanced functions such as CVR/VVO and FLISR. Additional 5 standardization and practices for distribution connected energy storage and 6 microgrids will be established. The investments in 2024 and 2025 will substantially 7 increase the ability for the Company to integrate both utility and customer owned 8 DER into grid operations and will streamline portions of the design and engineering 9 for large customer interconnections. Optimization algorithms will be implemented 10 to allow for more flexible DER operation and increased levels of DER and storage penetration into the distribution system. The HIL system and testbed will be utilized 11 12 to validate that this new technology and functionality works together without 13 creating unexpected operating behavior.

14

15 F. Distribution Sensing and Monitoring (includg Line Sensors)

16 Q122. What are Distribution Line Sensors?

A122. Distribution Line Sensors are devices used to monitor the real time status of the
 distribution system and provide critical information to field personnel and system
 control room operators to help them better monitor and manage the grid.

20

21 Q123. What is the scope of the Distribution Line Sensors Program?

A123. This program includes overhead system sensors used to monitor power quality and
 fault data needed for real time load transfer analysis, fault locating, and system
 status and Underground Residential Distribution (URD) sensors for use in
 underground area to quickly direct field crews to fault underground sections to

improve isolation and restoration times. This program will also include a
 technology demonstration of new sensors intended to help monitor the system for
 broken pole and wire-downs, allowing dispatchers to better locate and differentiate
 between energized and deenergized wire-downs as well as down electrical lines
 versus joint use wires.

6

7 Q124. What are the benefits of Distribution Line Sensors?

8 A124. Distribution line sensors support faster outage restoration by helping to identify and 9 locate faults, and dispatching crews to the identified fault location. Line sensors 10 located at manual switches, crossings or other operating locations indicate to the control room that the fault has occurred beyond the device and a crew can be 11 12 dispatched to the location, first to immediately restore portions of the circuit then 13 to begin patrolling for the specific fault location from the line sensor location. 14 Visual indication on the line sensors also helps crews quickly identify faulted lines 15 when in the field. Many of the line sensors also collect loading and voltage data 16 that can be sent directly to the ADMS and fault information that can be used in the 17 ADMS advanced distribution applications like FLISR which contributes to 18 reducing outage duration for customers. The line sensors work with the 19 telecommunications system, described earlier in my testimony, to provide power 20 and fault information to the ESOC and engineering personnel via the ADMS 21 system.

22

23 Q125. What work was completed in 2023?

Line <u>No.</u>		
1	A125.	398 underground (UG) line sensors and 100 overhead sensors were installed.
2		Additionally, 300 pole sensors and 1000 overhead line sensors were purchased that
3		will be installed in 2024.
4		
5	Q126.	What is the scope of work for the Distribution Line Sensors Program for 2024
6		and 2025?
7	A126.	In 2024, 500 overhead line sensors will be installed, and 300 pole sensors will be
8		installed and to test sensor ability to detect wire-downs. In 2025 the remaining
9		overhead sensors and 1300 underground sensors will be installed.
10		
11	<u>Opera</u>	tional Technology
12	Q127.	How does DTE Electric structure its distribution technology investments?
13	A127.	Two primary areas make up the bulk of the DTE Electric distribution technology
14		investments: Corporate Technology investments which make up the majority of
15		traditional Information Technology (IT) assets, and Operational Technology (OT),
16		those investments made specifically within a major operating unit, such as
17		Distribution Operations.
18		
19		DTEE's (2023) Distribution Grid Plan (DGP) covers technology investments
20		specifically related to Grid Planning stating, "Implementing new information
21		technology (IT) and operational technology (OT) will streamline and optimize the
22		Company's planning while also improving safety and productivity. These
23		investments form the core of the Technology and Automation Pillar." (Exhibit: A-
24		23, Schedule M8, p. 129) The DGP forms the basis for a roadmap of technology
25		investments categorized into five (5) areas: Grid Management, Distribution

<u>No.</u>	
1	Planning, Work Management and Scheduling, Asset Management, and Mobile
2	Technology. These investment categories serve to organize individual investments
3	and will be discussed in detail in this testimony.
4	
5	This structure forms the underlying basis for planning and aligning the Company's
6	technology investments over a 5+ year planning horizon and is the foundation for
7	any updates or changes to this strategy as they represent the Company's technology
8	investment.
9	
10	Q128. How does planning for technology investments differ from the planning of
11	more traditional equipment investments in the context of distribution grid
12	planning?
13	A128. In navigating technology investments for distribution grid planning, it is crucial to
14	recognize the shared planning aspects with traditional equipment investments.
15	However, what sets technology investments apart are two key distinctions: the
16	inherent dynamism, demanding adaptability due to rapid pace of technology
17	change, and the ongoing deployed lifecycle, necessitating a nuanced strategy for
18	balancing continuous optimization and evolution with prudent investment
19	planning. Ongoing investments are necessary to address the changing technology
	landscene and take advantage of new functionality that delivers hanafite to the

- 21 customers.
- 22 Rapid pace of technology change: Many capital investments like transformers, • 23 switchgear, and conductors have useful design lives that are measured in 24 decades. These devices routinely spend their entire service lives without inplace updates or changes and usually do not need to be altered once deployed 25

SMH-89

Line No

Line
No.

until they reach end of life. Technology assets are different. The services, 1 2 features, and benefits provided by an asset often stem from its capability to 3 adjust technology through remote programming or updating capabilities in 4 place. It is that capability that delivers ongoing value to that asset yet makes 5 planning for changes an asset may undergo over time a unique challenge. 6 Technology asset change cycles are measured in months, quarters, or years, not 7 in multiples of decades. Thus, the planned state for a system or technology can 8 change rapidly, sometimes even over the course of initial deployment or shortly 9 thereafter. This is an advantage rather than a weakness, but it challenges the 10 concept that all these changes can be known prior to initially building and 11 implementing these investments.

12 Deployed lifecycle: The term deployed lifecycle refers to the various stages 13 and processes involved in deploying a software application or system. Each 14 phase, for example development, testing, deployment, monitoring, and 15 maintenance, contributes to the overall lifecycle ensuring a smooth and 16 effective deployment of software. Technology investments can have shorter 17 deployed lifecycles than other grid assets. The Company invests in advancing 18 technology, bringing it closer to customers as analog devices transition to 19 digital. Examples of this are modern grid control devices like reclosers and 20 meters, both of which have become computers in their own right. As more of 21 the elements of those investments achieve greater sophistication in terms of 22 computing responsibilities, the Company's need to protect them from the 23 physical and cyber perspectives increases. Many of the field devices have and 24 will continue to undergo rapid advances in capability. As the Company and 25 customers demand faster and more capable service, they will need to be cycled

Line	
<u>No.</u>	

1	in and out of service faster than their less capable predecessors. Just as there
2	are very few 20-year-old computers in homes, so too will the Company's utility
3	automation and technology investments need to be kept up to date more often
4	than the strictly mechanical devices deployed in the past.
5	To be successful in technology planning the Company must stay abreast of evolving
6	technologies, incorporate new functionalities, and address emerging challenges.
7	Continuous investment allows for the integration of innovations that deliver value
8	to customers, such as improved reliability, and better response to dynamic grid
9	conditions.
10	
11	Q129. Are there any additional differences to consider when planning for technology
12	investments and the planning of more traditional equipment investments in
13	the context of distribution grid planning?
14	A129. Yes. Other differences to consider include:
15	• External vulnerabilities: Any device placed into the grid infrastructure must be
16	protected. Various devices in the electric grid require security measures,
17	including Supervisory Control and Data Acquisition (SCADA) systems,
18	routers, switches, smart meters, and communication networks. Protecting these
19	devices is crucial to ensure the reliability and integrity of the grid. In the past,
20	when devices were largely electro-mechanical, those security needs were
21	primarily focused on preventing physical tampering and ensuring public safety.
22	Today, when an advanced technological device is placed into service that need
23	for protection goes beyond the physical, the company must now also prepare
24	for cyber threats. Cyber threats are very real, and when they happen can be
25	impactful and expensive. There is as much innovation and improvement going

1	on in that arena as there is in the improvement of the technologies' actual
2	purpose. As these threats gain sophistication, they can drastically affect the
3	useful life of an investment. These threats may in some cases force the
4	Company to modify or replace devices or systems prematurely when threats or
5	methods unknown in the industry at installation emerge. Increased frequency
6	of changes to address these threats are expected as indicated by the February
7	2024 testimony by the FBI and CISA (Critical Infrastructure Security Agency)
8	to Congress ⁹ on the active attacks by foreign nation states on domestic critical
9	infrastructure.

10 Industry Advances: Many of this industry's traditional suppliers understand • 11 utility investment cycles and design products with those long replacement 12 Technology investments are very different in that the cycles in mind. 13 components, standards, devices, and methods cross multiple industries, 14 minimizing the chance of supplier partners slowing the pace of their innovation 15 or product improvements. This difference often directly impacts how often the company replans investments, as newer versions and capabilities overtake 16 deployed solutions and require investment to keep pace. 17

18

19These factors underscore the necessity for the Company to consistently review and20adapt existing plans, occasionally expanding the scope of an investment shortly21after, or even during, a technology deployment.

22

⁹ Testimony of Dr. Charles Clancy available at <u>https://www.congress.gov/118/meeting/house/116802/witnesses/HHRG-118-HM08-Wstate-ClancyC-</u>

^{20240206.}pdf, accessed February 22, 2024

Line	
No.	

1	Q130.	How do the inherent differences in technology life cycles impact the timing of
2		design requirements in a technology deployment?
3	A130.	The inherent differences in technology life cycles can influence the timing of design
4		requirements in a technology deployment by necessitating adjustments to align with
5		evolving technology advancements and industry standards. Unlike standard capital
6		investments with relatively stable design parameters, technology life cycles
7		demand a heightened responsiveness to changing industry landscapes. This
8		dynamic environment impacts the need for updates, adaptations, and new features.
9		With solid practices and process and an agile and iterative approach to design, the
10		Company ensures that technology remains effective and aligned with current
11		standards throughout its deployment.
12		
13	Q131.	Does the Company ever change scope of OT projects in order to capture
14		additional benefits?
15	A131.	Yes. While the above questions pertain to all of OT planning, there are two specific
16		areas contained in this testimony where scope was changed to achieve additional
17		benefits. They are discussed below in Other Modernize Grid Management and
18 19		Customer Power Status Visibility Project.
20	Q132.	What are the major categories of Operational Technology investments?
21	A132.	OT investments are aligned to five major categories:
22		Grid Management
23		Distribution Planning
24		Work Management & Scheduling
25		Asset Management

Line <u>No.</u>		
1 2		Mobile Technology
3	G.	<u>Grid Management</u>
4	Q133.	What is Grid Management?
5	A133.	Grid Management is a category of investments that enable the Company to monitor,
6		control and optimize the operation of Grid Automation investments. These projects
7		include the full suite of ADMS distribution management applications, including
8		outage response, fault location, isolation, and service restoration (FLISR), and
9		advanced control toolsets. Investments in this category enable distribution
10		operators to model the real-time state of the electrical system and manage the entire
11		distribution network. This includes systems that monitor and control the power
12		system, manage planned and unplanned outages, and analyze and optimize the
13		quality and reliability of the network. These investments also include the platforms
14		that will enable the management of Distributed Energy Resources (DER) such as
15 16		the DERMS (Distributed Energy Resource Management System).
17	Q134.	What are the key drivers for the Grid Management investments?
18	A134.	The key drivers for the Company's grid management investment include the need
19		for:
20		• Cybersecurity: Investing in cybersecurity measures to protect against potential
21		threats to the grid's infrastructure.
22		• Electrification: Supporting the growth of electric vehicles and other electrified
23		technologies, which drives changes in grid capacity and management.
24		• Demand Response: Implementing strategies to match electricity consumption
25		with supply to optimize grid performance.

Line <u>No.</u>	
1	• Renewable Integration: Adapting the grid to incorporate renewable energy
2	sources and manage their grid impacts and intermittent nature.
3	• Reliability and Resiliency: Ensuring both a stable and reliable power supply to
4	meet increasing demand and reduce outages, while enhancing the grids' ability
5	to withstand and recover from disruptions or cyber-attacks.
6	Collectively these key drivers create the need for grid management solutions.
7	
8	Q135. Where are the capital investment details of the projects and programs in the
9	Grid Management category?
10	
	A135. Capital investment details of these projects and programs in this category of the
11	instant case can be found in:
11 12	 A135. Capital investment details of these projects and programs in this category of the instant case can be found in: Exhibit A-12, Schedule B5.4, page 17-18
11 12 13	 A135. Capital investment details of these projects and programs in this category of the instant case can be found in: Exhibit A-12, Schedule B5.4, page 17-18 Exhibit A-23, Schedule M7

1

	or a manageme		
Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
SOC: ESOC	p. 17, line 4	pp. 189-192	pp. 145-150
SOC: ASOC	p. 17, line 5	pp. 185-188	pp. 145-150
ADMS: DMS/OMS	p. 17, line 3	pp. 8-11	pp. 145-150
Other Modernize Grid Management	p. 18, line 40	pp. 164-168	pp. 145-150
ADMS Enhancements	p. 18, line 32	pp. 4-7	pp. 145-150
Operational Technology and EFC	p. 18, line 33	pp. 158-163	pp. 145-150
Customer Power Status Visibility	p. 17, line 18	pp. 29-33	pp. 145-150
AMI: Meter Communications Upgrade	p. 17, line 17	рр. 17-20	pp. 145-150
Microwave End of Life	p. 18, line 39	pp. 104-107	pp. 145-150
FLISR Implementation	p. 18, line 35	рр. 70-73	pp. 145-150
DERMS	p. 18, line 36	pp. 42-45	pp. 145-150, 241-242
Substation Cybersecurity	p. 18, line 37	pp. 193-196	pp. 148, 243
Automation Configuration and Test Record Database	p. 18, line 38	pp. 25-28	pp. 148-149, 243
Meter Improvements	p. 18, line 34	pp. 100-103	pp. 145-150

Table 5 Grid Management Exhibit Locations

2

3 System Operations Center (SOC) and Alternative System Operations Center

4 (ASOC) Projects

5 Q136. What is the SOC Modernization Project?

A136. The SOC Modernization project replaced the Company's previous outdated
primary SOC and the smaller, outdated backup SOC by constructing two facilities
designed using current security, resiliency, and operability standards. The two new
facilities are called the Electric System Operations Center (ESOC), which was
essentially completed and fully occupied as of February 2022, and the Alternate

1

2

System Operations Center (ASOC) which certification will be complete in third quarter 2024. The previous SOC and backup SOC had significant limitations, which I will describe later in my testimony.

4

3

5 Q137. What are the essential functions of a SOC?

6 A137. The SOC is the most critical facility in Distribution Operations. Personnel in the 7 SOC operate the subtransmission and distribution system in southeast Michigan, 8 and additionally support generation operations. SOC System Supervisors are the 9 ultimate authority for the DTE electrical system operation with the goal of 10 maintaining safety of the field personnel and public, reliability of the electrical grid 11 and the continuity of service to the customers. They monitor system conditions 12 including alarms, and direct field personnel to safely operate electrical equipment 13 for routine switching needed for maintenance, other planned activities, and for 14 outage restoration. The SOC also coordinates with Electric Dispatch personnel to 15 ensure appropriate crews are assigned to address system issues.

16

17 As a NERC registered Generator Operator (GOP) and Local Balancing Authority 18 (LBA) the ESOC employees are also required to maintain the reliability and safety 19 of the Bulk Electric System (BES) through coordination with the DTE Merchant 20 Operations Center (MOC), and the Transmission Operator (ITC). Certified NERC 21 operators in ESOC work closely with MISO, MOC, and the ITC to ensure system 22 generation and load levels are kept in balance along with ensuring customer 23 utilization voltage levels are maintained to prevent damage to customers 24 equipment, ensure their critical processes operate as needed, and maintaining 25 customer satisfaction with reliable power.

Line	
No	

Q138. Why was the SOC Modernization project needed to replace the previous SOC facility?

3 A138. The former SOC had several critical limitations, which DTE Electric identified 4 through extensive benchmarking at the inception of this project. These critical 5 limitations included DTE Electric's outdated facility with physical, manual 6 visualization methods, end of life legacy technology that was no longer receiving 7 necessary support and updates, space limitations to support future growth for 8 critical reliability functions and limited visibility into the performance of 9 supporting telecommunication infrastructure. The transformation from a manual 10 state to a modern automated approach was imperative to address these challenges 11 effectively.

12

13 Q139. What is the status of ESOC?

14 A139. ESOC integration has been successfully completed and integrated into full15 operations.

16

17 Q140. What is the ASOC?

A140. The ASOC will be the NERC required alternate backup redundant control center to
 the ESOC. Located inside the recently constructed Waterford Service Center it is
 comprised of approximately 16,300 square feet with back-up generation and double
 redundancy for wireless and internet capabilities. Construction on the Waterford
 Service Center in Waterford, Michigan, began in November 2022.

23

24 This facility will include electronic displays and software/hardware that meet 25 dispatcher and operator needs and mimic the current ESOC standards. This will

Line	
<u>No.</u>	

1		allow for a fully functioning, alternate location to carry-on the activities of the
2		current Headquarters ESOC seamlessly, in the event of an emergency, as well as
3		provide for the future training/re-training and testing of Electric System Operation
4		Center employees.
5		
6	Q141.	With the completion of the new ESOC, is a new backup facility (ASOC) still
7		needed?
8	A141.	Yes. Without an alternate facility available in the event of a disruption at ESOC,
9		recovering from a storm or other disaster would be extraordinarily challenging, and
10		delay restoration. The reasons for building a new modernized backup facility have
11		not changed since the Commission originally approved building a new ASOC in
12		Case No. U-20561. Given the critical nature of the ESOC in operating the electric
13		infrastructure, under any emergency conditions, a backup facility is required in the
14		event the primary facility is inoperable. While the Company does utilize the current
15		backup SOC on occasion, the facility is inadequate for sustained operations, and
16		for disaster recovery efforts.
17		
18	Q142.	Has the MPSC ruled on the costs for the ASOC?
19	A142.	Yes. On Page 119 of the December 1, 2023 Order in Case No. U-21297 the MPSC
20		stated that "the Commission finds that the proposed ASOC spending is reasonable
21		and prudent," and the amount requested by the Company was approved.
22		
23	Q143.	What is the status of the ASOC project?
24	A143.	The construction portion of the ASOC buildout was completed in December of
25		2023, and completion of the technology build out of the space and interior
		SMH-99

Line No. construction will continue into the 2nd quarter of 2024. The ASOC is expected to 1 achieve full NERC certification in 3rd quarter of 2024. 2 3 4 Q144. How will customers benefit from the total SOC Modernization project? 5 A144. Customers will benefit from the SOC Modernization project's two facilities (ESOC 6 and ASOC) due to the improved communication paths between the resources that 7 will be co-located in the new facilities. This will provide quicker and improved 8 coordination to create and implement restoration strategies more effectively. In 9 addition, customers will benefit from reduced risk of disruption in operations 10 during outage events, and faster restoration times regardless of the facility from which the System Operations organization operates from. The ability to understand 11 12 system conditions, and dispatch resources to address issues, will be greatly 13 enhanced by the technology available in the new facilities and the co-location of 14 the System Operators, Power Dispatchers, and support personnel. In addition, 15 ESOC is more resilient and hardened to withstand adverse natural and man-made 16 disasters, allowing electric grid operations to recover much more quickly in the 17 event of a major catastrophe. These benefits have already started to materialize due 18 to the utilization of the ESOC and will be fully realized once the ASOC is complete.

19

20 Advanced Distribution Management System (ADMS) Distribution Management

21 System (DMS)/Outage Management System (OMS)

22 Q145. What is ADMS DMS/OMS?

A145. The Advanced Distribution Management System (ADMS) is a modern operating
 technology platform that is essential to the Company's grid modernization efforts
 which improves system reliability and operational efficiency. These software

Line
No.

1 solutions are used to monitor, control, and optimize the distribution of electricity in 2 real-time. ADMS combines Distribution Management System (DMS) and Outage 3 Management System (OMS) functionalities to enhance the overall management of 4 power distribution networks. The series of systems that comprise the ADMS 5 platform represents a significant advance in the Company's situational awareness 6 of grid condition, coordination of system operators and field personnel, and control 7 of grid assets. It provides a consistent integrated view of the system to all organizations, supports faster restoration times, and allows for improved 8 9 monitoring and control of the distribution system.

10

11 DMS is the Distribution Management System, which provides a complete network 12 model of the electrical system for operators to view operating conditions in real 13 time. DMS consists of multiple applications such as the Network Model (eMap), Distribution Power Flow (DPF), Distribution State Estimation (DSE), and 14 15 applications with more advanced functionality such as Fault Location, Isolation, 16 and Service Restoration (FLISR), Volt/Var Control (VVC), Conservation Voltage 17 Reduction (CVR), Feeder Reconfiguration (FR), and electronic Switch Order 18 Management (SOM).

19

20 OMS is the Outage Management System, which aggregates emergent trouble 21 information reported by customers and AMI meters and allows system operators 22 and dispatchers to prioritize response and properly assign crews for repairs, 23 enhancing their ability to manage and minimize disruptions in service for 24 customers.

25

Line	
<u>No.</u>	

10.		
1	Q146.	Has the MPSC ruled on ADMS: DMS/OMS?
2	A146.	Yes, on page 114 of its Order dated December 1, 2023 in Case No. U-21297, the
3		Commission approved DTE Electric's requested expenditure for this component of
4		ADMS, agreeing that outage restoration response is a critical area stating that, "the
5		company took reasonable steps to address the problems with the DMS/OMS in light
6		of the available options and approves DTE Electric's requested expenditure for
7		inclusion in rate base."
8		
9	Q147.	What was the scope of work completed in 2023 for ADMS: DMS/OMS?
10	A147.	DMS and OMS went live in February of 2023. Prior to go-live, the Company ran
11		parallel operations for OMS where a subset of operations users used the new tool
12		in parallel with the old tool to prepare for go-live. After go-live the Company
13		moved into the hypercare phase of the project. Hypercare was an intense and
14		focused phase of support and monitoring that immediately followed go-live. It
15		involved round-the-clock support for system operations and field personnel as they
16		became accustomed to operating the new systems. Additionally, EMS (Energy
17		Management System), which is a software solution that allows for monitoring,
18		control, and optimization of energy generation transmission, was upgraded at that
19		same time to bring the existing EMS to a compatible version with OMS and DMS.
20		
21	Q148.	Given that DMS has gone live with OMS, have all DMS applications been
22		operationalized?
23	A148.	No. Although all DMS applications were deployed in February 2023, the Company
24		will continue to build upon this foundation by implementing additional modules
25		and enhancements throughout 2023 and beyond. At go-live, the eMap application

Line	
No	

1	and SCADA integration with OMS immediately enabled more accurate and timely
2	outage event creation and situational awareness. Additional benefits will be
3	realized as the Network Model is tuned and penetration of SCADA devices in the
4	distribution grid increases. The investment to enable these remaining applications
5	over the next 3-5 years is found in the ADMS Enhancements and FLISR
6	Implementation line items in Exhibit A-12, Schedule B5.4, p.18, lines 32 and 35.
7	More information on those applications and benefits can be found later in the
8	ADMS Enhancements and FLISR Implementation sections of my testimony.

9

10 Other Modernize Grid Management

11 Q149. What is Other Modernize Grid Management?

12 A149. Other Modernize Grid Management is a category of investments that encompass a 13 diverse set of projects designed to enhance the Company's operational capabilities, 14 particularly during high-volume outage events, those that impact hundreds or 15 thousands of customers. From software improvements to licensing acquisitions, 16 each investment contributes uniquely to bolstering efficiency and resilience in the 17 Company's technology landscape.

18

19 Q150. Were there any changes in this category of investment in 2023?

A150. Yes. The Company's achievement on February 6, 2023, with the launch of the
 comprehensive ADMS grid management set of tools marked a significant
 milestone. During the subsequent catastrophic ice storm, the Company leveraged
 the newly implemented system's breakthrough capabilities. Swiftly learning from
 this experience, the Company promptly initiated targeted projects to improve storm
 restoration and customer communications, integrating the lessons learned with the

<u>No.</u>	
1	enhanced capabilities of the ADMS grid management tools. Early results showed
2	the initiatives implemented resulted in immediate improvements to:
3	• Outage analysis processing, enabling faster event creation and initiating the
4	restoration process for customers sooner.
5	• Momentary outage processing by improving the interfaces between ADMS
6	and our AMI network.
7	• Faster outage restoration by leveraging improvements to bulk event
8	updating and bulk crew assignment creation.
9	This highlights the system's adaptive response and its crucial role in optimizing
10	storm resilience efforts.
11	
12	Q151. What are the key investments in this category?
13	A151. The key investments in this category are:
14	OSI Licensing
15	• Qlik 3-year license purchase
16	• CT/VT High voltage, and test accuracy console
17	EFC Communications
18	• Purchase of backhaul capable field area routers
19	Pre-Storm ADMS Enhancements
20	Post-Storm ADMS Enhancements
21	
22	Q152. Which projects in this category were initiated in 2023 to enhance storm
23	restoration and communication efforts?
24	A152. The following projects were initiated to support storm restoration and customer
25	communication efforts:

Line

<u>No.</u>	
1	Pre-Storm ADMS Enhancements
2	Post-Storm ADMS Enhancements
3	EFC Communications
4	
5	Q153. What was the timing of the investment in these projects that were initiated to
6	enhance storm restoration and communication efforts?
7	A153. These projects were swiftly initiated in 2023 in response to the severe storms and
8	new ADMS enabled technology to make improvements. These projects, crucial to
9	supporting storm restoration and communication, will continue in 2024 and
10	beyond. Future investments into these projects are listed in separate line items in
11	Exhibit A-12, Schedule B.5.4 as detailed in Table 6.

12 13

Line

 Table 6
 Future Investment Mapping of Storm Restoration Projects

Projects Initiated in 2023	2023 Investment Exhibit A-12, Schedule B5.4 Location	Future Investment Exhibit A-12, Schedule B5.4 Location
EFC Communications	Line 40	Line 33
Pre-storm ADMS Enhancements	Line 40	Line 32
Post-Storm ADMS Enhancements	Line 40	Line 32

14

15 Q154. Are any of the Other Grid Modernization projects discussed in other company

16 witness testimony?

A154. Yes, the Error Free Communication (EFC) project is an Other Grid Modernization
project which is discussed in Part Six of Witness Hatsios' testimony. My testimony
will describe Other Modernize Grid Management excluding EFC. The table below
describes the breakout of Other Modernize Grid Management.

21

Line	
<u>No.</u>	

1		Table 7Other Mod	ernize Grid N	Aanagement	by Year (\$00)0)
		Project	2022	2023	2024	2025
	Ma	Other Modernize Grid anagement excluding EFC	3,660	24,430	2,200	2,500
		EFC	4,140	1,970	0	0
r		Total	7,800	26,400	2,200	2,500
2	0155.	What is the OSI license inv	estment?			
4	A155.	The OSI license investment	refers to a fi	nancially pru	dent investm	ent as part of
5		Other Modernize Grid Mana	gement. Spec	ifically, it ent	ailed the acqu	isition of five
6		vear on-premise licenses for	the Company	's Outage Mar	nagement Svs	tem which is
7	mission aritical activities					
, 0		mission-entical software.				
0	015(W/h = 4 = = 4h = h = =			• • •	49
9	Q156.	what are the key drivers a	nd benefits o	t the USI lice	ense investmo	ent?
10	A156.	This investment was an op	portunity to p	ourchase licer	ises on a 5-y	ear term that
11		would reduce the cost of the	se licenses by	~\$1 million	over that dura	tion and shift
12		the warranty period to cover	that entire ter	m. This chan	ge will allow	the Company
13		to save money and accuratel	y project costs	s and ensure c	contractual ser	vice levels.
14		The savings realized in this	area will rec	duce the over	all investmer	nt need. The
15		enhanced warranty terms with	l benefit the C	Company's en	nployees direc	etly due to the
16		increased support priority	the agreeme	ent brings, a	nd therefore	support the
17		Company's customers.				
18						
19	Q157.	What factors drove the tim	ing of the OS	SI license inv	estment?	
20	A157.	This investment was undertain	ken now as the	e term of the c	urrent license	and warranty
21		period was due to lapse in the	ne 2023 calend	dar year, allo	wing immedia	ate savings to
22		begin.				

<u>.</u>		
1	Q158.	What is the Qlik software license investment?
2	A158.	The Qlik investment refers to a financially prudent investment as part of Other Grid
3		Modernization. Specifically, it entailed the acquisition of a three-year license for
4		the Qlik software, as the license was due to expire.
5		
6	Q159.	What are the key drivers of the Qlik license investment?
7	A159.	The license, which was set to expire in September 2023, is crucial for the
8		functionality of all applications utilizing OMS data through the enterprise data
9		repository. Failure to renew this license would have resulted in our inability to use
10		this important asset after September 2023. This would have directly impacted field
11		efficiency, in the ability to receive updates from field resources (e.g., Outage Status
12		Application) that is used to status work/crew assignments, add comments, upload
13		pictures, update cause codes and estimated restoration times, etc.
14		
15	Q160.	What are the benefits of the Qlik license investment?
16	A160.	This nearly instantaneous data source empowers applications and reports to
17		aggregate and visualize OMS information. These reports and applications are used
18		during outage restoration processes, analyzing hazard events, and proactively
19		notifying field resources when critical events (large outages, hazards, etc.) occur on
20		the system. This, in turn, enhances restoration processes and facilitates quicker
21		outage restoration for customers.
22		

Q161. What is the Current Transformer/Voltage Transformer (CT/VT) High Voltage Test Console project?

SMH-107

Line <u>No.</u>

Line <u>No.</u>		
1	A161.	The Current and Voltage Transformer (CT/VT) Test Console is an end-of-life
2		equipment replacement project. This system is used to perform accuracy &
3		dielectric testing on medium voltage transformers.
4		
5	Q162.	What is the key driver of the CT/VT High Voltage Test Console project?
6	A162.	The existing system is well beyond end-of-life rendering it virtually non-
7		serviceable and unable to be restored in the event of a failure. This type of system
8		is required to maintain the capability to calibrate and certify these transformers.
9		
10	Q163.	What are the benefits of the CT/VT High Voltage Test Console project?
11	A163.	When implemented in 2024, this test system will provide capability to maintain
12		billing accuracy compliance required by the MPSC. Furthermore, the system will
13		enable testing of High Accuracy instrument transformers that the current system
14		cannot support. High Accuracy transformers for metering applications have gained
15		momentum as the manufacturing standard for revenue protection and regulatory
16		compliance. This project removes the risk of losing the capability to perform a
17		required function due to equipment failure.
18		
19	Q164.	Why is it important to undertake this project now?
20	A164.	The existing system is not maintainable because many components and servicing
21		options are no longer available.
22		
23	Q165.	What are the pre-storm season and post-storm season ADMS Enhancements?
24	A165.	The pre-storm season and post-storm season ADMS enhancements are integral
25		components of a broader ADMS enhancement plan that is discussed later in my

Line	
<u>No.</u>	

1	1	testimony. They were strategically accelerated and scoped collectively, comprising
2	:	a sequence of targeted upgrades and projects designed to enhance the Company's
3	\$	storm restoration response. These enhancements included direct upgrades to the
4	1	ADMS applications, as well as upgrades targeting interfaces (e.g., AMI pre-
5	1	processing), reporting applications (e.g., System Outage Screen), and more.
6		
7	-	These enhancements align with the Company's commitment to storm preparedness
8	8	and improving the response to severe weather events. The investments made before
9	8	and after the 2023 storm season focused on improving response times, which
10	i	includes quicker identification of outages (improvements to outage analysis,
11	1	processing for momentary outages, event grouping, AMI/SCADA data processing)
12	8	and faster outage restoration (bulk event updating, bulk crew assignment creation,
13	1	reducing "okay on arrivals" to improve dispatching efficiency).
14		
15	Q166.	What is the key driver of these Pre-Storm and Post-Storm season ADMS
16]	Enhancements?
17	A166. 7	The key driver of these ADMS enhancements was to further develop the storm
18	1	response and communication capabilities of the current ADMS platform to meet
19	(changing needs and customer expectations. The series of severe weather events
20	1	that occurred in parallel with the ADMS hypercare period highlighted that the
21	(Company needed to prioritize how outages were predicted, analyzed, and grouped
22	t	for enhancement. The resulting changes better aligned the technology to show value
23	ä	and included considerable improvements as described later in my testimony.
24		

25 Q167. What is the scope of work completed in 2023?

Line	
No.	

1	A167. After go live in February 2023 and working with the new ADMS system through 2
2	storms, including the historic CAT storm, the Company identified program
3	enhancements that would support even greater improvements in storm response.
4	Throughout 2023 there were a series of targeted enhancements made to ADMS to
5	drive improvements in safety, system reliability, usability, and restoration timing.
6	
7	The scope of work completed is detailed below:
8	• Safety check feature – This enhancement mimics the safety check performed
9	by a field crew before the crew closes an open switch between two circuits.
10	Having this feature allows ADMS users (primarily system supervisors
11	coordinating switching with field crews) to know if that safety check will pass
12	or fail before putting a field crew in a position to have to perform that test.
13	• Enhanced outage prediction engine - This improvement to outage event/device
14	prediction increased the prediction accuracy for larger, multi-circuit outages in
15	the higher voltage network (stations, substations, subtransmission, etc.). This
16	enhancement resulted in a reduced number of events that must be managed, and
17	increased precision in communication.
18	• Outage analysis processing – These enhancements decreased the time it takes
19	for AMI notifications and customer calls to be analyzed and associated to an
20	event and device location, which reduces the time it takes to create a multiple
21	customer outage event and dispatch a crew.
22	• Momentary outages detected by SCADA devices - This improvement in
23	processing prevented sustained outage events from being created when
24	customers have already been restored. This reduces crews from being

Line	
No.	

1dispatched to outage events that are already restored and focuses their time on2sites needing restoration.

3 Event grouping - These enhancements reduce the time needed for dispatchers • 4 to analyze events before dispatching a crew, reducing overall restoration times. 5 Wiredown grouping - This new functionality enables better insight into 6 wiredown occurrences so that the right crews can be dispatched to the correct 7 places for quicker restoration, thereby increasing public safety and reducing 8 OK on Arrivals (crews sent to locations without active outages). For example, 9 this feature enables dispatchers to group geographically located wiredowns to 10 send the appropriate number of crews to restore an area rather than looking each wiredown as an isolated event. 11

- Outage analysis performance These improvements directly impact how
 quickly customers are associated to an outage event and their capability to
 receive updates for their outages, as well as how quickly their outage can begin
 the restoration process.
- User interface improvements in new grid framework These improvements
 allowed ADMS users to filter/group/sort events and crew assignments more
 efficiently. This reduces the time needed to analyze a large volume of
 events/crew assignments in the system and time needed to dispatch the required
 crews for an event.
- Switch Order Management (SOM) With the completion of the transition
 period for the first phase of SOM on the ADMS platform, system operators
 within the Company's control room were able to begin using ADMS integrated
 with the work management system (Maximo). This enabled the creation,

Line

No.

2

1

management, and completion of certain types of equipment shutdown coordination of the corresponding field work.

3

4 Q168. What are the benefits of Pre-Storm and Post-Storm ADMS Enhancements?

5 A168. These enhancements offer many benefits to the Company's customers, crews and 6 overall operations, most notably in the areas of safety, system reliability, usability, 7 and restoration. These enhancements have made the system more versatile and 8 capable of meeting evolving customer needs and have streamlined processes and 9 improved the overall efficiency of the system. By adding advanced features to 10 existing capabilities, the Company has increased safety for customers and crews, built additional system reliability by removing risk for human error, and increased 11 12 usability to move quicker to get crews dispatched timely and accurately which 13 improves restoration timing while providing customers with more accurate 14 restoration times.

15

16 **ADMS Enhancement**

17 Q169. What are ADMS Enhancements?

18 A169. As discussed in the ADMS section of my testimony, although all DMS applications 19 were deployed in February 2023, the Company will continue to build upon this 20 foundation by implementing additional modules and enhancements throughout 21 2023 and beyond. The investments in this category include operationalizing the 22 additional modules of the ADMS to extract the full benefits of the ADMS. 23 Additionally, as stated in the Other Grid Modernization section of testimony, the 24 Company is leveraging the newly implemented ADMS systems breakthrough 25 capabilities to improve storm restoration and customer communication. Initiated

<u>No.</u>	
1	in 2023 after the catastrophic ice storm, these investments were expedited from the
2	overarching ADMS enhancement plan to promptly deliver value to customers. The
3	Company remains committed to sustaining and furthering these investments.
4	
5	Q170. What are the key drivers of the ADMS Enhancements?
6	A170. The ADMS Enhancements are necessary to ensure that the Company
7	operationalizes all the ADMS applications as planned to realize the full benefits of
8	ADMS. Additionally, ADMS enhancements are necessary to keep up with the
9	evolving needs and challenges of the modern electrical grid, as well as regulatory
10	requirements and enhancements to strengthen cybersecurity measures to protect
11	against potential vulnerabilities.
12	
	0171 What is the scope of work planned for ADMS Ephancements in 2024 and
13	Q171. What is the scope of work planned for ADMS Enhancements in 2024 and
13 14	2025?
13 14 15	2025?A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM
13 14 15 16	2025?A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality:
13 14 15 16 17	 Q171. What is the scope of work plained for ADIVIS Eliharcements in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application
13 14 15 16 17 18	 Q171: What is the scope of work plained for ADMS Elihatechienens in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology,
13 14 15 16 17 18 19	 Q171. What is the scope of work plained for Abids Emilateentents in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system
 13 14 15 16 17 18 19 20 	 Q171. What is the scope of work planned for ADMS Emhancements in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system are being exposed. These changes will allow the Company to quickly
 13 14 15 16 17 18 19 20 21 	 Q171. What is the scope of work planned for ADMS Emhancements in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system are being exposed. These changes will allow the Company to quickly leverage the full capability of ADMS. The eMap is the intersection and
 13 14 15 16 17 18 19 20 21 22 	 Q171. What is the scope of work planned for ADMS Emhancements in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system are being exposed. These changes will allow the Company to quickly leverage the full capability of ADMS. The eMap is the intersection and operational interconnection of the as-operated state of the electric grid and
 13 14 15 16 17 18 19 20 21 22 23 	 Q171. What is the scope of work planted for ADMS Elimatechnetics in 2024 and 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system are being exposed. These changes will allow the Company to quickly leverage the full capability of ADMS. The eMap is the intersection and operational interconnection of the as-operated state of the electric grid and advanced engineering data. This combination provides the Company the
 13 14 15 16 17 18 19 20 21 22 23 24 	 2025? A171. The scope of work in 2024 and 2025 is focused on the eMap application, SOM phase 2, SOM phase 3, and added AMI functionality: eMap application As the Company continues to operate and integrate this new technology, areas of opportunity to further enhance data and refine usage of this system are being exposed. These changes will allow the Company to quickly leverage the full capability of ADMS. The eMap is the intersection and operational interconnection of the as-operated state of the electric grid and advanced engineering data. This combination provides the Company the capability to enable novel applications, such as FLISR, which is an

Line
Line <u>No.</u>	
1	• Switch Order Management (SOM) phase 2
2	• SOM phase 1 was implemented in 2023 SOM phase 2 includes enabling
3	and activating switching and tagging, which directly relates to hazardous
4	energy control and is one of the key Safety and effectiveness components
5	of the ADMS vision. Phase 2 of the SOM implementation will permit DTEE
6	ADMS users to create switching steps and execute orders related to those
7	steps within the ADMS platform. Utilizing this capability in the tightly
8	integrated ADMS platform means that users may be able to automatically
9	model the state of the electric system on the ADMS eMap while performing
10	work related to switching and tagging.
11	• SOM Phase 3
12	\circ SOM phase 3 rounds out the utilization of the SOM application by focusing
13	on the tagging aspect of switching and tagging. Fully integrating switching
14	and tagging throughout DTE applications means that all switching and
15	tagging must be electronic. SOM Phase 3 completes the transformation of
16	switching and tagging into a fully electronic process by focusing on a digital
17	version of red tag records. Red tag records are the way in which hazardous
18	energy controls are documented. DTEE anticipates that this technology
19	advancement will lead to additional business integrations and process
20	improvements that will benefit the customer through an added layer of
21	safety checks and efficiency-related opportunities.
22	AMI Functionality
23	\circ To further improve outage prediction and restoration additional AMI
24	functionality will be incorporated with ADMS. This includes further

integration of AMI voltage read data for energization/restoration

25

Line <u>No.</u>		
1	verification, visualization of voltage data, and aggregation/visibility	y on
2	multiple customer outage events.	
3		
4	Q172. What are the benefits of the ADMS Enhancements?	
5	A172. The eMap plays a crucial role in managing energy operations efficiently	and
6	ensuring reliability and stability of the power grid. Enhancements to the eMap	o are
7	necessary and foundational to unlock advanced functionality in OMS, DMS,	and
8	SOM applications. For example, FLISR, an advanced application within DM	S, is
9	dependent on the eMap enhancement work in order to be enabled. This w	vork
10	benefits customers through improved restoration efforts.	
11		
12	Operational Technology and Error Free Communication (EFC)	
13	Q173. What is the Operational Technology and EFC investment ?	
14	A173. The Operational Technology (OT) and EFC investment is a collection of rel	ated
15	investments that is sub-divided into two complimentary categories: OT investm	ents
16	and EFC investments. The OT investments support the operational activ	ities
17	required to ensure customer commitments, such as restoration times, are	met.
18	Whereas the EFC investments are focused on communicating with the custome	er on
19	those operational efforts. These EFC investments are aimed at resol	ving
20	communication challenges that lead to customer dissatisfaction.	
21		
22	The OT and EFC investments have resulted in, and continue to add	ress,
23	opportunities to accurately provide single estimates to customers and de	liver
24	effective communications to customers about the status of their restoration.	The

Line <u>No.</u>	
1	investments strategically align at various junctures ensuring a cohesive and fully
2	coordinated set of effective communications for customers.
3	
4	Q174. Is this project also discussed in another Company witness's testimony?
5	A174. Yes, the project has two separate but related parts. The EFC portion of this project
6	is supported by Company Witness Hatsios. My testimony will describe the OT
7	portion. Table 8 below describes the breakout between OT and EFC.
8	

Table 8OT and EFC Project/Projects by Year (\$000)

Project	2022	2023	2024	2025
OT	1,254	84	2,400	800
EFC	4,242	52	3,200	600
Total	5,496	136	5,600	1,400

10

11 Q175. What work was completed in 2022 and 2023 for the OT investments?

A175. In 2022 and 2023 the OT investments were focused on the following projects: Type
 2 Customer Communication & Processes; Outage Status App Updates and Security
 Upgrades; and the Pentos PPE Dashboard.

15

16 The Type 2 Customer Communication & Process project implemented three 17 enhancements to improve the Type 2 damage claims process:

- Introduced new notifications to enhance communication regarding claim
 status.
- Implemented functionality to offer comprehensive status categories,
 involve key stakeholders, and transition Smartsheet functionality into SAP
 for improved user experience.

2

3

4

5

6

 Automated the Damage Claims Type 2 process for Electric and Gas customers from initiation to resolution. The primary goal is to minimize customer communication challenges related to their damage claims that often result in MPSC complaints, and to enhance communication and resolution timeliness for customers.

7 The Outage Status App Updates and Security Upgrades project developed a revised 8 security framework for authorizing access to non-badged contractor crews through 9 the Outage Status app. Prior to this project, contractor crews were required to be 10 badged to have access to the Outage Status app, which is a tool utilized to perform their job duties. Being a badged contractor also allowed the contractor crews access 11 12 to other Company information. The Company identified the need to restrict certain 13 contract workers to updating the Outage Status app exclusively, therefore removing 14 their access to other Company information. This required a new security 15 configuration to allow non-badged contract crews access to the Outage Status app.

16

The Pentos PPE Dashboard project included the development of an employee tile in SAP to centralize and provide access to Personal Protective Equipment (PPE) information for Supply Chain, the Glove Lab, Supervision, and front-line employees. This dashboard was integrated into SAP Success Factors Tile for a unified platform managing all employees' equipment. Additionally, the project also included the implementation of self-service equipment ordering (e.g., PPE, rubber gloves, sleeves, calibration equipment) for both employees and admins.

24

Line

<u>No.</u>

1 2

3

These initiatives collectively contribute to enhancing operational efficiency, communication, and resource management within the OT space.

4 Q176. What is the scope of work in 2024 and 2025 for Operational Technology?

5 A176. In 2024 and 2025, specific investments are planned in the areas of Data Analytics 6 and Data Engineering, Damage Assessment, DO RCO Enhancement GPS 7 Productivity, and System Outage Screen (SOS) Hardening. As part of this work, 8 investments in technology for Artificial Intelligence (AI) and Machine Learning 9 (ML) will be included to enhance various aspects of operations. Specific examples 10 include optimizing grid management, predictive maintenance, and improving overall system efficiency. These initiatives focus on bringing automation, data 11 12 analytics, and intelligent decision-making into processes, contributing to increased 13 reliability, cost-effectiveness, and sustainability.

14

15 Data Analytics and Data Engineering for Outage Restoration is a comprehensive 16 initiative that leverages data science to improve the precision of outage restoration 17 time estimates and enhance customer communications. This project involves 18 substantial data engineering and data science efforts to ensure synchronization 19 across various platforms, including outage management systems, AMI, customer 20 services, and communications. The success of this project will be gauged by the 21 accuracy percentage of the first-time estimate time of restoration (ETR) 22 communicated to customers. Importantly, the metrics used to measure success will 23 differentiate between storm and non-storm scenarios, providing a more nuanced 24 understanding of our performance.

25

Line
No.

1	The Damage Assessment and Inspections Image Analytics project utilizes Artificial
2	Intelligence (AI) and Machine Learning (ML) for image analytics to support the
3	Damage Assessment process. This approach involves training models to identify
4	equipment conditions and assess the extent of damage using images sourced from
5	field personnel, damage assessors, or customers. This technology has the potential
6	to be applied to day-to-day inspections, digitizing processes, and reducing manual
7	work. By adopting image analytics, the utility aims to keep pace with peer utilities,
8	while simultaneously enhancing reliability and improving the customer experience.
9	
10	The DO RCO Enhancement GPS Productivity project is focused on upgrading the

current GPS dashboard to address issues such as data errors, manual refreshing, and the need for real-time reporting. By leveraging modern technology and cloud-based platforms, the project aims to reduce manual tasks and provide same-day, real-time metrics. These metrics include vehicle time to leave, time to the first job, and time returned to the service center. The goal of the refreshed dashboard is to eliminate gaps in data, offering a comprehensive view of service center time metrics on the same day.

18

Within the OT investment is the SOS Hardening project. This project is focused on implementing enhancements to strengthen the resilience of the ADMS System Outage Screen (SOS) and its related capabilities, which includes the ongoing migration of crucial Azure infrastructure that supports SOS reporting and notifications within DTE's Azure environment. In addition, support is being provided for integrating the SOS application with the Outage Status Application (OSA) to enhance the client's Damage Assessment capabilities. The SOS

1		application provides real-time visibility into customer outages, field crews,
2		schematic diagrams, and other vital information necessary for effective outage
3		management. The primary focus is on ensuring optimal performance, particularly
4		under high-volume conditions during critical storm events. This is to ensure swift
5		responses to customer outages before the upcoming summer storm season.
6		
7	<u>Custo</u>	<u>mer Power Status Visibility Project (CPSV)</u>
8	Q177.	What is the Customer Power Status Visibility (CPSV) Project?
9	A177.	CPSV represents the first in a series of planned projects whose objective is to begin
10		the transformation of the Company's Advanced Metering Infrastructure (AMI)
11		asset from a purely billing based design to a system capable of maintaining the
12		billing excellence while adding in changes aimed at fully supporting the outage
13		detection and response use case. This use case will materially improve the
14		Company's capabilities related to energization status, outage detection, outage
15		localization, outage response, customer communication and reduction of outage
16		restoration duration.
17		
18	Q178.	What were the Key drivers for AMI when originally installed, and does that
19		differ from CPSV?
20	A178.	The Company embarked upon its AMI journey in 2009, installing a substantial,
21		real-world pilot to demonstrate the ability to produce and deliver accurate customer
22		bills based upon usage collected remotely, accurately, and efficiently. The AMI
23		pilot and the resulting full-scale implementation of this technology, approved by
24		the Commission in multiple subsequent rate orders between 2009 and 2019,
25		resulted in the Company's ability to consistently gather usage data from ~ 2.3

Line <u>No.</u>

1		million residential electric meters and ~1.3 million residential gas meters. This
2		eliminated the need to send meter readers out to collect that information which has
3		alleviated personal safety concerns while reducing human error. While the
4		Company intends to continue using this technology to maintain the same level of
5		service for customers for this important set of billing benefits, this single primary
6		use case for AMI meters is no longer sufficient to meet the needs of customers,
7		communities, or the Company.
8		
9	Q179.	What are the key drivers of the CPSV project?
10	A179.	The primary value driven objective of the Company's CPSV investments is to
11		increase the volume of AMI outage and restoration messages received. The
12		Company uses this information to provide communications to customers about
13		outage occurrences, estimates of repair time, confirmation of outage status and in
14		some cases the detection of nested outages. The Company will also be able to
15		leverage the expanded set of AMI data to reduce cases of outage work remaining
16		open that have been restored.
17		
18		Storm events in 2023 highlighted a significant opportunity to improve the way the
19		Company interacts with customers during these most impactful service
20		interruptions. Customers expect that the Company knows before they do that their
21		power has been interrupted, that the Company communicates with them
22		appropriately, and that those communications are timely and accurate.
23		
24		Since the February 2023 implementation of ADMS, the Company now possesses
25		an OMS capable of leveraging information about a customer's power status,

Line
<u>No.</u>

1	surpassing the capabilities of the previous systems. The collection and
2	transportation of this data from the meter to the OMS requires a level of capability
3	and capacity from the AMI system that was not part of the original design
4	specification to which the system was constructed. With the OMS now in place,
5	and having had multiple storm events in 2023 that provided data for analysis, the
6	Company has closely examined the customer communication opportunities and
7	determined an initial set of improvements that are the basis for this project.
8	
9	Fundamentally, this project will enhance the existing AMI Network by identifying
10	locations that lack the capacity to transport the volume of data needed from meters
11	to the OMS system and adding additional network communication devices to those
12	locations. These additions will be added in a structured manner based upon the
13	number of customers served, reliability of the electric grid in that area, and
14	reliability of AMI network in that area. Additional considerations, such as the
15	communities served by that network segment, will be taken into account to ensure
16	the Company effectively supports its most vulnerable customers.
17	
18	This project will focus on maximizing the:
19	• Number of customers that are included in outage communications
20	• Accuracy of the first and subsequent estimate provided to customers
21	• Timeliness of delivering first estimates to customers
22	• Ability to predict customer outages where no direct information is available
23	Reduction of OK on arrivals
24	
25	Q180. What is the scope of work planned for 2024 and 2025?

- <u>.</u>
- A180. The CPSV Project will achieve its objectives through a combination of the
 following scope items:
- 3 Replacement of 3000 end-of-life Field Area Routers (FAR) that are no longer • 4 performing their intended function in all weather conditions, with up to date 5 and fully functional devices. This replacement will result in more meter alarms and voltage information reaching the AMI system for use by the Outage 6 7 Management System, Customer system, digital channels, and error free 8 communications infrastructure. These FARs will now have a direct connection 9 to the AMI system reducing the number of communications hops currently in 10 the system to zero.
- Installation of 500 additional FAR's to be placed in densely populated areas
 reducing the number of meters each FAR manages to minimize data loss from
 oversaturation.
- Installation of 22,000 cellular meters placed strategically at premises adjacent
 to automatically resetting distribution circuit breakers (known as Reclosers) to
 understand the energization status of that circuit segment without having a
 SCADA device installed at that location. This will allow system operations to
 more accurately model and isolate outages.
- Deployment of in premise or on meter communications devices in areas where
 mesh design or other factors make meter communications intermittent as a
 secondary way of understanding the power status at select premises
 (prioritization to schools and our most vulnerable customers).
- Deploy a suite of monitoring and visualization tools for real time information
 on all components of the AMI network for operational response.

<u>No.</u>	
1	• Design, staff, and deploy a permanent AMI Network Operations Center to
2	monitor the AMI communications network with rigor and operational
3	awareness at the same level the electric grid that it serves is monitored. This
4	staff will include dedicated headcount to perform this monitoring, dispatching
5	crews and the field crews themselves, all tasked to keep the AMI network
6	operational during all weather conditions.
7	
8	Q181. What are the benefits of the CPSV project?
9	A181. The CPSV Project will provide the following benefits by the end of the Phase 1
10	period ending in December 2024:
11	• Maximize the Number of Customers that are included in outage
12	communications. In 2023 the Company included ~60% of customers in
13	proactive customer communications. This is driven by the commitment to only
14	communicate with customers when there is certainty of up to date and accurate
15	information. If that information is uncertain then proactive communications are
16	not undertaken. When this project completes its Phase 1 objectives this
17	percentage will bring the overall percentage to ~72%, thus adding more than
18	250,000 customers that will now have the ability to receive proactive and
19	accurate communications from the Company.
20	• Maximize the accuracy of the first and all subsequent estimates provided to
21	customers. DTEE measures estimate accuracy for all customers that have
22	meters that successfully provided a Power Out Notification to the AMI system.

Line

With the planned network improvements that population will be increased by10-15%.

1

2

3

4

5

6

• Maximize the timeliness of delivering a first estimate to the customer. With more alarms and voltage information making it to the AMI system the Company will be able to more quickly isolate and assess damage locations and severity improving time to deliver the first estimate by 10% by the end of Phase 1 which will improve on our existing first estimate delivery commitment by between 30 and 45 minutes during major storm events.

7 Maximize the ability to predict customer outages where no direct information • 8 is available. There are some number of customers that experience an outage 9 and neither the AMI information nor a customer call is available. These 10 customers are identified by predicting their status based on information derived from information from their area and other confirmed outages. More available 11 12 information reduces the number of outages that must be predicted and increases 13 the accuracy of the OMS outage prediction engine. By the end of 2024, this project will increase the accuracy of these predictions by 10 - 15%. 14

15 Minimize the number of OK on Arrivals. Due to the nature of a large-scale • 16 event like a storm there are restoration jobs where a customers' power is 17 restored and the OMS still has an active job or jobs associated with this 18 customer. Sending a crew to a job that is already restored wastes valuable 19 restoration capacity and prolongs the restoration of real ongoing work efforts 20 as crews report to already resolved outage situations. The Company can locate 21 instances of this condition if it can reliably get the meter status at these locations 22 and use that information to determine if a crew is really needed. At the end of 23 2023, the OK on Arrival percentage for outage jobs during storms was 26%. This project will reduce that percentage by ~25%, bringing the overall rate for 24 OK on Arrivals during storms to ~19% before other additional improvements 25

1		to processes are factored in. Using our most recent storm event in 2024 this
2		improvement, had it been executed prior to that event, would have prevented
3		~250 number of truck rolls saving ~ $$250,000$ (250 x 1000 calculated cost per
4		crew per assignment) and shortened the overall restoration effort by 4-6 hours
5		to closure.
6		
7	<u>Advar</u>	aced Metering Infrastructure (AMI) Meter Communications Upgrade
8	Q182.	What is the AMI Meter Communications Upgrade?
9	A182.	While the CPSV Project represents adding additional capability to the AMI
10		network through redesign and the additional capacity/capability that a denser
11		network device deployment will enable, the AMI Meter Communications Upgrade
12		project represents the capital hardware investment needed yearly to replace end of
13		life devices or those destroyed in the field due to weather events or other incidental
14		damage. There is an ongoing need to procure and install a portion of the fleet of
15		devices each year as part of ongoing pacing of replacement. While included as part
16		of DTEE's strategic projects in the current case, this investment will be covered as
17		routine replacement capital in future rate cases.
18		
19	Q183.	What are the key drivers of this program?
20	A183.	Every year there is a portion of the network devices, primarily field area routers,
21		that reach the end of their useful deployed lifecycle or are damaged in place because
22		of weather events or other operational events like third party damage and the build
23		out of new attachments. These devices must be installed and placed into service to
24		ensure that the communications network retains the ability to reliably cover the

Line <u>No.</u>		
1		service territory. This investment is key to continuing to deliver the value already
2		being derived from the AMI system.
3		
4	Q184.	What are the benefits of this program?
5	A184.	This investment allows the Company to continue to deliver accurate billing, offer
6		and manage new rate structures including the Time-of-Day rates, and contributes
7		to the timeliness of outage restoration. Much like other ongoing capital investments
8		in the health of the grid this investment protects performance of these assets
9		throughout the system's deployed lifespan.
10		
11	Q185.	What is driving the timing of this investment?
12	A185.	Like any project or program of this type, this spend represents the planned and
13		timely replacement of these devices within this period. That means that there needs
14		to be a yearly investment in these asset replacements. Failure to make this
15		investment will result in an increased likelihood of estimated bills for customers in
16		areas where this equipment fails to operate as expected, potentially extending
17		restoration times during outage events due to less certainty of energization state,
18		and leading to fewer, less accurate communications to customers.
19		
20	<u>Micro</u>	wave End of Life
21	Q186.	What is the Microwave End of Life Project?
22	A 10C	The Commence of the second of

A186. The Company owns and operates its own set of microwave communications installations. As the network grows, DTEE must replace aging assets as well as add components to strengthen, tune, and optimize the system. This investment includes replacement of microwave paths, enhancements to stabilize the microwave ring,

	0-21334
	and support changes mandated by the FCC in deregulation of the 6 gigahertz (Ghz)
	frequency.
Q187.	What are the key drivers of the Microwave End of Life Project?
A187.	Due to FCC deregulation of privately owned frequencies, DTEE must replace
	several microwave systems to maintain a reliable network and avoid collisions with
	other entities using the same frequency.
Q188.	What are the benefits for the Microwave End of Life Project?
A188.	These efforts provide overall improvements to infrastructure redundancy,
	availability, capability, and security and are being coordinated with the Grid
	telecommunications program fiber installations to increase resiliency and provide
	additional network capacity. Upgrading the microwave transport systems serves
	SCADA reliability, AMI, and provides business intelligence around storm related
	damages.
Q189.	What has been accomplished in 2022 and 2023 and what are the scheduled
	plans for 2024 and 2025?
A189.	In 2022 and 2023 the Company put into service several new communication
	support assets targeted at both enhancing existing microwave communication
	capabilities and securing communications capabilities for the future.
	In support of this in 2022, the Company erected a new tower in Marysville to house
	new 11Ghz microwave equipment that provides communication between Belle
	River and Marysville because the existing tower no longer met updated safety
	Q187. A187. Q188. A188. Q189. A189.

1	regulations and the new tower supported the installation of a larger number of
2	modern microwave receivers and transmitters. As a result, the Company replaced
3	a leased service link by installing a new microwave path between Hancock
4	substation and the Wixom Pole Yard, reducing overall operational costs.
5	
6	In 2023, the Company put into service a Frequency Assurance System that allows
7	management of interference on existing microwaves still in use. The Company is
8	on target to complete 3 more updates to 6Ghz equipment by the end of 2024.
9	
10	In 2024 and 2025, the Company will continue to replace both licensed critical paths
11	and unlicensed paths. The implementation of path replacement will improve quality
12	of service, reliability, and allow the Company to release leased telecom services,
13	having replaced them with privately-owned communications, which will reduce
14	operational costs.
15	
16	FLISR Implementation
17	Q190. What is Fault Location, Isolation, and Service Restoration (FLISR)?
18	A190. FLISR is a sophisticated software application that integrates with the other ADMS
19	platform applications, such as Distribution Power Flow (DPF), to enable efficient
20	fault response and power restoration. FLISR combines advanced automation, real-
21	time data analysis, and decision support tools to quickly detect, locate, and isolate
22	faults before restoring power in the event of faults or outages. FLISR is able to
23	function by utilizing information from various sensors, devices, and
24	communications networks. In detail, the components that enable the full
25	functionality of FLISR are as follows:

1	•	Distribution Power Flow (DPF): This	component	is	the
2		foundational/prerequisite application that calculate	s the power	flows	and
3		voltages through the eMap network model. This appl	ication is requi	ired for	r the
4		sequentially-occurring components of FLISR to run.	FLISR uses the	e outpi	ut of
5		DPF to estimate how much fault current would be	created if a fau	ult wei	re to
6		occur at any point on the eMap. When a fault occurs of	on the Company	y's ele	ctric
7		system, FLISR can combine status indications and	analog fault	current	ts to
8		estimate where that fault occurred.			
9	•	Fault Location ("FL" in FLISR): Fault locating estim	ates the locatio	n of a t	fault
10		after it occurs on the electric system using fault in	dicators and fa	ult cu	rrent
11		measurements.			
12	•	Isolation ("I" is FLISR): Isolation is the proces	s in which th	ne fau	lt is
13		separated/isolated from the rest of the electric sy	stem by using	g avail	able
14		switching devices to create an isolation zone.			
15	•	Service Restoration ("SR" in FLISR): Service rest	oration is the	proces	ss in
16		which electric service is restored to customers outs	ide of the isol	ation 2	zone
17		without creating loading/voltage violations.			
18					
19	Q191. W	hat are the key drivers of FLISR?			
20	A191. Th	his investment provides fundamental support to DTE	E's initiative t	o imp	rove
21	ov	verall outage restoration and storm restoration commit	ments, and the	e Comp	pany
22	ag	grees with the Commission's statement in Case No	. U-21297 tha	ıt, "ou	tage
23	res	estoration is a critical area" (U-21297, pg. 114). The	continued inv	estmer	nt in

duration, as well as enable the Company to continue realizing the full benefits of

FLISR will help the Company improve storm restoration via reduced outage

Line	
No.	

2

3

4

ADMS and automation. Achieving a fully functioning FLISR that operates automatically and safely unlocks an incremental benefit in automating the "isolation" and "service restoration" portion of FLISR.

5 The ability to isolate and restore in near real-time is dependent on both FLISR and 6 field equipment that is described in the Distribution Automation section of my 7 testimony. As DTEE system capacity increases and as there is an increase of 8 SCADA penetration, the Company will be able to use FLISR to aid in reconfiguring 9 the electrical system when a fault occurs and reduce outage size and outage duration 10 for customers overall.

11

12 Additionally, the components of FLISR allow the Company to respond to 13 undesirable situations on the electric system in a fundamentally different way. The 14 isolation/service restoration functionality will now allow for the near-real-time use 15 of non-protective devices to isolate faults by creating an isolation zone and restore 16 service to remaining customers by transferring them to adjacent circuits. This is 17 different from how the current system is set up to operate near-real-time and creates 18 more opportunities to impact customer outage size/duration than available currently 19 or that has been historically.

20

21 Q192. What are the benefits of FLISR?

A192. FLISR offers an array of benefits to DTEE and its customers. Improved fault
 locating logic will reduce outage duration and decrease strain on devices involved
 in local logic fault hunting schemes. On-demand isolation and service restoration
 plans will provide quick and precise ways to reduce the size of outage events in

1 periods of low and high loading. These beneficial advancements align with other 2 DTEE initiatives to increase SCADA penetration and grid capacity. 3 4 Improved fault locating logic benefits customers experiencing a sustained outage 5 by allowing DTEE to send crews to an estimated fault location instead of needing 6 to perform longer patrols. This becomes especially important in certain areas within 7 the electric system, such as the subtransmission network where crew patrols may 8 take longer due to long distances/overhead line miles that need to be patrolled. This 9 directly impacts the overall customer outage duration by reducing a key part of the 10 restoration timeline (crews patrolling for exact location of damage before repairs 11 can be made and customer's power restored). Getting to the location quicker where 12 repairs need to be made reduces the overall duration of the power outage, directly 13 impacting DTEE's SAIDI. 14 15 On demand isolation and service restoration reduces the size of sustained outages 16 by quickly restoring some of the customers in the initial outage area. The total 17 number of customers interrupted with a sustained outage is reduced when isolation 18 and service restoration occur. Within a short period of time after isolation/service 19 restoration occurs, the customers that are outside of the isolation zone are not 20 impacted with a sustained outage and reduces the overall number of customers 21 affected for the sustained outage event, directly impacting DTEE's SAIFI. 22 23 These combined benefits result in all-weather SAIDI improvements for DTEE's 24 system. The two main benefit drivers are fault location identification and

25 restoration switching analysis. Fault location identification was estimated to have

Line <u>No.</u>	
1	5-10 minutes of all-weather SAIDI benefit and restoration switching analysis is
2	estimated to have 4-14 minutes of all-weather SAIDI benefit.
3	
4	Q193. Are other benefits expected to be realized?
5	A193. Using the centralized logic FLISR provides instead of current local fault hunting
6	logic will reduce the stress incurred by devices on the subtransmission system and
7	loop schemes. This can prolong the usable life of such equipment.
8	
9	DTEE's loop schemes also face challenges on many circuits caused by limited
10	capacity. There are some situations where the loop scheme is unidirectional. This
11	means that one circuit can host load from an adjacent circuit, but the adjacent circuit
12	cannot host load from the first circuit. There are other situations where a loop
13	scheme is disabled outright during periods of high loading because the loop scheme
14	operation may result in system violations. The centralized logic of FLISR does not
15	require one-way configurations or preemptive disabling. Rather, it uses the real-
16	time state of the electric system as modeled in the eMap, SCADA indications, and
17	forecasted loading to make decisions in the moment of whether service restoration
18	is permissible. The dynamic decision-making process can result in successful
19	service restorations in situations where the local logic may have been defeated.
20	
21	Additionally, FLISR can be enabled one feeder/source at a time, as outlined in the
22	implementation plan further down in testimony. DTEE and customers start gaining
23	the benefits for feeders where FLISR is enabled incrementally as it is being
24	implemented over time, and do not have to wait for the full FLISR implementation

across the entire system to start gaining benefits from it.

25

1 Q194. What is the implementation plan for FLISR?

2 A194. The implementation plan for FLISR is a step by step, incremental capability 3 implementation. With this plan, the DTEE grid will see incremental benefits every 4 year, as opposed to an investment where all benefits happen after completion at the 5 end of the project. The initial part of the plan will start with the fault locating 6 functionality within FLISR, then continue to implement isolation/service 7 restoration. As DPF is converging and FLISR turned on for fault locating there is 8 incremental gain. As more devices are added it will incrementally gain some more. 9 FLISR is aligned to a 5-year plan to coincide with the installation of the SCADA 10 enabled field devices that the series of ADMS applications (including FLISR) will automatically control. In the first year of the project, the Company will focus on 11 12 enabling fault locating where possible in conjunction with developing an 13 implementation schedule that will move each source/circuit from initial fault 14 locating capabilities to the automatic processing for full fault 15 locating/isolation/service restoration via switching to restore customers. This final 16 step will achieve the full benefits of FLISR.

17

18 To achieve the desired outcome for complete FLISR automation, there are three
19 key areas that will be supported to get there.

System integration – Integrating FLISR within established infrastructure. The
 process for managing field devices (both currently installed and future devices) and
 incorporating them into the system. This includes smart fault indicators, power
 quality monitoring devices, low-cost monitoring devices, form 6 reclosers,
 distribution PTDs, micro-processor relays, Viper reclosers, etc.

Line	
No.	

1	•	Grid model tuning with FLISR – Assessing the network model in ADMS to identify
2		the regions for tuning, creating the plan for engineers to conduct grid model tuning,
3		and reporting to document the process/outcomes, and monitor functionality,
4		performance, and any issues/challenge encountered during the process.
5	•	Distribution Power Flow (DPF) convergence support - Iterative testing and
6		tuning/configuration to ensure convergence and high-quality results (e.g., precision
7		of topology and power flow results)
8		
9	Distril	buted Energy Resources Management System (DERMS)
10	Q195.	What is the DERMS?
11	A195.	The electric grid in the future will need to incorporate new technologies, including
12		Distributed Energy Resources (DER) such as solar and battery storage. To enable
13		and support the grid benefits of these resources as well as manage the complexities
14		of intermittent and two-way power flow, utilities must plan for DER integration.
15		DERMS is a control system specifically designed to handle DERs at the residential,
16		commercial, and industrial, and distribution grid levels. A DERMS acts as a
17		switchboard for DER-related protocols and information to simplify the
18		management of these disparate systems and feed information into other utility
19		backend systems for planning, operations, and customer engagement. In addition
20		to solar and storage, these DERs can include demand response, electric vehicles, or
21		other distributed technologies.
22		
23	Q196.	What functionality is present in a DERMS?
24	A196.	A Utility DERMS is composed of multiple key functionalities:

Line <u>No.</u>	
1	• Track the location, status, configuration, and capabilities of all DER on the
2	electrical system.
3	• Track the energy management and economic program assignments, criteria and
4	constraints for each DER and identify and prevent conflicts.
5	• Provide interfaces to all of the DER related protocols, controls, both utility
6	controlled, and vendor controlled, and interfaces to utility information systems
7	such as Customer Relationship Management (CRM), Billing, Market Systems
8	and the ADMS.
9	• Provide the capability to capture data, availability, and performance from the
10	DER, either directly or from third parties and to send dispatch commands to
11	those devices.
12	• Forecast the real time and short-term availability, energy balances, and
13	capabilities of registered DER, this includes Demand Management and
14	Response which coordinates solar, storage and flexible loads to regulate peak
15	demand, execute energy efficiency, and align with utility and market programs.
16	• Optimize those dispatch commands both for energy savings and economics, all
17	while maintaining and respecting program constraints, customer decisions and
18	grid constraints and maintaining the operability of the electrical system.
19	• Management functions of the DERMS are to aggregate DERs into groups that
20	can be more easily coordinated, controlled, and dispatched, and automate the
21	dispatch and optimization functions with algorithms to support Transmission
22	and Distribution System coordination while balancing Market and real time
23	operational constraints.

Line No. 1 Because of this broad scope, a DERMS system must have interfaces to nearly all 2 utility systems, most importantly the ADMS, market and the customer information 3 systems. 4 5 **O197.** What is the benefit of a DERMS? 6 A197. The DERMS provides a central location to consolidate interfaces to different DER 7 types and vendor systems and present it consistently to the ADMS. Without this 8 consolidation each different type of DER or vendor system would need a custom 9 integration to the ADMS and changes to vendor interfaces would impact ADMS 10 operations, making each integration more costly and time consuming. The DERMS 11 also provides optimization of dispatch of DER, allowing the system operator, or 12 market signal, to set a dispatch goal in the ADMS for a specific area of the system. 13 The DERMS evaluates the available and registered resources to accomplish the 14 goal, balancing DER constraints and customer impacts with the timing and duration 15 of the dispatch. 16 17 Q198. What is the optimal timing to begin DERMs implementation? 18 A198. DTE will begin investment in DERMs in 2025. This will allow a clear evaluation

of MISO FERC 2222 requirements that will be available by Q3 2024.
 Electrification and DER adoption will only increase over time, and more complex
 DER hardware is being made available to customers available to customers
 continuously. To meet customer needs and provide necessary operational
 coordination it is imperative to have a working system in place to support these
 capabilities. The complex implementation of a DERMS must begin now to allow
 adequate time for the number of interface and system changes required, and to

2

3

4

procure the necessary functions for compliance. In addition to preparation for future needs, immediate benefit from a DERMS can be realized through integration of many existing programs, producing streamlined coordination with the control room, and generating benefit from initial investments including demand response and load control programs.

6

5

7 Q199. What is DTE's strategy for deploying a DERMS cost effectively?

8 A199. The Company's strategy is to focus on the areas where DERMS is needed for 9 compliance and areas where it can increase the efficiency of existing processes and 10 systems and build interfaces or consolidate systems that currently do not work 11 together. This approach is a System of Systems, where components are 12 implemented as they are needed and at the scale that they are needed. Some of the 13 first components that are needed are consolidation of management systems that 14 coordinate DER and DR data and program participation and interfaces to the 15 ADMS. This will allow current DR and DER programs to be tracked more 16 efficiently, benefitting customers that are currently in DR, load management and 17 DER programs and enabling the dispatch of larger existing SCADA controlled 18 assets in coordination with the ADMS and Market Systems to support currently 19 implemented programs such as FERC841. Future phases will focus on the 20 forecasting and optimization as well as automation of constraint management and 21 Distribution System Operator (DSO)/ Transmission System Operator (TSO) 22 coordination.

23

24 Q200. What is the scope of the investment in DERMS in 2025?

Line	
No.	

1	A200.	The initial investment will be in the program and configuration database to
2		centralize program management, program constraints and the tools to assign DER
3		to system model nodes. This will be done in parallel with ADMS enhancements to
4		be able to control dispatch of identified resources and enforce constraints at circuit
5		level granularity. These first interfaces will utilize existing programs including
6		Commercial Interruptible customers, Demand Response, Interruptible heating and
7		air conditioning and Load Management System functionalities and other DER
8		programs. DTEE has identified a key list of requirements for framework,
9		functionality, demand response, and integration into utility systems and is currently
10		evaluating vendors to identify the partner best able to satisfy all needs.
11		

Q201. Will this approach be able to scale to support the state's clean energy transformation?

14 A201. Yes, this approach allows for capacity to expand while adoption rates of DER are 15 growing. Approaching the complicated problem of a DERMS by addressing 16 fundamental systems and data and investing in and implementing components as they are needed and at the scale they are needed, the DERMS implementation will 17 18 be able to benefit existing customers participating in DR and DER programs today 19 and expand as FERC 2222 and other future programs are brought online. As DER 20 integration grows, the speed of adoption is still uncertain, and it is not practical or 21 cost effective to implement a system that can initially provide the capability to 22 support millions of customer DER that may not materialize. However not having a 23 system to manage DER in a comprehensive way would lead to potential non-24 compliance, inefficiencies, and degraded customer experience.

25

1 <u>Substation Cybersecurity Program</u>

2 Q202. What is the Substation Cybersecurity Program?

3 A202. As technology and automation investment grows, the number of devices deployed 4 on the grid will also grow, driving a need for increased cybersecurity to protect the 5 devices and grid controls. The Substation Cybersecurity program will develop and 6 deploy cybersecurity tools supporting the increasing use of distribution automation 7 devices across DTEE substations and circuits. This program aligns with the NIST 8 Cybersecurity Framework (National Institute of Standards and Technology), 9 Cybersecurity program management and architecture requires situational 10 awareness, threat and vulnerability management, asset and configuration 11 management, and incident response among other activities.

12

13 Q203. What is the scope and benefits of the Cybersecurity Tools program?

14 A203. This project made improvements to the physical security at Stone Pool substation 15 in 2023 as well as procurement and testing of software for situational awareness, 16 threat and vulnerability management inside the substation, and asset and 17 configuration management. In 2024, penetration testing, and further integration of 18 physical and cyber alerts will be completed to close out the Stone Pool Substation 19 portion of the project. This work will ensure robust protection at Stone Pool as well 20 as inform standards, policies and procedures to ensure cybersecurity at future 21 substations and inform optimal mitigations at other existing substation in the future. 22 Work in 2024 and 2025 also includes the procurement of distribution device compatible cyber security hardware that can be used to secure devices that are 23 24 deployed on distribution circuits and the collection of industry data and best 25 practices for cybersecurity for circuit level distribution assets including an Line N<u>o.</u>

independent threat and vulnerability assessment of these approaches. This work
 will inform future process and program developments to ensure increased
 monitoring and control of the distribution system is paired with the necessary
 increases in cybersecurity.

- 5
- 6

Automation Configuration Database

7 Q204. What is the Automation Configuration Database Project?

8 A204. The Automation and Configuration Database is an investment in tools for improved 9 tracking of intelligent electronic devices, specifically distribution relay and network 10 communications equipment. As distribution automation equipment becomes ever 11 more sophisticated it is important to ensure more detailed information about devices 12 is retained and leveraged. Traditional relay database may only capture items like device type and settings, as devices become more sophisticated it becomes 13 14 important to track additional information such as device configurations, software 15 version, and firmware status. It is also important that this data be stored in a readily 16 accessible way to allow for connection with other data systems, effective patch 17 management, and cybersecurity monitoring. This project will replace the existing 18 in house database with an industry standard tool, improving data accessibility and 19 ability to coordinate asset, work management, and protection data between 20 databases increasing work efficiency and supporting increases in automation 21 resulting in faster design of projects for customers, reductions in commissioning 22 and maintenance duration where equipment is out of service and minimize the 23 chance of devices being misconfigured or having out of date settings that could 24 adversely impact customer reliability.

25

Q205. What is the scope of work on the Automation and Configuration database for 2024 and 2025?

A205. The 2024 scope will include the software evaluation and selection as well as
verification of compatibility of relay test equipment with software selection. 2025
scope will include data cleansing and implementation of the database as well as
establishment of connection between relay test equipment and automation and test
record database.

8

9 H. Distribution Planning

10 Q206. What is the Distribution Planning investment category?

11 A206. The dynamic nature of the grid requires that engineers regularly analyze grid 12 capabilities including capacity, reliability, and adequate voltage support, to support 13 integration of new load and other new customer needs such as DER. Distribution 14 Planning is a category of investments in the tools, processes, software applications 15 and data models supporting the near and long term planning of the distribution 16 system. It includes the applications to correlate and consolidate changes to the 17 electrical system model so that the different planning tools and the ADMS can 18 utilize the same data set to perform the necessary analysis for power flow, power 19 quality, contingency analysis and project scenarios. These tools assess the impact 20 of bulk power system modifications, customer requested interconnection and 21 loading changes, and utility initiated upgrades to the electrical system. This 22 category also includes the tools to assess the civil, mechanical and structural aspects of project engineering and design. In concert, these tools and systems allow the 23 24 Company to optimize projects and consider alternatives in a quantitative and 25 physics-based manner.

1 Q207. Where are the capital investment details of the projects and programs in this

category?

- A207. Capital investment details of these projects and programs in this category are
 included in:
 - Exhibit A-12, Schedule B5.4, page 17-18
 - Exhibit A-23, Schedule M7

```
7
```

5

6

8

Table 9Distribution Planning Investments Exhibit Locations

Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
ADMS: Network Management System	p. 18, line 41	рр. 12-16	pp. 150-155
Load Forecasting & Analytics	p. 18, line 42	pp. 92-95	pp. 150-155, 244
Interconnection Process Enablement	p. 17, line 29	pp. 87-91	pp. 150-155, 246-249
Hosting Capacity Enablement	p. 18, line 43	pp. 83-86	pp. 150-155, 250-251
Power Quality Analysis Program	p. 18, line 44	pp. 169-172	pp. 150-155, 251-252
Substation Design Tool Upgrade	p. 18, line 45	pp. 197-202	pp. 150-155, 252
Distribution Planning	p. 18, line 46	pp. 50-53	pp. 150-155
SCADA Remote Access and Configuration Platform	p. 17, line 19	pp. 177-180	pp. 150-155, 243

9

10 Q208. Why is investing in technology for Distribution Planning essential for DTEE

11 and customers?

A208. These investments incorporate enhancements to existing tools, new tools, and interfaces to allow more frequent and accurate modeling of the distribution system and analysis of planned changes. A number of different tools are used by

Line
No.

1	engineering and design during the development of a project and during annual
2	system studies. The investments in these different tools keep them up to date, add
3	enhancements and capabilities and improve the efficiency of the design process.
4	Distribution planning encompasses tools needed for distribution planning, design,
5	specification, modeling, forecasting and the analytics of associated data. This area
6	accounts for systems and engineering tools needed to perform modelling functions
7	accurately and effectively for all distribution planning activities and investments.
8	These individual tools are also used by planning engineers in modeling grid impacts
9	and the calculations needed to implement projects to design standards. These
10	investments support streamlining the customer interconnections process and
11	include investments in hosting capacity mapping.

13 <u>Network Management System (NMS)</u>

14 Q209. What is Network Management System (NMS)?

15 A209. As part of the ADMS project, the Company implemented a Network Management 16 System (NMS) in 2020. NMS incorporates network data from the Geographic 17 Information System (GIS) and combines the network data with other systems to 18 directly serve the new ADMS functionality. NMS consolidated multiple network 19 models to one common network model, resulting in a consistent view of the 20 electrical system in real time to be used by all functions of the ADMS. Moving 21 from multiple networks models into one had many advantages, it promotes data 22 consistency, simplifies maintenance, improves integration capabilities, and leads to 23 operational efficiency. This data model is also used by the distribution planning 24 tools to provide the base model information for all planning studies.

25

1 Q210. How was the NMS program structured and implemented?

2 A210. The NMS program was broken up into multiple phases to align with the short-term 3 and long-term data requirements for ADMS and other projects. The initial phase of 4 NMS included implementing operational dashboards for monitoring data quality, 5 employing machine learning models to correct data issues, and consolidating 6 multiple sources into a single location (GIS) for use in external systems. In 2020, 7 following the successful completion of the initial phase and setting the foundation 8 for maintaining high-quality systems for data, the Company adhered to its plan by 9 advancing the NMS investment. Additional initiatives were implemented to 10 improve and add more information into our network model, enabling future technology investments and existing technology enhancements to maintain a high 11 12 level of accuracy.

13

14 The NMS investments, which are described in detail later in my testimony, are 15 targeted to four areas of focus:

16

17 **1.** Common Platform: Moving to a shared technology foundation that facilitates 18 seamless interaction and collaboration between different systems, applications, and 19 devices. This allows for data to be extracted from the source and eliminates 20 potential for human error. For example, distribution circuit operating maps will be 21 directly generated from the GIS, ensuring more accurate data for field and system 22 operations. This avoids the work delays that field workers currently encounter 23 when manually reconciling map differences, allowing restoration work to happen 24 faster.

25

Line	
<u>No.</u>	

1	2. Network Model Enhancements: Involves improving and expanding the
2	representation within the network model. It includes adding new data fields,
3	refining existing ones, and incorporating more accurate and detailed information to
4	capture the characteristics of the network. The goal is to enhance the model's
5	accuracy, completeness, and usability for applications that use the data.
6	
7	3. Grid Model Analytics: Centers on using analytics to gain insight into behavior,
8	performance, and characteristics of the grid. The objective is to improve reliability,
9	efficiency, and overall functionality of the electrical grid by leveraging data-driven
10	insights derived from the grid model.
11	
12	4. Asset Data Integration: Consolidates data from different databases, sensors,
13	and sources to create a unified and comprehensive view of the assets. The goal is
14	to enhance data accuracy, accessibility, and usability, enabling better decision-
15	making and management in a coordinated manner.
16	
17	Q211. Has the MPSC supported past investments in NMS?
18	A211. Yes. On Page 116 of the December 1, 2023 Order in Case No. U-21297 the MPSC
19	stated that "The Commission agrees with DTE Electric that "[g]rid needs are
20	dynamic, and the tools to support reliability and grid modernization also need to
21	adapt and develop to support these emerging grid needs." 5 Tr 2945." and the
22	amount requested by the Company was approved.
23	
24	Q212. Will continued investment be needed for NMS?

Line	
No.	

1	A212.	Yes. As the electric grid continues to change, the systems that support the
2		management of the electric grid will also need to be updated and change. Sustained
3		investment provides critical source data for operational systems (e.g., ADMS -
4		DMS network model application), and is the basis for an accurate interpretation of
5		the current status of the electrical system. This is essential for the safe and effective
6		monitoring and operation of the electrical grid. Specifically, these initiatives will
7		improve the Company's capability to analyze electrical load distribution, identify
8		overloaded areas in the network, and plan upgrades more effectively. This approach
9		enables the Company to accurately model and analyze growing electrical demand
10		and improve service quality and reliability for customers.
11		
12	Q213.	Since the initial NMS Implementation, what has been accomplished to date?
13	A213.	To date, there have been prudent investments made in the four areas of focus:
14		• Common Platform: 328 operational maps have been converted.
15		• Network Model Enhancements: 30 new data fields have been added to the
16		network model.
17		• Grid Model Analytics: Data quality for dynamic protective devices and
18		capacitors improved by 18% in 2022, and data quality for switches, fuses, and
19		regulators has improved by 30% in 2023.
20		• Asset Data Integration: 8 asset types were synchronized between GIS and
21		Maximo and new data governance was established with clear data ownership
22		accountabilities and support processes. In 2023, the AC network meter
23		connectivity pilot was brought to completion and the NMS started supporting
24		Distribution Power Flow (DPF) application in enhancing the network data
25		models.

1 Q214. What are the plans for NMS in 2024 and beyond?

2 A214. The focus for 2024 is on supporting and strengthening DPF and FLISR applications 3 by developing new network models and augmenting existing network models with 4 the addition of 10 new data fields. The objective for grid model analytics is to 5 improve the data quality for primary and sub-transmission OH and UG lines by 6 10%. In addition, the Company will invest in AC network connectivity and asset 7 data integrations by synchronizing 4 asset types between GIS and Maximo. Future 8 plans are to continue to support DPF and FLISR applications and continue 9 implementation of AC network connectivity. For network model enhancements, the 10 goal is to add 5 new data fields to the network model and improve and develop new algorithms to enhance phasing and meter to transformer connectivity. In grid model 11 12 analytics, the target is the improvement of data quality for smart fault indicators 13 and DERs by 10%. These continued investments contribute to the Company's 14 capability to identify areas with high demand or vulnerabilities in the grid. Using 15 this data to improve our planning processes results in higher quality customer 16 service improvements.

17

Q215. What are the benefits of the investments in the Network Model for the Company's customers?

A215. High-quality data is the backbone of the ADMS system, and ADMS is central to
 day-to-day and storm grid management. Investing in data quality improvements is
 foundational to enabling all the potential value in the remaining ADMS
 components.

As an alternative to NMS enhancements, manually performing the functionality provided by network model investments would require an estimated 20 additional

Line	
<u>No.</u>	

1	Ful	ll Time Employees (FTEs) to manually maintain data between systems (for
2	exa	ample, synchronizing the location of the assets, operating voltage ratings, etc.,
3	acr	ross the systems). Highlighted in Case No. U-21297 by Witness Reterstorf (5T
4	291	11-2912), the Company referenced an avoidance of 20 O&M personnel due to
5	cor	ntinued investments in NMS (at the time of filing U-21297, the cost of adding 7
6	oft	these 20 personnel was avoided). At the time of filing, DTEE estimates that the
7	cos	st of adding 14 of these 20 O&M personnel has been avoided as a result of these
8	Ne	twork Model investments. DTEE is on track to achieve the 20-FTE target by the
9	enc	1 of 2024.
10		
11	Q216. Ca	n you describe the realized and projected operational benefits of the
12	ado	ditional investment in the four focus areas of NMS?
13	A216. Inv	restments to date have improved the Company's operational ability to generate
13 14	A216. Inv ma	ps from GIS, improved load analysis ability, and enabled more accurate
13 14 15	A216. Inv ma pre	ps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023,
13 14 15 16	A216. Inv ma pre this	ps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, s investment will continue to improve the data quality as outlined below.
13 14 15 16 17	A216. Inv ma pre this	restments to date have improved the Company's operational ability to generate ps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, s investment will continue to improve the data quality as outlined below.
13 14 15 16 17 18	A216. Inv ma pre this 1.	Approximate to date have improved the Company's operational ability to generate approved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, is investment will continue to improve the data quality as outlined below.
13 14 15 16 17 18 19	A216. Inv ma pre this 1.	restments to date have improved the Company's operational ability to generate aps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, is investment will continue to improve the data quality as outlined below. Common Platform: The transition to a single platform will provide more curate Network Model data for field operations by directly generating operating
 13 14 15 16 17 18 19 20 21 22 	A216. Inv ma pre this 1. acc ma	vestments to date have improved the Company's operational ability to generate aps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, is investment will continue to improve the data quality as outlined below. Common Platform: The transition to a single platform will provide more curate Network Model data for field operations by directly generating operating ps from the GIS and eliminating the CAD tool.
 13 14 15 16 17 18 19 20 21 22 23 	A216. Inv ma pre this 1. acc ma 2.	 vestments to date have improved the Company's operational ability to generate ups from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, is investment will continue to improve the data quality as outlined below. Common Platform: The transition to a single platform will provide more curate Network Model data for field operations by directly generating operating ps from the GIS and eliminating the CAD tool. Network Model Enhancements: These enhancements will improve
 13 14 15 16 17 18 19 20 21 22 23 24 	A216. Inv ma pre this 1. acc ma 2. dov	vestments to date have improved the Company's operational ability to generate ps from GIS, improved load analysis ability, and enabled more accurate eventative maintenance planning. Combined with the remaining work in 2023, s investment will continue to improve the data quality as outlined below. Common Platform: The transition to a single platform will provide more curate Network Model data for field operations by directly generating operating ps from the GIS and eliminating the CAD tool. Network Model Enhancements: These enhancements will improve wnstream processes—including distribution planning, grid operations, and
1 fields added to the model each year across the system to further understand and 2 quantify the effects of these types to the network model. 3 4 5 **3. Grid Model Analytics:** These machine learning models will be run periodically 6 to identify and correct data within the base Network Model. Improvements in data 7 accuracy and availability address attributes such as KVA, operating voltage, and 8 phasing. 9 10 4. Asset Data Integrations: Synchronizing the data in the GIS platform with the 11 data in the work management platform (Maximo) will provide accurate asset data 12 to improve preventative maintenance schedules, ultimately improving system 13 reliability. 14 15 **Load Forecasting & Analytics** 16 **Q217.** What is Load Forecasting and Analytics? 17 A217. Load Forecasting and Analytics is a program that represents investments in 18 planning tool capabilities that are focused on the essential industry standard 19 distribution planning tool CYME that models distribution circuits and calculates 20 load flow, and the load analysis tool Power Runner which combines SCADA, AMI 21 and forecasted load data to generate load allocation scenarios to CYME. This 22 category of investments include required software licensing, associated server

24 25 supporting planning tools.

23

Line No.

hardware, interfaces, and functionality enhancements for this software and

1	Q218.	Did the commission order in Case No. U-21297 express any concerns about
2		these investments?
3	A218.	Yes, the order indicated that additional evidence to support the investment was
4		needed, and also raised a question about accounting related to the amount of labor
5		when compared to materials. The following testimony details the program and
6		investments to provide additional evidence.
7		
8	Q219.	What investments were made in 2022 and 2023 and what are the benefits to
9		customers?
10	A219.	Investments in 2022 and 2023 included the upgrade of the CYME distribution
11		planning tools and required licensing and server hardware to the latest supported
12		version which will enable improved modeling for hosting capacity and non-wire
13		alternatives and allow for new modules that will be implemented in 2024 and
14		beyond. Investments also included the initial deployment of Power Runner
15		licensing, servers and software that combines SCADA, AMI and forecasted load
16		data from every meter on the system, to produce hourly load allocation curves. For
17		subtransmission tools, TSAT software and required license was purchased as it is
18		now a requirement for MISO Dynamic model studies.
19		
20	Q220.	What investments are planned in 2024 and 2025 and what are the benefits to
21		customers?
22	A220.	2024 investments include enhancing CYME to load data from Power Runner to
23		allow for multi time period scenario analysis and the implementation of CYME
24		Advanced Project Manager which allows sequencing of system model changes to
25		project plans and linkage to Maximo workorders. Enhancements will also be made

Line <u>No.</u> Line <u>No.</u>

1	to allow for substation models to be loaded into CYME to improve the analysis of
2	circuit load transfers, conversion, and consolidation. The combination of Dynamic
3	Data Pull (DDP) module for load allocation and Advanced Project Manager (APM)
4	module allows projects to be studied in multiple phases and validate that schedule
5	changes to project do not violate constraints. This will also improve interconnection
6	studies as the in-service date of projects can now be considered for coincident
7	projects to determine interactions. 2025 enhancements to CYME will begin the
8	implementation of the Advanced Distribution Planning System which is a
9	collection of CYME enhancements that are being implemented at other utilities that
10	address DER and NWA scenario planning and automate many common tasks and
11	reports that are run by engineers. Power Runner will be enhanced to provide more
12	validation of load profiles and be integrated with as-operated status of the system
13	to better model load transfers and switching. Power Runner will also incorporate
14	the sub transmission model hierarchy to allow for preparation of sub transmission
15	loading data sets into tools like PSSE. PSSE enhancements will be made in 2024 to
16	comply with MISO MOD32 data modelling requirements and to perform new gross
17	load calculations at model nodes. The SEEQ analytic tool will also be enhanced,
18	this provides detailed data analysis capabilities to time series signals and allows for
19	complex calculations for asset health and other engineering calculations. 2025
20	investments will begin to improve forecasting and propensity analysis of DER
21	adoptions. These enhancements will lead to more accurate system studies, more
22	efficient interconnection screens and studies and better optimized designs for
23	system improvement, non-wire alternative and loading projects. Customers will
24	benefit from reduced interconnection study and review times and more accurate up
25	front estimates of system upgrades.

Line	
<u>No.</u>	

1	Interc	onnection Process Enablement
2	Q221.	What is interconnection process enablement?
3	A221.	Interconnection process enablement are investments focused on the software and
4		interfaces for interconnection processing that includes both the interconnection
5		portal and the interconnection database, PowerClerk. Additional investments are
6		made in tools and interfaces to streamline interconnection processing, study and
7		screening and benefit customers by improving the application, screening and study
8		response times and accuracy. These investments are driven by changes to market
9		programs, interconnection rules, procedures, and tariffs. These enhancements also
10		streamline the process and improve the customer experience when applying for and
11		connecting DER.
12		
13	Q222.	What investments were made in 2022 and 2023 and what are the benefits to
13 14	Q222.	What investments were made in 2022 and 2023 and what are the benefits to customers?
13 14 15	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for
13 14 15 16	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to
13 14 15 16 17	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their
13 14 15 16 17 18	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk
 13 14 15 16 17 18 19 	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk forms, automation, website pages and documentation to support the new
 13 14 15 16 17 18 19 20 	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk forms, automation, website pages and documentation to support the new interconnection rules initiated in case U-20890 and implemented changes to fee
 13 14 15 16 17 18 19 20 21 	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk forms, automation, website pages and documentation to support the new interconnection rules initiated in case U-20890 and implemented changes to fee structures and online payment as part of the new rules.
 13 14 15 16 17 18 19 20 21 22 	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk forms, automation, website pages and documentation to support the new interconnection rules initiated in case U-20890 and implemented changes to fee structures and online payment as part of the new rules.
 13 14 15 16 17 18 19 20 21 22 23 	Q222. A222.	What investments were made in 2022 and 2023 and what are the benefits to customers? In 2022, the major investments implemented online payment processing for interconnection fees and enabled single login for customers, which allows them to access the interconnection portal with the same username and password as their DTEE online account. 2023 investments included improvements to PowerClerk forms, automation, website pages and documentation to support the new interconnection rules initiated in case U-20890 and implemented changes to fee structures and online payment as part of the new rules.

Line <u>No.</u>		
1		field gateway hardware investments will be split from this category to align the
2		program with the OT investments.
3		
4	Q223.	What investments are planned in 2024 and 2025 and what are the benefits to
5		customers?
6	A223.	Investments for 2024 include completing the payment portal changes to support the
7		new interconnection rules and security enhancements to a single sign on login. 2024
8		investments include the renewal and refresh of the PowerClerk system.
9		Enhancements in 2024 will increase automation associated to the interconnection
10		process for small interconnections. Additionally, the enhancements include
11		backend improvements to screening and study that will increase application
12		throughput and reduce manual labor in preparing and running studies. Further
13		updates and automation improvements will be done in 2025 to comply with
14		interconnection procedures changes. The 2025 investments also aim to streamline
15		the screening and study process and initiate the implementation of FERC 2222
16		related application and screening processes into PowerClerk.
17		
18	<u>Hostir</u>	ng Capacity Enablement
19	Q224.	What are the investments in Hosting Capacity Enablement?
20	A224.	Hosting Capacity Enablement includes improvements to the online publicly
21		available map system that displays hosting capacity, and the capabilities to compute
22		hosting capacity and process the data for it to be available publicly.
23		

Q225. What investments were made in 2022 and 2023 and what are the benefits to
customers?

Line
<u>No.</u>

1	A225.	Investments in 2022 and 2023 included publishing the initial hosting capacity map
2		for DER and improving backend data handling to prepare updates. In 2023, the
3		focus was on developing the loading capacity map. These maps allow customers to
4		see the amount of remaining capacity and hosting capacity in their area.
5		
6	Q226.	What investments are planned in 2024 and 2025 and what are the benefits to
7		customers?
8	A226.	Investments in hosting capacity for 2024 are aimed at enhancing the backend data
9		update mechanisms of the system. In 2025, the focus will shift towards integrating
10		the analysis capabilities, which are being developed in the load forecasting and
11		analytics project, into the outputs of the hosting and load capacity maps. This
12		integration will result in a more detailed representation of hosting capacity values
13		across numerous circuit sections. The increased granularity of data will provide
14		customers with additional information, aiding their decision-making process.
15		
16	Power	Quality Analysis Program
17	Q227.	What is the Power Quality Analysis program?
18	A227.	The Power Quality Analysis program are investments in software to centralize,
19		collect, correlate, and visualize power quality data such as fault and disturbance
20		waveforms, voltage disturbances, harmonics, flicker and momentary information
21		from various metering sources on the system and provide analysis capabilities to
22		help determine root cause of events and begin to establish predictive capabilities
23		from analysis of disturbances that have not yet created an outage or equipment
24		issue.

25

Line <u>No.</u>	
1	Q228. What investments were made in 2022 and 2023?
2	A228. None, this is a new investment category in 2024.
3	
4	Q229. What investments are planned in 2024 and 2025 and what are the benefits to
5	customers?
6	A229. Investments in 2024 will be to centralize power quality information into a single
7	data set that can be analyzed and correlated with complaints, trouble events and
8	outages. Interfaces for near real time capture of power quality meter data will be
9	established. In 2025 analysis tools and machine learning capabilities will be added
10	to the system to determine root cause and begin the process of identifying
11 12	precursors to predict failures and outages from sensor and power quality data.
13	Substation Design Tool Upgrades
13 14	<u>Substation Design Tool Upgrades</u> Q230. What are the investments in substation design tools?
13 14 15	Substation Design Tool UpgradesQ230. What are the investments in substation design tools?A230. This category of investments is comprised of design and structural calculation tool
13 14 15 16	 Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and
13 14 15 16 17	Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new
13 14 15 16 17 18	Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and
13 14 15 16 17 18 19	Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration integration
13 14 15 16 17 18 19 20	Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration integration integration and cost estimating.
 13 14 15 16 17 18 19 20 21 	 Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration interview work management, scheduling and cost estimating.
 13 14 15 16 17 18 19 20 21 22 	 Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration into work management, scheduling and cost estimating. Q231. What investments were made in 2022 and 2023 and what are the benefits to the structure calculated benefits to the structure calculated benefits to the structure benefits
 13 14 15 16 17 18 19 20 21 22 23 	 Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration into work management, scheduling and cost estimating. Q231. What investments were made in 2022 and 2023 and what are the benefits to customers?
 13 14 15 16 17 18 19 20 21 22 23 24 	 Substation Design Tool Upgrades Q230. What are the investments in substation design tools? A230. This category of investments is comprised of design and structural calculation tool that are used by engineers, planners, and designers to implement standards and calculated physical analysis into designs prior to construction. This includes new tools to facilitate rapid compliance for pole and overhead structure calculations and steel work as well as enhancement to CAD design tools to improve integration into work management, scheduling and cost estimating. Q231. What investments were made in 2022 and 2023 and what are the benefits to customers? A231. Investments in 2022 and 2023 included renewal of PLSCAD, a sophisticated

Line <u>No.</u>		
1		editing and collaboration software for CAD designs. Other investments began the
2		process of implementing compatible units for substation standards and structural
3		design testing.
4		
5	Q232.	What investments are planned in 2024 and 2025 and what are the benefits to
6		customers?
7	A232.	2024 investments include renewal and enhancements of the Spidacalc pole design
8		software and to acquire specialized structural modelling tools to allow for
9		engineered structure designs to be verified. Additional structural design testing will
10		be done in 2024 to validate the modelled parameters in the software and update
11		design standards accordingly. 2025 will begin the process of updating the
12		substation design tools and interfaces to utilize the compatible units and closely
13		link design to the Maximo and supply chain process.
14		
15	<u>Distri</u>	bution Planning
16	Q233.	What is Distribution Planning (Exhibit A-12 Schedule B5.4, Page 18, line 46)?
17	A233.	Distribution Planning is a collection of projects within the Distribution Planning
18		OT category and represents a set of investments from the other sub programs in the
19		Distribution Planning OT category.
20		
21	Q234.	What investments were made in 2022 and 2023 and what are the benefits to
22		customers?
23	A234.	The breakdown of significant investments are as follows:
24		• \$98,000 of this investment to load allocation and analytics for a tool to evaluate
25		transformer overloads and root causes, as well as a tool to understand EV

Line	
<u>No.</u>	

10.		
1		adoption and how it is impacting circuit and transformer loading. This tool
2		allows the Company to more accurately pinpoint where infrastructure needs to
3		be updated due to DER.
4		• \$603,000 to the load allocation and analytics project for the CYME 9.2 upgrade.
5		This includes the license renewal and server hardware for that project. The
6		benefits of those investments are covered in the Load allocation and analytics
7		and Cyme Upgrade sections earlier in the testimony.
8		• \$64,000 to the substation and structural tools budget for Bluebeam CAD
9		markup tool for license renewals. Bluebeam CAD significantly streamlines
10		field print markup for substation designs and reduces planning and design time.
11		• This line item also includes investments made to systems that support the
12		Company's ADMS system to bring additional operational data to our
13		employees when responding to unplanned field events resulting in better overall
14		control and effectiveness (\$8.46 million).
15		
16	Q235.	What investments are planned in 2024 and 2025 and what are the benefits to
17		customers?
18	A235.	This category will invest in small emergent needs for planning tools in 2024 and
19		2025 that do not clearly align to the other sub projects. Projects are selected from
20		an existing backlog list for each investment year. These investments will either
21		evolve into their own sub projects in the future or be incorporated into existing sub
22		projects. Larger investments that can be clearly aligned with existing OT sub
23		programs will be charged appropriately to eliminate the historical mixing of
24		investment categories in this project going forward. A major investment planned
25		for this category in 2024 and 2025 is the Circuit Reliability Optimization project.

L	in	e
N	0	

1 The scope of this system is to provide a digital platform to examine and monitor 2 every circuit for emergent events, reliability initiatives, maintenance tasks, and 3 enhancements. It will also assess the influence of reliability programs, maintenance 4 activities, and upgrades on the improvement of each circuit's reliability and evaluate 5 the most effective reliability enhancement strategies, including ETTP, PTMM, 6 Hardening, and Conversion. The system will also quantify the impact of various 7 programs on the reliability of circuits, substations, sub-transmission, and the 8 contribution to the overall system.

9

10

I. <u>Work Management and Scheduling</u>

11 Q236. What is Work Management and Scheduling?

12 A236. Work Management is a systematic approach to track and measure work as well as 13 streamline both business processes and routine tasks. This category of investments 14 describes the essential set of work management tools and technologies that are used 15 to coordinate work on the distribution system, from initiation through close out of 16 work orders, including the work steps, assignment of labor, materials, and other 17 tasks. While current schedules and processes rely on Microsoft Excel, the benefits 18 of automation, like drag-and-drop schedules, real-time field status updates, and 19 integration with systems such as OMS and Maximo, are realized through these 20 investments. Job planning, along with managing labor, material, tools, and services, 21 is also part of the suite of tools for effective work management.

22

Q237. Where are the capital investment details of the projects and programs in this category?

Line No.

1 A237. Capital investment details of these projects and programs in this category are

- 2 included in:
 - Exhibit A-12, Schedule B5.4, page 17 and 18
 - Exhibit A-23, Schedule M7
- 5

3

4

6

Table 10 Work Management and Scheduling Exhibit Locations

Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
Enhance Maximo Capabilities and Processes	p. 18, line 47	pp. 62-65	pp. 155-157
Primary Service Orders Replatform	p. 18, line 48	pp. 173-176	pp. 155-157
External Crew Efficiency	p. 17, line 23	pp. 66-69	pp. 155-157
Work Management and Scheduling Upgrades	p. 18, line 49	pp. 219-222	pp. 155-157
Substation Reporting and Process Enhancements	p. 17, line 20	pp. 203-206	рр. 155-157

7

8 **Enhance Maximo Capabilities and Processes**

9 Q238. What is Enhance Maximo Capabilities and Processes?

- A238. Enhance Maximo Capabilities and Processes is a project aimed at improving and
 expanding the functionality of Maximo, the Company's Work and Asset
 Management system, and optimizing its associated processes.
- 13

14 Q239. What are the key drivers of Enhance Maximo Capabilities and Processes?

- 15 A239. DTEE's Work and Asset Management system, Maximo, has both on-premise and
- 16 field enabled capabilities. The field portion of that system is currently filled by a
- 17 field module, EZMax Mobile, that would have been replaced as part of the Maximo

Line
<u>No.</u>

1		transformation program that is under re-evaluation. With that program now on hold
2		the Company will invest in an upgrade of the EZMax mobile product in 2025 to
3		ensure that users retain the ability to work effectively at the point of activity using
4		an up-to-date product.
5		
6	Q240.	What are the benefits of Enhance Maximo Capabilities and Processes?
7	A240.	This project will bring more of the capability of the existing Maximo system to the
8		front line in the form of additional inspection forms, inspection workflows and
9		expanded asset information. Bringing this capability to the field worker will
10		eliminate a portion of the remaining paper-based data collection as well as ensuring
11		that field teams have electronic access to the up-to-date equipment records when
12		performing work making that work safer and more efficient.
13		
14	Prima	ry Sarvice Orders Repletform
	<u> </u>	
15	Q241.	What is the Primary Service Orders (PSO) Replatform?
15 16	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting
15 16 17	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them
15 16 17 18	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer
15 16 17 18 19	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services
15 16 17 18 19 20	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services Group, other departments such as Regional Relations, MAS, and the Relay Group
15 16 17 18 19 20 21	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services Group, other departments such as Regional Relations, MAS, and the Relay Group use this system when working with or for these customers.
 15 16 17 18 19 20 21 22 	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services Group, other departments such as Regional Relations, MAS, and the Relay Group use this system when working with or for these customers.
 15 16 17 18 19 20 21 22 23 	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services Group, other departments such as Regional Relations, MAS, and the Relay Group use this system when working with or for these customers. The PSO Replatform project is a 3-year investment beginning in 2024 with a
 15 16 17 18 19 20 21 22 23 24 	Q241. A241.	What is the Primary Service Orders (PSO) Replatform? The Primary Services Group at DTEE is responsible for working with and assisting many of the Company's largest commercial and industrial customers. To help them perform their work, a web-enabled tracking system that houses primary customer information is used. In addition to being an important tool for the Primary Services Group, other departments such as Regional Relations, MAS, and the Relay Group use this system when working with or for these customers. The PSO Replatform project is a 3-year investment beginning in 2024 with a targeted completion in 2026. The scope of the project has 4 major components:

Line <u>No.</u>		
1		• Capture and maintain detailed customer information and electronic primary
2		operating orders.
3		• Digitize and archive the primary customer infrastructure as-builts and sketches.
4		• Build interfaces between the new application and supporting systems, such as
5		customer relationship management, enterprise asset management and mapping
6		systems.
7		
8	Q242.	What are the key drivers of PSO Replatform?
9	A242.	Today there are three separate systems required to fully support these functions.
10		The PSO Replatform project will combine all the existing systems into one
11		consolidated system and provide automated connections to other systems that today
12		are not connected. This new system, when fully implemented, will connect with
13		other customer facing systems such as the customer relationship management
14		(CRM), enterprise asset management (Maximo) and mapping systems (ESRI). The
15		current primary services application requires extensive manual processing and data
16		entry, resulting in productivity loss and an inability to keep up with increasing
17		demand. This negatively impacts the customer experience and level of service
18		DTEE can provide.
19		
20	Q243.	What are the benefits of PSO Replatform?
21	A243.	The goal of this project is to create a single system that houses primary customer

A243. The goal of this project is to create a single system that houses primary customer
 information and equipment needed to isolate customers from DTE Electrical
 system and vice versa. This system will provide support to field resources with
 quick access to customer infrastructure and eventual connectivity to ESRI, Maximo
 & CRM with up-to-date information needed to effectively support primary

Line <u>No.</u>	
1	customer needs. Customers will receive better and faster service and employees
2	will be able to effectively handle more requests faster.
3	
4	External Crew Efficiency
5	Q244. What is External Crew Efficiency?
6	A244. External Crew Efficiency is a category of capital investments targeted at the
7	efficient and cost-effective use of external contract crews used to augment
8	Company crews. The capability to utilize external crews efficiently and cost-
9	effectively is a key component to improving the speed and efficiency of storm
10	restoration. The primary investment in this category is the Utility Restoration
11	Management Application (URMA).
12	
13	Q245. What is URMA?
14	A245. URMA is an application that will manage crew rosters for external contract crews,
15	track current jobs status and work completed in the field, while enabling visibility
16	into contractor productivity and payment.
17	
18	Q246. What are the key drivers of the URMA application?
19	A246. The Company relies heavily on external contract crews to support restoration
20	efforts when there is a significant event on the grid, especially during major weather
21	events. As the Company works to improve restoration for customers during storms
22	the command, control and logistics associated with the deployment of those crews
23	has never been more critical. Currently the Company lacks visibility into work
24	performed by non-DTE contract crews and cannot easily measure productivity for
25	these crews. Additionally, the rosters submitted for these crews are not

Line	
<u>No.</u>	

1		standardized, many being excel files that are submitted individually, making it
2		challenging to easily view and analyze rosters for all crews. In order to reduce
3		waste and improve productivity, ultimately leading to faster storm restoration, the
4		Company needs improved visibility and monitoring over these crews.
5		
6	Q247.	What is the scope of the URMA application?
7	A247.	This is a multi-year project that began in June of 2023 with the first implementation
8		occurring in February of 2024. Delivered in that first implementation was an end-
9		to-end crew rostering application. The rostering application standardizes qualified
10		crew make up and the equipment used at the job site by external contract crews,
11		enabling operational control and the development of cost benchmarking to assist in
12		continuing to reduce overall cost per outage event.
13		
14		The next set of investments for 2024 and 2025 are planned to include:
15		• Mobile application expansions that will status and ensure workflows for all
16		assigned work.
17		• A work completed input form that will document all material used, actual work
18		completed by teams in the field, give visibility on work mix, and validate
19		invoices from external contract crews.
20		• Expand rostering capabilities to Baseload contractors, Secure First, Single
21		Damage Assessors, and Damage Assessors to deploy these teams efficiently
22		and accurately.
23		• Expand the use of the electronic mobile work application to Baseload
24		contractors, Secure First, Single Damage Assessors, and Damage Assessors.

	• Expand the use of the work completed input form to Baseload contractors,
	Secure First, Single Damage Assessors, and Damage Assessor.
	• Deliver a billing app to document contractor time entries, validate work
	assignments, and expedite accurate invoicing.
]	Productivity improvements for outages include:
•	• Enhanced functionality in URMA will allow external contract crews to have
	quick electronic access to job specific information (maps, assignments,
	chronology), driving improvements on patrol and restoration times.
•	• Real time job status and updates on work required will allow the Emergency
	Field Leaders and Regional Incident Command to take quick action to manage
	crews more effectively.
	• Clear line of sight into crew make-up and available equipment will inform
	resource assignment and optimization.
•	• Right-crew to the right job: Contractor resources are currently not optimized
	across restoration work type (i.e., too many contractors on smaller jobs or
	spending too much time on the job). Using Single outage jobs as an example,
	most jobs require only 2 crew members and should be completed in less than 2
	hours.
Q248. V	What are the benefits of the URMA application?
A248. (Currently, much of the coordination with external contract crews is manual process-
ł	based and not system-enabled. This can lead to gaps in timely visibility into work
	Q248. 4 A248. 6

Line

performed in the field, challenges with the ability to measure foreign and contractor
crew productivity, and overall control of those resources in real-time. These

Line N<u>o.</u>

> 1 challenges are further exacerbated during major storms. The benefits of URMA 2 include: reduction of waste through improved quality controls and crew validation; 3 improved ability to monitor and audit contractor invoicing to ensure accuracy; and 4 improved visibility of contract crew work scope and real time job statues. The crew 5 rostering application supports the reduction of waste and improved auditing of 6 contractor invoicing by providing visibility, validation and verification of crew pay 7 rates, crew sizes, and equipment utilized per job. The improved visibility of 8 contract crew work scope and real time job statuses provides the Company 9 leadership increased oversight and ability to monitor performance and drive 10 productivity real time during storm restoration. Additionally, URMA provides more efficient communication of contract crew work assignments directly to the 11 12 crews, reducing wait time for crews to receive work assignments, and allows 13 contract crews to access job specific information electronically, improving 14 restoration time. The Company has estimated these improvements will drive 15 efficiencies and productivity in storm restoration efforts, reducing the average 16 storm duration by three hours.

17

18 Work Management and Scheduling Upgrades

19 Q249. What Work Management & Scheduling upgrade investments were made in 20 2022 and 2023?

A249. Type 2 Customer Communication & Process Efficiency - (Closed Loop) - Phase 2,
 Contract Agreement System (CAP) Replacement, Maximo Application Suite
 Upgrade Phase 1 sponsored by Company Witness Sharma, Crew Management
 Enhancements (2022/2023), multi-year renewal license purchase for ARCOS

Line <u>No.</u>	
1	operator call out application, PMO Primavera upgrade and field operations tools
2	automation are the investments made in 2022 and 2023.
3	
4	Q250. What is the Type 2 Customer Communication & Process Efficiency Closed
5	Loop project?
6	A250. The Type 2 Customer Communication & Process Efficiency – Closed Loop project
7	included the development of a new application designed to track customer type 2
8	damage claim interactions, instances where customers file a claim that the
9	Company damaged their property while performing work. The new application
10	was initiated to improve claim management, communication with customers
11	regarding their claim, and reduce overall process cycle time for customers.
12	
13	Q251. What are the key drivers of Type 2 Customer Communication & Process
14	Efficiency?
15	A251. The Damage Claims group historically utilized multiple systems, or tools such as
16	Excel, to manage damage claims and communicate updates to customers. These
17	systems were not integrated, nor did they provide visibility to all key stakeholders
18	and customers. The cycle time to resolve damage claims was on average 60-90
19	days, and there was no automated way to send customers standard updates
20	throughout the process and when claims were closed. Additionally, when customers
21	called into the DTEE call center, the call center representative did not have
22	visibility into a claim status and could not provide the customer information
23	regarding a claim. As a result, the Company received complaints from customers

25

Line No.

Q252. What are the benefits of Type 2 Customer Communication & Process Efficiency?

3 A252. With the completion of this project claims are tracked and processed centrally 4 through the new application which includes all case information and is integrated 5 in the Company's customer relationship management system (CRM). This 6 includes a validation tool for customers to confirm their claims have been 7 submitted, a feedback loop for customers once claims have been resolved, and a 8 one stop repository for both active and resolved claims. This investment improved 9 the response time for damage claims resolution, with the average response time 10 dropping from an average of 60-90 days down to 23 days in 2023. Additionally, this system is integrated with the Company's CRM, which allows customer service 11 12 representatives in the call center to see claim statuses and provide customers 13 updates as requested. This investment also enabled the Company to automatically 14 send weekly communications to customers regarding claim status updates and a 15 communication when a claim has been resolved through various methods such as 16 letters, texts and calls. In 2023, 100% of customers that filed a claim were 17 communicated to upon claim resolution.

18

19 Q253. What is the Contract Agreement System (CAP) Replacement?

A253. In 2022 the Company began a project to replace the existing Contract Agreement
 System (CAP). That system was an internally created program which was no longer
 meeting the needs of the business unit. The system did not have the capability to
 easily create new agreement types and had no electronic document signing or
 interchange mechanisms.

25

Line No.

1 **Q254.** What are the key drivers of CAP Replacement?

A254. The Company enters into over \$3 million dollars a year in contracts for new business and construction/service work. The current system is limited in the information it provides and inefficient, it does not include automated workflow for timing, nor does it have alerts to assist the contracts team in understanding when any step in the process has taken longer than expected to complete. This can result in extended construction service times and negatively impact customers that are attempting to have services performed by the company on their behalf.

9

10 Q255. What are the benefits of CAP Replacement?

A255. This system helps the Company remain compliant with service levels related to 11 12 timing for new business and construction/service work for customers. In addition, 13 it provides the flexibility to create new types of agreements, allows more rapid 14 process improvements more easily than the previous system, and has improved 15 worksheet operability covering 15 electric service and construction agreements. For 16 customers, this translates into more efficient contract approval, a simplified 17 electronic routing processes for document management and leverages DOCUSIGN 18 for electronic signature to improve the customer experience.

19

20 Q256. What is Crew Management Enhancement?

A256. Crew Management Enhancement is a Crew Rostering system for DTEE crews that
 replaced the outdated Crew Rostering system and will be integrated into the URMA
 application as it goes into service. This is crucial for the Company's operational
 groups to effectively build, manage, and deploy crews while adhering to union

Line <u>No.</u>		0-21334
1		agreements and maintaining DTEE's commitment to safe, timely, and qualified
2		service.
3		
4	Q257.	What are the key drivers of Crew Management Enhancement?
5	A257.	DTEE employs processes and systems for resource management of internal DTEE
6		crews. The two-year project brought significant improvements, including
7		infrastructure updates, enhanced crew visibility, automated tracking of overtime
8		and training, adjustments for union contracts, and the integration of apprentice
9		rostering without manual intervention. Additional enhancements in 2024 and 2025
10		is part of the External crew efficiency project.
11		
12	Q258.	What are the benefits of Crew Management Enhancement?
13	A258.	The capacity to efficiently roster and deploy crews ensures that work can be
14		accomplished with greater safety and speed.
15		
16		In 2022, the system transitioned to new infrastructure, improving performance, and
17		features such as visible crew resources, automated overtime and training tracking,
18		and integration of vacation calendars were introduced. A visual dashboard
19		increased crew availability visibility, and record-keeping for employee OT
20		scheduling improved.
21		
22		Continuing into 2023, continuous improvement led to additional enhancements, a
23		dedicated training environment, adaptability to changes in union contracts, Fleet
24		Organization integration for calendaring and OT reporting, and expanded
25		management-level reporting. The introduction of a training environment allowed

Line <u>No.</u>	
1	users to train on the rostering system beyond initial introductory training. With the
2	ability to effectively roster and deploy crews, work will be done more safely and
3	quickly.
4	
5	Q259. What is PMO P6 Primavera Refresh project?
6	A259. PMO P6 Primavera Refresh project is an upgrade from the current unsupported
7	version of Primavera Scheduler used by DO Scheduling and DO PMO Groups to
8	the newest version of Primavera. In addition, the project includes the replacement
9	of the current WTA (Walter Tanner & Associates) interface between Primavera and
10	Maximo with an industry standard product called Maxavera.
11	
12	Q260. What are the key drivers of PMO P6 Primavera Refresh?
13	A260. Primavera is the scheduling software used by DTEE's DO Scheduling and PMO
14	Groups to manage and execute the entire DO strategic capital investment. The
15	current version of Primavera used by DO Scheduling and PMO was 16 major
16	revisions behind and unsupported by the vendor. If the software were to crash, DO
17	Scheduling and PMO would lose the ability to manage the DO strategic capital
18	portfolio, affecting critical capital investments in the grid.
19	
20	Q261. What are the benefits of PMO P6 Primavera Refresh?
21	A261. The upgraded Primavera version (and Maxavera interface product) will eliminate
22	data latency that is currently present with the Primavera and Maximo systems and
23	provide a more robust application. It will also bring the DO PMO group to the
24	same version of the scheduling product as the corporate project management office
25	is using allowing fee exchange and interoperability of schedules across all DTEE.

Line	
<u>No.</u>	

1	Q262.	What is the Multi-year Renewal license purchase for ARCOS?
2	A262.	DTEE has utilized the ARCOS Callout solution for several years, necessitating
3		frequent license renewals. Recently, the company successfully negotiated a
4		comprehensive 5-year agreement during the latest renewal, preventing year-over-
5		year cost increases and ensuring elevated warranty support throughout the period.
6		
7	Q263.	What are the key drivers of Multi-year Renewal license for ARCOS?
8	A263.	The ARCOS license was expiring, and the Company was facing potential cost
9		increase for future licenses. This system is crucial for the Substations group to
10		conduct after-hours callouts while adhering to collective bargaining agreements
11		and union rules.
12		
13	Q264.	What are the benefits of Multi-year Renewal license for ARCOS?
14	A264.	This investment ensures the continuity of an operational callout system,
15		maintaining efficiency and reliability in managing after-hours dispatching for the
16		substations group. By negotiating a 5-year agreement the company was able to
17		reduce future cost increases for licenses and obtain elevated warranty support.
18		The ARCOS system itself enables timely and accurate job callouts, reducing
19		response times for substations employees to respond emergent issues on the grid.
20		
21	Q265.	What is Field Operations Tools Automation?
22	A265.	Field Operations Tools Automation is an investment undertaken to replace existing
23		operational tools, applications and dashboards that perform important operational
24		control functions but that no longer have the capability to support DTEE's rapidly
25		evolving operational processes. Some DO apps use extremely old technology and
		SMH-172

1

2

3

4

utilize on-premises servers. These apps are built on 20-year-old foundations, such as classic ASP and PHP, which substantially increases maintenance cost. The objective is to automate manual efforts and reduce reliance on managing operations through excel spreadsheets.

5

6 In 2023, a project to develop a system for use in confirming Customer Power Status, 7 particularly in-line with restoration efforts was in place. The project created a 8 facility to visualize the power status of meters at Customer sites along with the state 9 of the communications devices necessary to backhaul the data to DTE. This utility 10 gives insights to analysts tasked with determining why the current power state at a 11 customer site is unknown and facilitates detection of nested outages or field 12 communication devices that may need repair.

13

14 Q266. What are the key drivers of Field Operations Tools Automation?

15 A266. As the Company continues to work to improve its operations both in normal 16 weather conditions and during increasingly frequent weather events it continues to 17 rely upon both departmental applications and internally built solutions. Many of 18 these solutions do not scale and are not serving current or emerging needs 19 adequately. Several systems that measure day-to-day performance are dependent 20 on manual steps and do not have a consistent approach to data management. Report 21 generation is not consistent between groups/regions/service centers. This leads to 22 process inefficiencies and reduces situational awareness. The Field Operations 23 Tools Automation project was undertaken to begin to select the most important of 24 these use cases and automate them in an effective and supportable manner.

Line
NT.

<u>No.</u>

1

2

3

4

Increasing automation in these activities will increase visibility into process adherence, help better identify gaps and improve situational awareness. Q267. What are the benefits of Field Operations Tools Automation?

A267. For customers, this investment will result in tighter control of field events, more
information in the hands of crews to be shared with customers at their work
locations and improved response and restoration times during outage events.
Employees will be able to minimize usage of and reliance upon cumbersome
manual processes, add new opportunities to collaborate when reviewing/ sharing/
editing, and tracking activities. Instances of duplicative effort and human error will
be reduced. Team members can focus on value-add versus manual activities.

12

The 2023 efforts around CPS facilitated faster detection of on-going electric service and communication network issues that can impact a customer's service restoration and timely notifications. It was important to undertake the project in the time frame it was executed to provide supporting insights to the larger Customer Power Status Visualization (CPSV) program efforts designed to improve DTEE's outage detection and service restoration efforts.

19

25

Q268. What are the new investments planned for 2024 and 2025 in the Work Management & Scheduling upgrade category?

- A268. The planned investments in the work Management & Scheduling upgrade category
 for 2024 and 2025 are: Circuit ownership app, Wiredown Associated Call
 Enhancement, and moving Mobile timesheet (MTS) Data to cloud.
 - Circuit Ownership application:

Line
<u>No.</u>

1	The Circuit Ownership App is a new tool that consolidates data to a central location
2	for the Circuit Owner's comprehensive review. This data encompasses AMI Meter
3	Data, SCADA Data, Circuit Maps, current Maximo Work Orders in the field, and
4	Damage Assessment Information.
5	The new tool will facilitate a centralized contact accountable for real-time circuit
6	performance, strategizing, and advocating for the circuits. This strategy may
7	involve both short-term reliability projects (completed in under a year) and
8	extensive multi-year reliability projects.
9	The identified benefits include a streamlined process, reducing engineers' time
10	navigating various systems, resulting in quicker analysis and decision-making for
11	service-affecting issues on the circuits they oversee.
12	
13	• Wiredown Associated Call Enhancement:
14	The company frequently receives redundant reports of wires down in the field,
15	resulting in the creation of multiple jobs in OMS. This causes delays and
16	unnecessary truck rolls.
17	
	The Wiredown Associated Call Enhancement investment involves updating the
18	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing
18 19	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing productivity. The Field Service Edge application will be modified to display
18 19 20	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing productivity. The Field Service Edge application will be modified to display associated calls on a job, enabling crews to access necessary data for safe evaluation
18 19 20 21	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing productivity. The Field Service Edge application will be modified to display associated calls on a job, enabling crews to access necessary data for safe evaluation of wire down incidents and addressing public safety concerns. This enhancement
18 19 20 21 22	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing productivity. The Field Service Edge application will be modified to display associated calls on a job, enabling crews to access necessary data for safe evaluation of wire down incidents and addressing public safety concerns. This enhancement aims to streamline and enhance the efficiency of wiredown job responses.
 18 19 20 21 22 23 	The Wiredown Associated Call Enhancement investment involves updating the OMS to efficiently link wiredown jobs, reducing wasted truck rolls and enhancing productivity. The Field Service Edge application will be modified to display associated calls on a job, enabling crews to access necessary data for safe evaluation of wire down incidents and addressing public safety concerns. This enhancement aims to streamline and enhance the efficiency of wiredown job responses.

Line <u>No.</u>

1		Presently, the Company can observe general time sheet charges and manually delve
2		into specifics for OH/UG crews for an event requiring a truck roll.
3		The new cloud-based data will allow the OH/UG teams to automate reports on
4		detailed crew time charges, enhancing our understanding of defect codes like wait
5		time. Utilizing the cloud data platform will integrate disparate sources, such as
6		Mobile Timesheet charges and Outage Management events, enabling automated
7		reporting dashboards for timely field productivity visibility.
8		The implementation of this system can eliminate approximately 2 hours of daily
9		manual work for four individuals, equivalent to a full-time Operations Analyst
10		position worth \$80,000 per year. This will not completely offset the position, but
11		provides an opportunity for more productive and analytical tasks. Additionally, it
12		increases the capacity to run reports for all Service Centers, saving time and
13		identifying opportunities to enhance field productivity, both in storm and non-storm
14		scenarios.
15		
16	J.	Asset Management
17	Q269.	What is Asset Management?
18	A269.	Asset Management is a category of investments that involve utilizing technology
19		to support effective asset management. These investments include projects that
20		support managing physical assets, such as personal protective gear and large fleet
21		vehicles, as well as projects that support electronic asset data management.
22		

Q270. Where are the capital investment details of the projects and programs in this category?

Line No.

A270. Capital investment details of these projects and programs in this category are included in:

- Exhibit A-12, Schedule B5.4, page 17-18
- Exhibit A-23, Schedule M7
- 5 6

3

4

Table 11 Asset Management Exhibit Locations

Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
Systematic Tracking of Rotatable Assets	p. 17, line 22	pp. 207-210	pp. 157-159
Asset Management Upgrades	p. 17, line 21	pp. 21-24	pp. 157-159

7

8 Systematic Tracking of Rotatable Assets

9 Q271. What is the Systematic Tracking of Rotatable Assets?

10 A271. This new investment in 2025 includes developing and implementing a digital 11 tracking repository for items like personal protective equipment that have 12 expiration dates and must be managed through their deployed life cycles. It 13 improves the accuracy, efficiency, and accountability on the movement of materials 14 within a process. Examples include Field tracking of assets using RFID (radio 15 frequency identification trackers) readers on trucks, in warehouses and tracking 16 rubber goods (sleeves and gloves used by line workers) for front line employees. 17 Benefits include decreasing the risk of having outdated assets in the field, and improving the accuracy, efficiency, and accountability on the movement of 18 19 materials within a process.

20

21 Q272. What are the key drivers of Systematic Tracking of Rotatable Assets?

1	A272.	Field tracking of assets that must be rotated in and out of the field on a regular
2		cadence and the record keeping needed to ensure that none of them remain deployed
3		beyond their expiration date is a key and critical component of DTEE's overall
4		safety program. Prior to this investment, these assets were being tracked manually.
5		A practice subject to human performance or tracking errors.
6		
7	Q273.	What are the benefits of Systematic Tracking of Rotatable Assets?
8	A273.	Ensuring that all PPE is current and safe to use will reduce the likelihood of injury
9		to workers, a core value of the Company.
10		
11	Asset	Management Upgrades
12	Q274.	What is the Brigade 360 Cameras Project?
13	A274.	The Brigade 360 cameras project was an investment specifically undertaken to
14		reduce the occurrence of motor vehicle accidents and improve crew and facility
15		safety. This included installing 360-degree cameras on Distribution Operations
16		vehicles. These cameras provide additional views that allow drivers to see aerial
17		equipment hazards.
18		
19	Q275.	What are the key drivers of the Brigade 360 Cameras Project?
20	A275.	DTEE's bucket and digger trucks represent a significant investment on the road,
21		and due to their size and driver visibility have some inherent challenges with
22		impacts of low hanging tree limbs, awnings, etc. Safeguarding these assets and
23		ensuring their operational efficiency is crucial for success, especially when
24		considering the limited availability of trucks in the overall market. This technology
25		investment provides for both real-time and recorded imagery for crews and allows

1 them to operate their vehicles with more situational awareness and higher levels of 2 safety. Between 2022 and 2023, 550 heavy-duty vehicles, 37 medium-duty 3 vehicles, and 69 light-duty vehicles were fitted with the Brigade 360 cameras. 4 Approximately 60 bucket trucks and 250 light trucks in the fleet are awaiting fitting 5 of the system. 6 7 Q276. What are the benefits of the Brigade 360 Cameras Project? 8 A276. Impacts with tree limbs and overhead structures happens typically more than a 9 dozen times per year and can cost as much as \$3,500 each time to repair the bucket 10 and other parts of the vehicle. 11 The Company made this investment with the goal of decreasing motor vehicle 12 incidents, measured by the Collisions per Million Miles (CPMM) metric. Since 13 inception, motor vehicle accidents have decreased from 140 (2022) to 119 (2023), 14 marking a 17% improvement. It's crucial to note that factors like inclement weather 15 and road conditions affect this metric, and this investment is part of a broader effort 16 to enhance vehicle safety. Lowering vehicle incidents not only enhances public 17 safety but also reduces expenses associated with repairing or replacing damages, 18 contributing to overall affordability of products. 19 20 K. Mobile Technology 21 Q277. What is Mobile Technology? 22 A277. Mobile Technology is a category of investments focused on creating seamless 23 transitions between on-line and off-line operations and provide integrated 24 communication, including workflows, between the control room, field leaders, field

25 crews, and supporting organizations. Mobile capabilities include both devices and

<u>No.</u>	
1	applications that are engineered for mobile access and usage. Applications include
2	dispatch, work execution and forms digitization, location tracking, route
3	navigation, analytics, and secure file sharing.
4	
5	Q278. Where are the capital investment details of the projects and programs in this
6	category?
7	A278. Capital investment details of these projects and programs in this category are
8	included in:
9	• Exhibit A-12, Schedule B5.4, page 17-18
10	• Exhibit A-23, Schedule M7
11	
12	Table 12Mobile Technology Exhibit Locations

Program/Project	Exhibit A-12 Sch. B5.4	Exhibit A-23 Schedule M7	Exhibit A-23 Schedule M8
Mobile Tools Expansion	p. 18, line 50	pp. 116-119	pp. 133, 159-161
Maintain Compliance	p. 18, line 51	pp. 96-99	pp. 133, 159-161
Enhance and Expand Cybersecurity	p. 18, line 52	pp. 58-61	pp. 133, 159-161
Mobile Equipment Replacement	p. 18, line 53	pp. 108-111	pp. 133, 159-161
Mobile Technology	p. 18, line 54	pp. 112-115	pp. 133, 159-161

13

Line

14 Mobile Tools Expansion

15 Q279. What is Mobile Tools Expansion?

A279. Mobile Tools Expansion is a category of investments related to tools and
 applications utilized by field resources. Mobile tools are a critical investment to

Line <u>No.</u>		
1		support operational crews and leadership drive efficiency, productivity, and safety.
2		The primary investment in this category is the Every Day Daily Plan (EDDP).
3		
4	Q280.	What is Every Day Daily Plan (EDDP)?
5	A280.	The Everyday Daily Plan is a web application designed to serve as a consistent
6		"all-weather" tool for both storm and non-storm scenarios. This tool facilitates the
7		Company's response to planned and trouble work on the electric system, utilizing
8		real-time data to bundle and prioritize jobs. Customizable inputs allow for the
9		escalation of variable customer needs, such as Election Day Polling Locations and
10		School Count Day. The EDDD will work in tandem with an auto-assign function,
11		driving optimization of job and crew dispatch for the first job of the day.
12		
13	Q281.	What are the key drivers of EDDP?

14 A281. After the 2023 catastrophic ice storm the Company undertook a series of actions to 15 take advantage of system capabilities and opportunities that were never possible 16 prior to the replacement of the outdated OMS system in February of 2023. The 17 lessons learned during that storm and the capabilities that the new systems offered 18 allowed DTEE to explore opportunities within its mobile tools, which will 19 ultimately dramatically transform the ability to serve customers quickly and safely 20 as power is restored after significant storm events. This EDDP was begun as one 21 of multiple ways that DTEE will bring new capability to field teams. Historically, 22 planning and prioritizing work for the day involves using multiple databases, 23 human performance for priority evaluation, and manual phone calls. Additionally, 24 the prioritization and bundling of work during a storm utilized different tools than 25 normal operations day to day work. During storm situations a team of five

Line	
No.	

1 individuals worked 16 hour shifts through the night manually developing a storm 2 restoration plan for the next day. Also, during storm and during normal operations 3 the first job a crew received was manually dispatched to the crews, at times causing 4 delays for crews getting to their first job of the day, especially during high event 5 days and storms. The EDDP enables the automation of several processes, such as 6 prioritization, bundling and auto-assigning work of work, reducing manual work 7 and driving efficiency. This ultimately improves crew efficiency and enables crews 8 to get to their first job quicker, reducing restoration time for customers.

9

10 **Q282. What are the benefits of EDDP?**

11 A282. The EDDP streamlines storm and normal operations daily planning processes, 12 creating one standard process used during all weather events. This tool automates 13 daily work prioritization, budling and dispatching of the first event of the day to 14 crews in the field. The automation of this work reduces manual labor and individual 15 decision making, drives efficiency through bundling of work and geographically 16 routing, and improves restoration efforts through faster dispatching of jobs in the 17 morning. The tool will seamlessly integrate all crews, of all types, into flexible and 18 timely daily plans. The EDDP will reduce an average one hour a day per crew in 19 wait time for their first job of the day, increasing productivity and reducing 20 restoration time for customers.

21

22 Maintain Compliance

23 Q283. What is Maintain Compliance?

A283. DTE Electric is subject to multiple regulatory authorities and must maintain compliance with the MPSC, FERC, NERC and other industry regulations and

Line
No.

1	orders. The level of regulatory and industry oversite has grown to the point that a
2	program is being undertaken to ensure successful compliance. This investment is
3	expected to grow year-over-year, especially beyond 2025 when the Company
4	anticipates the need for additional compliance components to be required on several
5	topics including but not limited to energy justice (EJ), electrification, cyber security
6	and expanding NERC requirements. Having access to accurate, timely and
7	complete operational data is key for compliance. System investments to compile
8	day-to-day operational information and demonstrate compliance are needed to
9	replace labor intensive manual methods that have been used to date.

10

11 **Q284.** What are the key drivers of Maintain Compliance?

12 A284. Real-time operational data enables DTEE to adapt to changing regulations and 13 demonstrate adherence to those changes. Investing in compliance automation to 14 meet new demands and having data accessible in a timely and cost-effective manner 15 for reporting are some examples as to why this investment is prudent.

16

17 Q285. What are the benefits of Maintain Compliance?

18 A285. Like any other industry the Company stewards a body of sensitive data required for 19 effective operations. This data includes electrical system, operational, customer, 20 and payment data. Many regulations and compliance mandates govern the 21 Company's use of this information and how it must be safeguarded. DTEE's 22 customers benefit from this investment when the information is collected, used, and 23 secured in such a way that the information is safeguarded both within Company 24 facilities and when in the hands of DTEE employees while serving the customer at 25 their location. Employees benefit by having ready access to the information needed

Line <u>No.</u>	
1	to serve wherever the work requires, knowing that mobile systems comply with all
2	the regulations that govern their job functions.
3	
4	Enhance and Expand Cybersecurity
5	Q286. What is Enhance and Expand Cybersecurity?
6	A286. The Company plans to invest hundreds of millions of dollars in its grid automation
7	programs over the next decade. The automation that is placed in the field to enable
8	that automation and control must be protected from cyber-attack and that protection
9	presents unique and ever evolving challenges as bad actors will recognize this field
10	automation as a potential that they will look to exploit. This project is designed to
11	place targeted technologies, both hardware and software, into the Company's
12	infrastructure in a controlled manner to test and evaluate the most effective ways to
13	address these threats.
14	
15	Q287. What are the key drivers of Enhance and Expand Cybersecurity?
16	A287. Industry-wide there is recognition both for the need to automate the ever evolving
17	and more complicated grid to control it in real-time and that this automation will
18	create potential vulnerabilities for outsiders to exploit. If these potential threats are
19	not addressed early in automation programs, then the opposition will gain a
20	significant advantage over the Company's ability to safely operate the grid. This
21	program will assess the cybersecurity needs for this infrastructure and inform the
22	selection of tools and techniques to combat these threats.
23	

24 **Q288.** What are the benefits of Enhance and Expand Cybersecurity?

Line	
No.	

1	A288.	Adequately understood and implemented tools and countermeasures will serve to
2		ensure that the grid is as reliable, available, and defensible as possible. Customers
3		will benefit from a more resilient, more effectively run grid, while at the same time
4		this project will be foundational in ensuring that only the authorized operators are
5		able to access and control the automation that is put in place. This is critical from
6		both a safety and an operational standpoint.
7		
8	<u>Mobil</u>	e Equipment Replacement
9	Q289.	What is Mobile Equipment Replacement?
10	A289.	The Company has thousands of mobile devices that have been deployed to front-
11		line workers and their leadership. These devices have planned useful deployed
12		lifecycles of 6 years. The Company plans and executes device replacements yearly
13 14		on \sim 1/6th of those devices to keep the devices operational and secure.
15	Q290.	What are the key drivers of Mobile Equipment Replacement?
16	A290.	Up to date devices are more reliable and technically secure from cyber threats than
17		older, less capable equipment. It is important for field workers to have operational
18 19		and up-to-date equipment to perform their work functions safely and effectively.
20	Q291.	What are the benefits of Mobile Equipment Replacement?
21	A291.	Correctly functioning equipment running effectively, and up-to-date systems
22		contribute to efficient processes and work completion, an advantage to customers
23		in terms of DTEE's ability to be responsive to their needs and helps shorten outage
24		restoration times.
25		
Line		

<u>No.</u>		

1	<u>Mobil</u>	e Technology
2	Q292.	Why has the Company chosen to represent its Mobile Technology spend more
3		specifically in this rate case?
4	A292.	In previous rate cases, Mobile Technology was represented in the financial exhibit
5		as the sum of several included projects and talked about at that higher level.
6		Feedback from the commission and the types of discovery questions from
7		intervenors indicate that a more itemized approach was desired so for this case that
8		category has been reworked to itemize its key investments.
9		
10	Q293.	What were the key investments made in 2022 and 2023 that are Mobile
11		Technology?
12	A293.	The key investments grouped under the heading of Mobile Technology were
13		Outage Status App Changes for Damage Assessment, Tree Trim's Vegetation
14		Management Software Replacement Pilot Project, Service Center Wi-Fi Upgrades,
15		Lemur Pro Multiyear License Purchase and Field Service Edge Overhead
16		(OH)/Underground (UG) Enhancements.
17		
18	Q294.	What is Outage Status App Changes for Damage Assessment?
19	A294.	The scope of this project was to create a capability within the Outage Status
20		Application (OSA), the mobile storm tool used by DTEE's tree trim and all foreign
21		crews for storm response, allowing automated near real time access to update
22		damage assessment from the field to planning staff.
23		
24	Q295.	What are the key drivers of Outage Status App Changes for Damage
25		Assessment?

Line No.

> 1 A295. Over the last several years the amount and severity of damage caused by storm 2 events has increased as weather in Michigan changes for the worse. It is critical 3 that damage assessment teams get into the field and get their data back to planning 4 staffs as rapidly as possible immediately following an event. get. This project adds 5 damage assessment capability to one of DTEE's key field tools that it previously 6 did not incorporate. With the inclusion of this capability, the automated damage 7 assessment form is accessible by all damage assessors to record and provide 8 information on outage events with this information flowing into the OMS system 9 in real time as the form is completed and sent electronically.

10

11 Q296. What are the benefits of Outage Status App Changes for Damage Assessment?

12 A296. Having damage assessment data rapidly available allows the Company to plan 13 restoration work more accurately for any given outage event. This information 14 provides crews with advance knowledge about what types and quantities of 15 materials they may need due to the assessor's detailing of the actual location and 16 severity of the damage that has occurred. This benefits the customer in faster 17 restoration times and more accurate estimates. It also advantages the Company's 18 employees as advance notice of this kind improves the safety of the workers and 19 the efficiency of logistic response at the point of damage. A final benefit comes 20 from use of the damages assessment data to predict the needs for future events. 21 Where this data is available, it can be used to model future events and improve 22 work standards and processes. If damage levels in advance of an incoming event 23 can be better predicted, then the ability to have the right number of resources deployed at the right locations will continue to improve response times, repair 24 25 effectiveness, and overall cost per event.

SMH-187

Q297. What is Tree Trim's Vegetation Management Software Replacement Pilot Project?

- A297. The Company's existing Vegetation Management system is approaching end of life
 and will need to be replaced within the next 3-4 years. This pilot project is a key
 component in selecting an appropriate replacement that will fulfill the business
 outcomes needed for achieving and maintaining a 100% on cycle trimming program
 and helping to move the Company to predictive on demand vegetation
 management.
- 9

Q298. What are the key drivers of Tree Trim's Vegetation Management Software Replacement Pilot Project?

12 A298. The replacement of DTEE's existing Vegetation Management tool will be a 13 multiyear, multi-million-dollar investment. The Company solicited multiple 14 companies through a formal RFP and selected an initial preferred partner. To verify 15 this selection a pilot project was undertaken to demonstrate the capabilities of that 16 selected software to further validate the selection before accepting the final 17 statement of work for the larger program. The activities within the pilot will allow 18 the team to experience firsthand the software, participate in configurations based 19 on key business requirements, experience onsite training, perform device setup, 20 engage in ongoing Q&A and evaluate vendor support throughout pilot program. 21 All these activities will validate the front runner's solution in the Company's 22 environment and shorten overall implementation of a final product. Choosing a 23 vendor without piloting the software beforehand may lead to receiving a product 24 that does not meet expectations.

1	Q299.	What are the benefits of Tree Trim's Vegetation Management Software
2		Replacement Pilot Project?
3	A299.	The pilot program is a key piece in evaluation of a potential work management
4		software replacement for Tree Trim. The pilot will highlight key business
5		functionality requirements for field and back-office users, with the goal of finding
6		and addressing any functionality discrepancies between the RFP requirements and
7		the actual vendor product prior to the beginning of the project.
8		
9	Q300.	What is the scope of the Service Center Wi-Fi Upgrades?
10	A300.	The project scope was to upgrade current Wi-Fi Infrastructure at all Service Centers
11		including Warren and the Technical Development center (TDC). It included
12		installation of additional Wi-Fi capacity / coverage. With increase of over 100%
13		in the number of mobile devices in use by teams at decentralized locations (MDTs,
14		laptops, tablets, and phones) and the increase in the size of the area that had to be
15		covered at each location, the existing Wi-Fi footprint and capacity had to be
16		increased. Addressed coverage issues inside the building and reconfigured existing
17		layout to meet updated requirements. The project also added outdoor coverage in
18		the parking areas, truck bays and garages.
19		
20	Q301.	What are the key drivers of Service Center Wi-Fi Upgrades?
21	A301.	Service Center demand on Wi-Fi has increased over time. Existing capacity and

area of coverage was no longer sufficient to support the increased usage of mobile
devices like MDTs, laptops, tablets, and phones. It became necessary to increase
indoor and outdoor Wi-Fi capacity and coverage at 15 locations (13 Service
Centers, Warren Center and the TDC.) Field personnel will be able to connect to

Line <u>No.</u> Line <u>No.</u> 1 proper applications and will have appropriate bandwidth to run applications and 2 obtain data on the network. 3 4 Q302. What are the benefits of Service Center Wi-Fi Upgrades? 5 A302. With this investment employees will be able to use their mobile tools anywhere on 6 service center property to transfer data and software updates. The original Wi-Fi 7 designs at these locations were built with the assumption that any data intensive 8 transfers (e.g., maps, software patches, and operating system updates) to mobile 9 devices would be accomplished through a wired interface with only. This limited 10 how often and how time consuming these transfers were, which in turn limited the 11 number of changes that were made. As business needs have evolved and the 12 frequency of these activities has increased a different solution was needed. As a 13 result, the process for these activities went from monthly or quarterly wired updates 14 to on demand wireless ones. This is now possible as this technology has matured, 15 and its capabilities have improved. Wireless has the capacity to deliver large 16 updates and handle hundreds of connections over longer distances. 17 18 Q303. What is Lemur Pro License Purchase and why is it necessary to have these 19 licenses? 20 A303. Purchase of 3-year Lemur Pro license renewal was completed in 2023. Lemur Pro,

from Locana, is the application used by the OH/UG/PSR field resources to access the As-Built maps of the electrical system. It provides access to the maps and equipment attribute information in both connected and disconnected/offline conditions. Crews can see the location of their work in relation to circuits and other equipment as well as the location of other crews and contractors.

Line	
No.	

1	Q304.	What are the key drivers of Lemur Pro License Purchase?
2	A304.	By purchasing a 3-year license agreement with Locana the Company, and by
3		extension the customers, can be protected From unanticipated price increases and
4		by ensuring the level of warranty support that is provided by DTEE's vendor
5		partner.
6		
7	Q305.	What are the benefits of Lemur Pro License Purchase?
8	A305.	Cost containment and Warranty support inclusion are the main benefits of this
9		investment.
10		
11	Q306.	What is Field Service Edge (FSE) for Overhead and Underground crews?
12	A306.	Field Service Edge (FSE) was deployed in Feb 2023 for electric field operations
13		and Overhead (OH) and Underground (UG) crews. The FSE mobile application is
14		being used to allow OH/UG field resources to receive trouble job assignments and
15		details associated with those jobs. At the initial launch, the Company had
16		implemented the same feature set that was originally planned for the Compass
17		mobile tool before Compass was retimed to after go-live. Once in place and in use
18		it was determined that this tool could enable additional features that would
19		contribute to improved storm restoration efforts.
20		
21	Q307.	What are the key drivers of FSE for OH/UG?
22	A307.	After the catastrophic ice storm in February of 2023 the Company focused on
23		improving storm restoration processes. Adding additional capability to the primary
24		field tool was determined to be an important investment. This led to a series of
25		enhancements to the system based on storm improvement efforts and feedback from

Line
No.

the field and dispatch teams on improvements to the usability of the FSE mobile
 app.

Some of the Field Service Edge (FSE) enhancements that were deployed to the
overhead/underground field crews in 2023 include:

- Consolidated input screens: Changes in how field crews will handle accelerated
 storm restoration led to an opportunity to consolidate some of the input screens
 that the crews interact with and ensures that all of them most important
 information in a simplified workflow.
- Added an assignment prioritization grid view that closely mimics that same functionality at a dispatchers station in the OMS. This view now highlights priority jobs, allows sorting and filtering to help crews focus during storms rather than a first in first out flow that was typical of the original product delivery.
- Implemented bulk updates and quick completions for common issues.
- Added the ability to view all the crew's current assignments on a map to assist
 in geographically tracing wire downs and circuit issues. This type of analysis
 function was previously found at the dispatch level, but this allows movement
 of that awareness and decisioning to the point of activity.
- Simplified the meter exchange job flow and allowed bar code scanning for
 serial numbers to accomplish routine tasks often associated more rapidly with
 restorations.
- Added link to report of all crews working on the same circuit to help with
 situational awareness.
- Improve data quality by enabling required functionality for specific data fields
 and formatting of data being sent back to OMS.

SMH-192

Line <u>No.</u>

1 Q308. What are the benefits of FSE for OH/UG?

- A308. The above-described enhancements to workflows and screen consolidations have
 been implemented, all of which are integral components to improve storm
 restoration efforts.
- 5

6 **Q309.** Does this complete your direct testimony?

7 A309. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

MICHAEL J. HATSIOS

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF MICHAEL J. HATSIOS

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Michael J. Hatsios (he/him/his), and my business address is One
3		Energy Plaza, Detroit, Michigan, 48226. I am employed as Director - Customer
4		Service Operations by DTE Energy Corporate Services, LLC, a subsidiary of DTE
5		Energy.
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric, DTE, or
9		Company).
10		
11	Q3.	What is your educational background?
12	A3.	I earned a bachelor's degree in mechanical engineering from Lawrence
13		Technological University in Southfield, MI, and a master's degree in business
14		administration from the University of Michigan's Ross School of Business, Ann
15		Arbor, MI.
16		
17	Q4.	What work experience do you have?
18	A4.	Prior to joining DTE, I was employed in various roles as a design and
19		manufacturing engineer for Ford Motor Company and Visteon Automotive. I
20		joined DTE in 2001, and since then I have held positions of increasing
21		responsibility in our non-regulated subsidiaries, Treasury, the Controller's Office,
22		Fossil Generation, Enterprise Performance Management (EPM), and Customer
23		Service.
24		
25	Q5.	What are your current duties and responsibilities?

2		the Chief of Staff for the Senior Vice President of Customer Service. In this role,						
3		I am responsible for the Annual Planning Cycle (APC), Customer Research, Data						
4		Analytics, and the Customer Service IT Capital, and Customer Service O&M,						
5		portions of DTE Electric and DTE Gas rate case filings.						
6								
7	Q6.	Have you previously sponsored testimony before the Michigan Public Service						
8		Commission (MPSC or Commission)?						
9	A6.	Yes. I have sponsored testimony in the following case:						
10		U-21087 Voluntary PrePay Billing Program						
11		U-21297 DTE Electric Company 2023 General Rate Case						
12		U-21291 DTE Gas Company 2024 General Rate Case						
13								
14	Part	1. Purpose of Testimony						
15	Q7.	What is the purpose of your testimony?						
16	A7.	The purpose of my testimony is to:						
17								
18		• Describe and support the Company's Customer Service IT Portfolio and capital						
19		investment in the following IT Investment Categories: Regulatory/Compliance,						
20		IT Enhancements, and Strategic.						
21		• Support the reasonableness and prudency of capital expenditures for applicable						
22		projects within DTE Electric's Customer Service IT Portfolio in the amount of						
23		\$62.1 million for the historical test year ended December 31, 2022, \$74.6						
24		million in the bridge period (for the 24 months ending December 31, 2024), and						
25		\$33.0 million for the projected test year period ending December 31, 2025. My						

1		testimony describes, among other things, how these projects improve
2		operational efficiencies, reduce operating costs, enhance customer interactions,
3		increase customer access to information, satisfy regulatory and compliance
4		requirements, and create opportunities for more customers to voluntarily
5		participate in the expansion of the Company's renewable energy portfolio.
6	•	Provide details supporting the Company's request for cost recovery of \$11.4
7		million in historical capital investments related to digital self-service projects
8		and a portion of the Advanced Analytics Use Case project that were approved
9		in Case No. U-20836 but subsequently disallowed in Case No. U-21297,
10		consisting of \$5.7 million in 2021 and \$5.7 million in 2022-2023.
11	•	Provide details supporting the capital that is being sought for the Company's
12		Error Free Communication – Outage Status initiative shown in Exhibit A-12,
13		Schedule B5.4 Distribution Plant – Technology and Automation page 18, Lines
14		33 and 40 for 2022-2023 investments and Line 33 for 2024-2025 investments,
15		in the amount of \$8.4 million for the historical test year ended December 31,
16		2022, \$5.2 million in the 2023-2024 bridge period (for the 24 months ending
17		December 31, 2024), and \$0.6 million for the projected 2025 test year period
18		ending December 31, 2025.
19	•	Discuss the variance of actual 2022 capital spend compared to 2022 capital
20		spend approved in Case No. U-21297. Additionally, provide explanation for
21		projected budget differences in 2023 and 2024 (as compared to U-21297) for
22		projects that meet the requirement established in the U-20162 final order.
23	•	Provide details of the Company's actual \$112.4 million Customer Service
24		Operation and Maintenance (O&M) expenses for the twelve-month period that
25		ended December 31, 2022, and support the Company's projected \$118.6

Line No				M. J. HATSIOS U-21534
1		million	Customer Serv	rice O&M expenses for the projected test year period
2		ending	December 31, 2	025.
3		C		
4	Q8.	Are you sp	oonsoring any e	xhibits in this proceeding?
5	A8.	Yes. I am s	ponsoring the fo	ollowing exhibits:
6				
7		<u>Exhibit</u>	Schedule	Description
8		A-12	B5.7.3	IT Customer Service Capital Expenditures
9		A-13	C5.7	Projected Operation and Maintenance Expenses -
10				Customer Service
11		A-13	C5.9.2	ACPP and TOD Regulatory Asset Deferrals
12		A-24	N1.1	Customer Service IT Business Cases - Executive
13				Summaries
14		A-24	N2	Historical Spend Variance Summary
15		A-24	N3.1	Customer IT Capital Investments with Additional
16				Project Details
17		A-24	N5	Call Volume Reduction Savings Summary
18		A-24	N6	NPV Model for Digital Self-Service Projects
19		A-24	N7	Error Free Communication (EFC) Capital Spend
20		A-24	N8	IT Capital Approved in Case No. U-20836
21		A-24	N9	Operational Efficiencies Summary
22		A-24	N10	2022-2024 Outage and EFC Channel Enhancements
23				
24	Q9.	Were these	e exhibits prepa	ared by you or under your direction?

Line <u>No.</u>		M. J. HATSIOS U-21534
1	A9.	Yes, they were. I co-sponsor Exhibit A-24, Schedule N2, with Company Witness
2		Sharma and Exhibit A-13, Schedule C5.9.2 with Company Witness Bennett.
3		
4	<u>Part 2</u>	. Customer Service IT Portfolio Overview
5	Q10.	How do the projects in the Customer Service IT Portfolio align with the
6		Company's overall IT Investment Portfolio?
7	A10.	The Customer IT Portfolio is a subset of DTE's IT Investment Portfolio and has
8		been developed in parallel with the DTE IT 5-year plan (2021-2025) filed in Case
9		No. U-20561. A view of the structure of the DTE IT Investment Portfolio, the
10		associated IT Investment Categories, and the responsible witness in the instant case
11		is provided in Figure 1.
12		

Figure 1 - DTE IT Investment Portfolios



14

13

Consistent with the other IT Investment Portfolios, the projects in the Customer
 Service IT Portfolio have been categorized into five areas of targeted investment –

 M. J. HATSIOS

 Line
 U-21534

 No.
 1

 1
 Regulatory/Compliance, Sustainment, Return to Health, IT Enhancements, and

 2
 Strategic (Figure 2).

 3
 4

 4
 Figure 2 - DTE IT Investment Categories

Non-Discretionary	Regulatory/ Compliance	Required spend due to regulatory requirements
	Sustainment	Required spend to `run' the organization (e.g., basic internal labor, base operating and system maintenance costs)
	Return-to- Health	Required investments to update systems that are in critical health or have reached end of life
Discretionary	IT Enhancements	Discretionary capacity/capability performance upgrades to core platforms (e.g., SAP, IT) determined by business needs which are not required for `keeping the lights on'
	Strategic	Strategic spend to unlock a new business capability that can realize value for the organization (e.g., customer satisfaction, increased revenue to offset rate increases, etc.)

5

Q11. Which IT Investment Categories within the Company's Customer Service IT Portfolio are addressed in your testimony?

8 A11. As shown in Figure 1, my testimony includes projects within DTE Electric's 9 Customer Service IT Portfolio in the following IT Investment Categories: Regulatory and Compliance, IT Enhancements, and Strategic. As noted in Figure 10 11 2, the capital projects addressed in my testimony relate directly to those non-12 discretionary and discretionary projects that either are required by mandate or 13 compliance rules (Regulatory and Compliance), or directly target enhancing the 14 customer experience, reducing operational costs, and improving the effectiveness 15 with which we serve customers (IT Enhancements and Strategic).

	M. J. HATSIOS U-21534
	Not included in my testimony are those Customer Service IT Portfolio projects that
	are included in the Sustainment and Return-to-Health IT Investment Categories.
	These are included in Exhibit A-12, Schedule B5.7.2 and discussed in Company
	Witness Sharma's testimony.
<u>Part 3</u>	8. Company Witness Hatsios Sponsored Projects – Overview
Q12.	Please confirm DTE Electric's Customer Service capital investments in each
	of the three IT Investment Categories (e.g., Regulatory/Compliance, IT
	Enhancements, Strategic).
A12.	As reflected in Exhibit A-12 Schedule B5.7.3, DTE Electric will invest the below
	amounts in the three IT Investment Categories covered in my testimony:

Line No.

1

2

3

4

5

6

7

8

9

10

11

13 Regulatory and Compliance – the Company will invest \$59.9 million in the 14 Regulatory and Compliance category over the course of 48-months ending 15 December 31, 2025, consisting of \$21.1 million in the historical period, \$21.3 16 million in the 2023-2024 bridge period, and \$17.5 million in the 2025 test period, as shown in Lines 1 through 17 of the Capital Expenditures Exhibit A-17 18 12 Schedule B5.7.3.

19 • IT Enhancements - the Company will invest \$18.8 million in the IT 20 Enhancements category over the course of 48-months ending December 31, 21 2025, consisting of \$7.4 million in the historical period, \$4.2 million in the 22 2023-2024 bridge period, and \$7.2 million in the 2025 test period, as shown in 23 Lines 18 through 26 of the Capital Expenditures Exhibit A-12 Schedule B5.7.3. 24 Strategic – the Company will invest \$90.6 million in the Strategic category over 25 the course of 48-months ending December 31, 2025, consisting of \$33.2 million

MJH-7

	M. J. HATSIOS U-21534
	in the historical period, \$49.0 million in the 2023-2024 bridge period, and \$8.4
	million in the 2025 test period, as shown in Lines 27 through 47 of the Capital
	Expenditures Exhibit A-12 Schedule B5.7.3.
Q13.	How do the Customer Service Regulatory and Compliance, IT Enhancements,
	and Strategic capital projects in your testimony align with the Company's
	priorities?
A13.	The Company is committed to providing reliable, safe, and affordable utility service
	to its customers, expanding its renewable energy portfolio, and reducing its carbon
	footprint. DTE's Customer Service organization is aligned with and supports these
	priorities, and is committed to cost effectively providing customers with engaging
	and satisfying transactional (e.g., orders) and non-transactional (e.g., inquiries)
	interactions across its service channels, which includes enrolling customers in the
	Company's voluntary clean energy products and services.
	To that end, the Regulatory, IT Enhancement, and Strategic capital projects
	supported in my testimony are intended to deliver the following outcomes and
	customer benefits:
	1. Effective and Affordable Digital Self-Service Solutions - Provide customers
	with satisfying and seamless digital self-service alternatives to having to call
	the Contact Center, which makes it easier for customers to complete their
	interactions, improve service levels, and reduce operating expenses, with
	resultant savings passed on to customers through the ratemaking process.
	Q13.

MJH-8

1		2. Increased Operational Efficiencies - Create efficiencies across the Customer
2		Service operating groups to improve the efficiency and productivity of our
3		operations and projects, or to reduce the cost of operations, with resultant
4		savings passed on to customers through the ratemaking process.
5		3. Enhanced Customer Interactions – Improve the effectiveness and quality with
6		which the Company interacts and communicates with customers, ensuring
7		customers receive timely, accurate, and consistent information.
8		4. Enhanced and Expanded Clean Energy Products - Provide customers with
9		voluntary programs and services that promote and support their carbon
10		reduction goals and the growth of the Company's renewable energy assets.
11		
12	Q14.	Please specify how capital projects are consolidated and presented in your
13		testimony to align with the above-referenced outcomes and customer benefits.
14	A14.	I have consolidated the projects for which I am providing testimony in a manner
15		that aligns the individual projects with the outcomes and customer benefits
16		described in my response to Q13. As such, the remainder of the capital IT portion
17		of my testimony is organized as shown below.
18		
19		Part 4 – Digital Self-Service Projects
20		Part 5 – Operational Efficiency Projects
21		Part 6 – Projects that Enhance Customer Interactions
22		
		Part 7 – Regulatory, Compliance, and Clean Energy Projects
23		Part 7 – Regulatory, Compliance, and Clean Energy Projects Part 8 – 2022 Historical Capital Project Variance

Line

No.

1Q15.Are there any IT projects shown in Exhibit A-12 Schedule B5.7.3 that have2already been approved for cost recovery in a prior rate case and for which the3Company is not providing additional supporting testimony in the instant case?4A15.4Yes. The projects in Table 1 below, which were supported in my testimony in Case5No. U-21297, and which were approved for cost recovery by the Commission in6their final order in that case, will not be further discussed in my testimony in the7instant case.

8

Line

No.

9

Table 1	•
---------	---

•	Capital	Projects	Approved	in	U-21297
•	Cupitar	I I UJCCUS	1 ippi 0 · cu		

Project Name	Portfolio	Category	U-21534 Exhibit Reference	U-21297 Exhibit Reference
ACPP/Time of Day	Customer	Regulatory/Compliance	Line 1, A-12 B5.7.3	Line 1, A-12 B5.7.3
Corporate Energy Forecasting	Customer	Regulatory/Compliance	Line 2, A-12 B5.7.3	Line 2, A-12 B5.7.3
MIGP - Fixed Price Product(Rider17)	Customer	Regulatory/Compliance	Line 5, A-12 B5.7.3	Line 3, A-12 B5.7.3
MIGP Section 61 Settlement	Customer	Regulatory/Compliance	Line 9, A-12 B5.7.3	Line 6, A-12 B5.7.3
Payment Stability Plan	Customer	Regulatory/Compliance	Line 13, A-12 B5.7.3	Line 8, A-12 B5.7.3
Treasury Credential on File	Customer	Regulatory/Compliance	Line 17, A-12 B5.7.3	Line 13, A-12 85.7.3
Customer Legacy Applications Enhancement	Customer	IT Enhancements	Line 20, A-12 B5.7.3	Line 15, A-12 85.7.3
Customer Service Communications	Customer	Strategic	Line 32, A-12 B5.7.3	Line 33, A-12 B5.7.3
Enhanced Training Environments	Customer	Strategic	Line 34, A-12 B5.7.3	Line 35, A-12 85.7.3
Field Service Management Billing & Metering	Customer	Strategic	Line 37, A-12 B5.7.3	Line 40, A-12 85.7.3
Field Service Management for RM&P	Customer	Strategic	Line 36, A-12 85.7.3	Line 39, A-12 85.7.3
Platform Integration Component	Customer	Strategic	Line 43, A-12 B5.7.3	Line 50, A-12 85.7.3
Qualtrics Expansion	Customer	Strategic	Line 44, A-12 B5.7.3	Line 53, A-12 85.7.3
Speech Analytics	Customer	Strategic	Line 46, A-12 B5.7.3	Line 57, A-12 B5.7.3
Workforce Automation for Contact Center	Customer	Strategic	Line 47, A-12 B5.7.3	Line 58, A-12 B5.7.3

10

11 Q16. Are you providing any additional project details for the projects in Exhibit A-

12 **12, Schedule B5.7.3**?

<u>No.</u>

1	A16.	Yes. I am providing in Exhibit A-24, Schedule N1.1 business case executive
2		summaries for all the projects, and project capital, included in Exhibit A-12,
3		Schedule B5.7.3. Exhibit A-24 Schedule N3.1 also provides a greater level of detail
4		in the format requested by Commission Staff, as set forth in new filing requirements
5		adopted in the Commission's May 18, 2023 Order in Case No. U-18238.
6		
7	<u>Part 4</u>	. Digital Self-Service Projects
8	Q17.	Can you explain why the Company is investing capital in its Digital Self-
9		Service solutions?
10	A17.	Yes. The Company is investing capital in its digital self-service solutions to provide
11		customers with seamless and satisfying self-service alternatives to having to call
12		the Contact Center, both to meet the demands of those customers who prefer to
13		engage with the Company in a self-service channel, and to reduce the volume of
14		live calls handled by DTE's CRs.
15		
16	Q18.	What is the Company's motivation to reduce the volume of calls handled by
17		CRs in its Contact Center?
18	A18.	The cost of Contact Center operations represents the largest portion of the total
19		Customer Service (CS) Operating & Maintenance (O&M) expense, as shown in
20		Figure 3, which reflects the percent of the total CS O&M expense incurred by each
21		of the CS operating groups during the 2022 historical period - as provided in
22		Exhibit A-13, Schedule C5.7, Line 5, Column G.
23		





2		
3		In the 2022 historical period, the Contact Center contributed 50% of the total CS
4		O&M expense, with the most significant driver of Contact Center costs being the
5		handling of live phone calls by CRs. In fact, each incremental call handled by a
6		CR in the Contact Center costs the Company \$11.34, which reflects the 2022
7		weighted average cost of the Company's internal and external CR resources, and
8		includes overhead costs (e.g., benefits, payroll taxes, etc.) for the internal DTE CRs.
9		
10	Q19.	How do customers benefit from the reduction in call volumes?
10 11	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at
10 11 12	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at \$11.34/call results in tens of millions of dollars in DTE Contact Center O&M
10 11 12 13	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at \$11.34/call results in tens of millions of dollars in DTE Contact Center O&M expense, which is passed on to customers through the utility ratemaking process.
 10 11 12 13 14 	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at \$11.34/call results in tens of millions of dollars in DTE Contact Center O&M expense, which is passed on to customers through the utility ratemaking process. As such, reducing calls represents a significant opportunity for the Company to
 10 11 12 13 14 15 	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at \$11.34/call results in tens of millions of dollars in DTE Contact Center O&M expense, which is passed on to customers through the utility ratemaking process. As such, reducing calls represents a significant opportunity for the Company to reduce its operating costs and the associated O&M expense that is passed on to
 10 11 12 13 14 15 16 	Q19. A19.	How do customers benefit from the reduction in call volumes? CRs continue to handle millions of live calls from customers every year, which at \$11.34/call results in tens of millions of dollars in DTE Contact Center O&M expense, which is passed on to customers through the utility ratemaking process. As such, reducing calls represents a significant opportunity for the Company to reduce its operating costs and the associated O&M expense that is passed on to customers.

1 Additionally, with fewer live calls to handle, the Company can sustain its desired 2 service levels (e.g., average speed of answer, call abandon rates), and CRs will have 3 the capacity to more effectively handle those more complex inquiries from customers that may not be as effectively handled in a digital self-service solution 4 5 (e.g., low-income self-sufficiency program – LSP and payment stability plan – PSP 6 enrollments). 7 8 **Q20**. How does the Company's volume of calls compare to its peers? 9 A20. The Company continues to lag its utility peers in the volume of calls it handles per 10 customer, as reflected in the most recent 2023 First Quartile Consulting 11 Benchmarking Study (Figure 4). 12

13

Figure 4 -





Line
No.

3

4

The above study reflects full-year 2022 data as submitted by each of the participating utilities, with DTE currently at the bottom of the 4th quartile, indicating that there remains significant opportunity for DTE to reduce calls, and the associated costs of handling those calls.

6

5

7 Q21. What are the most common reasons why customers call the Company?

8 A21. The Company has identified the types of transactional (e.g., orders) and non-9 transactional (e.g., inquiries) interactions with customers that drive the majority of 10 its total call volume, which I have summarized below.

- 11
- Collection Calls from customers who received a shutoff notice, or have been
 disconnected for nonpayment, and are contacting the Company to discuss the
 options available to them to avoid shutoff or to restore service. Many of these
 calls are from the Company's most vulnerable, low-income customers who are
 calling about available energy assistance and to discuss payment plan options.
- Billing Calls from customers who want to verify their account balance, have
 questions about their bill, or want to enroll in one of the Company's billing
 programs (e.g., Budget Wise Billing, ebill).
- 3. Move-In/Move-Out (MIMO) Calls from existing and new customers
 requesting to Start Service at a new location, Stop Service at an existing
 location, Transfer Service between locations, or inquiry about or change to an
 existing MIMO service order.
- 24 4. Payments Calls from customers who want to pay their monthly bill or to check
 25 on the status of a recent payment.

MJH-14





10 The call volumes reflected in Figure 5 include the total volume of calls received 11 from both DTE Electric and DTE Gas customers. For the remainder of my 12 testimony, unless otherwise stated, the outcomes and customer benefits associated 13 with each of the capital projects for which I am providing testimony, can be 14 assumed to be shared between DTE Electric and DTE Gas customers.

Q23. How have the Company's historical investments in its digital self-service
 solutions contributed to the reduction in calls since 2018?

1	A23.	The Company has been able to enhance and expand its digital self-service solutions
2		in a manner that provides customers with increased and effective self-service
3		alternatives to calling the Contact Center. Over time, as these digital solutions grew
4		and matured, customers increasingly chose to engage in the use of these solutions
5		in lieu of calling the Contact Center.
6		
7		For example, in 2018, customers could view and pay their bill online, report and
8		check on the status of outages on the Web and in the Mobile App, and use the Web
9		to complete their MIMO transaction. Today, customers can do all those things and
10		more, including, but not limited to, interacting with the Company via social media
11		and Web chat, processing Collection restores on the Web and in the Interactive
12		Voice Response (IVR) system, enrolling in a payment extension in the IVR through
13		a Virtual Assistant (VA) and on the Web, self-analyzing their bills online and in
14		the IVR through a VA, processing MIMO requests in the IVR through a VA, and
15		tracking the status of their MIMO and Collection requests using the Company's
16		online order trackers.
17		
18	Q24.	How does the Company measure the level of customer engagement in the use
19		of its digital self-service solutions?
20	A24.	The Company has established a "Digital Engagement Rate" (DER) metric for each
21		of the five categories of customer interactions - Collection, MIMO, Billing,
22		Payment, and Outage - to measure and track the engagement of its customers in
23		the digital self-service solutions.

No. 1 For each of the identified five customer interactions, the Company measures the 2 percent of customers who complete a transactional interaction in a digital self-3 service channel, relative to the total number of completed served and self-served 4 transactional interactions – e.g., if customers complete a total of 20,000 total MIMO 5 transactions in a week, and 10,000 of those are successfully completed using a 6 digital self-service solution, the MIMO DER for that week would be 50%. With 7 the exception of Billing interactions, for which non-transactional inquiries are 8 included in the DER, non-transactional interactions are excluded from the DER 9 calculation for the other customer interactions. Going forward, I will use the term 10 transaction when discussing the DER for each category of customer interactions.

11

Line

12 How has the DER been trending in recent years? Q25.

13 A25. The Company has been tracking the DER for each transaction since 2020, and has 14 seen the overall DER steadily increase from 53% to 69% (Figure 6).

- 15
- 16







1 Q26. What factors impact the DER, and how has the DER increased for each of the 2 transactions?

A26. The DER for each transaction is a function of the number of customers who choose
to use a digital self-service solution, and the number of those customers who are
able to successfully complete their interaction in that solution, which the Company
refers to as the "Digital Completion Rate" (DCR).

7

8 In other words, to increase the DER for a particular transaction, the digital self-9 service solutions for that transaction must be seen by customers as an attractive 10 alternative to calling the Contact Center, and it must be designed so that a high 11 percentage of customers who choose to use a digital solution are able to 12 successfully complete their transaction. In general, the more complex the 13 transaction, and the more information customers are asked to provide, the more 14 opportunity there is for customers to "drop-off" and call the Contact Center to 15 complete their transaction. Below is a summary of the DER (Table 2) for each 16 transaction since 2020, along with the Company's long-term targets.

- 17
- 18

19

Table 2.	Digital Engagement Rate by Transaction

Transaction	2020	2021	2022	2023	Long Term Target
Collection	0%	5%	16%	30%	60%
MIMO	19%	25%	32%	42%	60%
Billing	76%	86%	89%	92%	95%
Outage	91%	93%	94%	96%	98%
Payment	78%	80%	82%	84%	85%
Overall	53%	58%	63%	69%	80%



These increased DERs are a direct result of the Company's investment in the
 expansion of its digital self-service offerings, and its commitment to ensure that
 customers who choose to engage in the use of these solutions are able to
 successfully complete their transaction.
 Q27. What are DER and call volumes that the Company is forecasting to achieve

through its capital investments in its digital self-service solutions?

A27. The Company is forecasting that its investments in its digital solutions will further
increase customer engagement in the digital solutions, increase DER closer to the
Company's long-term target, and reduce call volumes to near upper quartile levels
(Figure 7).

12

7

13

Figure 7 - Forecasted DER and Call Volumes



14

Detailed summaries of the realized and forecasted DER increases, call volume
 reductions, and O&M savings can be found in Exhibit A-24, Schedule N5.

1	Q28.	What are the total cumulative call volume savings the Company is forecasting
2		to achieve through its investments in the digital self-service solutions?
3	A28.	As seen in Exhibit A-24, Schedule N5, Page 1, Column h, Line 16, the Company
4		is forecasting that reducing total call volume to 2.7 million (Figure 7) will provide
5		customers with total cumulative net O&M savings through 2027 of \$15.6 million.
6		
7	Q29.	Is the Company removing the forecasted call volume savings from its
8		operating budget and its requested O&M recovery in the instant case?
9	A29.	Yes. As it did in U-21297, the Company is removing the annual call volume
10		savings for the projected test year from the Customer Service O&M budgets and
11		from its requested O&M recovery in the instant case, which is discussed in my
12		Customer Service O&M testimony (Part 9) and as reflected in my supporting
13		Exhibit A-13 Schedule C5.7 on Line 5, Column (k) for Customer Records and
14		Collection Expenses, and in footnote 3. This reduction is also highlighted in Exhibit
15		A-24, Schedule N5, Page 1, Column f, Line 17.
16		
17	Q30.	Which projects support the enhancement and expansion of the Collection
18		digital solutions?
19	A30.	The Company will invest \$10.7 million in five projects to enhance and expand the
20		Collection digital solutions over the course of 48-months ending December 31,
21		2025, consisting of \$2.8 million in the historical period, \$5.9 million in the 2023-
22		2024 bridge period, and \$2.0 million in the 2025 test period, as shown in Exhibit
23		A-12, Schedule B5.7.3, and which I have summarized in Table 3 below. See
24		Exhibit A-24 Schedule N3.1 Lines 13-15, 20-21, 25-26, 41 for additional project
25		details.

Note that \$0.4 million of the total \$2.8 million in 2022 historical spend for the Customer Relationship and Billing (CR&B) Enhancement project was allocated to the digital projects, with \$0.1 million allocated to Collection. \$2.3 million of the \$6.8 million in 2022 historical capital for the Journey Work Product Transformation Teams project was also allocated to Collection digital solutions.

 Table 3.
 Collection Digital Self-Service Capital (\$000s)

Line Item	Project Name	Year	Total Capital	Allocated to Collections
21	CR&B Enhancement	2022	\$2,794	\$100
29	Collection Web Self-Service	2023-25	\$7,880	\$7,880
31	Customer Closed Loop Development	2022	\$314	\$314
39	Journey Work Product Transformation Teams	2022	\$6,744	\$2,300
48	API Integration Security Gateway – API Layer*	2022	\$70	\$70
	Total (2	022-2025)	\$17,802	\$10,664

* Included in Projects < \$250K

10

9

Line

No.

1

2

3

4

5

6

7

8

Q31. Can you elaborate on the scope of work that is being funded by the Collection digital self-service capital?

A31. Yes. The capital allocated to the Collection digital self-service solutions is intended
to enhance the Company's existing Collection digital solutions, and to expand the
number of available digital solutions, as follows – please note in 2022-2023 the
four projects in Table 3 incurred \$5.1 million in capital to modify the customer
systems as necessary to deliver the highlighted improvements, while in 2024-2025
an additional \$5.5 million in capital will be spent solely by the Collection Web SelfService project.

	M. J. HATSIOS
Line <u>No.</u>	U-21534
1	
2	2022-2023 Collection Digital Improvements
3	• Increase Collection DCR and DER by addressing defects and cumbersome
4	process flows in the digital solutions that are preventing customers from
5	successfully completing their digital transaction (2022-2023).
6	• Provide customers the ability to process a restore of service on the Web
7	(February 2023).
8	• Provide customers the ability to enroll in a payment extension hold on the Web
9	(August 2023).
10	• Provide customers the ability to check on the status of an account lock on the
11	Web for the status of payment extension holds, medical holds, pending energy
12	assistance funding, and pending income status verifications (October 2023).
13	
14	2024-2025 Collection Digital Improvements
15	• Increasing Collection DCR and DER by addressing defects and cumbersome
16	process flows in the digital solutions that are preventing customers from
17	successfully completing their digital transaction (2024-2025).
18	• Expanding restore and payment extension eligibility to include more customers
19	(2024-2025).
20	• Providing the ability for customers to enroll in a payment arrangement on Web
21	to pay their past due amount over time. (May/June 2024).
22	• Providing customers with new online assistance tools that will guide customers
23	who are having difficulty paying their bill to the most appropriate payment
24	solutions, and sources of energy assistance (2024-2025).
25	

MJH-22

Line	
No.	

1	Q32.	What are the realized and forecasted customer benefits of the identified scope
2		of work funded by the Collection digital self-service capital?
3	A32.	In terms of call volume reductions, while 2023 Collection call volumes are not
4		materially different than they were four or five years ago, they have been reduced
5		by 50,000 relative to 2022 (Figure 5). This is despite an 11% increase in the number
6		of active low-income customers versus 2022, a 28% increase in the number of low-
7		income customers who reached final arrears status, a 15% reduction in available
8		Energy Assistance (EA) funding, and an increase in shutoff notices from 1.9 million
9		to 2.1 million.
10		
11		Together, these factors would be expected to significantly increase the volume of
12		Collection calls, especially for general inquiries and inquiries related to EA
13		funding. The Company maintains that the expected increase in Collection inquiry
14		calls, was mitigated by a reduction in the number of calls from customers who chose
15		to use a digital solution to restore service, to enroll in a payment agreement, or to
16		check on the status of an account hold.
17		
18		Given the results achieved to-date from the Collection digital self-service capital
19		investments, the Company is forecasting that its historical and planned investments
20		in the Collection digital self-service solutions will increase the Collection DER to
21		48% by 2027, will enable a cumulative decrease of 343,600 calls (2023-2027), and
22		will provide customers with a cumulative \$3.9 million in O&M savings (2023-
23		2027). The annual Collection call volumes and associated O&M savings are
24		provided in Exhibit A-24, Schedule N5.
25		

Line No.

1

2

Q33. Are there any other benefits, beyond O&M savings, to customers of the Company's investments in Collection digital self-service?

A33. Yes. While the Company anticipated that its payment extension VA and Web
solutions would provide increased numbers of customers an easy-to-use tool that
allows them more time to pay their past due balance, it did not expect such rapid
customer adoption of these solutions, nor did it expect the number of payment
enrollments to triple, as shown in Table 4.



- 9
- 10

ary

Year	Total Payment Extensions	DER	Paid On-Time
2021	47,400	4%	37%
2022	88,650	40%	39%
2023	144,350	67%	44%

11

The data in Table 4 indicates that in 2023, 67% of all payment extension enrollments were completed in a self-service solution, and 44% of the total enrollments were successfully paid within the required 10-day post enrollment period. In other words, 63,500 times (144,350 enrollments times 44% paid ontime), customers were able to leverage the use of a payment extension to pay their past due balance in full and avoid a shutoff of service.

18

19 Q34. Which projects support the expansion of the MIMO digital transaction?

A34. The Company will invest \$15.8 million in four projects to enhance and expand the
 MIMO digital self-service solutions over the course of 48-months ending

1	December 31, 2025, consisting of \$4.4 million in 2022 historical period, \$8.9
2	million in 2023-2024 bridge period, and \$2.5 million in 2025 test period capital, as
3	shown in Exhibit A-12 Schedule B5.7.3, which I have summarized in Table 5
4	below. See Exhibit A-24 Schedule N3.1 Lines 25-26, 39-40, 41, 58-60 for
5	additional project details.
6	
7	Note that \$0.4 million of the total \$2.8 million in 2022 historical spend for the

Customer Relationship and Billing (CR&B) Enhancement project was allocated to the digital projects, with \$0.2 million allocated to MIMO. \$3.0 million of the \$6.8 million in 2022 historical capital for the Journey Work Product Transformation Teams project was also allocated to MIMO digital solutions.

12

8

9

10

11

- 13
- 14

Table 5.	MIMO	Digital	Self-Service	Capital	(\$000s))
		— • • • •				

Line Item	Project Name	Year	Total Capital	Allocated to MIMO
21	CR&B Enhancement	2022	\$2,794	\$200
38	IVR Virtual Assistants	2022	\$1,161*	\$1,161
39	Journey Work Product Transformation Teams	2022	\$6,744	\$3,000
41	MIMO Web Self-Service	2023-2025	\$11,415	\$11,415
	Tot	al (2022-25)	\$22,114	\$15,776

15

*Net of 2023 reduction of (\$109,000), as shown in Exhibit A-12, Schedule B5.7.3

16

Q35. Can you elaborate on the scope of work that is being funded by the MIMO
digital self-service capital?

- A35. Yes. The focus for the MIMO digital self-service solutions in 2022-2023 was to
 enhance the existing MIMO Web, and MIMO start service Virtual Assistant (VA),
- 21 solutions to address defects and cumbersome process flows that were preventing

Line <u>No.</u>	M. J. HATSIOS U-21534
1	customers from completing their transaction (2022-2023), to enhance and expand
2	the MIMO VA solutions to include start and transfer service request (2022), and to
3	migrate MIMO Web from an on-premise solution to the cloud (2022-2023).
4	
5	Below is an overview of the types of MIMO digital self-service improvements that
6	were implemented from 2022-2023 through the Company's capital investments -
7	please note in 2022-2023 the four projects in Table 5 provided \$9.8 million in
8	capital to modify the customer systems as necessary to deliver the highlighted
9	improvements, while in 2024-2025 an additional \$6.0 million in capital is being
10	provided solely by the MIMO Web Self-Service project.
11	
12	2022 MIMO Digital Improvements
13	• Implemented MIMO start and transfer service VA solutions.
14	• MIMO Web start-service migrated to a cloud-based platform, and in parallel
15	improved the stop MIMO user experience and interfaces (UX/UI).
16	• Allowed MIMO Web customers to enter only the last four digits of their social
17	security number to validate their identity.
18	• Removed and/or replaced confusing Web error messages.
19	• Removed redundant and confusing Web tiles.
20	• Created ability to validate international addresses – from customers moving to
21	DTE's service territory from outside the United States.
22	
23	2023 MIMO Digital Improvements

<u>No.</u>	
1	• MIMO Web stop and transfer service migrated to a cloud-based platform, and
2	in parallel improved the overall MIMO stop and transfer service user experience
3	and user interface.
4	• Allowed authenticated Web customers to bypass identification requirements,
5	which was a common point of failure for existing DTE MIMO customers.
6	• Continued to improve the address search and validation MIMO Web
7	functionality, which was a significant point of failure for customers.
8	• Made it easier for customers who want to change the scheduled date of their
9	MIMO order by directing customers, via notifications and the MIMO online
10	order tracker, to the change order function in MIMO Web, and ensuring the
11	solution is easily navigated so they can complete their request.
12	• Incorporated Web chat across the MIMO Web transactions to provide
13	assistance to customers who get "stuck" in the process.
14	
15	The focus for the Company's 2024-2025 capital investments, will be to continue to
16	enhance the MIMO Web and VA solutions, with the goal of expanding the number
17	of MIMO scenarios that can be handled in a digital solution, and eliminating defects
18	and cumbersome process flows that are preventing customers from completing their
19	digital transaction.
20	
21	2024-2025 MIMO Digital Improvements
22	• Additionally-enhanced user experience and user interface experience.
23	• Waiving identification requirements for customers who authenticate by logging
24	into the Web to process their MIMO request.

Line
M. J. HATSIOS
U-21534

Line <u>No.</u>		U-21534
1		• Creating a Web stop service guest option, so customers do not have to login to
2		complete their stop service request.
3		• Eliminating Web technical errors, looping, blank page with error, and ad
4		blockers.
5		• Adding a Web chat link to all MIMO customer notifications.
6		• Expanding the Web and VA error logs to include secondary codes for improved
7		root cause identification.
8		• Fixing the defect related to document reversals, which are failing during a
9		digital move and requiring CR escalations.
10		• Implementing new VA skills to handle MIMO order changes, cancels and
11		inquiries.
12		
13	Q36.	What are the realized and forecasted customer benefits of the identified scope
14		of work funded by the MIMO digital self-service capital?
15	A36.	Enhanced and more effective MIMO Web start, stop, and transfer digital solutions,
16		along with the implementation of the MIMO VA solutions, provided customers
17		with more, and more effective, digital self-service solutions in which they could
18		choose to engage to complete their MIMO request. As a result, the MIMO DER
19		increased from 19% in 2020, to 42% in 2023 (Table 2), which has driven the
20		number of MIMO calls to an all-time low of 530,000 in 2023 (Figure 5).
21		
22		Given the results achieved to-date, the Company is forecasting that its historical
23		and planned investments in the MIMO digital self-service solutions will increase
24		the MIMO DER to 56% by 2027, will enable a cumulative decrease of 338,000
25		calls (2023-2027), and will provide customers with a cumulative \$3.8 million in

Line <u>No.</u>		M. J. HATSIOS U-21534
1		O&M savings (2023-2027). The annual MIMO call volumes and associated O&M
2		savings are provided in Exhibit A-24, Schedule N5.
3		
4	Q37.	Which projects support the expansion of the Outage digital transaction?
5	A37.	The Company invested \$7.8 million in 2022 historical period spend in two projects
6		to enhance and expand the Outage digital self-service solutions over the course of
7		12-months ending December 31, 2022, which are included in Exhibit A-12
8		Schedule B5.7.3, and which I have summarized in Table 6 below. \$6.3 million of
9		the \$14.9 million in 2022 historical capital for the Error Free Communications -
10		Outage Status project was allocated to Outage digital transaction. \$1.4 million of
11		the \$6.8 million in 2022 historical capital for the Journey Work Product
12		Transformation Teams project was also allocated to Outage digital transaction.
13		See Exhibit A-24 Schedule N3.1 Lines 30-32, 41 for additional project details.
14		

Table 6.Outage Digital Self-Service Capital (\$000s)

16

Line Item	Project Name	Year	Total Capital	Allocated to Outage
35	Error Free Communication – Outage Status	2022	\$14,904	\$6,330
39	Journey Work Product Transformation Teams	2022	\$6,744	\$1,444
	Te	otal (2022)	\$21,648	\$7,774

17

18	Q38.	Can you elaborate on the scope of work that is being funded by the Outage
19		digital self-service capital?

A38. Yes. Customers are very engaged in the use of the Outage digital self-service
solutions, as evidenced by the 96% Outage DER in 2023 (Table 2). However, the
record storm activity and resulting number of customer outages in 2021 and 2023,

No. 1 have provided greater insight into the opportunities to enhance the Outage self-2 service experience, and the quality of information the Company provides customers 3 during an outage. 4 5 The \$7.8 million in capital allocated to the Outage transaction reflects the entirety 6 of the Company's 2022 capital investments in its Outage digital self-service 7 solutions, and was used to improve the usability, ease-of-navigation, and quality of 8 the messaging and notifications provided to customers who were reporting or 9 checking on the status of storm related outages using the Web. I have summarized 10 these improvements below. 11 12 2022 Outage Web Improvements 13 Ongoing enhancements to the newly launched (late 2021) Police/Fire, 14 Municipality, and Outdoor Lighting cloud site. 15 Integrated Outage Web with the new "Where is My Order" (WISMO) and • 16 Premise Power Status (PPS) Outage systems. 17 • Ongoing enhancements to the user experience and user interface and navigation 18 of the Web and Mobile Web Outage centers. 19 • Enhanced and more accurate customer-facing error messages. 20 Integrated Web Outage with the new cognitive address search to make it easier • 21 for customers to search and find address. 22 • Completed changes required to support the planned 2023 Advanced 23 Distribution Management System (ADMS) launch. 24

Line

Line <u>No.</u>		M. J. HATSIOS U-21534
1	Q39.	What are the realized and forecasted customer benefits of the identified scope
2		of work funded by the Outage digital self-service capital?
3	A39.	The 2022 Outage Web self-service enhancements improved the visibility of the
4		Outage Web content, improved the quality of the information presented to
5		customers regarding their outage, and made navigation of the Outage Website
6		easier for customers, which resulted in increased numbers of customer reporting an
7		Outage to successfully complete their transaction in a digital channel – 87% in 2022
8		versus 92% in 2023 – and a corresponding increase in the Outage DER, which went
9		from 94% in 2022, to 96% in 2023 (Table 2).
10		
11		The volume of mitigated calls from this increased DER is dependent on storm
12		activity, and the number of customers who are reporting an Outage, which
13		increased from 900,000 in 2022, to 2.9 million in 2023. As a result, Outage

orting an Outage, which 023. As a result, Outage 14 reported by a CR increased from about 52,000 in 2022, to just over 125,000 in 2023, 15 more than doubling. However, Outage reporting through the digital self-service 16 solutions more than tripled from just over 850,000 in 2022 to 2.8 million in 2023, 17 indicating that significant numbers of customers chose to engage in the use of an 18 Outage digital solution rather than call to report their Outage, with 92% 19 successfully able to complete their transaction as compared to 87% in 2022.

20

21 Had the percent of successfully completed Outage digital transactions not increased from 87% to 92%, as a result of the Company's 2022 capital investments, Outage 22 23 reporting calls to the Contact Center could have increased by over 157,000. This 24 assumes that 3.15 million Outage reports were attempted in a digital solution (2.9 25 million completed transactions / 92% completion rate), and that if the completion

M. J. HATSIOS U-21534

2

3

4

5

rate in 2023 had remained at 87%, there would have been an additional over 157,000 failed digital Outage reports (3.15 million attempted in a digital solution x 5% decrease in percent completed), which could have resulted in a call to the Contact Center.

6 Regarding the Company's 2023-2024 investments, the focus for the Outage 7 transaction in 2023-2024 is on the improvement of the timeliness and accuracy with 8 which we provide customer power status updates, restoration estimates, and other 9 outage information and notifications. These investments are part of the Company's Error Free Communication (EFC) - Outage Status initiative, from which \$6.3 10 11 million (Table 6) was used to fund the described 2022 Outage Web improvements, 12 of which \$3.8 million was previously approved in the Commission's final order in 13 Case No. U-20836, as reflected in Exhibit A-24, Schedule N8, Page 2, Line 23. 14 Any required enhancements to the Outage digital self-service solutions from 2023-15 2024 are in support of the EFC- Outage Status initiative, which I will discuss in 16 detail in Part 6 of my testimony related to "Projects that Enhance Customer Interactions". 17

18

Cumulatively, the Company is forecasting its investments in the Outage digital solutions to increase the Outage DCR to 95% by 2027, will enable a cumulative decrease of 32,500 calls (2023-2027), and will provide customers with a net cumulative \$0.4 million in O&M savings (2023-2027). The annual Outage call volumes and associated O&M savings are included in Exhibit A-24, Schedule N5.

24

Q40. Which projects support the enhancement and expansion of the Billing digital solutions?

3 A40. The Company will invest \$5.0 million in three projects to enhance and expand the 4 Billing digital self-service solutions over the course of 36-months ending December 5 31, 2024, consisting of \$3.5 million in 2022 historical period and \$1.5 million in 6 2023-2024 bridge period capital, as shown in Exhibit A-12 Schedule B5.7.3, which 7 I have summarized in Table 7 below. Note that \$0.4 million of the total \$2.8 million 8 in 2022 historical spend for the Customer Relationship and Billing (CR&B) 9 Enhancement project was allocated to the digital projects, with \$0.1 million 10 allocated to Billing. See Exhibit A-24 Schedule N3.1 Lines 10-12, 25-26 for 11 additional project details.

- 12
- 13
- 14

Table 7	7.
---------	----

Billing Digital	Self-Service	Capital	(\$000s)
		Capital	ψυυυυ,

Line Item	Project Name	Year	Total Capital	Allocated to Billing
21	CR&B Enhancement	2022	\$2,794	\$100
27	Bill Management	2022	\$3,425	\$3,425
28	Billing Web Self-Service	2023-24	\$1,480	\$1,480
	Tota	al (2022-24)	\$7,699	\$5,005

15

Q41. Can you elaborate on the scope of work that is being funded by the Billing digital self-service capital?

A41. Yes. The three projects in Table 7 are providing \$5.0 million in capital from 20222024 to enhance the existing Billing digital solutions, which includes enhancing the
digital user experience by improving the quality of the data presented on the Web,
addressing defects in the online bill management tool, and enhancing the bill
management tool to support the Time-of-Day (TOD) rate implementation.

1	Q42.	Can you describe the scope of \$3.4 million in capital reflected in Table 7 that
2		was allocated to the Bill Management project?
3	A42.	Yes. In 2021, the Company launched a new online bill analyzer that consists of
4		two components, a bill impact analyzer and a bill simulator, that together provide
5		customers with an estimate of those items that impacted their current bill – usage,
6		weather, billing days – along with the ability to simulate their next bill based on
7		usage forecasts, and the impact of any usage reductions they could realize by
8		changing their behavior.
9		
10		The Commission, in its final order in Case No. U-20836, approved for recovery
11		\$2.6 million in capital for the implementation of this new "Bill Management" tool,
12		as reflected in Exhibit A-24, Schedule N8, Page 1, Column b, Line 5. The Company
13		invested an additional \$3.4 million in the Bill Management tool in 2022 to address
14		identified defects, to continue to enhance the Billing experience, and to incorporate
15		the ability for the tool to effectively analyze and simulate Time-of-Day
16		(TOD)rates/bills, which were implemented in March of 2023.
17		
18	Q43.	What are the realized and forecasted customer benefits of the identified scope
19		of work funded by the Billing digital self-service capital?
20	A43.	In 2022, customers completed over 6.2 million Billing transactions, with 5.5
21		million completed in a digital solution (89% DER), and 0.68 million completed
22		through a CR call. In 2023, total completed Billing transactions increased to 6.8
23		million, however, the number of transactions completed in a self-service solution
24		increased to 6.3 million (92% DER), while those completed through a CR
25		decreased to 0.55 million. This implies that while customer Billing inquiries

1		increased in 2023 due to the TOD implement	tation, signi	ificant nur	nbers of those
2		customers chose to engage in a digital solution	to handle t	heir inquir	ies. In fact, in
3		2023, over 210,500 customers accessed the C	Company's	online bil	l management
4		tool, over 483,200 times, and over 113,700 cust	tomers used	the Comp	any's high bill
5		inquiry VA over 159,300 times, to get answers	to question	ns about th	eir bill.
6					
7		Given the results achieved to-date, the Compa	any is fored	casting that	t its historical
8		and planned investments in the Billing digital	self-servic	e solution	s will increase
9		the Billing DER to 94% by 2027, will enable	e a cumulat	ive decrea	use of 244,000
10		calls (2023-2027), and will provide customers	with a net	cumulativ	e \$2.8 million
11		in O&M savings (2023-2027). The annual H	Billing call	volumes a	and associated
12		O&M savings are included in Exhibit A-24, Schedule N5.			
13					
14	Q44.	Which projects support the expansion of the	e Payment	digital tra	insaction?
15	A44.	The Company will invest \$4.6 million in a p	project to e	enhance a	nd expand the
16		Payment digital self-service solutions over	the course	e of 36-n	nonths ending
17		December 31, 2025, as shown on Line 42 of	Exhibit A-	12 Schedu	le B5.7.3, and
18		which I have summarized in Table 8 below. Se	e Exhibit A	-24 Sched	ule N3.1 Lines
19		63-65 for additional project details.			
20					
21		Table 8.Payment Digita	l Self-Servi	ice Capita	ıl (\$000s)
22					
		Line Item Project Name	Year	Total Capital	Allocated to Payments
		42 Payment Web Self-Service	2023-25	\$4,553	\$4,553

Q45. Can you elaborate on the scope of work that is being funded by the Payment digital self-service capital?

A45. Yes. The Company processes millions of customer payments every year, with the
majority of them completed using one of the Company's digital self-service
solutions, as indicated by the 84% 2023 Payment DER (Table 2). However, given
that the Company handles over 32 million payment transactions every year, even
small increases in the Payment DER significantly reduces call volumes.

8

9 In 2023, a minimal of amount (approximately \$50,000) of the \$4.6 million in 10 Payment Web Self-Service capital was focused on addressing known defects in the 11 Payment digital self-service solutions that were preventing customers from 12 successfully completing their transactions. This investment enabled an increase in 13 the percent of customers who were successfully completing their Payment digital 14 transaction from 76% in 2022 to 79% in 2023. In parallel with its focus on Payment 15 defect remediation in 2023, the Company increased customer awareness of the 16 availability of the Payment self-service solutions and made it easier for customers 17 to access those solutions through clickable links in email notifications and SMS 18 messages.

19

In 2024-2025, the Company is significantly increasing its capital investment in the Payment digital self-service solutions to improve the Payment digital experience by further increasing the percent of customers who are able to successfully complete their digital Payment transaction, and to improve the experience for customers intending to perform other transactions, as the current Payment digital experience was originally designed and implemented in 2018 as a stand-alone

1 transaction; however, with the increase in digital transactions in Collections and 2 MIMO over the past few years, the Payment solution is being leveraged across 3 multiple transactions. As such, it is important that the Company invest in both the 4 Payment digital solutions, and Payment experience within the Collections and 5 MIMO digital solutions. I have summarized the planned Payment digital solution 6 improvements below. 7 8 2024-2025 Payment Digital Improvements 9 Redesigning the online web payment center (authenticated version and guest • 10 version) to improve the resiliency and the user experience and the user interface. 11 Streamlining how other transactions integrate with the payment center (e.g., • 12 MIMO & Collections) to improve the user experience and technical 13 implementation process to integrate payments into other transactions. 14 Eliminating failure points for both Authenticated Payments (i.e., customers who • 15 log-in to their online account) and Guest Payments (i.e., customers who do not 16 log-in or who do not have an online account) that are preventing customers from 17 successfully completing their payment. 18 Simplifying the process for Autopay customers to update their saved payment • 19 methods, which today requires the customer to unenroll and reenroll in the 20 program and can lead to calls to a CR. 21 Implementing more descriptive error messages, so that when customers fail in • 22 their attempt to make a payment on the Web, they will know why and can 23 increase the likelihood of success on their next attempt. 24

1	Q46.	What are the realized and forecasted customer benefits of the identified scope
2		of work funded by the Payment digital self-service capital?
3	A46.	In 2022, the Company handled 32.84 million Payment transactions, of which 26.96
4		million (82% DER) were completed in a self-service solution, which for Payments
5		includes the Web, Mobile App, IVR, and Kiosk, as well as customers who use Auto
6		Pay and Electronic Funds Transfer (EFT). In 2023, the number of Payment
7		transactions increased to 32.92 million, but at the same time the volume of those
8		transactions completed in a self-service channel also increased to 27.80 million
9		(84% DER).
10		
11		So, while the number of Payment transactions only increased by 0.2% (60,000
12		transactions) the number of Payment transactions in 2023 that were completed in a
13		self-service channel increased by over 3% (78,000 transactions). However, the
14		increase of 840,000 digital Payment transactions includes the transition of over
15		460,000 Payments that in 2022 were made through the mail, but were made
16		electronically through AutoPay in 2023. Therefore, the reduction in Payment call
17		volumes from 2022 to 2023 was a net 280,000 calls (Figure 5).
18		
19		Given the results achieved to-date, the Company is forecasting that its historical
20		and planned investments in the Payment digital self-service solutions will increase
21		the Payment DER to 85% by 2027, which will enable a cumulative decrease of
22		~360,800 calls (2023-2027) and provide customers with a cumulative ~ $$4.1$ million
23		in O&M savings (2023-2027). The annual Payment call volumes and associated
24		O&M savings are included in Exhibit A-24, Schedule N5.
25		

Line No.

Q47. Are there other Customer IT capital projects that also support the Company's call volume reduction efforts?

3 A47. Yes. A total investment of \$1.4 million, consisting of \$0.5 million in 2023 and \$0.9 4 million in 2024 bridge period capital, from the Advanced Analytics Use Cases 5 project shown on Line 18 in Exhibit A-12, Schedule B5.7.3, also supports the 6 Company's call volume reduction efforts. Since \$0.4 million of the 2023 bridge 7 period capital has already been approved for recovery in U-20836, the Company is seeking recovery for \$1.0 million of 2023 bridge period capital for this project in 8 9 the instant case. See Exhibit A-24 Schedule N8 Page 2, Column c, Line 3 for details 10 on the capital approved for recovery in U-20836 for the Advanced Analytics (AA) 11 Use Cases project. What follows is a description of the scope of each of the 2023 12 and 2024 analytics use case as they relate to providing call reduction benefits.

13

14 <u>2023 AA Use Case - Scope and Benefits</u>

15 In 2023, the Company spent \$0.5 million in capital to develop an analytics model 16 that uses Natural Language Processing (NLP) technology and Speech Analytics to 17 improve the accuracy with which customer calls are categorized, especially as it 18 relates to those calls that would often be manually categorized as "Other" by the 19 CRs. Through the use of advanced algorithms, we have seen call categorization 20 accuracy improve from 74% to 86%, with most of that improvement related to those 21 calls that would have been previously allocated to the "Other" category being more 22 appropriately categorized into one of the five key transactions. The analytics model 23 is also self-learning so it will be continually updating its categorization algorithm 24 and enhancing the process and its ability to provide even deeper insight over time 25 into customer calls and call patterns.

Line <u>No.</u>

N	0

1

2 By dispositioning calls to the appropriate call categories, the Company is gaining 3 greater visibility into the total volume and most common reasons for calls from 4 customers across each of the five key transactions. This allows us to identify 5 process and policy improvements with each transaction that will provide 6 incremental call volume reductions. Through 2027, the use of the analytics model 7 is forecasted to provide a cumulative incremental call volume reduction, beyond 8 what is expected from our digital self-service projects, of $\sim 30,000$ calls, for total 9 sustained O&M savings of ~\$340,000. The call volume and O&M cost reduction 10 is reflected in Exhibit A-24, Schedule N5 (Page 2, footnote 7).

11

12

2024 AA Use Case - Scope and Benefits

In 2024, the Company is investing \$0.9 million to build an analytics model that will 13 14 identify the precise touchpoints and scenarios in the various customer interactions 15 that either cause a customer to call, or that result in a failure to successfully 16 complete their interaction in a digital self-service solution. This first requires a 17 complete mapping of the customer touchpoints for each customer interaction, 18 followed by advanced analytics modeling and tools that will uncover the underlying 19 reasons of why a customer chooses to call, as opposed to using a digital self-service 20 channel, and why a customer who started in a digital self-service solution had to 21 call the Company to complete their interaction. These efforts are expected to 22 reduce 17,500 additional calls in 2024 through 2025, resulting in cumulative and 23 sustained O&M savings of ~\$200,000. These call volume and the O&M cost 24 reductions are reflected in Exhibit A-24, Schedule N5 (Page 2, footnote 8 and 9).

25

1	Q48.	Is the Company requesting cost recovery of any previously approved
2		Customer IT capital project investments in the instant case, and if so, why?
3	A48.	Yes. As set forth in Exhibit A-24, Schedule N8, there is \$13.3 million in 2022-
4		2023 capital, across eight projects (Page 2, Columns b through d, Line 1, Lines 5-
5		11), that I am sponsoring in my testimony in the instant case, of which \$5.7 million
6		(Page 2, Columns b through c, Line 3 and Line 13) was previously approved by the
7		Commission for cost recovery in Case No. U-20836. Additionally, there is \$5.7
8		million in 2021 digital self-service capital, across three projects (Page 2, Column
9		a, Line 13), that were also previously approved by the Commission for recovery in
10		U-20836, but that is not reflected in Exhibit A-12, Schedule B5.7.3 of the instant
11		case.
12		
13		Despite their prior approval of this \$11.4 million in 2021-2023 capital, the
14		Commission in its final order in U-21297 disallowed for recovery the entirety of
15		these projects based on arguments made by the Detroit Area Advocacy
16		Organizations (DAAOs). Because the capital investments set forth in Exhibit A-
17		24, Schedule N8 were previously approved for cost recovery in Case No. U-20836,
18		and the Company relied on such approval when spending the capital, it is
19		appropriate for the Commission, in the instant case, to authorize cost recovery of
20		these capital investments to rectify the inadvertent retroactive disallowance that
21		resulted from the final order in Case No. U-21297.
22		
23	Q49.	Is the Company providing a detailed cost-benefit analysis for its Digital Self-
24		Service projects?

Line No.		M. J. HATSIOS U-21534
1	A49.	Yes. The Company is providing a Net Present Value (NPV) analysis of its digital
2		self-service projects, the details of which can be found in Exhibit A-24, Schedule
3		N6.
4		
5	Q50.	Please describe how the Company models the NPV for its Digital Self-Service
6		projects?
7	A50.	The NPV model determines the annual cost to customers that results from the
8		Company's recovery of the digital project cash outflows through the ratemaking
9		process, which is referred to as the "revenue requirement customer costs." This
10		includes the revenue recovery impact of the initial capital project costs, the project
11		cost-to-achieve O&M, and all of the ongoing sustainment capital and trailing O&M
12		costs. The model then calculates what is referred to as the "revenue recovery
13		customer savings," which is the difference between the annual digital project call
14		volume reduction O&M savings, and the annual project O&M costs, which
15		includes the digital project cost-to-achieve O&M and any ongoing project trailing
16		O&M costs.
17		
18		The difference between the revenue requirement customer costs, and the revenue
19		requirement customer savings, determines the "net annual revenue recovery" cost
20		or (savings) to customers, which the model then discounts back to today's dollars
21		to determine the NPV to customers of the digital projects. A negative NPV implies
22		the projects are value creating for customers (i.e., saves customers money), while a
23		positive NPV would imply the projects are not value creating for customers (i.e.,
24		costs customers money).
25		

Line

M. J. HATSIOS U-21534

1 Q51. Which capital investments are included in the NPV model?

2 A51. The NPV model, as reflected in Exhibit A-24, Schedule N6, includes all 2022-2025 3 capital projects that support the enhancement and expansion of the Company's 4 digital self-service solutions for each of the five key transactions, whose scope and 5 benefits are described in Part 4 of my testimony. Also included in the NPV model 6 are the previously described 2023 and 2024 AA Use Case capital project 7 investments, which as discussed are also intended to reduce call volumes and 8 deliver O&M savings for customers. Finally, the NPV model also includes \$12.0 9 million in 2021 digital self-service project capital, which was sponsored in my 10 testimony in DTE Electric Case No. U-21297 (MJH-41, Table 2).

11

12 Why is the Company including 2021 digital capital in its NPV analysis if it is Q52. 13 not included in the historical, bridge, or test period capital in the instant case? 14 A52. The 2021 digital investments are contributing to the realized and ongoing 15 reductions in call volumes, which are reflected in the NPV model and included in the NPV calculation. As such, it would be disingenuous to include the call volume 16 17 reduction savings in the NPV analysis, but to exclude the revenue recovery cost to 18 customers of the 2021 capital investments, as doing so would inflate the NPV.

19

20 Q53. What is the NPV of the Company's digital self-service projects?

A53. The NPV of the Company's digital self-service capital projects has been determined
to be a negative \$5.6 million, which confirms that the digital self-service
investments are value creating for customers, as reflected in Exhibit A-24 Schedule
N6, Line 23, Column (h). I am providing a summary of the results of the NPV
analysis in Figure 8.





4

5

6

7

8

9

As seen in Figure 8, customers start to realize net revenue recovery savings in 2027 (i.e., current year revenue recovery savings are greater than current year revenue requirement costs). These annual net savings continue to grow to an annualized \$15.3 million by 2036 and are sustained in perpetuity as reflected on Exhibit A-24 Schedule N6, Line 22, Columns n through w.

10 I would note here that the \$12.0 million in 2021 digital self-service capital included 11 in the NPV analysis, was part of the \$51.3 million in total digital self-service capital 12 for which the Company was seeking recovery in U-21297, and which was 13 subsequently disallowed for recovery in its entirety by the Commission in its final 14 order in that case. As such, the Company believes that its analysis conservatively 15 calculates the NPV of the digital self-service projects because customers are 16 currently not incurring the associated revenue recovery costs of the \$12.0 million 17 in 2021 capital. Should the Commission authorize recovery of the previously



Line No.

1	discussed \$5.7 million in 2021 digital self-service capital originally approved in
2	Case No. U-20836 (See Exhibit A-24 Schedule N8, Page 2, Column a, Line 13),
3	customers would still only be incurring the revenue recovery cost of less than half
4	of the \$12.0 million in 2021 digital capital.

5

6 Part 5. Operational Efficiency Projects

7 Q54. What is included in this section of your testimony?

8 A54. This section of my testimony will include a discussion of projects that align with 9 enabling operational efficiencies and stability in the Contact Center, Billing, and 10 the Revenue Management and Protection (RM&P) groups. I will also discuss 11 projects in which the Company is leveraging advanced analytics to capture 12 operational efficiencies that improve the customer experience and provide cost 13 savings. Additionally, I will discuss how we are also investing capital in projects 14 that improve the quality and efficiency of the Customer CR&B system, and with 15 which the Company implements its Customer IT projects.

16

Q55. Can you please describe projects that deliver operational efficiencies in the Contact Center?

A55. Yes. The Company is investing a total of \$2.5 million in capital, consisting of \$2.1
million in the 2023-2024 bridge period and \$0.4 million in the 2025 test period, in
two projects that will enhance the ability of the Contact Center to reduce the
Average Handle Time (AHT) of calls from customers, and that will improve
customer accessibility to the telephony systems during peak call times, such as
during a major storm event. These projects are both included in Exhibit A-12,
Schedule B5.7.3, and are summarized below.

Line <u>No.</u>

1	
2	1. Line 30 – Contact Center Enablement
3	The Commission previously approved, in its final order in Case No. U-21297, \$0.7
4	million in 2023-2024 capital for the Contact Center Enablement project, which
5	enhances the Customer Relationship Management (CRM) system for the Collection
6	transaction to reduce its AHT. The Company's actual spend for this project was
7	\$1.3 million in capital The incremental spend of \$0.6 million was due to emergent
8	scope in 2023 that resulted from the complexity of the required enhancements,
9	which necessitated engaging the services of additional SAP consultant resources.
10	Additionally, in 2025, the Company is forecasting to spend another \$0.4 million to
11	make similar enhancements in CRM to reduce AHT across the other key
12	transactions. This incremental capital is reflected in Exhibit A-24 Schedule N9, and
13	brings the total capital spend for this project to \$1.7 million.
14	
15	Therefore, in the instant case, the Company is seeking recovery of a total of \$1.0M
16	in incremental capital for this project, which includes the incremental \$0.6 million
17	that was required to complete the 2023 Collection scope, plus the additional \$0.4
18	million in capital to reduce the AHT of the other key transactions support. See
19	Exhibit A-24 Schedule N3.1 Line 18 for additional project details.
20	
21	2. <u>Line 45 – SIP in Contact Center</u>
22	The efficiency with which the Company manages and maintains its telephony
23	systems, including the IVR, significantly impacts the accessibility of these systems
24	for our customers. This is especially true in periods of increased customer usage.

Line <u>No.</u>		U-21534
1		such as during a significant customer outage event or during the application of
2		required software patches and upgrades.
3		
4		The Commission previously approved, in its final order in Case No. U-21297, \$1.7
5		million in 2022-2024 capital for the SIP in Contact Center project. The Company
6		actually spent \$0.9 million in 2023 to complete the project, as reflected in Exhibit
7		A-12, Schedule B5.7.3. The \$0.8 million reduction in total capital, versus what was
8		previously approved, is because the Company was able to leverage cost synergies
9		gained from the implementation of other projects, which reduced the time, effort,
10		and resources required. As such, there is no incremental capital associated with
11		this project for which the Company is seeking recovery in the instant case.
12		
13	Q56.	How is the Company investing capital to improve operational efficiency in
14		Billing?
15	A56.	In October 2022, DTE launched a new Meter Data Management (MDM) system to
16		replace an outdated and unsupported DTE IT solution. Since that time, the
17		Company has identified opportunities to enhance the new MDM solution to reduce
18		billing exceptions, reduce manual work, improve forecasting, and prevent delayed
19		bills for its largest commercial and industrial customers. To fund these
20		enhancements the Company is investing \$1.8 million in 2025 test period capital in
21		the Meter Data Management (MDM) Stabilization project, as reflected on Line 23
22		of Exhibit A-12 Schedule B5.7.3.
23		
24		These enhancements will reduce by 80% the number of manual touches (~12,000)

currently required to remediate exceptions and prevent delayed bills, providing 25

1		~\$100,000 annually in O&M savings. The MDM project will also reduce
2		potentially higher energy market settlement charges due to forecasting errors from
3		estimated commercial and industrial load. See Exhibit A-24 Schedule N3.1 Line
4		42 for additional project details.
5		
6	Q57.	How is the Company investing capital to improve operational efficiencies in its
7		RM&P group?
8	A57.	The Company is investing \$0.4 million in 2025 test period capital to improve the
9		management of instances of theft and fraud with the Never Billed Accounts due to
10		Theft / Fraud project (Exhibit A-12, Schedule B5.7.3, Line 24). The Commission
11		previously approved, in its final order in Case No. U-21297, \$0.4 million in 2024
12		capital for this project. However, the project has been re-timed to 2025 to provide
13		capacity for other more urgent IT projects. The Company is seeking continued
14		recovery of this capital in the 2025 test period in the instant case.
15		
16		As discussed in U-21297, this project creates new functionality in the core billing
17		system that will provide a new screen for the Revenue Management and Protection
18		(RM&P) Exceptions Team to utilize when a customer needs to be billed for theft,
19		ID fraud, or bankruptcy, and the normal billing process cannot be used. As no bill
20		is generated today, the account does not progress through the collection (SAP
21		dunning) process. Since the SAP CR&B system went live in April 2017 through
22		March 1, 2024, ~\$1.6 million in charges have accrued on customer accounts that
23		have not been billed and are aging in active arrears. See Exhibit A-24 Schedule
24		N3.1 Line 61 for additional project details.
25		

1	Q58.	How is the Company leveraging Advanced Analytics to capture operational
2		efficiencies and optimize customer programs and processes to reduce
3		uncollectible expense (UCX) and O&M costs?
4	A58.	DTE is investing in analytics resources and technologies that will provide greater
5		insight into customer segments, behaviors, and improving the customer experience.
6		To that end, the Company is investing \$6.6 million in capital, consisting of \$1.1
7		million in the 2022 historical period, \$2.5 million in the 2023-2024 bridge period,
8		and \$3.0 million in the 2025 test period, in the Advanced Analytics (AA) Use Cases
9		project as shown on Line 18 of Exhibit A-12, Schedule B5.7.3.
10		
11		The Commission, in its prior order in U-20836, previously approved \$1.5 million
12		in 2022-2023 capital for investment in Advanced Analytics use cases, to enable the
13		Company to gain a deeper understanding of our customers, customer segments, and
14		customer behaviors and preferences. See Exhibit A-24 Schedule N8 Page 2,
15		Columns b through c, Line 3 for details. As such, in the instant case, the Company
16		is seeking recovery of an additional \$5.1 million in capital for the implementation
17		of new analytics use cases, which includes \$1.0 million in capital for the 2023 AA
18		use case (\$0.1 million) and the 2024 AA use case (\$0.9 million) that I discussed in
19		Part 4 of my testimony because they support achievement of the Company's call
20		volume reduction commitments and provide O&M cost savings in 2023-2027. The
21		remaining \$4.1 million in capital, for which the Company is seeking recovery, will
22		be allocated to the 2024 and 2025 AA use cases to be described below that will
23		leverage advanced algorithms and machine learning to optimize customer programs
24		and processes to reduce uncollectible expense (UCX) and O&M costs. Specific
25		capital investment dollars and the customer benefit provided by the project is

Line No.

1

2

3

described and delineated for each individual 2024 and 2025 AA use case, just as they were for each 2023 and 2024 AA use case that contribute to call volume reduction described in Part 4. See Exhibit A-24 Schedule N3.1 Lines 3-6 for additional project details.

5

4

6

1. <u>2024 Energy Assistance AA Use Case – \$1.1 million</u>

7 The Company is investing \$1.1 million in 2024 bridge period capital to develop a 8 machine learning model to optimally allocate available energy assistance paired 9 with Energy Waste Reduction (EWR) to eligible low-income customers. Today, 10 energy assistance is available to DTE Electric low-income customers whose 11 balances are past due or who otherwise qualify for assistance. This support assists 12 customers in paying down their arrears and can help them avoid a disconnection 13 due to non-payment in the short-term. However, for a more comprehensive, long-14 term approach to assisting them in reducing their bills and managing their arrears, 15 a combined offering of energy assistance along with EWR funding would be more 16 effective. This AA use case funds development of a machine learning solution to 17 identify eligible customers for both energy assistance and EWR. When the model 18 indicates eligibility for both programs, a bundled offering will then be extended to 19 these low-income customers, who may not have been aware of their eligibility to 20 access both programs and how to apply for this support.

21

While traditionally customers seeking energy assistance funds must reach out to DTE or third-party agencies to start the process, instead we would be able to leverage the machine learning model to match customers with EWR and energy assistance program(s) that best fit their needs and circumstances, simplifying the

process. Through a more effective and optimal means of distributing energy assistance and helping our low-income customers to better manage their bills with EWR, we estimate that this offering can reduce customer arrears and UCX by \$300,000 in 2024 through 2025.

5

3

4

6

2. <u>2025 AA Use Case – Reducing MPSC Complaints – \$1.0 million</u>

7 The Company is investing \$1.0 million in 2025 test period capital to develop a 8 machine learning model to understand the drivers underlying Customer Service 9 MPSC complaints and make recommendations for improvements in our key 10 transactions, especially in Collection and Billing, which generate $\sim 80\%$ of 11 Customer Service complaints. Collection and Billing calls also have longer call 12 handle times at 12.6 minutes and 11.2 minutes, respectively, as compared to the 13 average of 10.5 minutes across all call types. The Company will leverage the 14 model's output to anticipate customer pain points that may be leading to their 15 dissatisfaction and frustration, and proactively reach out to these customers to 16 understand their concerns and resolve their issue before it becomes a MPSC 17 complaint. The model's output will also be integrated into our customer systems 18 so that if a customer who is likely to complain calls, the CRs can more swiftly 19 escalate the customer's issue for resolution. We anticipate that the actions taken to 20 address the drivers of customer complaints through process improvements in our 21 key transactions and taking proactive steps will reduce 110 or ~15% of Customer 22 Service MPSC Complaints (based on 2023 data) over a five-year period starting in 23 2026, and will provide operational efficiencies by reducing the volume of 24 complaints and better dedicating the same resources to focus on effectively 25 resolving the customers pain points that lead to complaints.

Line		M. J. HATSIOS
<u>No.</u>		0-21334
1		
2		3. 2025 AA Use Case - Automating CR Notes - \$2.0 million
3		The second 2025 AA use case will be focused on developing advanced analytics
4		models designed to reduce the average handle time (AHT) of calls by automating
5		the notes taken by CRs during or after a call. Currently, CRs manually enter notes
6		into CRM for ~30% of handled calls, particularly for inquiry calls as it provides
7		visibility into why the customer called. While these notes are valuable for follow-
8		up tasks, addressing subsequent customer calls, and understanding the reason for
9		calls when there is no transaction completed, this process adds to AHT, which
10		translates into Contact Center O&M costs, longer wait times, and potentially lower
11		service levels.
12		
13		Using advanced analytics algorithms that leverage natural language processing to
14		automate the note-taking process by analyzing call transcripts, the Company can
15		reduce AHT by ~ 20 seconds for 30% of the calls in which the CR enters notes for
16		an estimated savings of ~\$300,000 annually starting in 2026 and in perpetuity.
17		Automating the CR note-taking process also provides other benefits, such as more
18		comprehensive notes than those entered manually, enabling us to analyze customer
19		calls and look for opportunities to improve the quality of their call experience or
20		deflect calls to self-service.
21		
22	Q59.	What IT efficiency projects are intended to improve the quality and efficiency
23		of the Customer CR&B system and with which the Company develops and

deploy Customer IT projects and reduce system downtime?

24

Line
<u>No.</u>

1	A59.	The Company is investing \$9.1 million in 2022 historical period, 2023-2024 bridge
2		period, and 2025 test period capital in five IT efficiency projects that will be
3		discussed in the order they appear in Exhibit A-12, Schedule B5.7.3. Together,
4		these projects are intended to:
5		
6		• Reduce the frequency and associated remediation and monitoring costs of
7		CR&B system outages;
8		• Remediate defects and make minor enhancements to the CR&B system;
9		• Accelerate the development, quality assurance review, and testing of Customer
10		IT projects; and
11		• Ensure the up time of customer systems and applications through optimization
12		of the flow of work and load on the system.
13		
14		The Commission previously approved, in its final order in Case No. U-21297, \$8.3
15		million in 2022-2024 capital for these projects. The \$0.8 million increase in capital,
16		versus what was previously approved, is a result of the net impact of increases and
17		decreases in the individual projects, which I describe below.
18		
19		1. Line 19 – Automated Application Monitoring Enhancement
20		The Company is investing a total of \$2.7 million in capital, consisting of \$1.5
21		million in the 2022 historical period, \$0.3 million in the 2023 bridge period, and
22		\$0.9 million in the 2025 test period, in this project. The Commission, in its prior
23		order in Case No. U-21297, previously approved for recovery a total of \$3.3 million
24		in 2022-2024 capital for this project.
25		

Line
No.

1	While the total capital cost of \$2.7 million for this project is \$0.6 million less than
2	the \$3.3 million in capital that was approved for cost recovery in U-21297, \$0.9
3	million of capital has been to re-timed from 2024 to 2025, which will allow us to
4	evaluate the performance of the monitoring that has been implemented in 2022-
5	2023. As such, while the Company is not seeking recovery of additional total
6	capital for this project, it is seeking in the instant case recovery of the \$0.9 million
7	in the 2025 test period, which will complete the originally approved scope, and
8	expands the scope to include implementation of the Focus Build, Focus Insights,
9	and Customer Code Management modules.
10	
11	Focus Build manages requirements and software development for large, agile
12	innovation projects. Custom Code Management is the central point of access for all
13	functions that are used to monitor and manage the complete lifecycle of custom
14	developments from requirement to retirement. Focus Insights manages Focus Build
15	and distributes powerful customer-specific dashboards in minutes providing a state-
16	of-the-art user experience. See Exhibit A-24 Schedule N3.1 Line 9 for additional
17	project details.
18	
19	2. Line 21 – Customer Relationship and Billing Program Enhancement
20	The Company is investing total capital of \$4.0 million in enhancements to the
21	CR&B system that support improved customer experiences across the five key
22	transactions, which consists of \$2.8 million in the 2022 historical period, and \$1.2
23	million in the 2023 bridge period. The Commission in its final order in Case No.
24	U-21297, previously approved \$2.0 million in 2022 capital for this project. The
25	additional \$2.0 million in capital, for which the Company is seeking recovery in

1	the instant case, results from increased spending of \$0.8 million in 2022 to fund
2	emerging enhancement opportunities, and \$1.2 million of new capital spend in
3	2023, which funded newly identified opportunities for enhancement. See Exhibit
4	A-24 Schedule N3.1 Lines 25-26 for additional project details.
5	
6	The majority of these 2022-2023 CR&B enhancements were related to the MIMO,
7	Collection, and Billing transactions, and were intended to increase First Contact
8	Resolution (FCR), which is a measure of the Company's ability to address a
9	customer's request or inquiry, over the phone or in a digital channel, on the first
10	try, without the customer having to reach out repeatedly. Overall, these investments
11	resulted in an increase in the average FCR, across the five key transactions, from
12	84% 2021 to 86% in 2023. With over 43 million transactions completed each year,
13	every 1% increase in FCR impacts the experience of a significant number of
14	customers, making it easier for them to complete their transaction, and avoiding the
15	frustration that comes with having to repeatedly contact the Company to resolve
16	their inquiry or request. Below are examples of the types of enhancements funded
17	by the total 2022-2023 capital for each transaction.
18	
19	2022-2023 MIMO CR&B Enhancements
20	A total of 99 defects and enhancements were remediated and implemented in 2022-
21	2023 for the MIMO transaction, which enabled an increase in the MIMO FCR from
22	87% in 2021 to 89% in 2023, with some of the more significant examples described
23	below.
24	

Line <u>No.</u>		U-21534
1	•	Updated the arrangement of Customer Relationship and Management (CRM)
2		screens used by the Customer Service Representatives (CRs) - providing a
3		better call handling experience for customers and lower AHT.
4	•	Created new notification templates for Force Move-Out customers, ~40% of
5		the move-out population and for whom we have never sent notifications.
6	•	Updated the WISMO ("Where is my order?") refresh rate so that the MIMO
7		Order Tracker provides near real-time data from 15 minutes to 1 minute.
8	•	Incorporated "clickable" links and information bubbles for the CRs through the
9		MIMO screens in CRM – reducing customer wait times and AHT.
10	•	Established the ability to Web register customers during the MIMO process in
11		CRM – at inception we observed a 200-300% daily increase.
12	•	Enhanced the system to perform a check so that a customer is not erroneously
13		assigned more than one contract account at the same premise / address when
14		the account is being created, eliminating the risk of customers receiving
15		multiple billing statements.
16	•	Supported the new VA functionality to allow customers to create a Move-in or
17		Move-out using the VA, reducing the number of customers transferred to a CR.
18	•	Created functionality to allow customers starting service with a known lease-
19		end date to schedule a Move-out and not have to call DTE again.
20	•	Created functionality within CRM that allows a CR to click on a link for
21		additional instruction on how to complete the customer transaction. Reduces
22		handle time per call and prevents unnecessary escalations.
23	•	When a customer transfers service within the DTE service territory, we will
24		now automatically transfer their LSP plan with them. This prevents additional
25		calls from the customer to transfer their plan.

Line <u>No.</u>	U-21534
1	• Removed barriers that made web registration more difficult for customers,
2	allowing them to perform future transactions in self-service channels.
3	• Added error codes to CRM that allowed us to better diagnosis and remedy VA
4	failures so that the process can work more frequently for customers.
5	
6	2022-2023 Collection CR&B Enhancements
7	A total of 150 defects and enhancements were remediated and implemented in
8	2022-2023 for the Collection transaction, which enabled an increase in the
9	Collection FCR from 78% in 2021 to 79% in 2023, with some of the more
10 11	significant examples described below.
12	• Updated the 65 New Closed Loop emails and added SMS to keep customers
13	informed of where they are in the collection process (SAP Dunning), improving
14	our communications with the customer.
15	• Upgraded the Payment Kiosk to accept payments on customer accounts that
16	were disconnected for non-payment.
17	• Automated Senior Flag to update when a customer reaches the age of 65. This
18	flag protects Seniors from disconnection due to non-payment as part of the
19	Winter Protection Plan (WPP), annually from November 1 through March 31.
20	• Refinements to optimize the collection process (SAP Dunning) to reduce
21	growth in arrears and potential write-offs and UCX.
22	• Notification enhancements to proactively give customers information regarding
23	their accounts, landlord accounts, payment plan updates, and payment
24	extension status.

• CRM enhancements to allow transactions to function properly including
customer refunds, completing theft service orders, payment allocations,
ensuring accurate LIA/RIA enrollment status, and low-income verification.
• Web/VA work to ensure we are offering customer appropriate solutions for
Payment extensions and Payment Agreements, and to update customers of lock
status so they know they are not at risk of a disconnect due to non-payment.
• Updated the cash only flag logic so that good paying customers are not impacted
and forced to change payment method.
2022-2023 Billing CR&B Enhancements
A total of 50 defects and enhancements, some related to TOD, were remediated and
implemented in 2022-2023 for the Billing transaction, with some of the more
significant examples described below. From 2021 through 2023 Billing FCR has
held steady at 75% despite remediating defects from the 2023 full implementation
of Time-of-Day rates. Some of the more significant examples described below.
• Billing system "sum check" calculation, as well as usage check calculations so
that customers do not receive bills with substantial errors.
• Updates to CRM to increase the visibility of customers enrolled in a billing
program and or payment plan to include Flexible Due Date, Reduced Bill
Frequency, My Bill, My Time, and CoolCurrents.
• Ability to compare DTE Gas rates versus an Alternative Service Provider's rate.
• Improved the productivity of internal business users when querying and
viewing the status and statistics for Billing business exceptions.

Line

Line <u>No.</u>	U-21534
1	• Banner Letter enhancements to provide customers detailed information
2	regarding an account's adjustments or billing corrections.
3	• Supported CRM enhancements related to MPSC rate case implementation to
4	ensure billing accuracy and to help customers enroll and unenroll in rates more
5	efficiently such as for the Dynamic Peak-Pricing (D1.8) rate.
6	• Enhancements to reduce the manual touches need during the monthly billing
7	process for our Major Accounts (Assigned Customer) Team.
8	• Enhancements to e-bill process to increase customer adoption rate and improve
9	the customer experience.
10	
11	3. <u>Line 22 – IT Application Environments Enhancement</u>
12	The Company invested a total of \$0.5 million in capital in the IT Application
13	Environments Enhancement project, which consisted of \$0.2 million in the 2022
14	historical period, and \$0.3 million in the 2023 bridge period, to create a new Quality
15	Assurance (QA) environment. The total capital cost for this project included in the
16	instant case, is \$0.4 million less than the \$0.9 million in 2022-2024 capital that was
17	previously approved for cost recovery by the Commission in Case No. U-21297.
18	
19	The project was completed in 2023, a year ahead of schedule and with favorability
20	to its budget, due to efficiencies that were realized by the selected vendor. As such,
21	although DTE Electric is not seeking recovery of any incremental capital for this
22	project in the instant case, the Company is including the project here to explain the
23	significant favorable variance relative to what was approved for recovery.
24	
25	4. Line 25 – Supporting Capabilities Test Data and Test Data Management

1	The Company invested the net amount of \$0.9 million in capital in the 2022
2	historical and 2023 bridge period to establish a process to generate automated test
3	data and test scripts. The Commission, in its final order in Case No. U-21297,
4	approved for recovery \$1.2 million in capital for this project. The reason for the
5	reduced capital spend of \$0.3 million is that because during the execution phase,
6	the anticipated need for additional infrastructure (servers), and corresponding labor,
7	were found to be unnecessary. Although DTE Electric is not seeking recovery of
8	any incremental capital for this project in the instant case, the Company is including
9	the project here to explain the favorable variance relative to what was approved for
10	recovery.
11	
12	5. Line 26 – Transform and Modernize PO Architecture
13	The Company will invest \$1.0 million in 2025 test period capital to transform and
14	modernize the Process Orchestration (PO) architecture to alleviate system
15	bottlenecks due to network traffic and growing functionalities in the CR&B system.
16	The Commission, in its final order in Case No. U-21297, approved for recovery
17	\$1.0 million in 2024 capital for this project. This project has since been rescheduled
18	into 2025, and as such, we are including it here as part of the Company's request to
19	approve this project for recovery in the 2025 test period in the instant case. Below
20	is a summary of the scope of the project, along with an updated view of the
21	associated customer benefits, which have been determined to be more significant
22	than originally forecasted.
23	
24	This project remains critical. As the Company enables more capabilities in its
25	customer channels and the CR&B system, it creates additional stress and burden

1		for the PO to ensure increasingly complex jobs and functions perform as expected.
2		During periods of high traffic, such as during a storm or in the fall with the influx
3		of college move-ins, the Company's transactional system and digital channels must
4		scale up to handle the additional workload or risk an unplanned system outage. By
5		upgrading the PO to a more robust architecture, DTE Electric will be able to reduce
6		unplanned system outages that disrupt the Company's ability to serve customers
7		either digitally or through the Contact Center.
8		
9		While the system is typically back up in \sim 3 hours during an unplanned outage, it
10		takes at least eight hours to identify the root cause and implement a longer-term fix
11		to stabilize the system. The cost of CRs who wait for the system to be restored
12		during unplanned system outages could be considerable. If it takes \sim 3 hours for the
13		system to come back up, assuming we are able to reduce unplanned system outages
14		from 10 to 3 by 2028, by multiplying this idle / wait time by the average number of
15		CRs per year between 2026 and 2028 and the hourly labor cost of a CR, this project
16		can reduce the O&M cost of CR wait time by ~\$310,000. See Exhibit A-24
17		Schedule N3.1 Line 87 for additional project details.
18		
19	<u>Part 6</u>	5. Projects that Enhance Customer Interactions
20	Q60.	Can you describe the Company's rationale for investing capital in projects
21		that will enable "Enhanced Customer Interactions"?
22	A60.	The Company's strategy to enhance customer interactions is simple – improve the
23		customer experience and the effectiveness and efficiency with which the Company
24		manages customer interactions, by prudently investing in capital projects that
25		enable end-to-end monitoring of customer interactions, which provide customers

Line <u>No.</u>		M. J. HATSIOS U-21534
1		and employees full transparency into the status of these interactions, and that
2		improve the quality of the data and information provided to customers during these
3		interactions.
4		
5	Q61.	Which of the capital projects you are sponsoring in your testimony are
6		intended to "Enhance Customer Interactions"?
7	A61.	There are five projects I will discuss in my testimony that are intended to Enhance
8		Customer Interactions, three of which are included in Exhibit A-12, Schedule
9		B5.7.3, which I am sponsoring, and two of which are included in Exhibit A-12,
10		Schedule B5.4 Technology and Automation, which is co-sponsored by Company
11		Witness Hartwick (see below).
12		
13		Exhibit A-12, Schedule B5.7.3
14		• Line 31 – Customer Closed Loop Development
15		• Line 33 – Customer Service Communications – Phase 2
16		• Line 35 – Error Free Communication – Outage Status
17		
18		Exhibit A-12, Schedule B5.4, Distribution Plant - Technology and Automation
19		• Page 18 – Line 33 – Operational Technology and EFC
20		• Page 18 – Line 40 – Other Modernize Grid Management
21		
22	Q62.	Can you describe the Company's investment in the Customer Closed Loop
23		Development project?
24	A62.	Yes. The Commission, in its final order in Case No. U-21297, approved for
25		recovery \$1.4 million in 2023-2024 capital for this project. The Company's actual

1 investment totaled \$1.8 million in capital in the Customer Closed Loop 2 Development project, consisting of \$0.3 million in the 2022 historical period, and 3 \$1.5 million in the 2023 bridge period, as shown on Line 31 of Exhibit A-12, Schedule B5.7.3. The 2022 historical spend of \$0.3 million was previously 4 5 approved in Case No. U-20836 as shown in Exhibit A-24 Schedule N8 on Page 2, 6 Column b, Line 22. 7 8 The \$0.4 million in additional capital the Company spent on this project, relative to 9 what was approved for recovery in U-21297, is due to the \$0.3 million in capital 10 the Company spent in 2022, which as stated was previously approved in Case No. 11 U-20386, but was subsequently disallowed in U-21297 due to being part of the 12 \$51.3 million in digital self-service projects, and which was used to complete the 13 scope of work for the MIMO and Collection transactions, plus the incremental 14 spending of \$0.3 million in capital in 2023 to complete the scope of the Billing and 15 Payment Closed Loop notifications, which was offset by \$0.2 million in 2024 16 capital that was previously approved in U-21297 but that is no longer required. As 17 such, the Company in the instant case is seeking recovery of an additional \$0.4 18 million in capital for this project. Included below is the 2023 scope and benefits 19 realized from the incremental investment in the Billing and Payment Closed Loop 20 notifications. 21

The intent of the investment in Closed Loop Billing and Payment notifications was to provide customers greater visibility into their Billing and Payment interactions, to share with them clear and concise communications related to those interactions, and to provide them clickable links that would allow to track the status of these
interactions in a digital self-service solution. Below I describe some of the Closed Loop Notifications that were enhanced or newly developed with the 2023 investment. See Exhibit A-24 Schedule N3.1 Lines 20-21 for additional project details.

5

6

Line

No.

1

2

3

4

Billing Closed Loop Notifications

7 All Billing notifications had an update component (i.e., SMS function added) or 8 were newly developed in this project. The new Closed Loop notifications were 9 added where the customer would benefit from more visibility into their billing 10 transaction. One such update was with the Flexible Due Date (FDD) Process with 11 manual communications. This was addressed by automating all FDD 12 communications via email or SMS. This notification informs customers that their 13 request for Flex Due Date has been received and provides updates throughout the 14 process (received, being reviewed, eligible, or ineligible). This level of visibility 15 either did not exist for customers before the project or was being sent inconsistently. 16 Below is the list of Billing Closed Loop notifications that were updated or newly developed. 17

18

- BudgetWise Billing enrollment / unenrollment
- eBill enrollment / unenrollment
- eBill ready to view notifications.
- Flexible Due Date request
- Meter tests updates and status
- Billing investigations status

Line
No.

2

• BudgetWise Billing Program status

3 Payments Closed Loop Notifications

4 All Payment notifications were reviewed for completeness and accuracy in their 5 messaging and to incorporate modern language as advised by Corporate 6 Communications. New Closed Loop notifications were added where the customer 7 would benefit from more visibility into their payment transaction, such as for 8 Autopay where there was not an email and SMS notification previously for 9 Autopay withdrawals. The new AutoPay notifications informed customers if the 10 AutoPay did not withdraw (for reasons described in the notification) and that a 11 manual payment would be required. This visibility did not exist for customers 12 before the project. Through our voice of the customer surveys, customers indicated 13 that notifications were important for communicating completion and confirmation 14 of their payment status. Below is the list of Payment Closed Loop notifications 15 that were updated or newly developed.

16

17

- Payment due reminders
- 18 Payment cancelled
- Payment past due reminders
- Payments declined
- Credit card expiring
- Autopay withdrawal issues

2

3

As with MIMO and Collection Closed Loop notifications, the Billing and Payment notifications are expected to reduce customer calls and increase FCR and customer satisfaction.

4

5

Q63. Can you describe the Customer Service Communications – Phase 2 project?

6 A63. Yes. The first phase of the Customer Service Communications was approved for 7 recovery in Case No. U-21297, which included \$3.3 million in capital for the 8 implementation of a new notification platform – Message Broadcast – the scope of 9 which was completed in 2023. The Company, in the instant case, is seeking 10 recovery of \$2.0 million in 2024 bridge period capital, as reflected in in Exhibit A-11 12, Schedule B5.7.3, Line 3, to complete Phase 2 of the project, which includes 12 the migration of 99% of all customer notifications to the new Message Broadcast 13 platform, and the leveraging of the new platform to enhance the quality and 14 effectiveness with which we communicate with customers. This includes the 15 ability to create, customize, catalog, and store customer notifications with delivery 16 confirmation, so that we have visibility into which customers did not receive which 17 notifications, and the use of the platform's tools to ensure the integrity of the 18 customer contact data, to quickly create Messages On Demand (MODs) by an 19 assortment of methods, including list, zip code, electrical device, and geography, 20 and to be able to provide customers the ability to communicate with us via 21 SMS/texting. See Exhibit A-24 Schedule N3.1 Line 28 for additional project 22 details.

23

24 Q64. Can you provide an overview of the Company's EFC – Outage Status 25 initiative?

1	A64.	Yes. In simple terms, the Company determined that it needed to transition from a
2		"work-based" power status system to a "premise-based" system, with premise
3		being the Company's term for a customer's home or business location. The
4		Company's "work-based" system aggregates outage data from the AMI network,
5		input from field crews, and customer calls, and couples this data with the electrical
6		system equipment hierarchy to determine outages at a circuit level. The work-based
7		system does not focus on tracking and monitoring individual customer outages.
8		Creation of a "premise-based" system allows the Company to leverage its AMI
9		infrastructure to monitor individual premise outage data and restoration status, and
10		provide power status and notifications at the customer level. This significantly
11		enhances the relevance and quality of the information and communications
12		provided to customers and improves the customer Outage experience.
13		
14		There are six technical components that form the landscape of systems necessary
15		to create the Company's premise-based system, some that already existed, some
16		that existed but needed to be modified, and some that were completely new:
17		
18		1. Outage Management System (OMS) - Existing system that processes outages
19		with work-based calculations, using field crew job and equipment data.
20		2. AMI - The Company's Automated Metering Infrastructure (AMI), which
21		supplies voltage, Power Outage Notifications (PONs), and Power Restoration
22		Notifications (PRNs) into Premise Power Stats (PPS—see below) for processing

23 premise-based calculations.

MJH-67

Line <u>No.</u>

Line <u>No.</u>		U-21534
1	3.	ESRI's ArcGIS - Maintains the equipment hierarchy for the electric grid and
2		uses the hierarchy to map equipment outages to the customers attached to that
3		equipment.
4	4.	Event Hub – A new system that streams the outage events from OMS into the
5		new PPS system.
6	5.	Premise Power Status (PPS) – A new system that translates work-based outage
7		information from OMS and the AMI meter data into premise-based outage
8		information.
9	6.	"Where is My Order" (WISMO) – The Company's order tracking system, which

- y's order tracking system, which 10 for Outages integrates information from PPS to allow for tracking of individual 11 customer outages, and to trigger the appropriate notifications to customers.
- 12

13 **O65**. Can you provide an update on the amount of capital the Company has 14 invested, and is planning to invest, in its Error Free Communications (EFC) -15 **Outage Status initiative?**

16 A65. Yes. The Company in its DTE Electric U-21297 rate filing, requested recovery of 17 \$35.9 million in 2021-2024 capital to support the modification of the above systems 18 to support the EFC Outage Status initiative, of which \$29.7 million was approved 19 by the Commission in its final order in that case. The Company is now forecasting 20 to spend a total of \$50.0 million in total capital from 2022-2025, which excludes 21 \$2.4 million in 2021 capital previously requested and approved for recovery in U-22 21297. Exhibit A-24, Schedule N7 provides a complete breakdown of how the total 23 \$50.0 million in capital is being allocated across the back end "Core" systems, and 24 front end "Customer-Facing" systems, including the total amount of capital being 25 invested in each system component or workstream, and the portion of the total

Line <u>No.</u>		M. J. HATSIOS U-21534
1		capital that was previously approved for recovery by the Commission in its final
2		order in Case No. U-21297. Additional project details are in Exhibit A-24 Schedule
3		N3.1 on Lines 30-32.
4		
5	Q66.	How much total capital is allocated to the Core systems to support the EFC –
6		Outage Status initiatives?
7	A66.	The Company is investing a total of \$14.2 million in the EFC Core systems,
8		consisting of \$8.4 million in 2022 historical period that was approved for recovery
9		by the Commission in its final order in Case No. U-21297, plus an additional \$5.2
10		million in 2023-2024 bridge period capital, and \$0.6 million in 2025 test period
11		capital, which were not previously requested for recovery. A detailed summary of
12		the capital allocated to the Core systems, including those amounts that were
13		previously approved in Case No. U-21297, can be found in Exhibit A-24 Schedule
14		N7, on Pages 1-2.
15		
16	Q67.	How much total capital is allocated to the Customer-Facing systems to support
17		the EFC – Outage Status initiatives?
18	A67.	The Company is investing a total of \$35.8 million in capital in the Customer-Facing
19		systems to support the EFC - Outage Status initiatives, which consists of \$14.9
20		million in 2022 historical period capital, and \$20.9 million in 2023-2024 bridge
21		period capital. Of the total \$35.8 million in capital, \$19.0 million was previously
22		approved for recovery by the Commission in its final order in Case No. U-21297,
23		including \$7.0 million in 2022 historical capital, and \$11.9 million in 2023-2024
24		bridge period capital. The \$35.8 million also includes the \$6.3 million in 2022
25		capital allocated to the enhancement of the Outage digital solutions, as described in

Line No		M. J. HATSIOS U-21534
1		Part 4 of my testimony. A detailed summary of the capital allocated to the
2		Customer-Facing systems, including those amounts that were previously approved
3		in Case No. U-21297, can be found in Exhibit A-24 Schedule N7, on Pages 3-4.
4		
5	Q68.	To-date, what improvements in Outage metrics have been realized through
6		the Company' investments in its EFC – Outage Status initiative?
7	A68.	In addition to Outage call volume reductions enabled by the \$6.3 million in 2022
8		EFC - Outage Status initiative capital, which was allocated to the enhancement of
9		the Outage digital solutions as described in Part 4 of my testimony, the Company
10		has realized improvements in 1) the timeliness and accuracy of its outage
11		restoration communications, 2) the timeliness and accuracy of its restoration
12		estimates, and 3) the percentage of successfully delivered outage notifications. I
13		am providing a summary of each of these realized improvements in the pages that
14		follow.
15		
16		Power Restoration Accuracy and Timeliness
17		Prior to the implementation of EFC – Outage Status initiative, the customer's power
18		status was tied to the job status, which was overall 94% accurate, but with a range
19		between 80% to 94% during high impact and storm days. Because the power status
20		was not premise-based, the Company could think the customer's power was
21		restored, and communicated this status to the customer, when, in fact, the customer
22		was not restored.
23		
24		With the implementation of EFC, where the customer's power status is based on
25		AMI meter data, the Company has consistently achieved a 99% accuracy rate for

1	the customer's power status. However, timeliness of identifying the customer's
2	power status could be delayed with the use of AMI data, so a new metric was
3	developed to ensure timely delivery of power status updates - Restoration
4	Communication within 1-hour. In 2023, 41.5% of customers who were restored
5	received confirmation of their restoration within 1-hour, which the Company is
6	forecasting to increase to 65% in 2024, while maintaining 99% Power Restoration
7	Accuracy, and for which the Company has established a long-term target of 90%.
8	
9	First Estimate Accuracy
10	One of the most significant drivers of customer dissatisfaction during an outage is
11	the lack of an accurate restoration estimate. As such, one of the key elements of
12	the EFC – Outage Status initiatives is to improve the timeliness and accuracy of the
13	first Estimate Time of Restoration (ETR) that is delivered to the customers. Our
14	leading metric, First Estimate Accuracy, measures the percent of customers that
15	received a single and accurate estimated restoration time (ETR). The Company
16	measures First Estimate Accuracy based on the restoration estimate information
17	provided to our customers. In Non-Storm conditions, customers receive a day and
18	time estimate, while in Storm conditions customers receive a day-level estimate.
19	During a storm, an estimate is accurate if the customer receives a single estimate
20	communication and is restored the same day as the day provided in the estimate.
21	The Company defines First Estimate Accuracy more stringently during a Non-
22	Storm day, as the customer must receive a single estimate and be restored no earlier
23	than 10 minutes and no later than 3 hours of the estimate communicated. Through
24	its EFC investments, the Company has made steady improvement in this metric,

achieving the highest catastrophic storm accuracy rate to date in the January 2024
 CAT storm (Figure 9).





Line

No.

3

4

6 As seen in Figure 9, we have improved our first estimate accuracy between 2022 7 and 2023 by 48% for catastrophic storms (CAT) from 31% to 46%, and by 43% for 8 non-catastrophic storms (Non-CAT) from 42% to 60%. Additionally, during the 9 January 2024 CAT storm, we performed at 70%, which is above our 2024 Target 10 of 65% for all storms. Similarly, the Company has realized improvements in 11 estimate accuracy for Non-CAT storms, which has increased from 45% in 2023, to 12 57% in 2024. I would note here that because the Company changed the way we 13 define Non-CAT estimate accuracy in 2023, there is no comparative data for 2022 14 performance. Long-term, the Company is targeting 95% First Estimate Accuracy 15 during all storms, and is targeting delivery of those estimates within 4-hours of the 16 storm weather clearing, and within 1-hour during non-storms.

17

Additionally, we have improved our estimate delivery timeliness—the amount of
time between the weather clearing the service territory and the time outage-specific

⁵

1		estimates are delivered to customers. Based on all process improvements, our
2		timeliness has dramatically improved for both CAT and Non-CAT Storms. For
3		Non-CAT storms, we are delivering estimates on average within 5.5 hours after
4		weather has cleared, compared to 16-24 hours before the standard processes were
5		developed. For CAT storms, we are providing estimates on average within 10 hours
6		after the weather has cleared, as compared to 24-36 hours before the standard
7		processes were developed.
8		
9		Outage Notification Delivery
10		Historically, only 45% of customers with reported outages successfully received
11		the expected outage status notifications, which includes confirmation of their
12		outage, global restoration estimates, their personal restoration estimates, updates on
13		the status of their outage (e.g., crew assigned, damage being assessed), and their
14		power restored status. With its investments in EFC, the Company has increased this
15		percentage to 70% in 2022 and 88% in 2023, and is forecasting to increase this
16		percentage further to 92% in 2024, with a long-term target of 95%.
17		
18	Q69.	Can you describe what additional Core system enhancements beyond the
19		original project scope, are being enabled by the Company's incremental
20		investments in the EFC – Outage Status initiative?
21	A69.	Yes. The Company has identified and is investing \$5.8 million in incremental
22		2023-2025 capital to address emergent defects that emerged as a result of the 2023
23		ADMS implementation and to further enhance the PPS system, further improve
24		restoration estimate accuracy, and to enhance outage tracking and reporting
25		capabilities. This incremental capital is included in Exhibit A-24 Schedule N7, Page

Line No. 1 1, Lines 1, 2, 4, 6, and 7. I describe these enhancements, and their expected 2 outcomes and benefits, in the remainder of my response to this question. 3 4 **PPS** Enhancements 5 The Company is investing \$2.3 million in 2023 and 2024 bridge period, and \$0.3 6 million in 2025 test period, capital to further enhance PPS and its interfaces with 7 the AMI system, ADMS, and WISMO. In 2023, these enhancements allowed for 8 the implementation of system enhancements to ensure that the number of customer 9 outages align across all systems such as the outage map, internal outage dashboards, 10 and website outage totals. In 2024 and 2025, we are adding logic to our systems to 11 allow the Outage Management System (in ADMS) time to process outages before 12 we send communication to customers. This will prevent us from erroneously 13 sending pre-mature estimate communications and/or inaccurate power status 14 notifications. This will also help us reduce the number of power status unknown 15 notifications. These notifications are sent when we cannot reach the customers' 16 meters and are unable to determine whether they have power. This \$2.6 million in 17 incremental capital is included in the total Core system investments, which is 18 reflected in the EFC Exhibit A-24 Schedule N7, on Page 1, Columns c through e, 19 Lines 1, 2, and 4. 20

21 <u>Restoration Estimate Timeliness and Accuracy</u>

The Company is investing \$1.1 million in the 2023 and 2024 bridge period, and \$0.3 million in the 2025 test period, capital in its Restoration Estimate initiative, which leverages a standardization of processes and machine learning models to achieve its long-term estimate accuracy goals and objectives. This \$1.4 million in

	M. J. HATSIOS
Line <u>No.</u>	U-21534
1	incremental capital is included in the total Core system investments, which is
2	reflected in the EFC Exhibit A-24 Schedule N7, on Page 1, Columns c through e,
3	Line 6.
4	
5	There are eight defining guiding principles (Figure 10), which have informed the
6	creation of seven Restoration Estimate workstreams (Figure 11), two of which have
7	been completed, that support the continuous improvement of restoration estimates
8	to accelerate achievement of the Company's long-term 95% First Estimate
9	Accuracy target, and the timeliness by which estimates are communicated to
10	customers.
11	
12	Figure 10 - Restoration Estimate Guiding Principles









During non-storm outages, our outage management system generates an estimate based on an algorithm and sends it within 1 hour to our customers. And while we have improved First Estimate Accuracy significantly in 2023 (Figure 9), the continued use of a manual process during storms to generate restoration estimates means that many customers go for prolonged periods of time without an estimate, especially during CAT storms.

9

2

3

4

5

6

7

8

10 To reduce the amount of time required to provide customers a restoration estimate 11 during storms, a team of data scientists has developed several versions of a 12 restoration estimate machine learning model and are in the process of validating 13 them against historical storm data. Once fully developed, the machine learning 14 model will improve the timeliness of delivering storm estimates by being able to 15 process a significant volume of historical data, such as the number of customers 16 out, location, weather, and other environmental factors, without human intervention 17 to generate an estimate. The chosen model will be used in the summer of 2024 to generate restoration estimates alongside our existing manual method to gauge the 18

1 level of improvement and its accuracy. Once the accuracy of the model is 2 established, we will integrate it with the outage management system. Peers with 3 estimate models have spent several years refining their models. The model itself 4 will require a small team of data scientists to continue to train and refine it year 5 after year. 6 7 Outage Tracking and Reporting 8 The Company is investing \$1.8 million in 2024 bridge period capital to enhance its 9 outage monitoring, reporting and analytics capabilities. This incremental capital is 10 included in the total Core system investments, which is reflected in the EFC Exhibit 11 A-24 Schedule N7, on Page 1, Column d, Line 7. 12 13 Prior to the EFC – Outage Status initiative, we did not have one central location to 14 monitor customer outages and the related customer experience during an outage. 15 The systems available allowed us to monitor our job completion progress on outage 16 restoration, but we had no way of monitoring what our customers were 17 experiencing. For example, we did not have a robust or highly accurate method of 18 knowing how many, and which, customers were without power, if they had 19 received restoration estimates, and if those estimates were about to expire. 20 Furthermore, the Company had no visibility into the status of outage notifications 21 sent or received by our customers due to the issue of a legacy communication 22 platform that was not able to consistently and dependably handle the high volume 23 of communications required to be sent, nor provide an accurate record of what was 24 the exact communication sent and make it available in all our customer channels so 25 that customers are not provided with different information. For example, during Line No.

> 1 several of the 2021 storms, we found there were performance problems causing the 2 system to stop sending notifications, a situation for which the Company had no 3 visibility of until hours later. Therefore, customers did not receive proactive 4 information regarding their power status. 5 6 In August of 2022, the Company created new storm dashboards that allow for the 7 monitoring of the customer experience during power outages, including real-time 8 monitoring of the number of customers out, the number of customers restored, those 9 without outage restoration estimates, and customers with expiring estimates. These 10 dashboards provided the Company the visibility required during the heavy 2023 11 storm activity to improve the information provided to customers during both storm 12 and non-storm outages. The dashboards also allow us to monitor the success of 13 delivering outbound outage notifications. 14 15 Lessons learned from the use of these dashboards in 2023 informed opportunities 16 for enhancements in 2024 that will allow the Company to be more proactive and 17 aware during a storm, allowing it to better prioritize its restoration and 18 communication efforts. Examples of the 2023 enhanced dashboards are in Figures 19 12 and 13 below. 20



Figure 12 - Customer Outage Status Dashboard

2

3

Figure 13 - Customer Outage Notifications Dashboard

Error Free Out High level overview of	nge N	Notificati	on Monitoring by H to DTE customers during a p	OUF ower ou	tage by hour.				Refres Primar Latest	h Frequency: Hourly ET y Audience: Outage Exp Available Data: 3/11/20	erience Team 024 1:00:32 PM	
Period Filter	@ 0	utbound Suc	cess/Failure		Successful Ou	tbound SI	15/Email		Success by	Message Type		
Last ~ 1 Select	· 12	tal notifications	OTE sent to customers		Successful notific	ations DTE s	ent to custor	ners	Sucessful notif	ications DTE sent to custom	ers by MOT groupings	
Date Range	•	Fail Success	Suppressed O% of Failed Message	•	●EMAIL ®SHS				Outage c	Estimate CEstimate	Estimate 🕨	
3/11/2024 🖯	MBID	4.04		20% 8	NBID 1K				UIBW JK			
Premise ID	9000	3.0K		Nes	ique				anba			
All	 N 	2.0K		10% Pales	E 2K				5 2K			
WISMO Event ID	Court	1.0K 0.7	3.6% 2.6%	% of	0.4K		5 1K 0.7K 0.2K 0.1K 0.2K 0.1K 0.4K					
All	~	0.0K =1.4		0%	OK 2 2		2 2 2 3		ок 🛒		55555	
Message Type		10	99 111 112 12A 12A 12A 24 25 25 25 25		77	401	12A 1A 2A	1 2 3 3 2 3	8 2	12 12 12 12 12	42929	
All	~	No	30 1 vember December Qtr 4 2023		Nov	30 ember	Qtr-4	1 December		30 November D Qtr 4 2023	1 lecember	
EMAIL		By Hour by Date			By Hour by Date					By Hour by Date		
SMS		Success/Fail	Fail	1	Date	EMAIL	SMS	Total	Date	Outage confirmation	Estimate available	
County		Date	Latest Timestamp Count % of	Palled M	□ 11/30/2023	606	727	1333	11/30/20	23 447	361	
All	. 1	11/30/2023	30	1	□ 12/1/2023	7242	8093	15335	· 12/1/202	3 5230	3690	
	- 11	12/1/2023	336	1	12/2/2023	6466	7154	13620	□ 12/2/202	3 3065	1979	
Campaign		12/2/2023	263	1	□ 12/3/2023	7270	7904	15174	□ 12/3/202	3 5147	3130	
companyo		12/3/2023	402	1	12/4/2023	3801	4060	7861	0 12/4/202	3 2170	1404	
All	× I	12/4/2023	304	1	12/5/2023	2944	3412	6356	··· 12/5/202	3 1944	1254	
	- 1	12/5/2023	272	1	12/6/2023	5690	5873	11563	D 12/6/202	3 3804	3213	
	2	12/6/2023	485	1	0 12/7/2023	5258	5483	10741	···· 12/7/202	3 3591	3022	
All dates and times are in	ET	12/7/2023	320	1	0 12/8/2023	2691	2780	5471	12/8/202	3 1662	1220	
and a state of the state of the state		Total	70020	1	Tatal	1050000	1100020	2200046	Total	723134	544239	

4

Line

No.

Line
No.

1		The data and visibility provided by these dashboards allows Company employees
2		to delve deeper into analyzing and understanding the impact of downstream meter
3		issues on the effectiveness of our customer outage communications. For several
4		reasons, such as the battery life remaining in the AMI meter before it powers down
5		or drops in the relay of information across the meters and routers in the mesh
6		network, the performance of AMI meters communicating a power outage within 30
7		minutes was at 35% in 2023, and the percent of meters with "Power Unknown"
8		status after restoration, which relies on the PRNs successfully reaching the
9		Company, was at 17%.
10		
11		The EFC Reporting Team has been analyzing the Power Outage notifications
12		(PONs) and Power Restoration Notifications (PRNs) from the AMI meters to
13		identify opportunities to improve the accuracy and timeliness of the Company's
14		outage notifications and are pursuing 2024 capital investments that will increase
15		the percent of meters communicating within 30 minutes to 52%, and will reduce
16		the percent of meters with Power Unknown status to 5%.
17		
18	Q70.	Can you describe what additional Customer-Facing system enhancements,
19		beyond the original project scope, are being enabled by the Company's
20		incremental investments in the EFC – Outage Status initiative?
21	A70.	Yes. As previously described, the Company is seeking recovery for an additional
22		\$16.8 million in 2022-2024 EFC capital, beyond what was approved for recovery
23		in U-21297, and which is inclusive of the impact of \$5.2 million in 2022 EFC
24		historical capital that was previously disallowed as part of the Commission's
25		disallowance in U-21297 of the total \$51.3 million portfolio of digital self-service

2

3

4

5

6

projects. This incremental capital is included in the total amounts reflected in EFC Exhibit A-24, Schedule N7 on Pages 3-4, and which has been allocated to addressing emerging defects in the Customer-Facing systems that resulted from the 2023 ADMS implementation and to enhance the Customer-Facing systems to provide additional benefits to customers. I describe these enhancements in the remainder of my response to this question.

7

8

WISMO and Outage Map

9 The Company is investing \$5.2 million in incremental 2022-2024 capital in 10 WISMO and the Outage Map to remediate defects from the 2023 implementation 11 of ADMS, and to fund improvements in the integration between WISMO, the 12 Outage Map, and ADMS. Improved integration between WISMO and the Outage 13 Map enhances the consistency of data between what is presented in customer 14 outage notifications and what customers see on the Outage Map. This incremental 15 spend also addressed CRM performance issues encountered during the February 16 2023 CAT storms, which were related to outage reporting that was migrated from 17 CRM to WISMO, and enabling the use of WISMO to track outages reported by 18 Police, Fire, or Municipalities, thereby providing for these stakeholders the same 19 proactive monitoring, tracking, and messaging for these outages as for those 20 Details on costs by year for these system reported by other customers. 21 enhancements are in the EFC Exhibit A-24 Schedule N7 on Page 3 Lines 1-3.

22

23 <u>Notifications</u>

The Company is investing \$3.0 million in incremental 2022-2024 capital to further enhance the customer outage notifications experience. In 2023, this work included:

1	1) modifying the language and content for 38 outage Email, SMS, and Voice
2	notifications as part of the transition from the prior OMS (InService) to ADMS; 2)
3	eliminating duplicate messages; 3) ensuring proper sequencing of messages and
4	timeliness; and 4) improving the Preference Management Center to accurately
5	capture and use the customers' preferred service and communication channels.
6	
7	This incremental investment enhances the Company's ability to proactively reach
8	out to customers who are experiencing an outage. The details of this outreach are
9	provided below, and for which the capital investment details by year can be found
10	in Exhibit A-24 Schedule N7 on Page 3 Lines 4-5.
11	
12	1. Notifications to Customers who are "Likely Out" – The Company uses various
13	data points (e.g., AMI, equipment status, customer outage reports, etc.) to
14	predict when a whole circuit or area is without power. While the new premise-
15	based system uses customer AMI data to determine if a customer is without
16	power, the AMI data is not available 100% of the time—such as when a meter
17	has failed to communicate back to the Company for 100% of the impacted
18	customers. To proactively reach out to customers who are very "likely out", the
19	Company is developing the ability to trigger notifications to these customers to
20	let them know that the region in which they live has been impacted by a storm,
21	how many customers are impacted, and that it is believed that they are without
22	power as well, and provide these customers a method (e.g., two-way texting) to
23	confirm their power status.
24	2. Notifications of Planned Outage Communications - The Company is
25	leveraging its premise-based system to improve the timeliness and quality of

Line <u>No.</u>	U-21534
1	customer notifications for planned outages. All our work to date has focused
2	on unplanned outages. We still receive feedback from customers that we can do
3	a much better job communicating planned outages.
4	
5	Customer Channels
6	The Company is investing \$3.4 million in incremental 2022-2024 bridge period
7	capital to 1) remediate emerging CRM and digital channel defects that occurred
8	after the 2023 launch of ADMS, 2) fund an additional \$1.1 million in 2022 Outage
9	digital self-service solution enhancements, and 3) make ongoing enhancements,
10	including new Outage functionality and features in the Web and Mobile App.
11	
12	This effort has included the continuous improvement of the Outage Map, a
13	redesign of the native Outage App functionality, updating the Outage Center and
14	map statistics, the customer checklist (step 2) in the report outage workflow, and
15	the ongoing improvement in streetlight reporting, and the Police and Fire Web
16	portal which includes enhancing the downed power line reporting form, providing
17	additional wire types on which to report a problem, allowing Police and Fire
18	personnel to upload photos for their reported problem, and providing Police and
19	Fire personnel the estimated time of arrival (ETA) of DTE resources.
20	
21	In 2024, the enhancements provided to Police and Fire personnel will be expanded
22	to the Company's residential customers, first on the Web and then in the Mobile
23	App.

1 Proactive "Status First" Outage communications - The Company is notifying 2 customers that it is aware of their outage and providing those customers with 3 relevant information. This includes messaging customers who are using a digital 4 self-service channel to report their outage. Details on costs by year for these 5 Channel enhancements are in the EFC Exhibit A-24 Schedule N7 on Page 3 Lines 6 6-8. Also, see Exhibit A-24 Schedule N10 for the completed 2022 and 2024 Outage 7 and EFC Channel enhancements. 8 9 Part 7. Regulatory and Compliance Projects 10 **Q71**. Which Regulatory and Compliance projects will you discuss in this section of 11 your testimony? 12 Regulatory and Compliance investments are non-discretionary investments that A71. 13 must be made to satisfy MPSC requirements and other industry regulations and 14 compliance items the Company must adhere to provide service to its customers. 15 Part 7 of my testimony explains in detail the Company's non-discretionary 16 investments in the Regulatory and Compliance IT Investment Category, as shown 17 in Lines 1 through 17 of Exhibit A-12, Schedule B5.7.3. The planned costs across 18 the Regulatory and Compliance projects are discussed further below. 19 20 Q72. What specific projects are included in the Regulatory and Compliance IT 21 **Investment category?** 22 A72. There are twelve projects classified as Regulatory and Compliance. Eight projects 23 are related to Clean Energy. The remaining four projects include two that are 24 necessary to comply with industry regulations and standards, and two projects that 25 support the implementation of rates per approved MPSC rate case orders.

Line No.

1

2

Q73. Please explain why the Company is investing in the Clean Energy projects.

3 A73. DTE Electric customers are becoming more aware of, and interested in, 4 opportunities to support the growth in renewable energy and reduce or offset their 5 carbon footprint. As such, the Company is investing in seven projects totaling 6 \$22.9 million, consisting of \$1.1 million in historical period, \$7.3 million in 2023-7 2024 bridge period, and \$14.5 million in 2025 test period capital as shown in 8 Exhibit A-12 Schedule B5.7.3, in the expansion and creation of products and 9 services that allow customers to contribute to a cleaner environment. These 10 investments satisfy the Company's commitments to the MPSC and our customers 11 under the approved renewable energy plans (U-20851 and U-20713). Additionally, 12 there is one project called MIGP Data and Reporting on Line 40 of Exhibit A-12 13 Schedule B5.7.3 that is categorized in the Strategic investment category that is 14 included in this section.

15

16 Each of the MIGP tariffs have been approved by the MPSC for implementation, 17 with the associated capital dollars reflecting the investment necessary to build the 18 required fixed or volumetric charges in the CR&B system, to enroll or reserve 19 customer interest in a specific MIGP program, to update the Company's MIGP 20 Website, or to create supporting internal dashboarding and reporting to enable 21 efficient management of the MIGP programs. I will discuss each project below that 22 the Company is requesting for recovery in the instant case in the order in which 23 they appear in Exhibit A-12 Schedule B5.7.3.

24

25

1. Line 4 – MIGP Customer-Requested Renewable Energy Projects

Line		M. J. HATSIOS U-21534
<u>No.</u>		
1		2. Line 6 – MIGP Low Income Solar Pilot
2		3. Line 7 – MIGP Reservation System for New Enrollments
3		4. Line 8 – MIGP Website Update
4		5. Line 10 – MIGP Large Customer Prepayment
5		6. Line 11 – MIGP Scope 3 Billing and Enrollment
6		7. Line 15 – Rider 17: MIGreenPower, Residential and Small
7		Commercial & Industrial
8		8. Line 40 – MIGP Data and Reporting (Strategic Investment Category)
9		
10	Q74.	What is the scope of the MIGP Customer-Requested Renewable Energy
11		Projects?
12	A74.	The Company is investing \$2.7 million in 2023-2024 bridge period, and \$5.5
13		million in 2025 test period capital in the MIGP Customer-Requested Renewable
14		Energy Projects. The capital requested in on Line 4 of Exhibit A-12 Schedule
15		B5.7.3 reflects a variance of \$4.6 million less in the 36 months ending December
16		31, 2024, than was approved for cost recovery in U-21297 as the project has been
17		pushed out to 2025 due to a delay in the construction of these projects.
18		
19		These projects are unique contracts between a company and DTE to build dedicated
20		renewable assets to offset the customer's electricity use with green energy. The
21		Company has entered into agreements with two uniquely contracted customers to
22		build two dedicated solar parks with 650 MW and 400 MW of capacity,
23		respectively. Similar in scope to many of our MIGP renewable projects, this project
24		will include end-to-end enhancements to the CR&B system that will include billing,
25		reporting, accounting, and provide enrollment functionality for individual

	customer-requested projects, and any additional updates to fulfill the Company's
	commitment under these contracts. These unique contracts also require the creation
	and integration of a new product named "customer-requested solar park" into the
	CR&B system and will require enhancements and integration with SAP Business
	Warehouse (BW) and SAP Commerce Cloud. Customers will enroll and be billed
	based on the generation from these assets when the projects go into service. See
	Exhibit A-24 N3.1 Line 48 for additional project details.
Q75.	What is the scope of the MIGP Low Income Solar Pilots project?
A75.	The Company is investing \$1.2 million in 2024 bridge period, and \$0.8 million in
	2025 test period, capital in the MIGP Low Income Solar Pilots project as shown on
	Line 6 of Exhibit A-12 Schedule B5.7.3. The capital requested reflects a variance
	of \$1.0 million less in the 36 months ending December 31, 2024, than was approved
	for cost recovery in U-21297 as the pilot program is taking longer than expected to
	launch due to funding sources. Because of this, we are not ready to enroll and bill
	customers for this program.
	The MIGP Low-Income Solar Pilots project provides the IT functionality in the
	CR&B system to comprehend the Pilot's program parameters and objectives and
	enroll qualified low-income customers in the program. Additional functionality
	must also be developed in the system to collect donations that will offset the
	premium required for providing solar energy-sourced power to enrolled customers.
	This project will expand MIGP offerings to low-income customers who might not
	otherwise be able to participate in the program, and by enabling anyone, whether a
	DTE customer or not, the option to contribute into a low-income renewables fund.
	Q75. A75.

1		The funds from these voluntary contributions would be used in tandem with third-
2		party donations to fully-subsidize MIGP subscriptions for low-income customers.
3		The system capability to offer this program is addressed in the Company's Section
4		61 filing in MPSC Case No. U-20713, where further details of this and all MIGP
5		programs can be found. When this project is put into service customers will enroll
6		and be billed based on the generation from the assets. See Exhibit A-24 N3.1 Line
7		52 for additional project details.
8		
9	Q76.	What is the scope of the MIGP Reservation System for New Enrollments
10		project?
11	A76.	The company is investing \$1.5 million in 2023 bridge period capital in the MIGP
12		Reservation Systems project as shown on Line 7 in Exhibit A-12 Schedule B5.7.3
13		to allow residential and small business to enroll into a waitlist if the demand for the
14		MIGP Program exceeds the renewable energy generation currently available. From
15		the waitlist, customers will be enrolled into the MIGP program on a first come, first
16		serve basis when capacity becomes available. Similar in scope to many of the
17		MIGP renewable projects, this project will include end-to-end enhancements to the
18		CR&B system for the waitlist functionality and any related reporting and website
19		updates. See Exhibit A-24 Schedule N3.1 Line 53 for additional project details.
20		
21	Q77.	What is the purpose of the MIGP Website Update project?
22	A77.	The Company invested \$1.0 million in 2022 historical period capital in MIGP
23		Website Update project as shown on Line 8 of Exhibit A-12 Schedule B5.7.3 which
24		reflects a variance of \$0.2 million more in the 12 months ending December 31,
25		2022, than was approved for cost recovery in U-21297.

2 The MIGP Website Update project redesigned and updated the MIGP Website and 3 migrated it to the Cloud platform in line with the Company's cloud strategy and 4 roadmap for all non-core processes and applications. This upgrade improves the 5 customer experience and ease of use through a revamped process for new customer 6 enrollments, providing existing customers with the ability to change their 7 enrollment levels, and offering greater flexibility with guest enrollment and the 8 customer identification process—all of which reduced the complexity of these 9 processes. See Exhibit A-24 Schedule N3.1 Line 57 for additional project details.

10

Line

No.

1

11 Q78. What is the scope of the MIGP Large Customer Prepayment?

12 A78. The Company is investing \$1.3 million in 2025 test period capital in the MIGP 13 Large Customer Prepayment project as shown on Line 10 of Exhibit A-12 Schedule 14 B5.7.3 to allow contracted customers the ability to prepay for future renewable 15 energy charges per Section 61 of the Settlement Agreement. Development will 16 include creating a separate renewable energy accounts receivable section on the 17 customer's bill, a new accounting and general ledger system, and data and reporting 18 tools to enable the program. See Exhibit A-24 Schedule N3.1 Line 50 for additional 19 project details.

20

21 Q79. What is the purpose of MIGP Scope 3 Billing and Enrollment project?

A79. The Company is investing \$3.9 million in 2025 test period capital in the MIGP
Scope 3 Billing and Enrollment project, as shown on Line 11 of Exhibit A-12
Schedule B5.7.3 to allow for sponsored MIGP enrollment per the Section 61
agreement. Customers will have the ability to incur the renewable energy charges

1		of another customer. For example, a business could elect to be billed for the
2		renewable energy charges of their employees that enroll in the MIGP
3		program. Similar in scope to many of the MIGP renewable projects, this project
4		will include end-to-end enhancements to the CR&B system that will include the
5		required billing, accounting, and reporting functionality. See Exhibit A-24
6		Schedule N3.1 Line 54 for additional project details.
7		
8	Q80.	What is the scope of the Rider 17 - MIGreenPower, Residential, Small
9		Commercial, and Industrial project?
10	A80.	The Company is investing \$1.9 million in 2023-2024 bridge period and \$3.0 million
11		in 2025 test period capital in the Rider 17 - MIGreenPower, Residential, Small
12		Commercial, and Industrial project. This capital reflects a variance of \$1.9 million
13		less in the 24 months ending December 31, 2024, than was approved for cost
14		recovery in U-21297. This is because the planned work could not start until after
15		the Commission approved the project in November 2023.
16		
17		This project replaces the Rider 19 MIGP Large Commercial & Industrial project,
18		as Rider 19 ended on August 19, 2022, and has been merged with Rider 17. The
19		project scope includes CR&B system changes required to create a fixed price
20		offering for large customers and the ability to enroll residential and streetlighting
21		accounts, bill customers, and other enhancements to manage and administer the
22		program. See Exhibit A-24 Schedule N3.1 Line 80 for additional project details.
23		

Q81. Is the Company investing in any other projects related to supporting the management of the MIGP Programs or to integrate its renewable programs with other products and services?

4 A81. Yes. The Company is also investing \$0.9 million in 2023 bridge period capital in 5 the MIGP Data and Reporting project as shown on Line 40 of Exhibit A-12, 6 Schedule B5.7.3 that will enhance the management of the MIGP programs and 7 integrate the MIGP programs with other products and services into one reporting 8 solution. The capital investment in this project reflects a variance of \$0.7 million 9 less in the 24 months ending December 31, 2024, than was approved for cost 10 recovery in U-21297, because the project being rescheduled due to project 11 reprioritization.

12

13 This solution will allow the Company to efficiently track and manage MIGP 14 enrollments, usage data, and revenue. The current dashboard and reports rely on a 15 manual process of exporting reports from the source system, analyzing the results, 16 and then importing files to view in a dashboard. A more efficient solution would 17 allow a new dashboard to be updated directly from the source system without 18 manual intervention and in real-time. In addition, the existing manual process is 19 becoming unsustainable as the number of MIGP enrollments continue to grow. The 20 upward trend in the volume of data points being processed is contributing to further 21 slowdowns in processing time.

22

Q82. What is the purpose of the Customer Notifications – TCPA Compliance project?

1	A82.	The Company is investing \$0.3 million in 2024 bridge period capital for the
2		Customer Notifications – TCPA Compliance project as shown on Line 3 of Exhibit
3		A-12 Schedule B5.7.3 to comply with the Telephone Consumer Protection Act
4		(TCPA), a federal regulation enacted in 1991 that was amended in 2023 to include
5		SMS/text messages sent to a customer. The regulation includes guidelines on what
6		constitutes a marketing communication versus necessary account communication.
7		With our established automated notifications program, we need to enhance
8		reporting to ensure proper monitoring of the quantities and types of notifications
9		sent to the customer to ensure the Company's TCPA compliance. Fines for non-
10		compliance range from \$500.00 to \$1,500.00 per instance. The Company sends
11		approximately 60 million notifications annually, most of those automated messages
12		are sent in mass to customers requiring tools to monitor these volumes. See Exhibit
13		A-24 Schedule N3.1 Line 24 for additional project details.
14		
15	Q83.	What is the purpose of the PCI Compliance project?
16	A83.	To ensure DTE Electric complies with the Payment Card Industry (PCI) Data
17		Security Standards (DSS) established by the credit card industry and audited by a
18		certified PCI Security Assessor.
19		
20	Q84.	Why does DTE need to maintain PCI compliance?
21	A84.	In 2019, the Company achieved PCI DSS Compliance. The Company is investing
22		\$0.1 million in 2022 historical period, \$0.3 million in 2022-2023 bridge period,
23		\$0.2 million in 2025 test period capital to maintain PCI DSS compliance to the most
24		recent standards. The 2023-2024 spend was approved for cost recovery in U-21297.
25		See Exhibit A-24 N3.1 Lines 66 and 69 for additional project details.

Line <u>No.</u>

1		
2		35-40% of payments received from customers are made using a credit or debit card.
3		To accept, store, process, and transmit payments and cardholder data, DTE Electric
4		must adhere to PCI DSS. Failure to adhere to PCI DSS could result in the loss of
5		payment certification with our banking partners and would prevent us from being
6		able to accept credit or debit card payments. This project ensures that DTE's
7		Contact Center's telephony and Interactive Voice Response (IVR) systems remain
8		PCI-compliant. Through these Contact Center systems, DTE customers can
9		complete self-service payments over the phone's automated system as well as
10		provide CRs with credit card information to complete their payments.
11		
12	Q85.	What is the purpose of the Regulatory Compliance project?
13	A85.	The Company is investing \$0.8 million in 2022 historical period, \$5.6 million in
14		2022-2023 bridge period, and \$2.8 million in 2025 test period capital, for the
15		Regulatory Compliance project as shown on Line 14 of Exhibit A-12, Schedule
16		B5.7.3 to fund ongoing and emerging rate changes required to be implemented in
17		the CR&B system. The 2022-2024 spend was approved for cost recovery in U-
18		21297. See Exhibit A-24 Schedule N3.1 Line 77 for additional project details.
19		
20		This project funds CR&B and reporting system changes necessary to comply with
21		the outcome of any MPSC rate orders, to provide funding for emerging regulatory
22		compliance items, and to fund the implementation of new rates and programs as
23		approved by the MPSC.
24		

1 In 2022, funding from the Regulatory Compliance project supported the roll-out of 2 the D13 rate as DTE Electric proposed a D13 XL-HLF rate to provide the Company 3 the opportunity to optimize its load base and make incremental contributions to 4 DTE Electric's fixed costs. The D13 rate aimed to provide customers with 5 competitively priced electricity consistent with cost-of-service-based rates to 6 address the changing circumstances of its automotive and other advanced 7 manufacturing customers. 8 9 In 2023, this project, as in prior years, provides a yearly investment that allows 10 DTE to implement IT system changes inclusive of logic and screen changes to the 11 CR&B system for the Agency Website/Online Resource for Energy Assistance 12 Agencies (AGW/ORA) applications, and StreamServe for bill formatting changes 13 to support emergent Regulatory work. 14 15 As a result of a 2023 MPSC ruling, the CR&B system application revised outflow 16 billing determinant calculation for all Rider 18 demand-based rates. The outflow 17 demand will be determined by the average of On-Peak demand during the billing 18 period. Also, for Rider 18 D1.8 customers, the invoice should display the Critical-19 Peak, Mid-Peak, On-Peak and Off-Peak information under the Current Billing 20 Information section of the bill. Additionally, the redesign of the existing Low 21 Income Self Sufficiency Plan (LSP) will allow for a reduced monthly plan amount 22 developed for each household based on their previous 12-months usage while 23 issuing monthly credit incentives based on household income and consumption. 24 The redesigned LSP program will also change the way arrears forgiveness is issued

1 and introduce plan amount reviews at regular intervals to ensure the customer's 2 budget portion is aligned with their recent consumption pattern. 3 4 In the 2024 bridge period, as described by Company Witness Willis in his testimony 5 related to the Company's proposal for transitioning D1.6 customers to the new 6 D1.11 TOD rate and closing the D1.6 rate, investments from the Regulatory 7 Compliance project will fund the CR&B system changes required to complete the 8 three key elements of this transition. 9 10 Currently, the Low-Income Assistance (LIA) credit is available only to customers 11 taking service on D1.6 – a customer who is otherwise eligible but chooses to take 12 service on a different base rate may not avail themselves of the credit. The transition 13 to Time-of-Day rates provides an opportunity not only to re-align rate design for 14 D1.6 customers, but also to expand their ability to choose their base rate schedule 15 while retaining the LIA credit. The Company anticipates the implementation of this 16 transition will occur during the projected bridge year. Thus, the Company's Exhibit 17 A-16, Schedules F3 and F8 both reflect the continuation of D1.6 into the 2025 18 projected test year given the requirement to continue utilizing the rate for a period 19 of time. 20 21 In addition to the scope previously described, this project also ensures there is 22 sufficient funding for planned and emergent revisions to electric rates, amendments 23 to rate schedules and rules governing the distribution and supply of electric energy,

24 25 and any other modifications of DTE Electric rates in accordance with MPSC orders.

1	Q86.	What is the scope of the Securitization Project?
2	A86.	The Company invested \$0.3 million in 2022 historical period capital in the
3		Securitization project as shown on Line 16 in Exhibit A-12 Schedule B5.7.3 to
4		complete the necessary rate changes in the CR&B system to include two new
5		securitization surcharges for residential, industrial, and commercial customers.
6		DTE filed MPSC Case No. U-21015 requesting MPSC approval to issue
7		securitization bonds and implement a surcharge related to the cost of the
8		Company's retirement of the River Rouge power plant and a surge in tree trimming
9		costs. The Commission granted approval for the securitization of up to \$235.8
10		million in qualified costs on June 23, 2021. See Exhibit A-24 Schedule N3.1 Line
11		81 for additional project details.
12		
13	Part 8	3. Historical 2022 Project Spend Variance and Other Project Variance
14	Q87.	How much total Customer IT Portfolio capital did the Company spend in
15		2022, and how does it compare to what was approved for recovery in Case No.
16		U-21297?
17	A87.	The Company spent \$224.3 million of capital on IT projects in 2022 compared to
18		the \$165.0 million approved by the Commission in Case No U-21297, as shown in
19		Line 18 of Exhibit A-24 Schedule N2, which is \$59.3 million more than was
20		approved.
21		
22	Q88.	For projects supported in your testimony in the instant case, what is the
23		variance between the capital the Company spent in 2022, and what was
24		approved for recovery in Case No. U-21297?

1	A88.	For the projects that I support in my testimony in the instant case, there is a variance
2		of \$21.9 million between the amount of capital that was approved for cost recovery
3		in Case No. U-21297 and capital invested by the Company. This variance is
4		associated with seven projects shown in Exhibit A-24 Schedule N2 and include:
5		Error Free Communications, Bill Management, Customer Relationship and Billing
6		Program Enhancement, Advanced Analytics Use Cases, and three projects whose
7		spend were a sub-set of the \$51.3 million Digital Self-Service Project Portfolio
8		described in U-21297. The specific projects that make up the variance are listed
9		below with references to the corresponding testimony in the sections above and/or
10		in Table 9 below.

Project	Variance Testimony Reference	Variance Explanation
Error Free Communication - Outage Status	Page MJH-81, Lines 7-16.	In 2022, the Company invested \$7.8 million more than was approved in U-21297 for cost recovery. The additional spend is due to \$0.7 million spent on WISMO and Outage Map system enhancements to fund enhancements to the WISMO and Outage Map interfaces with the core system enhancements, \$0.8 million for updating customer notifications and development of Outage status dashboard reporting, and \$6.3 million on customer channel enhancements for the Web and IVR. Of the \$7.8 million variance in 2022, \$5.2 million funded investments to improve the customer's outage digital experience and was part of the \$51.3 million portfolio of digital self-service projects that was disallowed in the Commission's Final Order in U-21297.
Journey Work Product Transformation Teams	Page MJH-21, Lines 3-5. Page MJH-25, Lines 9-11. Page MJH-29, Lines 10-12.	See testimony reference. The Company invested \$6.7 million in 2022 to fund investments to improve the customer's Collections, MIMO and Outage digital experience and this spend was part of the \$51.3 million portfolio of digital self-service projects that was disallowed in the Commission's Final Order in U-21297.
Bill Management	Page MJH-34, Lines 12-16.	See testimony reference. The Company invested an additional \$3.4 million in the Bill Management tool in 2022 to address identified defects, to continue to enhance the Billing experience, and to incorporate the ability for the tool to effectively analyze and simulate Time-of-Day (TOD) bills, to support the TOD project go-live in March of 2023.
IVR Virtual Assistants	Page MJH-25, Table 5. Page MJH-25, Lines 19-21. Page MJH-26, Lines 1-3.	See testimony reference. The Company invested \$1.3 million (\$1.2 million net of 2023) in 2022 to fund investments in the MIMO Virtual Assistant to improve the customer's MIMO digital experiences and this spend was part of the \$51.3 million portfolio of digital self-service projects that was disallowed in the Commission's Final Order in U-21297.

Line No.

Project	Variance Testimony Reference	Variance Explanation
Customer Relationship and Billing Program Enhancement	Page MJH-21, Lines 1-3. Page MJH-25, Lines 7-9. Page MJH-33, Lines 7-10. Page MJH-54, Lines 24- 25. Page MJH-55, Lines 1-4.	The Company invested \$1.2 million more in 2022 spend composed of the following two reasons: 1) \$0.4 million of the 2022 CR&B spend variance is because this spend was part of the \$51.3 million portfolio of digital self- service projects that was disallowed in the Commission's Final Order in U-21297. See testimony reference. 2) The variance of \$0.8 million more than was approved for recovery in U-21297 was due to additional scope required to support enhancements in the Collection, MIMO and Billing transactions to improve the customer's experience and improve First Contact Resolution (FCR). See testimony reference.
Advanced Analytics AA Use Cases Implementation	N/A	In 2022, the Company invested \$1.1 million more than approved in U-21297 for cost recovery. The Advanced Analytics Use Cases project leverages advanced analytics, machine learning and other data science techniques and technologies in specific use cases to derive greater insight into customer segments, behaviors, and pain points, to understand the drivers of customer satisfaction, and to support reduction in O&M costs and uncollectible expense (UCX) or to capture operational efficiencies that improve the effectiveness of our processes and key transactions. All the 2022 variance is due to the full disallowance of the entire \$4.3 million in 2022-2024 project spend in the Commission's Final Order in U-21297.
Customer Closed Loop Development	Page MJH-63, Lines 8-13.	See testimony reference. The Company invested \$0.3 million in 2022 to fund investments to improve the customer's MIMO and Collection digital experience and this spend was part of the \$51.3 million portfolio of digital self-service projects that was disallowed in the Commission's Final Order in U-21297.

1

2	Q89.	Were there any other projects that had variances that you have not yet
3		discussed?

- 3
- A89. Yes. There are two projects listed below that were not completed in 2022 and 2023 4
- 5 and are not planned for completion in 2024 as previously approved for cost
- 6 recovery in Case No. U-21297.
| Line | | M. J. HATSIOS
U-21534 |
|------------|--------|---|
| <u>No.</u> | | |
| 1 | | 1. IVR Natural Language – This project is currently being rescheduled and upon |
| 2 | | approval of the confirmed project dates, the request for cost recovery will be |
| 3 | | re-submitted for approval in a future rate case. |
| 4 | | 2. Secure Cloud Payment Provider Migration - This project is currently being |
| 5 | | rescheduled and upon approval of the confirmed project dates, the request for |
| 6 | | cost recovery will be re-submitted for approval in a future rate case. |
| 7 | | |
| 8 | Part 9 | – Customer Service Operation and Maintenance Expense |
| 9 | Q90. | What work does the Customer Service group perform? |
| 10 | A90. | Customer Service is responsible for managing the customer support processes for |
| 11 | | both DTE Electric and DTE Gas. Customer Service is comprised of operational |
| 12 | | and customer strategy and insight organizations that are responsible for conducting |
| 13 | | the work associated with customer transactions, data analytics, arrears reduction, |
| 14 | | billing, and payment acceptance. |
| 15 | | |
| 16 | Q91. | What is the role of Customer Service for DTE Electric? |
| 17 | A91. | The Customer Service team supports the delivery of highly satisfying customer |
| 18 | | experiences and drives improvement where needed. Through continuous |
| 19 | | improvement, technology is leveraged to meet and anticipate changing customer |
| 20 | | expectations. This technology includes digital channels for customers to conduct |
| 21 | | business in the channel of choice and programs that provide added ease and |
| 22 | | convenience. |
| 23 | | |
| 24 | | To better assist our employees in making decisions in moments of service and |
| 25 | | enable service excellence, the Company established the Keys of Service |

Line <u>No.</u>		U-21534
1		Excellence. These keys are: Safe, Caring, Dependable, and Efficient. All Customer
2		Service activities pass through the Service Keys. Our desired culture is one where
3		all employees have a service mindset and a strong emotional connection to caring
4		for our customers and each other.
5		
6	Q92.	What are the two divisions of Customer Service?
7	A92.	Customer Service is made up of Operations and Customer Strategy & Insight.
8		
9	Q93.	What departments make up Customer Service Operations and what are their
10		functions?
11	A93.	Customer Service Operations consists of the following departments:
12		
13		Contact Center Operations
14		• Metering, Billing, & Exceptions
15		Revenue Management & Protection (RM&P)
16		Customer Service Operations Support
17		
18		Contact Center Operations manages requests for new service, responds to inquiries

to inquiries regarding account information, schedules work requests from customers, and 19 20 responds to emergency and trouble calls.

21

22 Metering, Billing, and Exceptions is responsible for meter reading, residential and commercial billing, major accounts billing, customer print and delivery, and bill 23 24 issue resolution. The team is responsible for working and resolving any billing and 25 collection issues that include manual intervention. These items primarily consist of

		M. J. HATSIOS
Line <u>No.</u>		U-21534
1		billing exceptions, collections exceptions, bankruptcy, ID fraud probate, and theft
2		work.
3		
4		RM&P manages credit policies, administers low-income programs, and accounts
5		receivable collection. RM&P is also responsible for theft investigations,
6		remediation, and determining accountability for unauthorized usage.
7		
8		Customer Service Operations Support is responsible for quality and training of
9		Customer Service staff. It also has responsibility for the overall Continuous
10		Improvement efforts of the Customer Service Organization.
11		
12	Q94.	What departments make up Customer Strategy and Insight and what are their
13		functions?
14	A94.	Customer Strategy and Insight consists of:
15		
16		Customer Service Transformation
17		Customer Service Analytics
18		• Executive Consumer Affairs Center (ECAC)
19		Digital Experience
20		
21		The Customer Service Transformation organization provides system and technical
22		support for the Customer Relationship & Billing (CR&B) system. The System
23		Support group identifies emerging trends in SAP, coordinates business design,
24		manages the translation of business needs to system design, identifies defects, and
25		supports solutions. The Technical Support group are experts in functional design

1

2

3

4

5

and serve as liaisons to the ITS organization. They conduct unit testing, complete simple configuration, support proof of concept designed, and resolve incident management tickets as applicable. The Customer Service Transformation organization also develops dashboards to visualize transaction completion and other performance metrics.

6

7

8

9

Customer Service Analytics is responsible for providing data analytics support to Customer Service, which includes data queries, reports on customer segmentation, and predictive modeling.

10

11 ECAC resolves escalated customer issues that are received from the Michigan 12 Public Service Commission, "I Can Help" (including Media, Government Affairs, 13 Regional Relations, and Employees), Better Business Bureau, the Attorney 14 General, and DTE's Website. This organization also includes the Customer 15 Insights & Research team that manages all aspects of customer satisfaction 16 measurement and feedback loops to resolve outstanding issues from the customers 17 surveyed. The team also collaborates with internal stakeholders to develop and 18 execute customer-facing research such as online quantitative surveys, qualitative 19 focus groups, and individual interviews that are used to gather customer insights.

20

Digital Experience is responsible for creating a customer-focused, consistent, multichannel experience that emphasizes the use of DTE's self-service channels, including mobile applications, kiosks, the DTE website, and Interactive Voice Response (IVR) to provide excellent and efficient customer service. The team has two components: (1) Transactional Experience, which focuses on customer

Line No.		M. J. HATSIOS U-21534
1		transactions including policy reviews and process design to mitigate hand offs and
2		customer dissatisfaction and (2) Digital Experience, which focuses on efficient and
3		satisfying methods to complete these transactions.
4		
5	Q95.	How are costs allocated between DTE Electric and DTE Gas for Customer
6		Service?
7	A95.	Customer Service costs are allocated based on utility-specific data that is
8		representative of the amount of electric- or gas- related work conducted within the
9		organization. The allocations for the current year are based on actual activity data
10		from the previous year. Several costs are allocated based on the number of electric
11		and gas customers.
12		
13		Call Center Operations, Customer Service Operations Support, Customer Service
14		Transformation, Digital Experience, and ECAC expenses are allocated based on
15		the number of electric and gas customers. For a customer who is both an electric
16		and a gas customer, that customer is counted as one-half electric and one-half gas.
17		For 2022, 66.2% of these expenses were allocated to DTE Electric.
18		
19		Customer Billing expense is allocated between DTE Electric and DTE Gas via two
20		cost allocation drivers. The first driver is based on the number of electric and gas
21		customers and the second, used for Meter Reading expenses, is based on the number
22		of Advanced Metering Infrastructure (AMI) and non-AMI customers. For 2022,
23		66.2% of Customer Billing expense was allocated to DTE Electric based on the
24		number of electric and gas customers. Based on AMI and non-AMI customers, the
25		2022 DTE Electric allocation for Meter Reading Expenses was 9.3%

Line <u>No.</u>		M. J. HATSIOS U-21534
1		RM&P allocates costs based on the number of accounts in arrears. For 2022, 65.2%
2		of RM&P expense was allocated to DTE Electric.
3		
4	Q96.	What was the total DTE Electric O&M cost related to Customer Service for
5		the 2022 historical test year?
6	A96.	The total O&M cost related to Customer Service for the adjusted 2022 historical
7		test year is \$112.4 million. A detailed breakdown of the 2022 historical test year
8		actual O&M expense adjusted by rate case eliminations, normalization
9		adjustments, inflation, and other known and measurable adjustments is provided in
10		Exhibit A-13, Schedule C5.7.
11		
12	Q97.	What expenses are included in the 2022 total O&M costs provided on Exhibit
13		A-13, Schedule C5.7?
14	A97.	The components that make up the \$112.4 million O&M expense:
15		
16		Customer Accounts Expenses \$94.7 million
17		Customer Service and Informational Expenses \$25.4 million
18		• Less Reclass to Marketing Exhibit \$7.6 million
19		
20	Q98.	What adjustments were made to the historical test period?
21	A98.	The following adjustments are shown on Exhibit A-13, Schedule C5.7:
22		
23		• Column (c) Line 20 reflects a \$7.6 million reclassification to Marketing
24		Expenses, sponsored by Company Witness Bennett on Exhibit A-13
25		Schedule C5.9 Line 5.

<u>No.</u>		
1		• Column (d) Line 19 eliminates \$173 million in expenses related to the
2		Energy Waste Reduction Program (EWR). O&M expenses for the
3		Company's EWR program are recorded in FERC accounts 905, 907, 908
4		and 909. Since these costs have their own distinct recovery surcharges and
5		are reconciled in separate MPSC proceedings, I have eliminated them from
6		O&M. These eliminations are shown in Column (d) of Exhibit A-13,
7		Schedule C5.7.
8		• Column (e) Line 19 eliminates \$23.9 million for the Low-Income Energy
9		Assistance Fund (LIEAF). The LIEAF expense being eliminated is
10		associated with the remittance of the revenue collected through the LIEAF
11		surcharge. Funds collected through the surcharge (a state-mandated charge)
12		are remitted directly to the state and help provide heating assistance to low-
13		income customers.
14		
15	Q99.	What are the primary activities included in the Customer Accounts Expenses
16		category totaling \$95.7 million?
17	A99.	The Customer Accounts Expenses category includes Supervision \$2.0 million,
18		Meter Reading \$2.1 million, Customer Records and Collection \$76.9 million,
19		Merchant Fees \$11.8 million as supported by Company Witness Peterson,
20		Customer 360 Amortization \$2.8 million as supported by Company Witness
21		Uzenski, and ACPP/Time of Day Reg Asset Amortization for \$0.1 million.
22		
23	Q100.	What makes up the \$2.0 million Supervision expense?
24	A 100	Second and the second s

Line

A100. Supervision expenses allocated to FERC 901 include Customer Service senior
leadership and support staff.

<u>).</u>	
1	Q101. What activities make up the \$2.1 million in Meter Reading?
2	A101. The Company utilizes external vendors to manually read meters not converted to
3	AMI meters and AMI opt-out meters. These costs also include other back-office
4	support such as route coordinators and personnel who are responsible for
5	monitoring the adherence of the contract terms by the service provider, handling
6	the weekly service provider billing, and analyzing meter reading complaints.

- 7
- 8 Q102. What organizations contribute to the \$76.9 million of customer records and 9 collection expenses?

- 10 A102. The organizations included in Customer Records and Collections are the following:
- 11
- 12 **Contact Center Operations** •
- Revenue Management & Protection (RM&P) 13
- 14 Metering, Billing, and Exceptions •
- 15 Customer Experience •
- 16 **Customer Service Operations Support**
- 17

18 Q103. What activities are comprised in the Contact Center Operations organization?

19 A103. Much of the activity in the Contact Center Operations organization is customer-20 facing. Handling over four million calls annually, the organization is the front line 21 for customer resolution. Support staff within the Contact Center Operations 22 organization handle routing for both internal and external calls, operational support, 23 and the telecom IVR technology associated with the Company's toll-free number. 24

25 Q104. What has been the focus of the Contact Center Operations organization?

		M. J. HATSIOS
Line <u>No.</u>		U-21534
1	A104.	The focus of the Contact Center Operations is streamlining the customer experience
2		and includes:
3		
4		• Incorporating CR represented web chats across MIMO and billing
5		transactions to provide assistance to customers.
6		• Workforce automations that provide real-time CR productive status and
7		schedule adherence to optimize off-phone activities.
8		• Continued closed-loop enhancements to provide efficient assistance to
9		customers during a single call interaction.
10		
11		These efforts are supported by projects outlined in the capital section of my
12		testimony.
13		
14	Q105.	What components make up the RM&P organization?
15	A105.	There are four major components that make up the RM&P organization:
16		
17		Internal & External Collections
18		Field Operations
19		Energy Advocacy Group (formerly Advocacy & Customer Offices)
20		• Strategy & Reporting and RM&P Staff
21		
22	Q106.	What are the activities of Internal and External Collections?
23	A106.	The Internal and External Collections group uses external collection agencies to
24		perform collection on outstanding arrears to reduce uncollectible expense.
25		Effective use of this partnership allows the Company to mitigate the impact of

Line

No.

1 uncollectible expense related to customers who have been disconnected. Company Witness Johnson provides more detail on uncollectible expense in her direct testimony.

4

2

3

5 Q107. What are the activities of the RM&P's Field Operations group?

6 A107. RM&P's Field group performs theft investigations and non-pay manual 7 disconnects. Field Operations is responsible for driving operational efficiencies 8 through accurate and timely shutoffs. DTE is committed to protecting the safety 9 of our communities throughout our service territory. Effective management of 10 energy theft minimizes lost revenue while safeguarding legitimate customers from bearing the cost of utility theft. The illegal connection activity associated with theft 11 12 also exposes customers and the public in general to potential life-threatening 13 hazards.

14

15 Q108. What activities comprise the Energy Advocacy Group (formerly Advocacy & 16 **Customer Offices**)

17 A108. The Energy Advocacy Group (EAG) focuses on some of the Company's most 18 vulnerable customers. This includes supporting our Low-Income Self-sufficiency 19 Plan (LSP) customers and working with partner agencies. In 2022, the EAG team 20 handled over 160,000 calls and completed 67,090 low-income validations and 21 approximately 3,574 medical exception hold requests. EAG assists all customers, 22 but with a focus on our most vulnerable. Customer Assistance Days (CADs) is one 23 way in which assistance is provided. In 2022, the EAG team continued to assist 24 households through virtual CADs including an In-Person DTE Customer Resource 25 Fair hosted in partnership with THAW during its 13th Annual Week of Warmth.

Line <u>No.</u>		M. J. HATSIOS U-21534
1		These events are often based on partnership with local agencies and organizations
2		to provide case management solutions, energy efficiency education, and utility
3		payment assistance to customers in need throughout the year.
4		
5	Q109.	What are the activities for the Strategy and Reporting RM&P staff?
6	A109.	The Strategy and Reporting RM&P staff is responsible for creating and maintaining
7		the customer service billing and payment plan policies. In addition, the team is
8		responsible for compliance, supporting metrics, and data analysis as they pertain to
9		these policies.
10		
11	Q110.	What are the activities of the Metering, Billing, and Exceptions group?
12	A110.	The Metering, Billing, and Exceptions group is responsible for obtaining manual
13		reads on DTE's meters; billing activities for residential, small commercial, large
14		commercial and industrial customers; print and delivery for customer-facing
15		mailings including bills; exceptions management including billing investigations,
16		bankruptcy filings, probate filings, ID fraud and theft billing; and billing programs
17		such as Budget Wise Bill (BWB) and eBill.
18		
19	Q111.	What activities make up Customer Experience?
20	A111.	Customer Experience is responsible for developing modern technologies for
21		customers to interact with the Company through self-service channels such as the
22		internet and mobile applications. The self-service applications include electronic
23		billing, payment, move ins/move outs, outage reporting, estimate communications
24		and status updates, and others.
25		

Q112. What work activities comprise the Customer Service Operations Support organization?

A112. Customer Service Operations Support organization has established, documented,
and implemented a Quality Management System (QMS) which includes processes
and procedures associated with Customer Service. Documented processes are
maintained and continually improved to ensure that the QMS achieves its intended
results. Over 1,000 Customer Service documented processes are included in the
QMS which includes but are not limited to: Call handling, collections, digital
experience, billing, and quality assurance.

10

QMS includes a structured quality approach to ensure processes are followed,
continually improved, and operational stability is maintained. Tools used to identify
risk and opportunities may include but are not limited to: Process Failure Mode
Effects Analysis (PFMEA), Strengths Weaknesses Opportunities Threats (SWOT),
Corrective Action Program (CAR), and Journey Mapping.

16

17 Additionally, the organization conducts training of new Customer Service 18 employees, provides ongoing training to existing employees, and provides quality 19 assurance for customer calls using advanced call monitoring and recording 20 technology. These and many other key activities drive defect prevention and 21 increase customer satisfaction. In 2021, as a result of driving continuous 22 improvement across the Customer Service organization, DTE received the world's 23 first ISO 9001:2015 certification awarded to a customer service organization. The 24 certification, from the International Organization for Standardization (ISO), 25 recognizes that the Company's employees are highly focused, motivated, and

Line No.

Line <u>No.</u>	M. J. HATSIOS U-21534
1	engaged in providing quality service for their customers. Customer Service will
2	champion recertification in 2024.
3	
4	Q113. What is included in the Customer Collection – Merchant Fees?
5	A113. Refer to Company Witness Bennett 's testimony in the instant case for details on
6	merchant fees.
7	
8	Q114. What are the primary components of the Customer Service and Informational
9	Expenses category totaling \$24.4 million?
10	A114. The Customer Service and Informational Expenses category is primarily made up
11	of activities related to Supervision \$3.8 million, Customer Assistance \$15.0
12	million, and Miscellaneous Customer Service and Informational Expenses \$5.6
13	million.
14	
15	Q115. What is included in the \$3.8 million in Supervision expenses?
16	A115. Most of the costs are labor for regulated marketing activities including internal and
17	external stakeholders.
18	
19	Q116. What are the primary components that comprise the \$15.0 million in
20	Customer Assistance Expenses?
21	A116. Excluding the Energy Waste Reduction Program and LIEAF offsets mentioned
22	above, there are four major components that make up the \$15.0 million in expense:
23	
24	Customer Service Groups
25	• Regulated Marketing (sponsored by Company Witness Bennet)

<u>No.</u>		
1		Distribution Operations
2		Public Affairs
3		
4	Q117.	What are the activities of the Customer Service Groups (Strategy & Insight)?
5	A117.	The Customer Service Groups drive strategy and continuous improvement
6		processes including system and process enhancements to improve the customer
7		experience. Activities such as benchmarking of best-in-class utilities and other
8		world-class customer service organizations allow us to ensure we are aware of
9		changing customer expectations and how others are responding to it. Root cause
10		analysis activities have been critical to improving the Company's internal service,
11		resulting in improved employee and customer engagement. The Customer Service
12		Groups identify key customer "blue chip" priorities such as reliability, transaction
13		excellence in the form of personalized, simple, transparent, and easy to navigate
14		customer interactions, and contact resolution to drive the development of
15		sustainable improvements to customer satisfaction and address performance gaps.
16		
17	Q118.	What activities comprise the Distribution Operations team?
18	A118.	The activities performed by this team include issue resolution, enrollment
19		management, and metering services including storm restoration. The team is
20		comprised of a contact center and a team of billing analysts.
21		
22	Q119.	What are the activities of Public Affairs?
23	A119.	Public Affairs identifies communities and customers in need of DTE programs and
24		services and provides a community forum to connect low-income customers with

Line

25 resources and several types of energy assistance offered through the Company.

1 Customers who qualify can sign up for the LSP or receive emergency relief 2 assistance, sometimes on the spot, given agencies are on site with us at these 3 community forums. At these forums, we also educate customers on the programs 4 we offer, such as Home Energy Consultations and EWR assistance. In addition to 5 these formal programs, the organization supports health and human service 6 agencies such as United Way and Salvation Army that distribute assistance to 7 vulnerable Michigan residents.

8

9 Our support to established community partners helps them provide facilities, 10 volunteers, transportation, and other resources to achieve additional outreach to 11 customers living under challenging circumstances. Many of the Company's 12 employees advocate for customer assistance when they volunteer to support 13 Michigan-based non-profits through the Company's enterprise-wide volunteerism 14 program Care Force, which is run through Public Affairs.

15

Q120. What are the primary activities that comprise the \$5.6 million of Miscellaneous Customer Service and Informational Expenses?

18 A120. These activities include responsibilities of the Customer Service Transformations, 19 Digital Experience, and Data Analytics teams. The Digital Experience department 20 works closely with other departments across the organization to ensure that all 21 digital touchpoints are fully integrated with DTE's business systems, providing a 22 seamless end-to-end customer experience. Additionally, the department 23 collaborates with external partners and vendors to implement innovative 24 technologies and innovations to further enhance the digital experience for customers. In addition to what is mentioned above, activities include the 25

Line <u>No.</u>		M. J. HATSIOS U-21534
1		implementation and sustainment of the Robotic Process Automation (RPA) team
2		and automation in the Customer Service organization (Closed Loop activities).
3		
4	Q121.	What is the total amount of Customer Service O&M that DTE Electric seeks
5		to recover in rates for the projected test period?
6	A121.	DTE Electric seeks to recover \$118.6 million (Exhibit A-13, Schedule C5.7
7		Column (m), Line 21) in Customer Service O&M in the projected test period.
8		Exhibit A-13, Schedule C5.7 provides a detailed breakdown of the projected test
9		period O&M expenses that the Company is requesting in this case.
10		
11	Q122.	What costs are included in the \$118.6 million of O&M expense?
12	A122.	In addition to the 2022 costs described in my testimony regarding the historical test
13		period, the Company has included the following changes: 1) inflation adjustments
14		in 2023 for \$3.1 million, 2024 for \$2.9 million, and 2025 for \$3.0 million; 2) a
15		known and measurable adjustment of merchant fees of \$0.5 million supported by
16		Witness Bennett (Line 6, Column k); 3) a reduction in Customer Records and
17		Collection Expenses of \$6.4 million (Line 5, Column k); and 4) ACPP / Time of
18		Use Reg Asset Amortization of \$3.0 million (Line 8, Column k).
19		
20	Q123.	How did you calculate the \$9.1 million for inflation?
21	A123.	Projected inflation for 2023, 2024, and 2025 O&M expenses was derived by
22		applying the inflation factors supported by Company Witness Uzenski to the
23		adjusted 2022 historical test period amounts (Column (g)).
24		

1	Q124.	What represents the \$6.4 million decrease in Customer Records and Collection
2		Expenses in Column (k)?
3	A124.	The \$6.4 million decrease is the forecasted savings from expected lower call
4		volumes enabled by Digital investments.
5		
6	Q125.	Can you please explain the estimated \$3.0 million Customer Service regulatory
7		asset impacts of the Company's Time of Day (TOD) Full Implementation?
8	A125.	As explained by Company Witness Uzenski, the Company deferred certain costs
9		related to the implementation of its Advanced Customer Pricing Pilot and Time of
10		Day rate offering. The \$3.0 million of expense represents the recovery of the
11		deferred costs over five years. See Uzenski Exhibit A-13, Schedule C5.9.3 for the
12		detailed calculation.
13		
14	Q126.	What are the Customer Service regulatory asset impacts of the Company's
15		TOD Full Implementation?
16	A126.	The Customer Service operational impacts of the TOU Full Implementation include
17		resource requirements to handle an estimated incremental 430K additional calls in
18		the Contact Center, and an additional 250K of billing exceptions. The one-time $$5.2$
19		million incremental costs in Customer Service related to these initiatives are shown
20		on Exhibit A-13, Schedule C5.9.2, Line 11. The Customer Service IT related costs
21		of \$2.5 million are shown on Exhibit A-13, Schedule C5.9.2, Line 9.
22		
23	Q127.	Does this complete your direct testimony?

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

BRIAN L. HILL

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF BRIAN L. HILL

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Brian L. Hill (he, his, him), and my business address is One Energy
3		Plaza, Detroit, Michigan, 48226 and I am employed by DTE Electric Company
4		(DTE Electric or Company).
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	I graduated from Michigan State University Eli Broad College of Business. I
11		graduated with a Bachelor of Arts Degree in Materials & Logistics Management
12		with a focus on Operations Management. I received a Juris Doctorate (JD) Degree
13		from the University of Detroit Mercy School of Law. I have also completed several
14		Company sponsored courses and attended various seminars to further my
15		professional development, including Lean Six Sigma Certification.
16		
17	Q4.	Please summarize your professional experience.
18	A4.	I began my career in the automotive industry working for Johnson Controls; a
19		world-wide Tier 1 OEM supplier. I worked there from 1994-2008 where I held a
20		series of positions in materials, operations, and plant management. In my plant
21		manager role, I was responsible for all aspects of the business including safety,
22		operations, engineering, quality, materials, finance/accounting, continuous
23		improvement, and human resources. The plant employed approximately 400
24		people comprised of both salaried employees and UAW union members. My
25		employment with DTE began in October 2008 as the Logistics Manager in Energy BLH-1

Line No.

> Supply. Between January 2011 and November 2012, I was the Senior Supply Chain 1 2 Manager at the Fermi 2 Nuclear Power Station where I held responsibility for 3 warehousing, procurement, contracts, and work management. These activities 4 were essential to supporting safe, reliable, and efficient plant operations, including 5 refueling outages. Between December 2012 and March 2015, I was a Director in 6 Corporate Services where I held increasing leadership responsibility in the Center 7 of Excellence, Supplier Performance Management, and Facilities Operations. In 8 this role I was responsible for strategic planning, operational metric reporting, 9 safety strategy, resource planning, financial forecasting, and continuous 10 improvement. I was also responsible for the long-term and daily operations of 11 facilities management, including asset management. Between April 2015 and 12 October 2016, I was the Director of Tree Trimming in the Distribution Operations 13 organization of DTE Electric. In this role I was responsible for leading the strategic 14 development and implementation of the Enhanced Tree Trim Program. In addition, 15 I was responsible for Tree Trim Operations, comprised of DTE Energy employees and tree trim contractors (comprising over 500 employees in 2016). In this role, I 16 17 was responsible for safety, quality, productivity, customer satisfaction, storm and 18 trouble restoration efforts, and relationships with municipalities. In November 19 2016, I started my current role as the Director of Scheduling and Coordination in 20 the Distribution Operations organization of DTE Electric. During this time, I was 21 also responsible for the Project Management Office from November 2016 until 22 June 2022 where I managed a large portfolio of projects and programs for 23 Distribution Operations that included planning and construction. In October 2023, 24 I was assigned the Director position for Southwest Regional Customer Operations 25 and Scheduling & Coordination.

1	05	De very held any contifications on one very a member of any professional
1	Q5.	Do you hold any certifications of are you a member of any professional
2		organizations?
3	A5.	Yes. I am a Licensed Attorney in the State of Michigan and a Lean Six Sigma
4		Black Belt.
5		
6	Q6.	What are your current duties and responsibilities?
7	A6.	My responsibilities as Director Southwest Regional Customer Operations and
8		Scheduling & Coordination include six primary areas: 1) Southwest Regional
9		Customer Operations, 2) Overhead & Underground Scheduling, 3) Substations
10		Planning & Scheduling, 4) Work Management, 5) Billing, Unitization, and
11		Inspection, and 6) Safety, Human Performance, and Hazardous Energy Control.
12		These organizations are briefly described below:
13		
14		Southwest Regional Customer Operations: Lead over 800 full-time and contract
15		employees responsible for engineering, planning, maintaining, operating,
16		constructing, and improving the electrical system to ensure the delivery of safe,
17		reliable electric service. The Southwest region has three service centers located in
18		Newport, Belleville, and Ann Arbor that serve approximately 605,000 customers.
19		
20		Overhead & Underground Scheduling: This organization schedules all planned
21		work for both DTE and contractor field crews on overhead and underground sub
22		transmission and distribution assets.
23		

1		Substations Planning & Scheduling: This organization plans and schedules all work
2		for both DTE and contractor field crews on substations assets. The team also
3		includes field contractor oversight for substation construction and modifications.
4		
5		Work Management: This organization leads systematic approaches to track and
6		measure work as well as streamline both business processes and routine tasks. The
7		team governs the Maximo Business Process that coordinates team collaboration and
8		workflows across all levels of the organization.
9		
10		Billing, Unitization, and Inspection: This team is responsible for contractor
11		accounts payable & invoicing, unitization of capital investments, and conducting
12		field quality inspections to validate construction is built to standards and
13		specifications.
14		
15		Safety, Human Performance, and Hazardous Energy Control: This team includes
16		subject matter experts (SMEs) in the areas of electrical safety, human performance,
17		and hazardous energy control (red tag/lock out tag out). The SMEs are responsible
18		for procedures, training, and governance of these safety programs.
19		
20	Q7.	Have you previously sponsored testimony before the Michigan Public Service
21		Commission (MPSC or Commission)?
22	A7.	Yes. I sponsored testimony in Case No. U-21297. In addition, I supported witness
23		testimony related to the enhanced tree trimming program in prior rate cases.

1 **Purpose of Testimony**

2	Q8.	What is the	purpose of yo	our testimony?
3	A8.	My testimor	ny supports,	as reasonable and necessary, the historical capital
4		expenditures	and proposed	capital expenditures related to base capital programs
5		(emergent re	placements, o	customer connections, relocations, and others). My
6		testimony als	so provides a	n explanation of the Company's purchase and use of
7		Portable Gen	erators (inclu	ded in Exhibit A-12, Schedule B5.4, page 13, line 28
8		under Infrast	ructure Resilie	ence and Hardening Pillar) and an update on Miss Dig
9		(which is not	a capital prog	ram or expenditure) reporting changes made since Case
10		No. U-21297		
11				
12	Q9.	Are you spor	nsoring any e	xhibits in this proceeding?
13	A9.	Yes. I am sp	onsoring the f	following exhibits:
14		<u>Exhibit</u>	Schedule	Description
15		A-12	B5.4	Projected Capital Expenditures – Distribution Plant
16				(Pages 1-8 & 13-22)
17		A-23	M4	Distribution Plant Capital Project Detail –
18				Base Capital
19				
20	Q10.	Were these o	exhibits prepa	ared by you or under your direction?
21	A10.	Yes, they we	re.	
22				
23	Q11.	How is your	testimony or	ganized?
24	A11.	My testimon	y consists of th	ne following four parts:
25		Part I	Emergent R	eplacements

Line			B. L. HILL U-21534
<u>No.</u>			0 21334
1		Part II	Customer Connections, Relocations & Other
2		Part III	Portable Generators
3		Part IV	Miss Dig
4			
5	Parts	I & II: Base	Capital Programs
6	Q12.	Can you plea	ase summarize what is included in Distribution Operations Base
7		Capital Prog	rams?
8	A12.	Capital inves	tments in base capital programs are summarized on Exhibit A-12,
9		Schedule B5.	4, pages 1 and 2, including Emergent Replacements on lines 2 through
10		7 and Custon	ner Connections, Relocations & Other, on lines 8 through 16 (with
11		additional det	tails on page 3 for Emergent Replacements and pages 4 through 8 for
12		Connections,	Relocations & Other). Also included on Exhibit A-12, Schedule B5.4
13		for base capit	al programs are AFUDC on page 19 and plant activity starting on page
14		20. Base cap	ital programs are further supported on Exhibit A-23, Schedule M4.

1 Part I: Emergent Replacements

2 <u>Emergent Replacements – Storm</u>

3 Q13. Generally, what is included in Emergent Replacement – Storm?

4 This category includes investments required to restore the overhead and A13. 5 underground distribution systems, the sub-transmission system, and substations 6 from damage and outages occurring during weather events called "storms." A 7 storm is defined as greater than 760 customer outage events (an outage event is 8 when customers are left without power) impacting greater than 200 circuits. These 9 investments are necessary and prudent to restore customers' power by replacing 10 damaged equipment that caused customer outages and/or public hazards. 11 Examples of equipment that are typically replaced in a storm include poles, 12 crossarms, and conductors, which are most often damaged by weather and tree 13 impacts. When poles and power lines break, they can result in customer power 14 outages and wire downs that create potential public safety hazards.

15

Line

No.

Q14. What is the Emergent Replacement – Storm expenditure forecast for 2023 through 2025?

A14. At the time the 2023 storm expenditures were estimated for use in the instant case,
prior to the end of 2023¹, the Company forecasts the 2023 Emergent Replacement
Storm expenditures to be \$282 million (Exhibit A-12 Schedule B5.4, page 1, line
3, column (c)). This forecast is higher than the 5-year historic inflation adjusted
average of \$230 million for the time-period 2018 through 2022 (Exhibit A-12
Schedule B5.4, page 3, line 5, column (g)). The 2023 storm expenditures were
higher than the 5-year average because the company and our customers experienced

¹ Unless otherwise noted, in this testimony 2023 forecasts are based on eleven months of actuals (January through November) with December being an estimate.

1		significant storm events in 2023. 2023 included five catastrophic storms, including
2		the most damaging winter ice storm in Company history, and another summer
3		catastrophic storm event that included heavy damage from historic six tornadoes.
4		Storm expenditures for 2024 and 2025 are forecasted at \$244 million and \$251
5		million, Exhibit A-12 Schedule B5.4, page 2, line 3, columns (f) and (g),
6		respectively, based on a 5-year inflation adjusted historic average of the period
7		2018-2022.
8		
9	Q15.	Why is the Company forecasting 2024 and 2025 Storm expenditures using a 5-
10		year inflation adjusted historic average?
11	A15.	DTEE is using a 5-year inflation adjusted historic average to forecast 2024 and
12		2025 because this method is consistent with Commission Orders in the Company's
13		previous rate cases, specifically Case Nos. U-20162, U-20561, Case No. U-20836,
14		and Case No. U-21297. The Company agrees with the Commission that this
15		method smooths out the variable impact of storms from year-to-year.
16		
17	Q16.	How is the Company reflecting the impacts of the actions it is taking to offset
18		inflationary pressures in the emergent category?
19	A16.	The Company is offsetting inflationary expenditures in emergent investments based
20		on strategic capital investments and the Tree Trim (TT) Surge program. This offset
21		is shown in Exhibit A-12 Schedule B5.4, page 2, line 6 and is \$21 million for
22		Calendar Year (CY) 2024 and \$21 million for CY 2025. These avoided
23		expenditures are calculated using the Company's reliability model as discussed by
24		Company Witness Kryscynski.
25		

BLH-8

- 1 Q17. Are there any investments planned by DTEE Information Technology (IT) 2 that support the Company's storm processes? 3 A17. Yes, there are three DTEE IT investments that support the Company's storm 4 processes. These investments are the Storm Data Lakehouse, the Storm Simulation 5 Lab, and the Storm Cloud. All associated investments and benefits for these 6 projects can be found in Exhibit A-12 Schedule B5.7.4 and B5.7.7 which are 7 sponsored by Company Witness Sharma. 8 9 **Catastrophic Storms of 2023** 10 Can you describe the number and nature of the storms that impacted the **O18**. 11 **Company's service territory in 2023?** 12 A18. Between January and August of 2023, the Company experienced seven storm 13 events. Driving investment expenditures in the emergent category, five of these 14 seven storms events (71%) were Catastrophic (CAT) in nature and amongst the 15 most damaging in Company history. The frequency and intensity of these CAT 16 storms resulted in a frustrating year of outages for our customers, and a significant 17 amount of storm restoration work for the Company. 18 19 The seven storm events included two level 1 catastrophic CAT-1 storms and three 20 level 2 catastrophic CAT-2 storms. A CAT-1 storm is defined as 110,000 21 customers or more without power in a 24-hour period (5% of total customers 22 affected). A CAT-2 storm is defined as 220,000 customers or more without power 23 in a 24-hour period (10% of total customers affected). The largest of these storms
- occurred on February 22nd, 2023 and left more than 675,000 of the Company's
 customers without power. Due to the extensive damage caused by the February ice

Line <u>No.</u>

1		storm, combined with the intensity and the frequency between the four summer
2		CAT storms, all storm damage could not be fully repaired before the next extreme
3		weather event hit our service territory. This left the electrical system in an abnormal
4		condition with many temporary repairs that made it more susceptible to damage in
5		subsequent storms.
6		
7	Q19.	Can you provide more detail on the February 2023 Ice Storm?
8	A19.	On February 22 nd , 2023, an ice storm struck Michigan, causing widespread power
9		outages and hazardous conditions. The freezing rain and ice that hit Michigan
10		downed trees and limbs, power lines, and cut power to about 700,000 homes and
11		businesses, closed schools and offices, and delayed air travel. This was the most
12		damaging ice storm in the Company's history, leaving 675,000 DTE customers
13		without power, some for extended periods of time. The ice was almost $\frac{3}{4}$ " thick in
14		many areas and the weight of the ice severely damaged trees, wires, equipment, and
15		poles. The ice storm also produced heavy wind gusts. The ice and wind caused
16		more than 14,000 reported downed wires across our service territory. Downed trees
17		(roads/streets were closed) and hazardous road conditions presented restoration

18 challenges for our crews.



2

Line

Q20. Can you provide more details on the August 2023 storm that included a historic six tornadoes in the DTEE service territory?

On August 23rd, 2023, seven tornadoes touched down in Michigan during late-night 5 A20. 6 thunderstorms that rapidly swept across the lower half of the state. This storm set a 7 Michigan record for the most single-day number of tornadoes in August. Six of 8 these tornadoes touched down in southeast Michigan and in the Company's service 9 territory, resulting in over 390,000 customers without power, some for extended 10 periods of time. The tornadoes uprooted large trees causing extensive damage to 11 pole and wires in several areas across our service territory. This weather event included over 4,600 reported wire downs. 12

13



2

Sand Cr

Line

Figure 2 August 23, 2023 Storm Tornadoes



1 Figure 3 August 23, 2023 Storm Damage Howell



2

3 Emergent Replacement – Non-Storm

4 Q21. Generally, what is included in Emergent Replacement – Non-Storm?

5 A21. This category includes capital replacements required to return the overhead and 6 underground distribution systems, and subtransmission electrical system to restore 7 power and/or return to normal operating configuration during non-storm 8 conditions. Non-storm conditions are defined as fewer than 760 customer outage 9 events for the entire system. It includes overhead & underground distribution and 10 the subtransmission system during non-storm conditions, but does not include 11 planned strategic replacements. The "non-storm" description does not imply that 12 these events are not caused by storms, high winds, or other weather-related events. 13 It simply means that there were not enough customer outages for the "storm"

Line <u>No.</u>

1

1	threshold to be declared within a twenty-four-hour timeframe. Severe weather
2	damage degrades the electrical system and subsequently results in emergent failures
3	that would then be considered non-storm emergent. This category also includes
4	equipment that fails for other reasons, not related to weather. Not all equipment
5	failures lead to outages. However, failed and damaged equipment are considered
6	emergent and the need to replace this equipment is reasonable and prudent, because
7	it poses risk of power outages and hazards. Examples of this type of work include
8	the replacement of a failed system cable or a broken insulator that has caused a
9	floating line which could break and create an outage or wire down. In addition to
10	trees, some of the non-storm causes for equipment failure include age, overloading,
11	electrical or mechanical issues, vehicles striking poles, or animal interference.
12	Table 1 provides the four high-level non-storm categories, brief descriptions, and
13	examples.

14

Table 1. Emergent – Non-Storm Description

Category	Description	Example
Non-Storm Emergent	Emergency replacements of equipment during period outside of a declared storm, when customers experience issues with their power supply under both outage and non-outage conditions, but when number of outages is below the Storm threshold	 7/7/2022 Dearborn Heights Garbage truck hopper contacted a communications line and ripped down 5 spans of primary wire and also broke 4 poles and cross arms Crew cleared the hazards, restored most customers, replaced wires and poles, and then restored remaining customers
Non-Storm Reactive	Replacements of equipment that does not need immediate action and can be scheduled. This includes replacement of failed devices that can be perform during follow-up work that is required to finalize the replacements of assets after initial work is completed to restore customer power and address immediate safety concerns	 4/13/2022, Detroit Broken pole reported due to vehicle accident; crew temporarily fixed pole to remove hazard Pole was replaced on 5/14/2022; this follow-up work was classified as "Non-Storm Reactive"
Non-Storm Corrective	Replacements of equipment that are required to restore system to original configuration and involve coordination from the System Operations Center (SOC)	 1/23/2022, Southfield Failed underground cable caused an outage that a crew restored, but left system in abnormal condition Planned outage took place 1/27/2022 and 1/28/2022 to replace the damaged cable; this work was categorized as "Non-Storm Corrective"
Non-Storm Environmental	The disposal of environmentally hazardous materials from the Company's retirement units/assets that are replaced outside of a declared Storm	 3/13/2022, Detroit Car hit pad mounted transformer, damaging it and causing an oil leak Crew removed transformer and replaced it Environmental crew cleaned up oil

³

Q22. What is the Non-Storm forecast for 2023 through 2025?

A22. At the time the 2023 non-storm actual expenditures were estimated for use in the
instant case, prior to the end of 2023, the Company forecasted expenditures to be
\$207 million (Exhibit A-12 Schedule B5.4, page 1, line 4, column (c)). This
forecast is the same as the 5-year historic inflation adjusted average of \$207 million
for the time-period 2018 through 2022, Exhibit A-12 Schedule B5.4, page 3, line
10 12, column g. The drivers behind increase non-storm emergent expenditures were
discussed in detail in Case No. U-21297 T5 2745-2750. This included supply chain

BLH-16

Line No.

⁴

1		disruptions, inflation, increasing frequency and severity of weather, greater
2		emphasis on replacing aged and outdated equipment rather than repair, a shift to
3		higher specification materials and components (e.g., fiberglass crossarms rather
4		than wooden), an increase in significant events that require more field crew
5		resources to remediate, a storm preparation strategy to call in crews earlier in
6		anticipation of storm events, and an increase use of contract and out-of-state field
7		crews to be able to more quickly respond to storm events and eliminate follow-up
8		work backlogs immediately after storms. Non-storm emergent expenditures for
9		2024 and 2025 are forecasted at \$220 million and \$227 million (Exhibit A-12
10		Schedule B5.4, page 2, line 4, columns f and g) based on a 5-year inflation adjusted
11		historic average of the period 2018-2022.
12		
13	Q23.	Why is the Company forecasting 2024 and 2025 non-storm expenditures using
13 14	Q23.	Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average?
13 14 15	Q23. A23.	Why is the Company forecasting 2024 and 2025 non-storm expenditures usinga 5-year inflation adjusted historic average?The Company is using a 5-year inflation adjusted historic average to forecast 2024
 13 14 15 16 	Q23. A23.	Why is the Company forecasting 2024 and 2025 non-storm expenditures usinga 5-year inflation adjusted historic average?The Company is using a 5-year inflation adjusted historic average to forecast 2024and 2025 because this method is consistent with Commission orders in previous
 13 14 15 16 17 	Q23. A23.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297
 13 14 15 16 17 18 	Q23. A23.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this
 13 14 15 16 17 18 19 	Q23. A23.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations.
 13 14 15 16 17 18 19 20 	Q23. A23.	Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations.
 13 14 15 16 17 18 19 20 21 	Q23. A23. Q24.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations. Would it be reasonable or prudent to defer Emergent Replacement – Storm &
 13 14 15 16 17 18 19 20 21 22 	Q23. A23. Q24.	Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations. Would it be reasonable or prudent to defer Emergent Replacement – Storm & Non-Storm?
 13 14 15 16 17 18 19 20 21 22 23 	Q23. A23. Q24. A24.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations. Would it be reasonable or prudent to defer Emergent Replacement – Storm & Non-Storm? No. This work is reasonable and prudent because it addresses system hazards,
 13 14 15 16 17 18 19 20 21 22 23 24 	Q23. A23. Q24. A24.	 Why is the Company forecasting 2024 and 2025 non-storm expenditures using a 5-year inflation adjusted historic average? The Company is using a 5-year inflation adjusted historic average to forecast 2024 and 2025 because this method is consistent with Commission orders in previous Case Nos. U-20162, U-20561, U-20836, and most recently, Case No. U-21297 dated December 1, 2023. The Company agrees with the Commission that this method is appropriate to account for year-to-year weather variations. Would it be reasonable or prudent to defer Emergent Replacement – Storm & Non-Storm? No. This work is reasonable and prudent because it addresses system hazards, including customers without power or having partial power. Deferring this work

additional equipment damage resulting in further customer outages, and leaves
 critical equipment in abnormal conditions. A learning from prior storms was that
 faster response to address abnormal circuits and equipment as much as reasonably
 possible before the next weather pattern impacts our service territory mitigates risk
 for larger customer outages.

7 Emergent Replacement - Substation Reactive

8 Q25. Generally, what does Emergent Replacement – Substation Reactive include?

9 A25. This category includes investments required to perform emergency replacements
10 for substation equipment. The Company makes these investments to replace
11 broken equipment that either led to customer outages, created risk of customer
12 outages, or impacted the operability of the electrical system. Table 2 provides the
13 high-level substation reactive categories, a brief description, and an example.



Table 2.Emergent – Substation Reactive Description

Category	Description	Example
Substation Reactive- Major Equipment	Replacement of the Company's substation equipment classified as major equipment	 August 2022, Twelve Mile Substation Fire led to catastrophic failure and complete loss of substation Company deployed portable equipment including a substation and multiple generators
Substation Reactive – Minor Equipment	Replacement of the Company's substation equipment classified as minor equipment	 April 2022 UNVIL Substation 40kV insulator broke free Replaced three 40kV insulators
Substation Reactive – Transformers and Regulators	Replacement of substation transformers and regulators	 October 2022, Middlebelt Transformer 2 40-year old transformer failed internally causing outages Load switched to another transformer for two days until change of transformer complete
Substation Reactive – Non- Electrical Equipment	Replacement of substation retirement units/assets not directly related to generation or transmission of electricity	 Control house HVAC heating to remove condensation which can erode equipment Fence/gate repairs which are mandated by NERC
Q26. What is the Substation Reactive investment forecast for 2023 through 2025?

2 A26. At the time the 2023 expenditures used for the instant case were estimated, prior to 3 the end of 2023, the Company forecasted expenditures to be \$42 million (Exhibit A-12 Schedule B5.4, page 2, line 5, column (e)). This forecast is lower than the 5-4 5 year historic inflation adjusted average of \$46 million for the time-period 2018 6 through 2022 (Exhibit A-12 Schedule B5.4, page 3, line 19, column (g)). Substation 7 Reactive expenditures for 2024 and 2025 are forecasted at \$49 million and \$51 8 million (Exhibit A-12 Schedule B5.4, page 2, line 5, columns (f) and (g)), 9 respectively, based on a 5-year inflation adjusted historic average of the period 10 2018-2022.

11

12 Q27. Why are non-electrical substation equipment failures classified under 13 substation reactive expenditures?

14 A27. They are classified this way because the assets and equipment are critical for safety, 15 reliability, and security of the distribution grid. For example, substation fencing 16 prevents the public from entering energized high voltage areas, protects critical 17 equipment, and is part of the grid security plan. When fencing and other physical 18 security type devices fail in an emergent manner, they need to be replaced quickly 19 to ensure public safety and protect the security of the grid. Other equipment like 20 HVAC systems control temperature and condensation in the substation. If this 21 equipment fails, it must be immediately replaced to ensure that the substation operates as designed. Another example of non-electrical substation equipment is 22 23 substation building infrastructure that houses equipment that fails and must be 24 replaced (roof, doors, sidewalks). These activities are truly reactive in nature and

require the Company to take immediate, prudent action to protect the safety, reliability, and security of the electrical system.

3

2

4 Q28. Would it be reasonable or prudent to defer Emergent Replacement – 5 Substation Reactive?

6 A28. No. This work is to replace critical electrical grid equipment that has failed. 7 Substation equipment tends to be less impacted by storms and other weather events, 8 however, when substation equipment fails, in many cases it leaves thousands of 9 customers without power for what can be extended periods of time. The failed 10 equipment significantly reduces distribution capacity and redundancy that is 11 necessary to serve customers in the event of additional system failures and 12 increased seasonal loads. Both these conditions increase risk of additional 13 customer outages. Substation capacity and redundancy is critical and required 14 because these types of failures generally result in repairs that are very lengthy in 15 time (weeks or months) which could result in extended customer outages.

16

Q29. Can you provide additional details regarding Emergent Capital categories for all storm, non-storm, and substation reactive expenditures?

A29. Yes. Categories of storm, non-storm, and substation reactive, along with
descriptions and examples, are provided in Tables 1-3. Expenditures in Storm and
Non-Storm Emergent are incurred in support of the field activities under eight work
type categories: Emergency Job, Critical Infrastructure, Customer, Hazards,
Multiple Customer Outage, Police/Fire, Public Safety Concern, Single Customer
Outage, and Single Customer Problem. Table 3 provides examples for each
category.

1 14	bit 5. Storm and Hon-Storm Work Category
Category	Description
Emergency Job	Non-outage events of the highest priority. These events are restricted to situations where the health and safety of a person are at imminent risk such as a person contacting the Company's electrical equipment, being trapped in a vehicle, building, or elevator due to power failure, downed wires, broken poles, etc.
Critical Infrastructure Customer	Outages affecting hospitals, schools, water and wastewater systems, or other critical infrastructure
Hazards	Non-outage events reported by customers to alert the Company of a potentially hazardous situation due to a sparking wire, broken pole, pole-top fire, and/or a tree or branch resting on a wire
Multiple Customer Outages	Outage events affecting more than one customer on a circuit. Events are created by the Outage Management System (OMS) prediction engine, which uses customer calls, AMI meter data, and the Company's network model to determine the size and extent of an outage. These outages can be caused by weather, trees, animals. public interference (e.g. vehicle accidents), and equipment failures and can involve concerted restoration efforts from overhead, underground, and substation personnel to restore power
Police/Fire	Non-outage events reported by a police or fire department. These events are created when police or fire personnel use their unique PIN number through one of the Company's reporting channels to report an event such as downed power line on a structure or a fire
Public Safety Concern	Non-outage events reported by customers where a primary or secondary wire is believed to have fallen and may pose a safety risk
Single Customer Outage	Outage events that affect a single customer through the same inputs as a multiple customer outage
Single Customer Problem	Non-outage events affecting a single customer that are not outages but can include power quality issues, such as low voltage or flickering lights, or downed service drops where a customer still has power

Table 3.Storm and Non-Storm Work Category

2

3	Q30.	Has the Company begun to track and report Substation Reactive imminent
4		failure work in accordance with the Order in Case No. U-20836 on November
5		18, 2022?
6	A30.	Yes. The Company modified its accounting system to begin to track these
7		expenditures and retrained its workforce to be able to separate expenditures related
8		to imminent failures.
9		

BLH-21

1 The Company first began collecting Substation Reactive expenditures associated 2 with imminent failures in January 2023. Imminent Failure Substation Reactive 3 categories are shown in Table 4.

Line

No.

Table 4.Substation Reactive – Imminent Failure Detail²

Substation Reactive	2023 (\$ thousands)
Imminent Failure – Major Equipment	\$15.9
Imminent Failure – Minor Equipment	\$587.7
Imminent Failure – Minor System/Circuits	\$605.1
Imminent Failure – Transformers/Regulators	\$10.0
Failures – Major Equipment	\$11,075.9
Failures – Minor Equipment	\$13,321.9
Failures – Minor System/Circuits	\$17.5
Failures – Transformers/Regulators	\$11,158.6
Failures – Non-Electrical	\$4,385.6
Total Substation Reactive	\$41,178.3

5

6 Part II Customer Connections, Relocations & Other Capital Investments

Q31. Can you please describe the Company's Customer Connections, Relocations & Other Capital Investments?

9 A31. The customer connections, relocations, and other investments category is broken

- 11 Relocations; (3) Electric System Equipment; (4) Normal Retirement Unit Change-
- 12 out (NRUC) and Improvement Blankets; (5) General Plant, Tools & Equipment

⁴

¹⁰ down into six major subcategories: (1) Customer Connections and New Load; (2)

² Values in this table are 2023 calendar year actuals (January through December).

		B. L. HILL
Line <u>No.</u>		U-21534
1		and Miscellaneous; and (6) Public Lighting Department Project. These six
2		subcategories are discussed in more detail below.
3		
4	Q32.	Why is the Company forecasting 2024 and 2025 Customer Connections,
5		Relocations & Other Capital Investments using a 3-year inflation adjusted
6		historic average?
7	A32.	DTEE is using a 3-year inflation adjusted historic average to forecast 2024 and
8		2025 for this category of expenditures because it believes this method is consistent
9		with the Commission Order in the Company's previous rate case, Case No. U-
10		21297.
11		
12		There are two exceptions in this category of expenditures that do not use a 3-year
13		inflation adjusted average because they are discrete projects for I-375 relocations
14		and Incremental Infrastructure for EV.
15		
16	Q33.	What capital expenditures fall into the Customer Connections and New Load
17		subcategory?
18	A33.	Connections and New Load expenditures include: (1) Small Load Growth Projects
19		(2) Customer Connections, (3) New Business Projects, and (4) Incremental
20		Infrastructure for EV.
21		
22		Small Load Growth Projects and Customer Connections both include projects
23		required to serve new load, perform upgrades necessary to address small loading
24		issues, and connect customers to the electrical system. Activities in these projects
25		may include reconductoring lines, expanding a substation, or transferring load to

1 provide local capacity. The Company may also install additional overhead and/or 2 underground lines to provide service to small commercial businesses or housing 3 developments. Small Load Growth & Customer Connections projects typically 4 require less than \$500,000 of expenditures to complete, are less complex in nature, 5 and are therefore developed and executed locally by regional distribution service 6 centers. Small Load Growth & Customer Connections projects are often requested 7 by customers and can include a customer contribution in aid of construction (CIAC) 8 component wherein the customer pays an allocated cost of the new service 9 depending on the load requested and service requirements.

10

Like Small Load Growth & Customer Connections projects, New Business projects are also required to serve new load, connect customers to the electrical system, or address local loading issues, however, they are larger scale projects. These larger customer-driven projects typically require more than \$500,000 of expenditures and require a more extensively engineered design to connect customers to the electrical system. New Business projects are typically requested by customers and can also carry a CIAC component.

18

Incremental Infrastructure for EV (electric vehicles) is incremental capital for
 construction of EV charging infrastructure and is a subset of the Company's
 Transportation Electrification Plan (TEP) discussed further in Question 41 of my
 testimony.

23

1	Q34.	What capital expenditures fall into the Relocation subcategory?
2	A34.	Relocation projects are requests from customers, cities, municipalities, or other
3		governmental entities, for example, the Michigan Department of Transportation
4		(MDOT). These are requests to relocate existing Company equipment and
5		facilities. These requests are typically related to construction related to the
6		modification of roadways, bridges, water mains, public sanitation, alleys, or other
7		customer activities.
8		
9		The Company equipment being relocated could include overhead lines and poles,
10		underground lines and transformers, and substations equipment. With the increases
11		in federal funding levels for investments in replacing and building infrastructure, it
12		is expected that these types of projects will become more frequent.
13		
14		These investments enable economic growth, meet customer needs, are required by
15		regulation, or in some cases are constructed at the request or mandate of
16		governmental entities. Like Customer Connections and New Business, some
17		projects in this category can carry a CIAC component.
18		
19	Q35.	What is the I-375 Relocations project under Major Infrastructure Relocation
20		Project in this instant case?
21	A35.	MDOT has notified DTEE that the Company will need to relocate distribution
22		infrastructure currently located in the I-375 below-grade freeway corridor, which
23		will be replaced with a grade-level boulevard. MDOT construction is expected to
24		begin in 2025, with DTEE work starting in 2023. This project captures the
25		Company's initial support for the MDOT's I-375 Reconnecting Communities

Line No

B. L. HILL Line U-21534 No. 1 Project. The Company's support for this project is estimated to require an 2 expenditure of \$39 million (Exhibit A-12, Schedule B5.4, page 5 line 37) spanning 3 from 2023-2025, with the majority of the required work being performed in 2024. 4 5 **O36**. What capital expenditures fall into the Electric System Equipment 6 subcategory? 7 The Company maintains an inventory of critical spare equipment to support A36. 8 emergent replacements and planned projects. This allows equipment repairs and 9 replacements to proceed expeditiously, without waiting for parts delivery from 10 vendors. Equipment purchased under this subcategory includes substation 11 transformers, distribution transformers, regulators, and meters. This equipment 12 often has long lead times, which in many cases have been increasing due to global 13 supply chain and raw material issues. To ensure we can provide electrical service when critical equipment fails or to connect new customers, the Company plans and 14 15 maintains necessary inventory levels of critical electrical system equipment. 16 17 Q37. What capital expenditures fall into the NRUC and Improvement Blankets 18 subcategory? 19 The expenditures that fall into this subcategory include: (1) System Improvements, A37. 20 (2) Normal Retirement Unit Change-Out (NRUC), and (3) Operational 21 Technologies. 22 1. System Improvement projects are focused on reducing the frequency and 23 duration of customer outages. Unlike larger scale, longer time frame 24 projects like conversions or subtransmission projects, they are smaller scope 25 projects managed by regional operations to immediately address localized

	B. L. HILL
	U-21534
	customer issues and complaints. These projects do not exceed \$350,000
	and do not require extended planning and design.
	2. Normal Retirement Unit Change-Out (NRUC) consists of projects to
	perform scheduled work that replace assets determined by equipment
	engineers to be at end-of-life.
	3. Operational Technologies consists of the infrastructure and associated
	applications that support the AMI platform and data. This also covers
	annual work in testing new meter types, designing and installing
	configurations, replacing communications equipment, and testing changes
	for new equipment.
Q38.	Has the Company analyzed the customer connections, relocations & other
	program and re-assigned program investment areas that do not fully align
	with the purpose of this category?
A38.	Yes. The Company removed Animal Mitigation and Batteries and Charges from
	Customer Connections, Relocations & Other to strategic capital. The Company will
	continue to review its project categorization and adjust in the future to help ensure
	alignment of investment categories.
Q39.	What capital expenditures fall into the General Plant, Tools & Equipment,
	and Miscellaneous subcategory?
A39.	General Plant, Tools & Equipment, and Miscellaneous includes new tools as well
	as beyond useful life replacement tools required for field workers to perform their
	tasks. It also includes engineering test equipment and substation physical security.
	Q38. A38. Q39. A39.

BLH-27

<u>NO.</u>		
1		These expenditures ensure that Company workers have the necessary tools and
2		equipment to conduct and construct field work. Examples of items include meters,
3		phase sets, and infrared cameras. It also includes DC hi-potential testers (Hipoters)
4		that are used to test insulation on cable, breakers, transformers, etc.
5		
6	Q40.	What was the Public Lighting Department Project?
7	A40.	The Public Lighting Department (PLD) project converted former PLD customers
8		to the Company's distribution system. This project included extending the
9		Company's overhead and underground system by performing activities like
10		transformer replacements and line extensions. This project was completed with
11		\$1.9 million of investment in 2023 (Exhibit A-12, Schedule B5.4, page 1, line 14,
12		column (c)) with the removal of three breakers from Waterman substation and final
13		connection of the Detroit Institute of Art (DIA).
14		
15	Q41.	What is the Incremental Infrastructure for Electric Vehicle (EV) capital
16		investment in Exhibit A-12 Schedule B5.4 on page 4, line 29 within Customer
17		Connections?
18	A41.	In Case No. U-20836, the MPSC requested DTE Electric to "prepare and submit in
19		its next rate case, a full scale, well-developed, permanent Charging Forward
20		proposal that includes a BCA [benefit cost analysis]."
21		
22		In response, Company Witness Bennett and her team has developed a
23		comprehensive Transportation Electrification Plan, with the goal to power and
24		enable a cleaner energy future for its customers through transportation
25		electrification.

BLH-28

1		Incremental Infrastructure for EV consists of capital investments of \$4.7 million in
2		2024 and \$11.4 million in 2025 needed to build out EV charging infrastructure,
3		which is a subset of the DTEE 2023 Transportation Electrification Plan. This capital
4		investment is supported by Company Witness Bennett's testimony in Section 2 The
5		Company's Proposal for a Transportation Electrification Plan and called out in
6		Answer 71.
7		
8	Q42.	What work is the Company performing to comply with the Commission's
9		Order No. U-21297 regarding line extensions?
10	A42.	The Company has reviewed Section 6 of the Rate Book with respect to customer
11		Contribution in Aid of Construction (CIAC) costs and updated them in Table 5
12		below. These costs represent current cost per foot or cost per kVA developed using
13		compatible unit estimates for associated labor and material costs. Refundable costs
11		contura the full cost of construction and non-refundable costs represent cost
14		capture the full cost of construction and non-refundable costs represent cost

Line <u>No.</u>

1

Table 5.	Line	Extension	Cost	Updates
1 4010 01		Lincension	0050	opantos

Section of Rate	D	Flowert to be undefed	Current	Updated
Book Page		Element to be updated	Rate	Rate
C6.2(1b)	C-28	Refundable construction advance of \$6.50 per foot	\$6.5	\$16.91
C6.3(A)(14)	C-33	\$1.00 per trench foot added for winter construction	\$1.0	\$1.0
C6.3(B)(2)	C-34	multiplying the sum of the lot front footage for all lots in the subdivision by \$3.00	\$3.00	\$18.30
C6.3(B)(6)(a)	C-35	\$3.00 per lot front foot for the total front footage	\$3.00	\$18.30
C6.3(C)(2)(a)	C-36	lot front footage for all lots in the park by \$3.00	\$3.00	\$18.30
C6.3(C)(2)(c)	C-36	Transformers - \$7.50 per kVA, for the total nameplate kVA installed.	\$7.50	\$18.47
C6.3(D)(2)(a)	C-37	total length of trench feet required for distribution facilities by \$4.30 plus \$7.50 per kVA (nameplate) of transformer capacity to be installed.	\$4.30 per trench ft + \$7.5 per kVA	\$17.84 per trench ft + \$18.47 per kVA
C6.3(E)(2)(a)	C-38	total length in feet multiplied by \$4.30	\$4.30	\$17.84
C6.3(E)(2)(b)	C-38	Transformers will be charged on an installed basis of \$7.50 per kVA	\$7.50	\$18.47
C6.4(A)	C-38	\$300 for trench lengths up to 200 feet	\$300	\$730
C6.4(A)	C-38	\$3.90 per foot for each additional foot added	\$3.90	\$9.48
C6.4(B)	C-39	\$3.90 per foot for each additional foot added	\$3.90	\$9.48
C6.4(C)	C-39	trench length in feet multiplied by \$4.30	\$4.30	\$17.84
C6.4(C)(2)(b) C-39.01		multiplying the horizontal length of the service lateral in feet by \$10.00.	No Change	
C6.4(C)(3)(c)(a)	C-39.02	\$4.30 per trench foot	\$4.30	\$17.84
C6.4(C)(3)(c)(c)	C-39.02	\$15 per kVA for all dry type transformers.	No Change	

Line <u>No.</u>

C6.4(D)(1)(c)	C-40	multiplying the horizontal length of the service lateral in feet by \$10.00	No Change
C6.5(A)(1)(a)	C-42	0.48 per kVA of installed transformer capacity for the first 10kVA	No Change
C6.5(A)(1)(b)	C-42	0.12 per kVA of installed transformer capacity for excess of 10kVA	No Change
C6.6(H)	C-45	Recalculate if more than \$1 for customer, or more than \$2 for someone no longer customer.	No Change

1

2 Part III Portable Generators

Q43. What are the Portable Generators in Exhibit A-12, Schedule B5.4, page 13, line 28 under the Infrastructure Resilience and Hardening pillar?

- A43. The \$4.5 million for Portable Generators in 2024 is to purchase generators that the
 Company will deploy to customers to provide temporary electricity during storms.
 The company will prioritize generators to customers based on the estimated
 duration of storm outage, customer medical needs, and other factors.
- 9

10 Deployment of generators will not be done by lineworkers and therefore will not 11 impact restoration time for our customers. Most of the generators allow customers 12 to use devices that draw less than 2,000 watts. This typically includes items like 13 refrigerators, freezers, personal medical devices, and sump pumps.

14

BLH-31

1 Part IV Miss Dig

Q44. What did the Commission order regarding the tracking of infrastructure strikes related to Miss Dig in Case No. U-21297?

- 4 A44. The MPSC Staff recommended, and the Commission Ordered the following 5 concerning Miss Dig in the Order No. U-21297, page 376, dated December 1, 2023: 6 "Pertaining to the Miss Dig program, DTE Electric Company shall commence 7 tracking and keeping records of expenditures incurred from damages caused by the 8 company to its own facilities; work with the Commission Staff to share damage 9 reporting data including the billing amounts for damages when a third-party causes 10 damages and expenditures for damages, and for sharing billing amounts when the 11 company causes damages; include a breakdown of damage prevention expenditures 12 in future general rate cases under Federal Energy Regulatory Commission account 13 580 including, but not limited to, internal locating and contract locating in future 14 general rate cases; and improve the company's damage reporting quality by 15 continuing to meet with the Commission Staff regarding damage report data and 16 committing the time and resources to submitting data into the format that aligns 17 with the Commission's processes."
- 18

Q45. How is the Company responding to these Miss Dig expenditures tracking and reporting requirements that were Ordered in Case No. U-21297?

- A45. The Company is actively working on plans to comply with the recommendations
 and reporting requirements. The Company met with MPSC Staff during Case No.
- 23 U-21297 and continues to meet with Staff on a bi-monthly basis.
- 24

Line No.

Line <u>No.</u>		U-21534
1	Q46.	What progress has the Company made since the Case No. U-21297 Order?
2	A46.	The Company updated the formatting and data in the Miss Dig damage report. This
3		report includes information on damage claims by responsible party, the amount of
4		damage/expenditures, and causes of the damage. This information is shared
5		monthly and reviewed during meetings with MPSC Staff and enables open dialogue
6		on damage prevention. The report includes first party damages caused by the
7		Company to its own facilities. The Company will continue monthly meetings with
8		MPSC Staff to further make additional improvements and comply with the order.

9

10 Q47. Does this complete your direct testimony?

11 A47. Yes, it does.

12

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

ALLEN J. KRYSCYNSKI

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF ALLEN J. KRYSCYNSKI

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Allen J. Kryscynski (he/him), and my business address is One Energy
3		Plaza, Detroit, Michigan, 48226 and I am employed by DTE Electric Company
4		(DTE Electric or Company).
5		
6	Q2.	On whose behalf are you testifying?
7	A2.	I am testifying on behalf of DTE Electric.
8		
9	Q3.	What is your educational background?
10	A3.	I earned a Bachelor of Science from the University of Michigan School of Natural
11		Resources and Environment with a dual concentration in environmental policy and
12		natural resource management. I also received a master's degree in Business
13		Administration (MBA) from the University of Michigan.
14		
15	Q4.	Please summarize your professional experience.
16	A4.	I held several positions with ITC Holdings including Senior Regulatory Analyst
17		and a variety of positions within the Local Community and Community Affairs
18		team culminating as a Senior Local Government and Community Affairs
19		Representative. At ITC Holdings, I worked on FERC and MISO regulatory issues
20		and represented ITC Holdings at community meetings to gain approval for new
21		transmission substations and transmission lines.
22		
23		I joined DTE Energy in 2014 as a Strategy and Corporate Development Associate
24		in the Corporate Strategy group. In this role, I did work on the initial Distribution
25		Operations (DO) investment strategy project to determine distribution grid

1 investment needs as well as work on DTE workforce projections and requirements 2 for both the Distribution Operations and Fossil Generation business units. In 2016, 3 I was appointed Manager of Distribution Operations Strategy and assumed 4 responsibility for continued work to evolve the distribution operations investment 5 strategy, operations strategy, and the chief of staff role for the Senior Vice President 6 of Distribution Operations. In early 2018, I was appointed Manager in Project 7 Management with responsibility to start up and operationalize the 4.8kV Hardening 8 Program to remove City of Detroit Arc Wire and harden the City of Detroit 9 electrical infrastructure. Later in 2018, I was appointed Manager of Tree Trim 10 Strategy where I was responsible for managing the initial Tree Trim Surge rate case, 11 Tree Trim contractor negotiations, and the overall Tree Trim strategy for 12 scheduling work, and ensuring there was an adequate supply of tree trimmers 13 necessary to complete the work. In 2020 I took over the Tree Trim Operations 14 Manager position and managed day to day Tree Trim operations including overseeing all of DTE's internal arborists and foresters as well as eight tree trim 15 contractors and their 1,600+ employees. In 2022 I was appointed as Manager of 16 17 Distribution Operations Regulatory Strategy and Grid Modernization and promoted 18 to Acting Director in 2023.

19

20 Q5. What are your current duties and responsibilities?

A5. As Director of Distribution Operations Regulatory Strategy and Grid
 Modernization, my current responsibilities are two primary focus areas: 1)
 managing Distribution Operations regulatory activities – including rate cases, the
 distribution grid plan filing, required reporting, and various Company/MPSC

4 Q6. Have you previously sponsored testimony before the Michigan Public Service 5 **Commission (MPSC or Commission)?**

6 A6. Yes. I sponsored testimony in Case No. U-21297. In addition, I supported Tree 7 Trim testimony and witnesses in U-20162, U-20561, and U-20836.

1 **Purpose of Testimony**

2 Q7. What is the purpose of your testimony?

3 A7. The purpose of my testimony is to support, as reasonable and necessary, the 4 historical Operations and Maintenance (O&M) expenses related to electric 5 distribution activities for 2022 historical period and for the projected test period 12-6 months ending December 31, 2025. Additionally, my testimony describes the (1) 7 Distribution Operations Overview which includes an introduction to the other 8 witnesses from Distribution Operations in this case and System Performance, 9 Overview, (2) Distribution Rate Request, (3) Distribution O&M, (4) Distribution 10 Grid Plan (DGP) Overview, (5) Strategic Capital Overview, (6) Overview of the 11 capital exhibits - Exhibit A-12 Schedule B5.4, and Exhibit A-23 Schedules M4, 12 M5, M6, and M7, (7) Variances between the 2022 actuals and the forecast in Case 13 No. U-21297 in Exhibit A-12 Schedule M1; projected capital expenditures 14 forecasted in Case No. U-21297 for calendar years 2023 and 2024 and the project 15 capital expenditures in this case for calendar years 2023 in Exhibit A-12 Schedule 16 M2 and 2024 in Exhibit A-12 Schedule M3, (8) Distribution Operations' Global 17 Prioritization Model (GPM) and Exhibit A-23 Schedule M14, (9) the Company's 18 Capital/Reliability Projection Model (10) Infrastructure Investment and Jobs Act 19 (IIJA) funding grants, (11) Updates on the Distribution Operation's approach to 20 Environmental Justice (EJ), and (12) Coordination Processes in place with local 21 municipalities.

22

I will discuss the capital exhibits and overview while the reasonableness and prudence of each specific capital investments will be supported by other DO witnesses.

Line No.				A. J. KRYSCYNSKI U-21534				
1								
2	Q8.	How is you	r testimony or	ganized?				
3	A8.	My testimo	ny consists of t	welve parts:				
4		Part I	Distribution	Operations Overview and System Performance				
5		Part II	Distribution	O&M and Capital Rate Request				
6		Part III	Distribution	O&M Overview and Exhibits				
7		Part IV	Distribution	Grid Plan (DGP) Overview				
8		Part V	Strategic Ca	pital Overview				
9		Part VI	Capital Exh	ibits Description				
10		Part VII	Capital Inve	estment Variance Discussion				
11		Part VIII	Global Prior	ritization Model				
12		Part IX	Capital/Reli	ability Model				
13		Part X	IIJA Grant (Opportunities				
14		Part XI	Environmer	Environmental Justice				
15		Part XII	Municipal P	Project Coordination				
16								
17	Q9.	Are you sp	onsoring any e	xhibits in this proceeding?				
18	A9.	Yes. I am sj	ponsoring the fo	ollowing exhibits:				
19		<u>Exhibit</u>	<u>Schedule</u>	Description				
20		A-13	C5.6	Projected Operation and Maintenance Expenses –				
21				Distribution Expenses				
22		A-23	M1	U-21297 2022 Forecast vs. U-21534 Comparison				
23		A-23	M2	U-21297 2023 Forecast vs. U-21534 Comparison				
24		A-23	M3	U-21297 2024 Forecast vs. U-21534 Comparison				
25		A-23	M8	2023 Distribution Grid Plan, MPSC Case No.				

				A. J. KRYSCYNSKI
Line <u>No.</u>				U-21534
1				20147
2		A-23	M14	GPM Project and Program Rankings
3				
4	Q10.	Were t	hese exhibits pro	epared by you or under your direction?
5	A10.	Yes, the	ey were.	
6				
7	<u>Part I</u>	: Distri	bution Operatio	ns Overview and System Performance
8	<u>Distri</u> l	oution O	perations Organiz	zation
9	Q11.	Can y	ou please desci	ribe the organization that manages the investments
10		include	ed in the exhibits	s you are sponsoring?
11	A11.	Distrib	ution Operations	(DO) is the organization that manages the investments
12		include	ed in the exhibits	I am sponsoring. The organization focuses on the design,
13		mainter	nance, and opera	tion of the Company's electrical distribution system and
14		subtran	smission system	, which together are often referred to as "the distribution
15		system.	." DO is compris	sed of nine suborganizations, described below.
16				
17		(i)	Central Engine	eering: This organization is responsible for determining,
18			maintaining, a	and improving the health of the Company's electric
19			distribution as	ssets, which includes defining technical standards for
20			distribution ed	quipment, long-term system planning including grid
21			modernization,	and developing major projects needed for customer
22			connections, re	elocations, increasing loads, infrastructure improvements,
23			reliability upgr	ades, and technology enhancements.
24				

Line	
No.	

1	(ii)	Regulatory Strategy and Grid Modernization: This organization is
2		responsible for two primary areas of focus: 1) Distribution Operations'
3		long term grid modernization strategy and the distribution grid plan (DGP)
4		and, 2) Distribution Operations regulatory activities – including rate cases,
5		the distribution grid plan filing, MPSC required reporting, and conducting
6		and organizing the numerous collaborations ordered by the MPSC.
7		
8	(iii)	Scheduling & Construction: This organization is responsible for: 1)
9		scheduling all planned work for both DTE and contractors' field crews on
10		overhead and underground distribution, subtransmission, and substation
11		assets; 2) leading systematic approaches to track and measure work,
12		streamlining business processes and routine tasks, and governing the
13		Maximo Business Process that coordinates team collaboration and
14		workflows across all levels of the organization; 3) planning, and field
15		oversight of out-of-state storm resources when required for large storm
16		events; 4) contractor accounts payable and invoicing, unitization of capital
17		investments, and conducting field quality inspections to validate
18		construction is built to standards and specifications; 5) governance of the
19		DO Safety, Human Performance, and Hazardous Energy Control
20		programs.
21		
22	(iv)	Operational Technology: This organization is responsible for Advanced
23		Metering Infrastructure (AMI) system enhancements and operations,
24		meter engineering and metrology, equipment calibration, grid mapping
25		including analytics, and working with business units within Distribution

Line	
No	

1		Operations to define, implement, and support technology and analytical
2		solutions including our Storm Excellence investments in support of our
3		storm restoration efforts. The organization also manages the Advanced
4		Distribution Management System (ADMS), which provides the
5		technological capabilities to monitor and operate the grid, respond to
6		emergency conditions and outages, and facilitates the deployment of
7		distributed energy resources.
8		
9	(v)	Regional Customer Operations: This organization is responsible for
10		overhead and underground emergent work, short-cycle (typically less than
11		a year) construction, new service and meter installations, and design and
12		planning focused on short-cycle reliability, and customer-requested work.
13		
14	(vi)	System Operation: This organization includes the Company's Electric
15		System Operations Center (ESOC), where DTE Electric monitors and
16		controls the electrical system to maintain a reliable and secure flow of
17		electric power.
18		
19	(vii)	Emergency Preparedness & Response "EPR": This organization plans
20		efforts to reduce the time customers spend without power and develops,
21		maintains, manages DO's incident response procedures and storm events
22		and enhances storm process for customers through improved
23		communication. EPR has expanded the organization with a pointed focus
24		on improving storm restoration processes and enhancing the Company's
25		ability to efficiently restore customers in "extreme weather" scenarios,

Line	
<u>No.</u>	

1			such as recent storms our customer base has been experiencing. EPR is
2			comprised of six groups (strategy, public safety, damage assessment,
3			Regional ICS, Productivity, and Event management). The team has set
4			individual targets within each group and has initiated projects focused on
5			addressing the gaps identified from previous storms. All of this work is
6			aligned to a broad strategic plan focused on improving day to day
7			emergent operations and storm processes.
8			
9		(viii)	Tree Trimming: This organization plans, communicates, and implements
10			the Company's tree trimming program.
11			
12		(ix)	Substation Operations: This organization is responsible for the operation
13			and maintenance of all the substations within the DTE Energy service
14			territory.
15			
16	Q12.	Have tl	nere been any significant changes to the DO organization since the filing
17		of U-21	297?
18	A12.	Yes. To	better support the increasing construction for grid investments, a Project
19		Manage	ement Office (PMO) was created by merging the DO project organization
20		with D	TE's Major Enterprise Projects (MEP) group to consolidate project
21		manage	ment expertise in one group. This new organization is responsible for
22		manage	ement and execution of the majority of Strategic Capital projects and
23		program	ns for Distribution Operations, as well as large investment projects for other
24		areas of	f DTE. The organization consists of the project managers, cost engineers,
25		schedul	ers, project estimators, and the leadership/support teams required to manage

1		an	d track the progress of DO's capital investments. The PMO has focus on driving					
2		co	st efficiency, managing project scope and schedule, and is specifically targeting					
3		ch	challenges in labor cost and availability, supply chain constraints and material					
4		av	availability, as well as obtaining needed land, permits, and easements. Some					
5		sn	naller programs and projects are still managed within the DO organization.					
6								
7	Q13.	Η	ow is the Distribution Operations testimony organized in this case?					
8	A13.	D	istribution Operation (DO) capital and O&M expenditures, as well as other					
9		ac	tivities, are supported by six (6) witnesses in this case. Together these witnesses					
10		di	scuss the reasonableness and prudence of DO capital and O&M expenditures,					
11		ex	hibit content, tree trim, Environmental Justice (EJ), and other topics related to					
12		D	O. A high level summary of these six witnesses' scope of testimony is introduced					
13		be	low:					
14		1)	Witness Allen J. Kryscynski is the Distribution Operations Regulatory Strategy					
15			and Grid Modernization. The purpose of my testimony is described above.					
16		2)	Witness Brian Hill is the Director Southwest Regional Customer Operations and					
17			Scheduling & Coordination. The purpose of witness Hill's testimony is to					
18			support as reasonable and prudent the investments in base capital programs,					
19			Emergent Replacements and Customer Connections, Relocations & Other.					
20		3)	Witness Morgan Elliott Andahazy is the Director of PMO Programs. The					
21			purpose of witness Elliott Andahazy's testimony is to support, as reasonable and					
22			prudent, investments in the strategic capital pillar Infrastructure Resilience and					
23			Hardening.					

2

3

 Witness Satvir Deol is the Director of Engineering. The purpose of witness Deol's testimony is to support, as reasonable and prudent, investments in the strategic capital pillar Infrastructure Redesign and Modernization.

5) Witness Shannen Hartwick is the Director of Automation for DO. The purpose of witness Hartwick's testimony is to support, as reasonable and prudent, investments in the Technology and Automation pillar including Grid Automation, Grid Automation Telecommunication, AMI and ADMS projects, and the Electric System Operations Center (ESOC) and Alternate System Operations Center (ASOC) projects, and other operational technology investments.

11 6) Witness Rachel Steudle is the Director of Tree Trim. The purpose of witness 12 Steudle's testimony is to (1) discuss the importance of and progress made in 13 DTE Electric's vegetation management ("Tree Trimming") program, (2) 14 provide details related to the Company's Tree Trimming Surge Program that will deliver on the reliability goals established in the Company's Distribution 15 16 Grid Plan (DGP), (3) describe the customer benefits of the Company's Tree 17 Trimming Surge Program to date, (4) support the Operations and Maintenance 18 (O&M) expenses related to tree trimming efforts for the historical test period 19 ending December 31, 2022, and the projected base O&M expenses and the Tree 20 Trimming Regulatory Asset Surge funding amount for January 1, 2025, to December 31, 2025, (5) request approval of incremental Surge funding for 2025, 21 22 (6) discuss the future of the Tree Trimming program once the Surge is 23 completed, (7) address the additional requests from U-21297.

1 <u>Electrical System Overview</u>

Q14. Can you briefly describe the electrical system that the Company owns and operates?

A14. The Company owns and operates approximately 31,000 miles of overhead
subtransmission and distribution lines, and 16,830 miles of underground
subtransmission and distribution lines. The Company's service territory
encompasses approximately 7,600 square miles and includes approximately 2.3
million residential, commercial, and industrial customers. Additional key statistics
are listed in Tables 1 – 4.

10

11

Table 1 D7

DTE Electric Substations by Type and Voltage

	Total	Number of Substations by Circuit/Low Side kV								
Substation Type	Number of Substations	4.8	8.3	13.2	4.8& 13.2	24	40	24& 40	Other	
General Purpose	542	244	4	243	30	4	13	3	1	
Single Customer	145	49	0	86	1	0	0	0	9	
Customer Owned	102	NA	NA	NA	NA	NA	NA	NA	NA	
Total	789	293	4	329	31	4	13	3	10	

12

13

Table 2 DT

DTE Electric Transformers by Voltage Level

Voltage Level	Number of Transformers	kVA Capacity
Substation - Subtransmission	178	13,085,000
Substation - Distribution	1,449	24,093,221
Distribution - Overhead and Pad- mount	451,919	33,078,863
Total	453,546	70,257,084

14

Line <u>No.</u>

Bus Voltage	Number of Circuits	Overhead Miles		Underground			Total	Total	
		13.2 kV	8.3 kV	4.8 kV	13.2 kV	8.3 kV	4.8 kV	Miles	Customers
13.2 kV	1,269	11,796	16	5,596	10,710	1	417	28,535	1,030,999
8.3 kV	13	0	45	0	1	18	0	63	8,202
4.8 kV	1,991	31	0	11,064	274	0	1,937	13,307	1,213,025
Total	3,273	11,828	60	16,660	10,985	18	2,354	41,905	2,252,226

Table 3

2

3

Table 4

Subtransmission Circuits and Line Miles by Substation Bus

Distribution Circuits and Line Miles

Voltage	Number of Circuits	Overhead Miles	Underground Miles	Total Miles
120 kV	68	59	8	67
40 kV	326	2,353	466	2,819
24 kV	242	177	732	909
Total	636	2,589	1,206	3,795

4

Voltage

5

6 Q15. What is the difference between the Company's distribution and 7 subtransmission voltages?

A15. Voltage and purpose distinguish the difference between the Company's
subtransmission system and distribution system. The Company operates
subtransmission voltages of 24kV, 40kV, and 120kV and this infrastructure is
designed to feed substations that convert the voltage to distribution levels, although
some larger industrial customers are fed directly from subtransmission. The
Company currently operates distribution voltages of 4.8kV, 8.3kV, and 13.2kV and
this infrastructure is designed to feed the circuits that provide power to customers.





fap Created: 11-1-2021

12 Q17. What is the age of the Company's distribution system assets?

A17. Table 5 provides the average age and age range of the Company's key distribution
assets along with the life expectancy and demonstrates that the Company's assets
are relatively aged. For some asset classes, poles for example, the average age and

4 6.5.202

the industry life expectancy of the asset are close to the same which can be an
indicator of challenges to current and future equipment health. While not the only
factor impacting reliability, age can become a significant factor when replacement
parts become unavailable or in the specific cases where asset health deteriorates
sharply with age. Eight of the 18 asset classes have an average age at or near the
life expectancy.

Table 5

Asset Age Summary

Asset (Section)	DTE Electric Age Range (Years)	DTE Electric Average Age (Years)	Life Expectancy (Years)	% of Asset Class at or Beyond End of Life
Substation Power Transformers	0-99	43	40-45	49%
Network Bank Transformers	0 – 85+	46	20 - 30	91%
Circuit Breakers	0 – 90	41	30 – 40	60%
Circuit Switchers	0-36	19	NA	NA
Relays	0-60+	33	15-50	NA
Switchgear	0 – 70	40	40	55%
Poles	0-90+	48	40-50	50%
Three-phase Reclosers	0-34	10	20	10%
SCADA (Supervisory Control and Data Acquisition) Pole Top Switches	0-31	15	20	38.5%
40 kV Automatic Pole Top Switches	0-50+	21	40	35%
Overhead Capacitors	Oldest: 25+	NA	20	NA
Overhead Regulators	Oldest: 25+	NA	20	NA
System Cable	0 – 100+	49	20 – 40	64%
Underground Residential Distribution (URD) Cable	0 - 60+	26	40	23.6%
Manholes	1-100+	78	Varies based on construction and field conditions	NA
Advanced Metering Infrastructure (AMI meters)	0-13	6.5	20	0%

1	Q18.	As shown in Table 5, how has the Company determined industry end of life
2		expectancy?
3	A18.	The Company's internal subject matter experts draw from a broad set of sources to
4		determine equipment life expectancy, including ongoing review of technical
5		papers, attending industry working groups, meeting with manufacturers, and
6		gaining specific experience with the performance of the assets on the Company's
7		electrical system.
8		
9	Q19.	Is age the only factor to consider when selecting assets for replacement?
10	A19.	No. Age is just one of the factors considered when determining asset health and
11		the need for equipment replacement. There are instances where younger equipment
12		is at higher risk of failure, for example due to specific known equipment issues, and
13		is selected for replacement ahead of more aged equipment. Additionally, there are
14		many instances where the Company assesses older equipment and finds that it still
15		can safely and reliably remain in service and serve customers. However, age is a
16		factor used throughout industry as one measure of asset health.
17		
18	<u>Syster</u>	n Performance
19	Q20.	How does the Company and industry measure system reliability?
20	A20.	The Company uses industry standard reliability metrics that are defined by the
21		Institute of Electrical and Electronics Engineers (IEEE) standard 1366 ¹ . DTE
22		Electric measures overall system reliability using the indices System Average
23		Interruption Duration Index (SAIDI), System Average Interruption Frequency
24		Index (SAIFI), and Customer Average Interruption Duration Index (CAIDI). These

¹ <u>Microsoft PowerPoint - Without video IEEE 1366- Reliability Indices 2-2019.pptx available at https://site.ieee.org/boston-pes/files/2019/03/IEEE-1366-Reliability-Indices-2-2019.pdf</u>

No. indices are typically calculated in two ways: 1) All-Weather conditions, and 2) 1 2 excluding Major Event Days (MEDs). An MED is any 24-hour period in which 3 there is a significant statistical difference in daily SAIDI. Excluding MEDs from 4 the indices offers a more accurate comparison between time periods and to other 5 utilities because it gives the Company a clear picture of day-to-day system 6 performance and customer experience absent significant weather events – which 7 are highly variable in size, impact, and system location from year-to-year and. The 8 Company's primary metric for measuring system reliability is the System Average 9 Interruption Duration Index (SAIDI). SAIDI is defined by IEEE as the total time 10 (in minutes) of all customer interruptions divided by the total number of customers 11

11 served. SAIDI measures the average time that customers are without power in a 12 year because it is calculated using both the frequency and the duration of 13 interruptions. SAIFI is calculated by dividing the number of customer interruptions 14 by the number of customers served. SAIFI measures the average number of 15 sustained interruptions experiences by the system's average customer. CAIDI is 16 calculated by dividing the sum of customer interruption duration by the total 17 number of customer interruptions. CAIDI measures the average time required to 18 restore power to the average customer who experiences an outage.

19

Line

Q21. What are the recent reliability metric trends for the Company's electrical system?

A21. Figure 2 through Figure 5 show the distribution system performance from 2017 to
 2023 for SAIDI-All Weather, SAIDI-Excluding MEDs, SAIFI-All Weather, and
 SAIFI-Excluding MEDs. As shown in Figure 2 and Figure 3, the Company
 performed in the 4th quartile in All-Weather SAIDI and 3rd quartile for SAIDI-



1 Excluding MEDs for 2023. The Company has been, except for 2020, in the fourth 2 quartile for SAIDI-All Weather for the seven years shown on Figure 2 below. As shown in Figure 4 and Figure 5, the Company performed in the 3rd quartile in All-3 4 Weather SAIFI and 2nd quartile for SAIFI-Excluding MEDs for 2023. SAIFI-All 5 Weather has been in the second quartile four of the last seven years. Benchmarking 6 quartiles are not yet available for 2023 so all quartiles refenced for 2023 are 7 compared to the 2022 benchmarking numbers. CAIDI can be calculated by dividing 8 SAIDI by SAIFI. Benchmarking is performed by the Institute of Electrical and 9 Electronics Engineers (IEEE) and made available to its members annually. 10

Figure 2



12





All Weather SAIDI Performance* (Minutes)

*Quartile information for 2023 is not yet available

14







*Quartile information for 2023 is not yet available

6

Line


*Quartile information for 2023 is not yet available

3

4 Q22. What large weather events impacted the Company's reliability performance 5 in 2023?

6	A22.	This past year, 2023, brought additional large storm events including back-to-back
7		storms in February, first ice and then snow, that left over 675,000 customers
8		without power for extended periods of time. These two storms alone contributed
9		730 minutes of All-Weather SAIDI to the annual metric, more than all SAIDI
10		minutes recorded in 2022. However, if the volatility of the extreme weather is
11		removed, SAIFI and SAIDI Excluding MEDs remain in the second quartile
12		indicating that the Company's non-storm performance is stable. See Witness Hill's
13		testimony for additional discussion on 2023 storm impacts.

14

Q23. How have previous strategic investments impacted reliability performance? 15

1	A23.	Positively. To name a few examples, the Company has seen improved reliability
2		results in areas that have had their Surge Tree Trim program, 4.8kV Hardening, and
3		Frequent Outage Programs. These programs and reliability improvements are
4		discussed in Witness Steudle and Witness Elliott Andahazy's testimony.
5		
6	Q24.	What are the primary challenges the Company faces with respect to reliability
7		improvements?
8	A24.	There are three primary challenges:
9		• First, the Company has seen an increase in the number of high wind speed
10		days which adds additional stress to the already aged fleet of equipment and
11		provides more opportunity for failures (Figure 6).
12		• Second, the system continues to get older. The average pole age has
13		increased from 40.7 years in 2012 to 47.9 in 2024 – See Figure 7. Notably,
14		the slope of the line becomes less steep starting in 2022, indicating the
15		average pole age increased at a slower rate as the Company increased
16		investment in 4.8kV Hardening, PTMM, and 4.8kV Conversion. Continued
17		investments in these programs is needed in order to continue to decrease the
18		rate at which the Company's assets are aging. The pole equipment age curve
19		was selected as a representative sample of the Company's overhead
20		equipment health. DTE will continue to invest in the rebuilding the
21		overhead system to flatten and bend down the age curve.
22		• Third, the Company is early on its journey to stabilize and rebuild the grid.
23		While the Company has made progress to date, increased, sustained
24		investment will be needed to improve and then maintain reliability. The
25		Company's 2023 DGP provides a path forward to both improve near-term



Figure 6 Michigan² Wind Gusts 2000-2021



5

Line

3

4

² Data from <u>https://mesonet.agron.iastate.edu/request/daily.phtml</u>. SE region represented by Detroit Metro, SW region represented by Ann Arbor, NW region represented by Pontiac.



- 3
- 4

Q25. What changes were made to the Company's investment strategy based on the 2023 weather events and system age and deterioration?

A25. The Company has increased its investment plans in both PTMM, 4.8kV Hardening
and Automation in order to target near and mid-term improvements in fundamental
grid resiliency and restoration. Long-term work such as conversions will continue
to support rebuilding the grid to increase system resilience and support needed
capacity. The Company is also working to improve storm restoration processes,

Line <u>No.</u>

³ Projected pole age assumes 2025-2028 strategic investment levels for PTMM, 4.8kV Hardening and 4.8kV Conversion are the same as the 2024 investments planned in the case. Poles replaced on base capital, including emergent replacements, are assumed to be constant.

<u>No.</u>		
1		including ADMS Enhancements, to be able to respond to storm events more
2		quickly.
3	<u>Part l</u>	I: Distribution O&M and Capital Rate Request
4	Q26.	What O&M and capital is the Company asking the Commission to include in
5		rates related to Distribution Operations?
6	A26.	The Company is including \$359.2 million of operation and maintenance (O&M)
7		expenses in the projected test period as shown in Exhibit A-13, Schedule C5.6, Page
8		1, Line 27.
9		
10		The Company is requesting \$3.14 billion of capital investments for the 24-month
11		bridge period ending December 31, 2024 and \$1.63 billion of capital investments
12		for the 12-month projected test year ending December 31, 2025, as shown in
13		Exhibit A-12, Schedule B5.4, Page 1, Line 23, supported and sponsored by
14		witnesses Hill, Elliott Andahazy, Hartwick, Deol, and Steudle in base rates.
15		
16	Q27.	Why are the levels of capital and O&M proposed by the Company necessary?
17	A27.	The levels of capital investment and O&M expense are necessary to achieve the
18		Company's goals of providing safe, reliable, and clean electricity to our customers
19		at reasonable rates. These investments also lay the foundation for grid
20		modernization, needed to support our customers' evolving needs for greater
21		resiliency in the face of increasingly frequent and intense storms, electrification
22		including electric vehicles (EVs), and the integration of distributed energy
23		resources (DERs).

24

Line

1	<u>Part I</u>	II: Distribution O&M Overview and Exhibits
2	Q28.	What does Exhibit A-13, Schedule C5.6, "Projected Operation and
3		Maintenance Expenses – Distribution Expenses" show?
4	A28.	This schedule reflects the operations and maintenance costs for DO, which are
5		primarily driven by systems operations costs (including operating the System
6		Operations Center which monitors and controls the subtransmission and
7		distribution grids), addressing day-to-day trouble and storm restoration, tree
8		trimming, equipment preventative maintenance and other system maintenance
9		requirements. The expenses shown in this exhibit represent both DO and street
10		lighting. Company Witness Bellini provides testimony addressing the streetlighting
11		costs, and Company Witness Steudle supports DO's tree trimming expenses. I am
12		supporting all other DO expenses.
13		
14	Q29.	Can you provide a brief explanation of the items listed under Distribution
15		Expenses in Exhibit A-13, Schedule C5.6?
16	A29.	The costs associated with dispatching, coordinating restoration, and tree trim efforts
17		are included in FERC accounts 580 (Operation Supervision and Engineering) and
18		581 (Load Dispatching). Accounts 582 (Station Expenses), 583 (Overhead Line
19		Expenses), 584 (Underground Line Expenses), and 588 (Miscellaneous Expenses)
20		incorporate the costs for developing and implementing training and work force
21		planning for the Company's substation operators and maintenance personnel,
22		apprentice lineman, splicers, technicians, engineers, riggers, and planners as well
23		as the staff groups to support these critical efforts. Job skills training is conducted
24		for the safety of employees and the public. Witness Bellini supports account 585
25		(Street Lighting and Signal System Expense). Meter testing and distribution costs

1 are incorporated into account 586 (Meter Expenses). Account 587 (Customer 2 Installations Expenses) includes expenses to support the specific needs of 3 customers served at primary voltages. Account 589 (Rents) reflects the expenses 4 associated with leased facilities and the Company attaching to poles not owned by 5 the Company. 6 7 Q30. What do the line items listed under Maintenance in Exhibit A-13, Schedule 8 C5.6 describe? 9 A30. Maintenance costs are critical to providing safe and reliable service. Account 591 10 (Maintenance of Structures) is to support the maintenance of existing physical 11 structures associated with the electric distribution system. Restoration, 12 troubleshooting and reactive maintenance work associated with substation, 13 overhead and underground equipment is included in accounts 592 (Maintenance of 14 Station Equipment), 593 (Maintenance of Overhead Lines), and 594 (Maintenance 15 of Underground Lines) respectively. In addition, account 593 includes the tree trim 16 expenses supported by Company Witness Steudle. The supervision and other 17 support costs for these important efforts are included in account 590 (Maintenance 18 Supervision and Engineering). Company Witness Bellini supports account 596 19 (Maintenance of Street Lighting and Signal Systems). 20 21 Q31. How are the 2022 historical O&M and the projected test period O&M 22 expenses for DO shown on Exhibit A-13, Schedule C5.6?

A31. Exhibit A-13, Schedule C5.6, page 1, summarizes the 12-month period ended
 December 31, 2022 actual O&M expense and the projected O&M expense for
 December 31, 2023 through December 31, 2025. Line 27, column (c) provides the

AJK-27

Lina		A. J. KRYSCYNSKI
<u>No.</u>		0-21337
1		total actual unadjusted O&M expenses for the 12-month historical test period ended
2		December 2022.
3		
4	Q32.	What are the adjustments in columns (d) and (e) of Exhibit A-13, Schedule
5		C5.6, page 1?
6	A32.	The adjustments in column (d) reduce the total historical test year O&M expenses
7		by the amounts related to the Transitional Reconciliation Mechanism (TRM) costs,
8		which are included in accounts 566 and 588. In column (e) the adjustment on line
9		20 is to normalize restoration expenses, see below. The total results of columns (d)
10		and (e) are added with column (c) to produce column (f).
11		
12	Q33.	What are the adjustments in columns (g) through (i) of Exhibit A-13, Schedule
13		C5.6, page 1?
14	A33.	The adjustments in columns (g) through (i) show the inflation adjustment to convert
15		the historical test period O&M expenditures to the projected test period dollars. The
16		inflation rates for all DO exhibits are supported by Company witness Uzenski.
17		
18	Q34.	What are the adjustments in column (j) of Exhibit A-13, Schedule C5.6, page
19		1?
20	A34.	These adjustments are one-time known and measurable adjustments to the
21		Distribution Expenses. The adjustment to Line No. 3, Operation Supervision and
22		Engineering, shows a \$1.6M increase related to the Damage Prevention Program.
23		The adjustment to Line No. 11, Miscellaneous Expenses, shows the cost for the
24		Peaker Study, \$0.3 million, that the Company agreed to complete in the IRP
25		settlement. The adjustment to Line No. 19, Maintenance of Overhead Lines – Tree

1		Trim, shows the \$3.4 million increase in Tree Trim base O&M to remain in line
2		with the funding levels outlined in the Tree Trim Surge plan. The adjustment in line
3		No. 20, Maintenance of Overhead Lines - Other, shows a reduction due to Tree
4		Trim Surge reduction of \$8.8 million offset by inspection expenditures of the Pole
5		and Pole Top Maintenance and Modernization (Pole/PTMM) program and the
6		4.8kV Hardening Program, an increase of \$5.0 million, a net decrease of \$3.8
7		million. The Pole/PTMM program are discussed by Company witness Elliott
8		Andahazy. The adjustment to Line No. 12 is an adjustment to the ADMS regulatory
9		asset supported by Company witness Uzenski.
10		
11	Q35.	How did the Company calculate restoration O&M expense for the projected
12		period?
13	A35.	As shown on Exhibit A-13, Schedule C5.6, page 2, line 22, column (h), the
14		Company shows projected restoration expenses, including inflation, of \$128.2
15		million. A five-year average method was used to normalize restoration expenses
16		and is consistent with the methodology used in the Company's previous rate cases
17		and the Commission guidance in Case No. U-21297. This method addresses the
18		variability in these expenses.
19		
20		The details of this calculation are shown on Exhibit A-13, Schedule C5.6, page 2,
21		"Restoration Expenses". Line 2 shows the actual expenses from 2018 to 2022
22		associated with restoration related to storm conditions. Line 10 presents the actual
23		expenses associated with non-storm restoration. Lines 3 and 11 include inflation

25 4 and 12 for storm and non-storm costs respectively. The expenses for the 2018 to

1		2022 period are averaged in column (g) and inflation is applied to those amounts to
2		determine the values in column (j). Column (h) shows the expenses included in the
3		historical test period adjusted for inflation. Column (j) shows the difference
4		between columns (h) and (i). Lines 17 to 22 summarize the calculations and shows
5		on line 22 the \$128.2 million five-year average (column (h)), the \$131.1 million
6		(column (i)) included in the historical test period and the difference of (\$2.9)
7		million (column (j)), which is the adjustment needed in the projected test period for
8		restoration costs in this case. The pre-inflation adjustment of (\$2.6) million
9		included in column (j), line 18 is carried to page 1 of Exhibit A-13, Schedule C5.6
10		in column (e), line 20.
11		
12	Q36.	How was the projected O&M expense amount in column (l) of Exhibit A-13,
13		Schedule C5.6, page 1, derived?
14	A36.	The 12-month historical test year period ended December 31, 2022 adjusted
15		expenses from column (f) were adjusted by inflation and other expected changes in
16		column (k) to derive projected O&M costs in column (l).
17		
18	<u>Part I</u>	V: Distribution Grid Plan (DGP) Overview
19	Q37.	What is the role of the Distribution Grid Plan (DGP) in supporting the grid
20		investments included in this case?
21	A37.	Consistent with Commission guidance on the need for shorter-term investments
22		and longer-term grid planning, the Company filed the updated DGP on September
23		29, 2023, in Case No. U-20147. The 2023 DGP built on the previous DGP filed in
24		September of 2021, also Case No. U-20147 and included an update to DTE
25		Electric's distribution investment strategy considering factors including the

Line	
No.	

14		development of investment plans in previous rate cases?
13	Q38.	Has the Company used previous versions of the DGP to support the
12		
11		the distribution system.
10		the Company's long-term plans and larger strategy for improving the strength of
9		between the DGP and the investments proposed for rate base treatment illustrate
8		the investments that are the basis of this case. Furthermore, the direct alignment
7		Generation (DG)/Distributed Storage (DS). The DGP supports the development of
6		advances in technology to support both reliability and incorporation of Distributed
5		year vision for the grid that includes capacity needed for electrification, and
4		years. In addition, the updated DGP maintains its focus on the Company's 10 to 15-
3		for customers a safer, more reliable, and more storm resilient grid over the next 5
2		DGP includes an increased focus on investments that will be able to quickly deliver
1		continued frequency and intensity of storms, and the aging grid assets. The 2023

15 In two of the Company's recent rate cases (MPSC Case Nos. U-20836, and U-A38. 16 21297), the Company referenced the 2021 DGP filed in September of 2021. In this 17 case the 2023 DGP, along with submitted testimony, supports the Company's distribution investments. The 2023 DGP is included as Exhibit A-23 Schedule M8. 18 19 The Company's investments as reflected in this case, and in previous cases, are 20 based on long-term distribution planning processes that identify customer and grid 21 needs and develop and prioritize projects that provide both benefits to customers in 22 terms of improved safety and reliability in the near term (primarily achieved 23 through Pole Top Maintenance and Modernization, Automation, and 4.8kV 24 Hardening), and provide the foundation for long-term changes, including increased 25 electrification and Distributed Energy Resource (DER) adoption. The investments



No.

in this case are consistent with the long-term vision laid out in the DGP filed in September 2023.

3

4

7

8

9

1

2

What was the Company's approach to developing the 2023 DGP? **O39**.

5 A39. To create the 2023 DGP, DTE Electric followed the five-step methodology used in 6 the development of the 2021 DGP:



- **Define DTE Objectives**: Reviewed objectives from the Company's previous • 2021 DGP and aligned them to the long-term distribution grid vision
- 10 Assess Future Drivers of Change: The future drivers of change that are • 11 expected to have a significant impact on the distribution grid over the next five 12 to fifteen years were reviewed, including previously identified scenario 13 signposts.
- 14 Assess Current State: Assessed the current grid and its capabilities to 15 determine how well it can support current and future customer demands.
- 16 Determine Gaps to Future State: Identified future state objectives based on • 17 future drivers of change, current state assessments and distribution grid gaps.
- 18 Develop Investment Plan: Based on those gaps, a five-year investment plan • 19 was developed, organized within the four pillars of investment. Individual 20 program and project prioritization within the investment plan is done through 21 the Company's Global Prioritization Model (GPM) process – discussed below.
- 22

10.		
1		Additionally, customer and stakeholder feedback were integrated into the Plan,
2		including a shift to consider environmental justice (EJ) in DTE Electric's
3		investment decisions so that projects benefiting our most vulnerable customers are
4		considered in the investment prioritization process.
5	Q40.	How did the Company gather feedback for the most recent DGP?
6	A40.	Feedback was received in several ways including:
7		• The March 2023 and August 2023 4.8kV Hardening and DGP Tech
8		Conferences which offered numerous stakeholders an opportunity to
9		provide feedback via roundtable discussions, questions, and written
10		comments.
11		• Through the regulatory process associated with Case U-21297, the company
12		received comments and feedback through MPSC Staff and stakeholder
13		testimony.
14		• The Commission issued Order and stakeholder comments received in Case
15		No. U-20147 containing feedback on the 2021 DGP.
16		• Regular engagement with the Company's customers via community
17		meetings, the DTE customer call center, MPSC complaint response, and
18		other miscellaneous forums.
19		
20	Q41.	Please describe how scenario planning informs DGP investments.
21	A41.	Grid modernization plausible scenario planning involves developing scenarios that
22		are directionally correct and plausible. In the context of grid planning, plausible is
23		preferable to using the most likely scenario, in order to analyze impacts that will
24		stress or cause impacts to the grid, and therefore should be reasonably planned for.

25 Plausible scenarios provide input to grid impact of potential future challenges, as

Line	
No.	

1		opposed to probabilistic or forecasted scenarios. These scenarios focus on a discrete
2		set of drivers and allow for a better understanding of the resulting grid impacts, as
3		well as the potential for overlapping impacts on needed capabilities and the
4		resulting determination of investments. The Company built on the work initially
5		done in the 2021 DGP, to update three scenarios to use for identifying (1) changes
6		coming to the grid in the future, (2) the grid impacts of those potential changes, and
7		(3) the investments needed to mitigate grid impacts. The three plausible future
8		scenarios selected were the Electrification scenario, the Increasing CAT storm
9		scenario, and the DG/DS Scenario (distributed generation [DG] solar photovoltaic
10		[PV] and distributed storage [DS]).
11		
12	Q42.	Can you please summarize the key highlights of the DGP?
13	A42.	Using the learnings from scenario planning, combined with an assessment of the
14		current state of the grid, the Company identified gaps between the existing grid and
15		the future state required to meet the DGP objectives.
16		
17		Based on this analysis, the 2023 DGP, in line with the 2021 DGP, remains focused
18		on closing these gaps through four investment pillars supporting grid improvement:
19		
20		1) <u>Tree Trimming</u> remains focused on completing the Surge plan and returning
21		our electric grid to a routine, maintenance cycle.
22		
23		2) Infrastructure Resilience and Hardening projects and programs focus on
24		making the grid more resilient in the face of increasingly severe storms,
25		replacing aging infrastructure at risk of failure, hardening the system, and

1		addressing areas of the system with known poor customer reliability. These
2		projects and programs specifically target equipment with known risks, (e.g.,
3		failed inspections or multiple prior failures), or in areas with known poor
4		customer reliability and potential safety issues, (e.g., high SAIDI or arc wire on
5		the system). Projects in this pillar are designed to provide improved customer
6		reliability and replace at risk equipment quickly. Key areas of focus in this pillar
7		are an expansion in the PTMM program to stabilize the aging overhead
8		equipment as well as finishing the 4.8kV Hardening program which will
9		conclude in 2026 once arc wire is removed. Infrastructure Resilience and
10		Hardening investments are supported by witness Elliott Andahazy.
11		
12	3)	Infrastructure Redesign and Modernization projects and programs make
13		fundamental improvements to the electrical system, including the conversion of
14		the 4.8kV system and upgrades of the fundamental subtransmission system.
15		Overall redesign and modernization of the system also brings reliability and
16		resilience improvements through the replacement of aging infrastructure.
17		Investments in this pillar provide benefits such as load relief (including
18		increased capacity for electrification) and increased system operability. This
19		pillar focuses on 4.8kV Conversion to rebuild the oldest sections of the grid in
20		orders to accommodate future load growth and boost reliability. The 4.8kV
21		Conversion projects will convert the 4.8kV system to a higher voltage and be
22		built to the latest, most resilient standards, provide higher capacity for
23		electrification, enable DER penetration, and improve safety by eliminating the
24		ungrounded delta configuration and removing arc wire from the city of Detroit.
25		More detail on the 4.8kV conversion is provided is provided in Exhibit A-23

Schedule M8 DGP. This pillar also includes subtransmission improvements to
 add capacity and improve performance of this fundamental part of the grid.
 Infrastructure Redesign and Modernization investments are supported by
 witness Deol.

5 4) Technology and Automation projects and programs are focused on ramping up 6 the Company's automation capability and operational Technology (OT) 7 investments that will enable the Company to monitor, control, and optimize the 8 operation of grid. Investments in this pillar focus on the physical infrastructure 9 needed to support a modern distribution grid including reclosers, capacitors and 10 voltage regulation, and grid telecommunications as well as the software and 11 technology needed for operations and improved customer communication. 12 Advanced technology and automation on the grid not only improve customer reliability but is also a key factor in enabling customer accessibility to the grid. 13 14 Additional investments include the electric system operation center (ESOC) 15 and advanced distribution monitoring system (ADMS), and develop more 16 advanced analytic capabilities. This pillar is an integral part of grid 17 modernization and will allow the Company to develop needed capabilities in 18 grid observability, analytics and computing, gird controls, and communications. 19 Investments in Technology and Automation are supported by witnesses 20 Hartwick and Steudle.

21

22 Q43. When will the Company file a new DGP?

A43. The Company expects to file another Distribution Grid Plan in 2025 on the normal
24 2-year schedule.

Line	
No.	

1 Part V: Strategic Capital Overview

2 Q44. How does the Company categorize capital investments?

3 Capital investments are broken out into two primary categories: Base Capital and A44. 4 Strategic Capital. Base Capital programs include work the Company is required to 5 perform as part of normal business activities. There are two sub-categories of Base Capital: (1) Emergent Replacements and (2) Customer Connections, Relocations & 6 7 Other. Emergent Replacements include expenditures to recover from interruptions 8 in electric service (e.g., emergent replacements during storms, equipment failures 9 at substations), address immediate safety concerns, or return the system to normal 10 operating conditions, and are reactive in nature. Customer Connections, 11 Relocations and Other are planned capital expenditures to address customer 12 requests for new or upgraded service connections, or to relocate equipment in response to third-party requests (e.g., Michigan Department of Transportation 13 14 [MDOT]). Details for Base Capital programs are included in Exhibit A-12, Schedule B5.4, pages 3 to 12, and in more detail on Exhibit A-23, Schedule M4, 15 16 and are supported by witness Hill.

17

The second primary category of capital is Strategic Capital. Strategic Capital projects and programs include work the Company performs to improve safety, reliability and operability, and grid automation and modernization. These investments are subcategorized into three areas or investment pillars: Infrastructure Resilience and Hardening, Infrastructure Redesign and Modernization, and Technology and Automation. Details for Strategic Capital programs are included in Exhibit A-12, Schedule B5.4, pages 13 to 18, and in more detail in Exhibit A-



Line	
No.	

1	A46.	In the projected test year ending December 31, 2025, the Company is proposing to
2		invest a total of \$827.3 million in strategic programs and projects as part of this
3		case (Exhibit A-12 Schedule B5.4 Page 1, Line 22). Additionally, the Commission
4		approved a Distribution Infrastructure Recovery Mechanism (Distribution IRM or
5		IRM) in Case No. U-21297 totaling an additional \$290.1 million in 2025 that is not
6		included in the Company's rate request in this case (Exhibit A-33 Schedule X1
7		Page 1, Line 8) - Witness Foley provides additional information on the IRM in his
8		testimony. Summing both the proposed strategic investment for the 2025 test year
9		and the 2025 IRM yields a total of \$1,117 million of 2025 strategic investment.
10		
11	Q47.	What are emergent replacements, and what level of investment is the
12		Company requesting for emergent replacements in the test year?
13	A47.	Emergent replacements are those necessitated by damage or failure on the system.
14		Although investments in this category are reactive, rather than proactive, they are
15		essential to restoring customers' power after an outage event, maintain system
16		operability, and in many cases increase reliability. For the projected test year
17		ending December 31, 2025, the Company forecasts \$506.9 million in emergent
18		capital (Exhibit A-12 Schedule B5.4 Page 1, Line 7). Witness Hill discusses
19		emergent replacements in detail in his testimony.
20		
21	Q48.	What type of work comprises Customer Connections, Relocations and Other,
22		and what level of investment is the Company requesting for Customer
23		Connections, Relocations and Other in the test year?
24	A48.	The Customer Connections, Relocations and Other category includes multiple
25		investment areas:

AJK-39

<u>No.</u>		
1		• <u>Connections and New Load</u> is work required to connect new customer sites
2		and load to the distribution system
3		• <u>Relocations</u> is work required to move DTE Electric infrastructure primarily
4		driven by MDOT and local road commission projects
5		• <u>Electric System Equipment</u> is an inventory of critical spare equipment to
6		support emergent replacements and planned projects
7		• Normal Retirement Unit Change-out (NRUC) and Improvement Blankets
8		is work focused on reducing customer outages, replacing end-of-life
9		equipment and supporting the AMI platform and data
10		• General Plant, Tools & Equipment and Miscellaneous are new replacement
11		tools required for field workers to perform their tasks, engineering test
12		equipment and substation physical security
13		• <u>Public Lighting Department Project</u> is a project to convert Public Lighting
14		Department customers to the Company's distribution system
15		
16		The Company is requesting \$301 million in Customer Connections, Relocations
17		and Other (Exhibit A-12 Schedule B5.4 Page 1, Lines 15 and 16). Witness Hill
18		discusses the Customer Connections, Relocations and Other category in detail in
19		his testimony.
20		
21	<u>Part V</u>	VI Capital Exhibits Description
22	Q49.	How will the Company support the capital investments it is requesting in this
23		case?
24	A49.	The Company is supporting the requested capital investments using witness
25		testimony as well as five capital investment exhibits:

Line

<u>No.</u>		
1		• Exhibit A-12 Schedule B5.4 Projected Capital Expenditures – Distribution
2		Plan (witnesses Hill, Elliott Andahazy, Deol, Hartwick and Steudle).
3		• Exhibit A-23 Schedule M4 Distribution Plant Capital Project Detail – Base
4		Capital (witness Hill).
5		• Exhibit A-23 Schedule M5 Distribution Plant Capital Project Detail -
6		Infrastructure Resilience and Hardening (witness Elliott Andahazy and Hill).
7		• Exhibit A-23 Schedule M6 Distribution Plant Capital Project Detail -
8		Infrastructure Redesign and Modernization (witness Deol).
9		• Exhibit A-23 Schedule M7 Distribution Plant Capital Project Detail -
10		Technology and Automation (witnesses Hartwick and Steudle).
11		
12	Q50.	What information is included in Exhibit A-12 Schedule B5.4?
13	A50.	Exhibit A-12 Schedule B5.4 includes the total capital forecast for all of Distribution
14		Operations categories from the historical test period, 2022, through the projected
15		test year 12-months ending December 31, 2025, excluding investments that will be
16		recovered through the Commission approved IRM for the 13 months ending
17		December 31, 2024 and 12 months ending December 31, 2025. Witness Foley
18		covers the IRM in his testimony.
19		
20		Page 1 of Exhibit A-12 Schedule B5.4, column (a) includes a brief description of
21		the expenditures included on the line, and column (b) includes the historical (2022)
22		actual investment for each category. Between columns (a) and (b) is a list of
23		footnotes that reference additional details for the investment and forecasting

Line

25

AJK-41

forecasts for each line item for 2023, 2024, and the 24-month period ending

1	December 31, 2024, respectively, while column (f) includes forecasts for the 12-
2	month period ending December 31, 2025, the projected test year.
3	
4	Page 2 of Exhibit A-12 Schedule B5.4 provides additional detail on the information
5	provided on page 1, showing the normalization adjustments used to reconcile the
6	historical 12 months ended December 31, 2022 to the projected calendar years of
7	2023, 2024 and 2025. Page 2 is structured in much the same way as page 1 with
8	the following exceptions: columns (c) and (d) include adjustments to normalize
9	emergent replacement capital to the five-year average for use in 2024 and 2025
10	forecasts, and columns (e) to (g) provide forecasted investment for 2023, 2024 and
11	2025 respectively.
12	
13	Page 3 of Exhibit A-12 Schedule B5.4 provides the calculations of the
14	normalization adjustment applied to emergent capital to reflect a historical five-
15	year average for forecasting less the emergent reduction due to strategic investment
16	and surge tree trim reduction on line 29. More detail on emergent capital
17	expenditures is provided by witness Hill, further detail on the emergent reduction
18	due to strategic investment is discussed in Part IX Capital/Reliability Model and
19	more detail regarding the surge tree trim reduction is sponsored by Witness Steudle.
20	
21	Pages 4 through 9 of Exhibit A-12 Schedule B5.4 provide the three-year historical
22	average and projected investments for the Customer Connections, Relocations, and
23	Other subcategories. More detail on these capital expenditures is provided by
24	witness Hill.

Line No. 1 Pages 10 through 12 provide project lists for the historic test period for New 2 Business and Relocations and are supported by witness Hill. 3 4 Pages 13 through 18 provide the same information as pages 1 and 2 for all the 5 strategic capital projects by category and are supported by various DO witnesses as 6 shown on these pages. 7 8 Page 19 provides detail on the Allowance for Funds Used During Construction 9 (AFUDC) for DO projects and is supported by witnesses Hill, Elliott Andahazy, 10 Deol, and Hartwick. Capital investments include an AFUDC for eligible projects 11 that are in Construction Work in Progress (CWIP) as described by Witness Uzenski. 12 The total DO-related AFUDC is projected to be \$13.8 million for the 12-month 13 period ending December 31. 2025. The authorized overall rate of return used was 14 5.561% per the Order in Case No. U-21297. 15 16 Pages 20 through 26, supported by witnesses Hill, Elliott Andahazy, Deol, Steudle, 17 and Hartwick, provide a breakdown of plant activities, which are used by witness 18 Uzenski to forecast Plant in Service, Accumulated Depreciation and CWIP on the 19 projected balance sheet. Column (a) lists the project and program descriptions listed 20 in the earlier emergent, the customer connections, relocations, and other strategic 21 capital pages. Column (b) includes a corresponding in-service assumption: 22 "Annual" indicates plant investment is generally unitized within the year of investment, while a specific in-service date is used for projects that remain in CWIP 23 24 for more than a year before moving into Plant in Service. Capital expenditures 25 consistent with page 1 are summarized in columns (c) through (f). Column (g)

1	includes an estimated percentage of removal costs included within the capital
2	expenditures. Removal costs, as discussed by witness Uzenski, are charged to
3	accumulated depreciation rather than Plant/ CWIP and are therefore not
4	depreciable. Removal cost of 15% based on historical trend of removals as a
5	component of capital expenditures is applied to Base Capital Programs,
6	Infrastructure Resilience and Hardening, and Infrastructure Redesign. Technology
7	and Automation projects are assigned 0% since there is no related removal work.
8	Columns (h) through (j) reflect calculated removal costs based on projected Capital
9	Expenditures in columns (d) through (f) multiplied by the removal cost percentage
10	in column (g). The remaining capital expenditures will appear in Plant in Service
11	columns (k) through (m) if the in-service assumption is "Annual", or CWIP
12	columns (n) through (p) until the date of in-service as indicated in column (b). At
13	the time of in-service (as indicated in column (b)), cumulative investment including
14	the historical period is transferred from CWIP to in-service (excluding the removal
15	cost estimate).

16

17 Q51. Can you describe what is included in the Exhibit A-23 Schedules M4-M7?

A51. Yes. Exhibit A-23, Schedules M4-M7, supported by witnesses Hill, Elliot
Andahazy, Deol, Hartwick and Steudle, provide greater project detail for all
projects and programs included in Exhibit A-12, Schedule B5.4, and represents
100% of the Company's total forecast capital for DO. Each document, which can
be from one to several pages, includes the following:

- 23 24
- Program: As described in Exhibit A-12, Schedule B5.4, pages 3 to 18 column (a).
- 25
- Purpose and Necessity: A description of the driving forces for the work.

A. J.	KRYSCYNSKI
	U-21534

Line <u>No.</u>		U-21534
1		• Category: The pillar of Strategic Capital investment from the DGP or the
2		Base Capital investment.
3		• Line Number: A reference to the exhibits, schedule, page, and line numbers
4		supported.
5		• Scope: The scope of work.
6		• Benefits: How the Company's customers benefit from the program and a
7		description of the how the project or program is expected to impact
8		operations and reliability.
9		• Impact Dimensions: The GPM dimensions the strategic capital project or
10		program will impact. Base capital is excluded from GPM scoring.
11		• Approximate Construction Schedule: Proposed work schedule for the rate
12		case period.
13		• Budget Basis: Origin of budget estimate.
14		• Total Estimated Cost: The total expected cost of the project in present
15		dollars – this field was added per direction from the Commission (Case No.
16		U-21297, p108).
17		• Projected: The expected cost of the program for the forecasted years 2023,
18		2024, and 2025 in current dollar values.
19		
20	Q52.	What is included in the "Other Cost" line item shown in Exhibit A-23
21		Schedules M4-M7?
22	A52.	The other cost line item represents the forecasted amount of overheads that get
23		applied to a given project/program. Examples of project or program overheads
24		include facilities, stock, and procurement. Facilities overhead represents the costs
25		related to preventative maintenance, repairs, and improvements to facilities; these

AJK-45

costs are allocated to capital projects based on the amount of direct labor. Stock
 overhead represents the costs related to operation of warehouses; these costs are
 allocated to capital projects based on their stock and material purchases.
 Procurement overhead is the cost related to the supply chain procurement process;
 these costs are allocated based on the project stock and material purchases,
 contractor expenditures, and consultant expenditures.

7

8 "Other" costs are allocated to projects based on the mix of direct costs such as labor, 9 material usage, contractor expenditures, etc. "Other" costs for each project/program 10 can vary year to year based on the mix of direct costs. If a project has material 11 purchases scheduled for year one and the labor to install scheduled for year two, it 12 could see more overheads associated with Stock and Procurement for the first year 13 and overheads associated with Facilities in the second year. As the mix of direct 14 costs change year over year, the other costs associated will change as well.

15

16 Part VII: Capital Investment Variance Discussion

17 Q53. What is the purpose of the variance analysis section of your testimony?

- A53. To describe variances from forecast in calendar years 2022-2024. The
 reasonableness and prudence of these expenditures is supported primarily by
 witnesses Hill, Elliot Andahazy, Hartwick, Deol, and Steudle in their respective
 testimonies.
- 22

23 <u>2022 U-21297 Forecast vs. U-21534 Actuals</u>

- 24
- Q54. How does the Company's 2022 forecast in Case No. U-21297 compare to the
 actual capital investment for 2022?

1	A54.	Exhibit A-23 Schedule M1 compares the 2022 actual capital investment to the
2		Company's capital forecast from Case No. U-21297. Overall, the Company
3		invested \$56.6 million more than forecasted in Case No. U-21297 for calendar year
4		2022, or approximately 4% above the original forecast (Exhibit A-23, Schedule
5		M1, page 1, line 25). The difference is driven by lower than projected base capital
6		of \$13.2 million and increased investments in strategic capital of \$69.8 million.
7		Exhibit A-23 Schedule M1, U-21297 vs. U-25134 2023 Forecast Comparison,
8		provides the project level detail of the variance.
9		
10	055	What are the main drivers of the decreased investment in base canital in 2022?
10	Q33.	what are the main drivers of the deer cased investment in base capital in 2022.
10	Q33. A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent
10 11 12	A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4
10 11 12 13	Q33. A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other
10 11 12 13 14	Q33. A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other (Exhibit A-23, Schedule M1, page 1, column c, line 15) and Customer Advances
10 11 12 13 14 15	A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other (Exhibit A-23, Schedule M1, page 1, column c, line 15) and Customer Advances for Construction (Exhibit A-23, Schedule M1, page 1, column c, line 16). Lower
10 11 12 13 14 15 16	Q33.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other (Exhibit A-23, Schedule M1, page 1, column c, line 15) and Customer Advances for Construction (Exhibit A-23, Schedule M1, page 1, column c, line 16). Lower investment in Emergent Replacements were driven by lower than forecast
10 11 12 13 14 15 16 17	A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other (Exhibit A-23, Schedule M1, page 1, column c, line 15) and Customer Advances for Construction (Exhibit A-23, Schedule M1, page 1, column c, line 16). Lower investment in Emergent Replacements were driven by lower than forecast equipment failure events. The lower investment in Customer Connections,
10 11 12 13 14 15 16 17 18	Q33. A55.	In 2022, the actual investment was \$2.8 million lower than forecast in Emergent Replacements (Exhibit A-23, Schedule M1, page 1, column c, line 7) and \$10.4 million lower than forecast in Customer Connections, Relocations and Other (Exhibit A-23, Schedule M1, page 1, column c, line 15) and Customer Advances for Construction (Exhibit A-23, Schedule M1, page 1, column c, line 16). Lower investment in Emergent Replacements were driven by lower than forecast equipment failure events. The lower investment in Customer Connections, Relocations and Other and Customer Advances for Construction was driven by a

20

21 Q56. What are the main drivers of the increased strategic investment in 2022?

A56. In 2022, \$34.3 million of increased investment was in the Infrastructure Resilience
 and Hardening Pillar. The Company was able to complete more units than
 forecasted in the Pole and Pole Top Maintenance and Modernization program with
 \$13.7 million of additional investment and \$6.2 million of additional investment in

Line
No.

1	the 4.8kV Hardening program. Similarly, the Company increased its investment by
2	\$4.5 million in the Frequent Outage Program (CEMI) program by both addressing
3	more circuits and increasing scope on circuits where more work was needed for
4	reliability improvements.
5	
6	The Infrastructure Redesign and Modernization Pillar had an increased investment
7	of \$10.3 million primarily driven by accelerating tree trimming work on CODI:
8	Islandview Substation ahead of circuit conversion work as well as progress
9	payments for long lead substation equipment for the 4.8 kV CC: I-94 Substation
10	and Circuit Conversion (Promenade) and System Loading: Richmond/Armada.
11	
12	The Technology and Automation Pillar had increased investment of \$25.2 million.
13	The Work Management and Scheduling Upgrades project had additional
14	investment of \$6.0 million for new tools supporting field and storm processes. For
15	the Grid Automation Telecommunications as well as NWA: Omega Load Relief,
16	both projects pulled ahead \$4.4 million of material and equipment purchases to
17	avoid supply chain delays. The "Other Modernize Grid Management project" had
18	an additional \$3.0 million in investment driven by Error Free Communications
19	interface work and field network end of life equipment replacement. For the Tree
20	Trim Risk Prioritization Model, the total investment was shown in Exhibit A-12,
21	Schedule B5.7.7, page 1, line 25 in Case No. U-21297. When the project was
22	implemented, the investment was split into two locations in this case. The \$6.4 IT
23	investment shows on Exhibit A-12, Schedule B5.7.7, page 1, line 39 and \$3.1
24	million of investment shows on Exhibit A-12, Schedule B5.4, page 17, line 24. This
25	split results in a \$3.1 million increase investment in the Technology and

1		Automation Pillar. For the Interconnection Process Enablement project, the
2		interconnection gateway platform development was pulled ahead leading to \$2.8
3		million of increased investment. An additional \$5.9 million of investment was
4		made across other projects as shown in exhibit A-23, schedule M1.
5		
6		These expenditures facilitated necessary system upgrades or improvements to
7		continue safe and reliable service to customers and were reasonably and prudently
8		incurred.
9		
10	Q57.	How did actual capital investments for 2022 compare to rates included in the
11		Commission's final Order for Case No. U-21297?
12	A57.	Distribution Operations' actual capital investments equaled \$1,496.1 million in
13		2022. In the rate order, distribution plant investments of \$1,434.3 million were
14		included in rate base, or \$61.8 million less than the actual prudently incurred
15		investments (see witness Uzenski's Exhibit A-12, Schedule B5, line 7).
16		
17	<u>2023 U</u>	J-21297 Forecast vs. U-21534 Forecast
18	050	
19	Q58.	How does the Company's 2023 forecast in MPSC Case No. U-21297 compare
20		to the forecast in this case?
21	A58.	Exhibit A-23 Schedule M2 compares the 2023 forecast capital investment Case No.
22		U-21297 to this case. Overall, the Company is projecting to invest \$129.4 million
23		more than forecasted in Case No. U-21297 for calendar year 2023, approximately
24		9% above the original forecast. The difference is driven by higher than projected
25		base capital of \$139.9 million and lower strategic capital investments of \$10.5

	A. J. KRYSCYNSKI U-21534
	million. Exhibit A-23 Schedule M2, U-21297 vs. U-25134 2023 Forecast Comparison, provides the project level detail of the variance.
Q59.	What are the main drivers for the 2023 base capital forecast changes?
A59.	The primary changes in the 2023 base capital forecast changes are driven by storms.
	2023 included five (5) catastrophic storms, including the most damaging winter ice
	storm in Company history, and another summer catastrophic storm event that
	included heavy damage from historic six tornadoes. See witness Hill's testimony
	for discussion on base capital.
Q60.	What are the main drivers for the 2023 strategic capital forecast changes?
A60.	For 2023, the Company is projecting \$42.4 million of increased investment in the
	Infrastructure Resilience and Hardening Pillar, \$29.0 million of increased
	investment in the Technology and Automation Pillar, and \$81.9 million of
	decreased investment in the Infrastructure Redesign and Modernization Pillar.
	Overall, the Company is forecasting \$10.5 million of decreased investment in
	strategic capital.
<u>2024 L</u>	J-21297 Forecast vs. U-21534 Forecast
Q61.	How does the Company's 2024 forecast in MPSC Case No. U-21297 compare

to the forecast in this case?

Line

<u>No.</u>

A61. Exhibit A-23 Schedule M3 compares the 2024 forecast capital investment Case No.

U-21297 to this case. Overall, the Company is projecting to invest \$59.8 million less than forecasted in Case No. U-21297 for calendar year 2024, or approximately 4% less the original forecast. The difference is driven by higher than projected base

Line No.

capital of \$111.0 million and lower strategic capital investments of \$170.8 million.
 Exhibit A-23 Schedule M3, U-21297 vs. U-25134 2024 Forecast Comparison,
 provides the project level detail of the variance.

4

5 Q62. What are the main drivers for the 2024 base capital forecast changes?

6 A62. Emergent replacements are forecast based upon a five-year historical average as 7 discussed in Witness Hill's testimony. In this case, per the approved methodology, 8 the five-year average calculation replaced 2017, a lower cost year, with 2022, a 9 higher cost year. This change increased the projection, resulting in an additional 10 \$69.2 million in the 2024 forecast for emergent replacement (Exhibit A-23, 11 Schedule M3, column d, line 7). This increase in Emergent Replacement did not 12 impact the Company's strategic capital investment level. For Customer 13 Connections, Relocations and Other, the I-375 relocation project is a primary driver 14 of increased investment with \$25 million projected in 2024. The other cost drivers 15 that make up the full \$111.0 million are found in Exhibit A-23 Schedule M3, U-16 21297 vs. U-25134 2024 Forecast Comparison.

17

18 Q63. What are the main drivers for the 2024 strategic capital forecast changes?

A63. In Case No. U-21297 the Company forecasted total strategic capital at \$879.6
million for the calendar year 2024. In this case the Company is forecasting a total
strategic capital investment of \$708.8 million, a decrease of \$170.8 million from
the U-21297 forecast. Of the \$170.8 million decrease, \$60.6 million is a simple
shift of investment to the IRM. Project and Program investment changes were based
on the Company's review of strategic factors since the initial Case No. U-21297
filling including 2023 ice storm learnings (increased focus on near term reliability

Line <u>No.</u>

<u>NO.</u>		
1		such as 4.8kV Hardening, and Automation) and the December Case No. U-21297
2		rate order. The Commission approved an annual investment level of \$659.4 million
3		in strategic investment in the Case No. U-21297 order, a difference of \$220.1
4		million from what the Company originally forecasted.
5		
6		In the Infrastructure Resilience and Hardening Pillar, the Company is forecasting
7		an increase of \$56.6 million, primarily driven by an \$80.0 million increase in the
8		4.8kV Hardening program, carryover work for Substation Risk: McGraw of \$37.8
9		million, an offsetting decrease of \$57.1 million in PTMM due to rate order
10		guidance, and other miscellaneous adjustments that result in an additional \$4.1M
11		reduction. The Company is forecasting an increased investment of \$24.4 million in
12		the Technology and Automation Pillar for operational technology projects initiated
13		to support and enhance storm restoration efforts. In the Redesign and
14		Modernization Pillar, the Company is forecasting a decrease of \$251.7 driven by
15		shifting \$60.6 million of investments to the IRM and \$191.2 million of project
16		investment to later years, in part, to shift investment to projects that impact near
17		term system resiliency, including Automation and Hardening.
18		
19 20	<u>Capab</u>	bility to Execute Strategic Work
21	Q64.	How does the Company ensure that it has the capabilities and resources
22		required to make its proposed strategic investments?
23	A64.	As the long-term needs of the electric grid call for increasing levels of investment,
24		the Company has responded by increasing our labor force (employees and
25		contractors, engineering and planning staff), leveraging partnerships, and
26		strengthening project management and supply chain oversight. The Company has

1

2

3

4

5

6

instituted workforce planning processes and tools that calculate overall resource demands for all field trades, as well as support and enabling groups including engineering, designers, and project managers. Estimates and forecasts for shortterm and long-term resource needs are performed on an ongoing basis as an input to our sourcing decisions. DTE Electric will add staffing as needed to address our growing capital investment portfolio.

7

8 The projected resources (Company and contractors) required by year-end 2023 to 9 complete the planned strategic capital investments is just over 5,200 full-time 10 equivalents (FTEs). The projected resources (Company and contractors) required 11 by year-end 2024 to complete the planned strategic capital investments is 12 approximately 5,500 FTEs. As a result, the Company currently has more line 13 workers in the field than ever before. Additionally, the Company utilizes strategic 14 partnerships with engineering and design firms and front-line labor contractors. Local contractor workforce has been growing as our investments have increased. 15 16 Contractor needs that exceed the local workforce availability and are supplemented 17 with additional work force from outside of the area.

18

As discussed above, the Company has a Project Management Organization (PMO) specifically focused on managing this growing work force. Additionally, the PMO works with the Company Supply Chain Management team to mitigate impacts of material supply chain challenges. These mitigation actions include, but are not limited to:

24

Line <u>No.</u>		U-21534
1		1) Increasing the number of suppliers for key equipment including transformers,
2		insulators, and cross arms.
3		2) Demand planning with a long-time horizon, including securing product slots
4		for current year and beyond with suppliers.
5		3) Deploying weekly and daily tracking calls with key suppliers (driving
6		collaboration and leveraging our resources, including transportation, to keep
7		orders on track).
8		4) Sending supply chain and other employees to supplier facilities to provide real
9		time governance and quality control on purchased materials.
10		
11		The Company continues to grow its strategic capital capabilities with over \$700
12		million invested in 2022 and over \$800M invested in 2023.
13		
14	<u>Part '</u>	VIII: Global Prioritization Model
15	Q65.	What is the Global Prioritization Model (GPM) and how does it support the
16		prioritization of capital strategic investments?
17	A65.	The GPM is a tool the Company's Distribution Operations team developed to
18		prioritize investments by ranking projects and programs based on the benefits the
19		project or program delivers for a given level of investment. The ranking is
20		accomplished through a process of evaluating a project across ten impact
21		dimensions, which represent project benefits, and developing a total project score
		based on the weighting of each impact dimensions. The model results serve as the
22		
22 23		initial basis for the Company's investment prioritization and highlight those
22 23 24		initial basis for the Company's investment prioritization and highlight those projects that have the highest relative benefit and/or are most urgent.

Line <u>No.</u>

1 Q66. Does the GPM consider benefits and costs? 2 A66. Yes. Each of the ten impact dimensions within the GPM measures a benefit of the 3 project or program. These benefits are weighed against costs in eight of the 4 dimensions. Costs are not considered when evaluating if the project or program 5 delivers benefits in the "Regulatory Compliance" or "Investment in EJ 6 communities" dimensions. 7 Q67. Does the GPM determine if benefits exceed costs? 8 9 A67. No. In order to determine if benefits exceed costs, all benefits would need to be 10 translated into a monetary value. Only two of the benefits the GPM captures, O&M 11 Avoidance and Capital Avoidance, are measured in monetary terms. All other 12 dimensions are quantified in non-monetary terms. While the GPM does not 13 determine if benefits exceed costs, it does utilize benefit-cost ratios in most of its 14 dimensions to provide a result where projects which deliver the most benefits per 15 dollar invested receive the highest scores. Not all dimensions use this structure, specifically "Regulatory Compliance" and "Investment in EJ Communities", where 16 17 programs receive a score without dividing by overall project cost. 18 19 Why doesn't the Company convert all project benefits to a monetary value? Q68. 20 A68. The non-monetary benefits which the GPM measures have no standard or generally 21 accepted method available to convert the quantified benefits into a monetary value. 22 While SAIDI and SAIFI can be monetized relative to the customer potential cost 23 impacts of an outage by using the ICE calculator developed by Lawrence Berkeley 24 National Laboratory (LBNL), that methodology has limitations including dated 25 customer survey data. Other benefits such as providing load relief so that equipment

1		does not operate over its designed rating, or reducing the probability of major
2		events, or investing in EJ communities do not have any commonly accepted
3		conversion to a monetary value. Additionally, the Company does not place a
4		monetary value on project benefits which deliver safety benefits such as a reduction
5		in energized wiredowns. Using the Current GPM methodology, the Company can
6		transparently demonstrate which projects provide the highest benefit for customers
7		across different impact dimensions.
8		
9	Q69.	What determines whether a project is scored in the GPM?
10	A69.	The engineering team evaluates alternatives to meet the system needs and selects
11		the best project or program to move forward. If necessary, a BCA takes place as
12		part of the engineering process to select the best option. The solution which is
13		selected to move forward is scored in the GPM for prioritization.
14		
15	Q70.	Has the GPM model been recently updated?
16	A70.	Yes. As introduced in the 2023 DGP filing the GPM has been updated to include
17		three new dimensions to capture additional project benefits and to align to two
18		additional planning objectives (Clean, and Customer Accessibility and Community
19		Focus). Specifically, the dimension of "Investment in EJ communities" was added
20		based on feedback from the Commission to incorporate equity into the decision-
21		making process. ⁴ Additionally, the weightings of each dimension have been
22		updated. The "Investment in EJ communities" addresses the Commission's order
23		in Case No. U-20836: "the Commission will continue to hold DTE Electric to its

⁴ See Commission's Order on November 18, 2022 in docket U-20836 (p 459).
commitments to more fully incorporate equity considerations into its decision making processes".

Q71. How does the GPM consider DTE Electric's planning objectives when evaluating the Company's distribution investment options?

5 A71. The Company uses the GPM to assess the benefits that strategic investments have 6 on the distribution system as they relate to each of five planning objectives of 1) 7 Safe, 2) Reliable and Resilient, 3) Affordable, 4) Clean, and 5) Customer 8 Accessibility and Community Focus. All impact dimensions that are measured in 9 the GPM are aligned to one or more of these five planning objectives as described 10 in Table 6. These five objectives also align with the Commission's overarching 11 objectives for the electric distribution system, which are safety, reliability and resilience, cost effectiveness and affordability, and accessibility.⁵ 12

13

14

Table 6Mapping of GPM impact dimensions to Planning Objectives

15

		Planning Objectives						
		Safe	Reliable and Resilient	Affordable	Clean	Customer accessible and community focus		
	Reduce Electrical Hazards	~		~				
ទ	Overload Relief	✓	✓	✓	~	✓		
. <u>.</u>	SAIDI	~	~	~				
ens	SAIFI		✓					
E	Regulatory Compliance	~	~					
t	Major event risk	✓	✓	✓				
ğ	Capacity Relief		~		~	~		
<u>-</u>	Investment in EJ communities					✓		
Σ	O&M Avoidance			~				
U	Capital Avoidance			~				

⁵ See Commission's Order on October 11, 2017 in docket U-18014 (pp10-12) and re-affirmed in the Commission Order on August 20, 2020 in docket U-20147 (pp 36-38).

<u>No.</u>		
1	Q72.	What impact dimensions are quantitatively assessed to determine project and
2		program impact across the Company's Planning Objectives?
3	A72.	In the GPM, strategic investments are evaluated against ten impact dimensions as
4		described in Table 7. Quantitative assessments are conducted for all the impact
5		dimensions to score and rank investments.
6		
7	Q73.	What impact dimensions have remained unchanged in the updated GPM?
8	A73.	Six of the Seven original impact dimension have calculations that remain
9		unchanged. Four impact dimensions, Regulatory Compliance, Major event risk,
10		O&M Avoidance, and Capital Avoidance, are unchanged from the previous GPM.
11		Two additional dimensions have been renamed but the calculations are the same as
12		in the previous GPM. The "Reduce electrical hazards" dimension was previously
13		named "Safety" and "SAIDI" was previously named "Reliability".
14		
15	Q74.	What impact dimensions were added or changed in the updated version of the
16		GPM?
17	A74.	Two dimensions were added, and one dimension was divided into two separate
18		dimensions. The two new dimensions are "SAIFI" and "Investment in EJ
19		communities". To better differentiate day-to-day loading challenges from
20		constraints that limit operational flexibility, the "Load Relief" dimension in the
21		previous iteration of the GPM has been split into two dimensions: "Overload Relief"
22		and "Capacity Relief".
23		
24	Q75.	Was the weighting of dimensions changed in the updated version of the GPM?

Line

- 2 three-point scale.
- 3

4

Table 7Global Prioritization Model Impact Dimensions

Impact Dimension	Drivers	Weight
Reduce Electrical Hazards	 Reduction in wire down events Reduction in secondary network cable manhole events 	
Overload Relief	Elimination of overloaded equipment	3
SAIDI	Reduction in duration of outage events	
SAIFI	Reduction in frequency of outage events	
Regulatory Compliance	 MPSC staff's recommendation (March 30, 2010, report) on utilities' pole inspection program 	
•	 Docket U-12270 – Service restoration under normal conditions within 8 hours 	2
	 Docket U-12270 – Service restoration under catastrophic conditions within 60 hours 	
	 Docket U-12270 – Service restoration under all conditions within 36 hours 	
	 Docket U-12270 – Same circuit repetitive interruption of fewer than five within a 12-month period 	
Major Event Risk	 Reduction in extensive substation outage events that lead to a large amount of stranded load for more than 24 hours 	
Capacity Relief	Elimination of system capacity constraints	
Investment in EJ	 Percent of customers impacted by investment in EJ communities 	
Communities		
O&M Avoidance	 Trouble event reduction and truck roll reduction Preventive maintenance investment reduction 	
Capital Avoidance	 Trouble event reduction and truck roll reduction Reduction in capital replacement either during equipment failures or avoided planned capital work 	1

Line <u>No.</u>

1 Q76. What are the drivers of the changes to the GPM?

2 A76. The GPM was changed to capture customer benefits that were not previously 3 accounted for, and to include benefits from across all of DTE Electric's Planning 4 Objectives (as shown in **Table 6**). "SAIFI" was added because reducing frequency 5 of outages is important to providing reliable power to our customers, and because 6 the State's Reliability and Service Quality standards provide guidance on what 7 outage frequency is consistent with an acceptable level of service. Project benefits 8 in the "Capacity Relief" dimension were added to measure projected load 9 constraints in 2035, and to account for benefits accrued by addressing circuits that 10 do not have enough capacity to fully realize automation capabilities. Incorporating 11 the 2035 load projection aligns with the Company's goals to provide a grid that 12 facilitates a transition to a decarbonized economy. "Overload Relief" accounts for 13 benefits that come from reduced day-to-day equipment loading. Finally, by adding 14 the "Investment in EJ communities" dimension, which scores a project based on 15 the percentage of customers benefiting from this project who are from EJ 16 communities, we have incorporated equity into our planning and capital prioritization process as directed by the Commission in 2022.⁶ 17

18

19 Q77. How are projects ranked using the GPM?

A77. Strategic investments are assessed, scored, and then ranked in a quantitative manner
 on how they support/improve each impact dimension. Table 8 shows the mapping
 of the investments to the impact dimensions they general receive a score in, based
 on the benefits the investment delivers.

⁶ See Commission's Order on November 18, 2022 in docket U-20836 (p 459).

Line <u>No.</u>

1 2

Table 8Selected programs and GPM impact dimensions

Program	Reduce Electrical Hazards	Overload Relief	SAIDI	SAIFI	Regulatory Compliance	Major Event Risk	Capacity Relief	Investment in EJ Communities	O&M Avoidance	Capital Avoidance
Substation Risk						Х		*		
4.8kV Hardening	Х		Х	Х				Х	Х	Х
PTMM	Х		Х	Х	Х			Р	Х	Х
Cable Replacement						Х		Р		Х
Frequent Outage			Х	Х	Х			Р		
Breaker Replacement			Х	Х		Х		Р	Х	Х
URD Replacement			Х	Х				Р		Х
Subtransmission Redesign		х					х	*		
CODI	Х	Х	Х	Х		Х		*	Х	Х
4.8kV Conversion	Х	Х	Х	Х		Х		*	Х	Х
System Loading		Х	Х	Х		Х	Х	*	Х	Х
Automation	Х		Х	Х				Р		

Investment in EJ Community Key: * = Dependent on location of project, X = Yes, addresses EJ communities, P = program where some areas of the program will occur in EJ communities

3

Detailed analyses based on historical data, engineering assessments, and field feedback was used to quantify each investment's benefits within each impact dimension. The quantified benefits were then compared to the investment's costs to derive benefit-cost ratios used to determine the relative difference between projects.

9

10 Unit measurements used for benefit-cost ratios are different for each impact 11 dimension. For example, reliability benefits are captured in customer minutes of 12 interruption reduction whereas O&M and reactive capital benefits are captured in 13 dollars avoided. Line <u>No.</u>

> 1 Each program's benefit-cost score for each impact dimension is indexed so that a project with a benefit-cost ratio at the 95th percentile receives a score of 100. 2 Projects scoring exceptionally high, above the 95th percentile, will receive a score 3 above 100. This method provides three benefits. First, by aligning the 95th 4 5 percentile to a score of 100, outlier projects do not skew the entire index. Second, 6 the 100-point scale makes it makes it easy to understand which projects are 7 delivering the highest benefit per dollar invested – namely, the ones which score 8 closer to 100. Finally, indexing, along with the weighting of dimensions, allows for 9 the consideration of multiple monetary and non-monetary benefits to be combined 10 into a single analysis.

11

12 Impact dimensions are weighted relative to each other. Table 7 lists the different 13 weights given to each impact dimension. The weights of each dimension were 14 simplified in the recent GPM update from a 10 point range to a 3 point range 15 Dimensions which align with core safety and reliability improvements, such as 16 Reduce Electric Hazards, one of the Company's most important impact dimensions, 17 is given the highest weight of 3. This change effectively means that a score of 100 18 in a lower weighted dimension will not be worth as much as a 100 rating in Reduce 19 Electrical Hazards. For example, if a project's Reduce Electrical Hazards score is 20 50 (on a 0-100 scale), it will be multiplied by a weighting factor of 3 to receive a 21 score of 150. A project with a Capacity Expansion score of 50 will be multiplied 22 by the weighting of 2 and contribute 100 to the total scoring. This example 23 illustrates how the impact dimension weights will rank projects higher if they 24 provide benefits in dimensions which have higher weightings. Once a program's 25 index scores have been calculated across all impact dimensions and adjusted by

Line <u>No.</u>		U-21534
1		weighting, the index scores are summed together to determine the program's
2		overall score. The higher the score, the better the GPM ranking.
3		
4	Q78.	How do the GPM results influence the Company's distribution investment
5		decisions?
6	A78.	We use the GPM to pick the highest relative benefit projects that will have the
7		greatest impact improving the grid and the overall customer experience. Projects
8		and programs are ranked using the GPM on an annual basis. Investments that score
9		highest in the GPM rankings are generally selected for the Company's distribution
10		infrastructure strategic investment plan. As described in detail below, there are
11		some projects that are chosen outside of the GPM process or lower ranked projects
12		within the process that are funded for various operational reasons.
13		
14		Projects and programs that span multiple years are evaluated every year and may
15		experience a change in GPM ranking if additional information changes the expected
16		project costs or benefits. However, to keep scoring relatively consistent year over
17		year, the entire project cost and entire project benefits are still used when scoring
18		the project or program – although the project costs and benefits will be adjusted for
19		known changes (examples include costs increases or more benefits than forecast).
20		
21	Q79.	How does the GPM support reasonable and prudent prioritization of
22		investments?
23	A79.	The GPM helps the Company compare hundreds of vastly different types of
24		projects and programs of different sizes and identify which ones are going to be the
25		most beneficial for customers.



1 What are the GPM scores for the projects and programs proposed in this case? **Q80.** 2 The total GPM scores for strategic capital projects and programs, ranked from A80. 3 highest to lowest, is illustrated in Figure 9. Table 9 lists the names of the capital projects and programs ranked in the top 50. GPM scores for the top 50 projects and 4 5 programs including scores for each of the 10 impact dimensions is included in Exhibit A-23 M14 GPM Project and Program Rankings. Tree trimming⁷ to the 6 7 enhanced specification, although excluded from the Table 9 and Figure 9, 8 continues to provide high customer benefits, and ranks within the top five projects 9 and programs in the Company's five-year investment portfolio. 10 Figure 9



9 Overall Benefit-Cost Scores for top 50 strategic capital programs and projects



⁷ Tree trimming, as an O&M program, is excluded from the **Figure 9** and **Table 9**. Nonetheless, tree trimming to the enhanced specification has a top 5 benefit-cost ranking among all programs.

Line <u>No.</u>

1

Table 9 Top 50 Strategic Capital Programs and Projects Based on GPM

2

Rank	Capital Program/Project
1	ADMS: DMS/OMS
2	Pole and Pole Top Maintenance and Modernization (PTMM)
3	Frequent Outage Program (CEMI)
4	Subtransmission Redesign & Rebuild: Tie 1568
5	40 kV: Automatic Pole Top Switch
6	4.8 kV CC: Hawthorne Relief and Circuit Conversion
7	4.8 kV Hardening
8	CODI: Charlotte Network Upgrade
9	Distribution Automation
10	Subtransmission Redesign & Rebuild: Trunk 2237-ST
11	CODI: Garfield Network Upgrade
12	Subtransmission Redesign & Rebuild: Trunk 7105
13	Substation Risk: Savage
14	Subtransmission Redesign & Rebuild: Trunk 7106
15	4.8 kV CC: ISO Conversion Program
16	4.8 kV CC: Zenon Circuit Conversion Phase 2
17	Subtransmission Redesign & Rebuild: Trunk 2419
18	CODI: Howard Conversion
19	4.8 kV CC: McKinstry Sub Decommission
20	Substation Risk: Port Huron
21	8.3 kV CC: Pontiac Overhead/Underground Conversion
22	4.8 kV CC: Grosse Pointe Substation and Circuit Conversion
23	Subtransmission Redesign & Rebuild: Trunk 2255
24	4.8kV CC: Barber Substation and Circuit Conversion
25	Subtransmission Redesign & Rebuild - Trunk 2448

Rank	Capital Program/Project
26	CODI: Targeted Network Secondary Cable
20	Replacement
27	4.8 kV CC: I-94 Substation and Circuit Conversion
27	(Promenade)
28	Substation Risk: Chestnut
29	Cable Replacement Program
30	Subtransmission Redesign & Rebuild: Trunk
31	CODI: Islandview Substation
32	Subtransmission Redesign & Rebuild: Tie 3416 Reconductoring
33	Subtransmission Redesign & Rebuild: Bernard
34	CODI: Kent/Gibson Conversion
35	Subtransmission Redesign & Rebuild: Trunk 7386
36	URD Replacement Program
37	Subtransmission Redesign & Rebuild: Trunk 7333
38	CODI: Alfred Substation Expansion
20	Subtransmission Redesign & Rebuild: Trunk
39	4217
40	4.8 kV CC: Birmingham Decommissioning and
40	Circuit Conversion
41	Subtransmission Redesign & Rebuild: Trunk
42	Subtransmission Redesign & Rebuild: Hurst
42	4.8 kV CC: Cortland / Oakman / Linwood
45	Consolidation
44	Subtransmission Redesign & Rebuild: Tie 6907
45	Subtransmission Redesign & Rebuild: Cortland
	Station Expansion
46	Breaker Replacement Program
47	Substation Risk: McGraw
48	4.8 kV CC: Belleville Substation and Circuit Conversion
49	Subtransmission Redesign & Rebuild: Sandusky Transformer 101 Breaker
50	Subtransmission Redesign & Rebuild: Waterman

3

5

4 Q81. Are there other factors besides the GPM ranking that determine final timing

of program and project selection?

A81. Yes. While the benefit-cost scores of programs and projects and their prioritization
 ranking provide the foundation for the Company's strategic investment decisions,
 there are other considerations that impact project selection and timing, as listed

4

below:

Line No.

5

6 Investment timing for programs and projects considers the impact on • 7 workforce needs. Resources required for engineering, design, project 8 management, scheduling, and construction need to be evaluated not only by 9 project type (substation, overhead or underground) but also by geographic location. Resource gaps and balancing are evaluated before project 10 11 sequencing decisions are made. Funding decisions also consider the Company's capacity to perform the work, as the Company often partners 12 13 with third parties to plan and execute projects.

System operational constraints and stability, occasionally including transmission, can cause the Company to pull a project ahead. For example, a project may be needed to address subtransmission system integrity caused by load growth.

Regulatory requirements or guidance also influence the selection of some
 projects and programs regardless of the GPM ranking. NERC requirements,
 for example, require upgrades to ensure the bulk electric system is
 unaffected by subtransmission outages. These NERC driven projects have
 benefits that are difficult to quantify in GPM.

Safety issues that cannot be easily quantified and indexed could warrant an
 investment outside of the GPM model to protect our customers or

Line No.

1

2

3

4

5

6

7

8

9

10

11

employees. For instance, subtransmission disconnect switches and the Pontiac vault projects are necessary to meet operational safety needs.
Pilot projects are excluded from the ranking process as they are used to determine what the true benefits and cost will be to complete an activity that the Company believes will be beneficial to its customers. In other words, the pilots help provide the data for a more adequate accounting of future project benefits. An example is non-wire alternative (NWA) projects. These NWA pilot projects focus on using alternative technologies to address circuit or substation overload concerns to help delay or offset traditional grid upgrades. The Company developed these NWA pilots to better understand the customer and costs benefits as part of the longer-term grid modernization plan, so that in the future these can be evaluated against more traditional

plan, so that in the future these can be evaluated against more traditional
alternatives. These pilots are supported by Company witness Hartwick and
detail is provided in Exhibit A-12 Schedule B5.4.1 through B5.4.7 and
B5.4.9.

16 Capital projects are subject to development milestones, especially in the • 17 conceptual design and early development stages, including land availability 18 and property purchases, municipal approvals and construction permits, right-19 of-way acquisition and easements, and lead times when procuring major 20 equipment. While the Company takes proactive measures to mitigate these 21 execution risks, many of these early-stage milestones are difficult for the 22 Company to control and can introduce schedule delays or cost increases. 23 Therefore, the Company's investment and maintenance plan is designed to 24 include some flexibility to accommodate these unpredictable variations in 25 timing and cost.

Line
<u>No.</u>

1	• Some capital replacement programs are funded annually, to avoid
2	acceleration of asset failures and the risk that a large quantity of assets would
3	reach end-of-life concurrently, thus exceeding available resources to replace
4	them (e.g., underground residential distribution cable program).
5	• If the Company is awarded grant money from the state or federal government
6	for specific projects, including IIJA grants, it could positively impact project
7	selection due to grant project completion requirements. In 2023, the
8	Company was awarded an Adaptive Networked Microgrids (ANMs) grant
9	which the Company has funded in both 2024 and 2025. This project is further
10	discussed by witness Hartwick.
11	• Projects already in active construction.
12	• Some Operational Technology (OT) projects are not evaluated through the
13	GPM, as the GPM is designed for investments which upgrade the physical
14	distribution grid. The specific benefits which OT projects deliver are
15	discussed in more detail in witness Hartwick's testimony.
16	
17	It is important to note that some programs and projects may not receive funding in
18	a particular year due to lower benefit-cost scores relative to other projects, but this
19	does not indicate that these programs or projects are not beneficial to customers, or
20	that they will not be selected in other years. Rather, all the programs and projects
21	identified by the Company and evaluated by the GPM provide system
22	improvements and may be funded at some point over the next several years. While
23	the strategic capital investment plan is primarily driven by the GPM, the Company
24	may adjust the annual plans based on changing circumstances and grid needs.
25	

1	Q82.	Do the GPM scores and rankings have the potential to change over time?
2	A82.	Yes. As the Company continues to make investments in distribution infrastructure,
3		the effectiveness of the capital investment is examined on a regular basis. The
4		benefit-cost scores of the programs and projects may change over time as new data
5		becomes available. The prioritization ranking of the programs and projects may
6		change accordingly.
7		
8	<u>Part I</u>	X: Capital/Reliability Model
9	Q83.	Based on DO investments requested in this case, what system reliability
10		improvements are expected?
10		1 I
11	A83.	The Company's reliability model projects that customers will experience an all-
11 12	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical
10 11 12 13	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical baseline of 563 minutes, assuming normal weather. Similarly, all weather SAIFI
10 11 12 13 14	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical baseline of 563 minutes, assuming normal weather. Similarly, all weather SAIFI will improve to 1.33 in 2025 from the historical baseline of 1.37. The model
11 12 13 14 15	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical baseline of 563 minutes, assuming normal weather. Similarly, all weather SAIFI will improve to 1.33 in 2025 from the historical baseline of 1.37. The model assumes that due to timing of the execution of projects and programs, half of the
11 12 13 14 15 16	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical baseline of 563 minutes, assuming normal weather. Similarly, all weather SAIFI will improve to 1.33 in 2025 from the historical baseline of 1.37. The model assumes that due to timing of the execution of projects and programs, half of the benefits are realized in the year of construction and full benefits are realized the
11 12 13 14 15 16 17	A83.	The Company's reliability model projects that customers will experience an all- weather SAIDI of 504 minutes in 2024 and 487 minutes in 2025 versus a historical baseline of 563 minutes, assuming normal weather. Similarly, all weather SAIFI will improve to 1.33 in 2025 from the historical baseline of 1.37. The model assumes that due to timing of the execution of projects and programs, half of the benefits are realized in the year of construction and full benefits are realized the following calendar year. Graphs of expected reliability improvements are shown in



2

Line

3 Q84. How does the Company calculate its reliability projections?

A84. The reliability calculations are performed at a circuit level based on historical
performance and the impact of planned investments on those circuits. The projected
performance of all circuits is summed to provide a system level projection. The
process to project reliability performance within the model can be summarized in
five steps:

9	0	Baseline: Calculate circuit-level baseline reliability performance
10	0	Program impact: Estimate impact of reliability programs
11	0	Degradation impact: Estimate impact of system degradation
12	0	Investment plan: Enter planned or expected in-service schedule for
13		reliability programs into model
14	0	Calculate Ex-MED performance: Combine baseline performance with
15		investment plan on a circuit level to project future performance
16	0	Calculate All-weather performance: Scale Ex-MED output to all weather
17		output and expected ranges

Line <u>No.</u>		U-21534
1		Each of these steps is described briefly below.
2		
3	Q85.	How is the starting point, or circuit baseline calculated?
4	A85.	Each circuit has a baseline of reliability performance based on five years of
5		historical, non-MED event volume. Events are further divided into tree and non-
6		tree, single and multiple, and outage and non-outage events. An average customer's
7		interrupted (CI) and customer minutes interrupted (CMI) per event is used to
8		convert the volume of events to a SAIDI Ex-MED and SAIFI ex-MED baseline.
9		
10	Q86.	Which reliability investments are included in the model?
11	A86.	The model's purpose is to forecast system reliability based on outage events on the
12		overhead distribution system (where the vast majority of the Company's outage
13		events occur), and therefore incorporates the impact of projects and programs
14		which have the potential reduce the impact of overhead outage events. The model
15		accounts for reliability improvements from six programs: Tree Trimming, 4.8kV
16		Hardening, PTMM, Customer Excellence, 4.8kV Conversion, and Automation.
17		
18	Q87.	How does the company estimate the effectiveness of the reliability
19		investments?
20	A87.	For programs that have been established for over 3 years, the Company looks at a
21		year worth of non-MED historical circuit outage data before reliability
22		improvement is deployed. Non-MED event data for years post deployment is
23		compared to the baseline to calculate the reliability improvement. For newer
24		programs or projects, the reliability improvement is based either on the assessment

AJK-71

Line No.

1

2

3

4

comparing the newer program to similar established programs. Programs impact the event types they are most likely to avoid. For example, if a circuit has tree trimming planned, the model will project a reduction in tree-related multiple events.

5

6 **Q88.** How is the circuit performance projected?

7 A88. The investment plan is entered in the model on a circuit level basis. For example, 8 the model has a list of circuits with planned PTMM in 2024 which is aligned with 9 our investment plan. If a circuit has no planned investment indicated in the model, 10 the model will calculate an increase in future event volume, or degradation, over 11 time. Circuits which have Tree Trimming, 4.8kV Hardening, PTMM, or Customer 12 Excellence work will have the program benefits applied to them by reducing the 13 future volume of events. Half of the maximum benefit will be applied in the year 14 of the investment, and the total benefit in the year after the investment. The benefit 15 will reduce over time due to factors such as the regrowth of trees, and the continued 16 aging of overhead equipment. The model assumes that significant rebuild work from 4.8kV Conversion will deliver a consistent benefit for 10 years after the 17 18 investment without any degradation. The impact of the Automation investment is a 19 reduction in the customer interrupted (CI) per event on the circuit, but there is no 20 associated reduction in event volume.

21

22 Q89. How are Ex-MED and all-weather reliability metrics calculated?

A89. The primary output of the model is a projection of ex-MED event volume, which
 is translated into SAIFI ex-MED and SAIDI ex-MED using a historical event
 average CI and CMI per event. The ex-MED results are scaled to all-weather

1 projections by calculating the ex-MED to all weather performance relationship of 2 64 large utilities based on historical data available on EIA.gov. As an example, for 3 utilities who had a SAIDI ex-MED of 100 minutes in a given year, the range of All-4 Weather SAIDI outcomes, excluding the top and bottom 20% of outcomes, was 5 140 minutes to 342 minutes. If the model projects the Company's SAIDI ex-MED 6 performance to be 100 minutes, it would also calculate a range of expected All-7 weather outcomes to be 140 to 342 minutes, with an average performance 8 calculated as the median of the data set. This range, based on industry performance, 9 accounts for weather variability.

10

11 Q90. Does the model capture all potential reliability benefits?

A90. No, as mentioned the model captures the benefits of the investment programs which
deliver the majority of the improvements on the overhead distribution system.
Other programs such as URD replacement, Cable replacement, Breaker
replacement, Substation Risk projects will also reduce outage events and impact
reliability. For specific benefits from these projects, please refer to testimony from
Witnesses Elliott Andahazy, Deol, and Hartwick.

18

19 Q91. How is this model an improvement upon previous reliability projections?

A91. The structure of this model has many improvements over previous methods to
 project reliability. First, the model is based on ex-MED events and reliability which
 has less inherent variability than all-weather performance. Second, by modelling
 the system on a circuit level basis, this methodology more accurately accounts for
 benefits from different programs without double counting. Finally, as circuit
 performance is disaggregated into many event types (tree vs non tree, single vs

Line <u>No.</u>		U-21534
1		multiple, outage vs non-outage), program improvements can more accurately be
2		modelled against the events they are most likely to address.
3		
4	Q92.	Does the reliability model project emergent reductions and how are these
5		reductions shown in Exhibit A-12 Schedule B5.4?
6	A92.	Yes. The reliability model projected emergent reduction, along with the surge tree
7		trim capital reduction shown on Exhibit A-22, Schedule L1, line 33, are shown in
8		Exhibit A-12, Schedule B5.4, page 1, line 6.
9		
10	<u>Part X</u>	<u>X: IIJA Grant Opportunities</u>
11	Q93.	What are IIJA grants?
12	A93.	The Infrastructure Investment and Jobs Act (IIJA)) was enacted federally in
13		November 2021. The goal of the IIJA grants is to provide funding opportunities in
14		multiple types of investments to catalyze public and private investment to enhance
15		the nation's infrastructure, with a particular focus on helping America's
16		disadvantaged communities. For electric infrastructure, the grants are mainly
17		administered in three broad categories: improving grid resilience, building smart
18		grids, and pursuing grid innovation.
19		
20	Q94.	Did the Company seek grant funding to invest in the distribution system in
21		2023?
22	A94.	Yes. In 2023, the Company applied for two direct grants to improve the distribution
23		system: Section 40101(c) - Grid Resilience and Section 40107 - Smart Grid. The
24		company also applied for a grant from the Michigan Department of Environment,
25		Great Lakes, and Energy (EGLE), who is administering funds awarded through

Line No.

Section 40101(d) – Preventing Outages and Enhancing the Resilience of the
 Electric Grid. Additionally, the Company was a partner on an application for
 Section 40103(b) – Grid Innovation Program. This grant was led by the State of
 Michigan.

5

6 **Q95.** Were any of the Company's IIJA grant applications selected to be funded?

7 A95. Yes. The DOE (Department of Energy) selected the Company's Section 40107 – 8 Smart Grid application for investment in October 2023. This project will deploy 9 Adaptive Network Microgrids (ANM) on the distribution system in two 10 communities and is discussed in Witness Hartwick's testimony. The Company 11 received positive feedback on its Section 40101(c) – Grid Resilience grant from the 12 DOE on the application, although was not selected. The Company is currently 13 waiting to hear the outcome for its Section 40101 (d) – Preventing Outages and 14 Enhancing the Resilience of the Electric Grid application filed on November 17th, 15 2023. DTE Electric expects a response from EGLE in the first half of 2024.

16

Q96. Will the Company continue to seek additional IIJA grant funding to invest in the distribution system in 2024?

A96. Yes. The Company is currently pursuing the second round of funding for Section
40101 (c) – Grid Resilience, incorporating he feedback from the DOE on project
scope and strategic alignment. The Company filed a concept paper on January 12,
2024 and will continue to update our IIJA grant planning as requested with reports
filed in U-21227.

Line No.

1

2

Q97. What are the objectives and details of the 40101(d) Preventing Outages and Enhancing the Resilience of the Electric Grid grant?

3 A97. Unlike the two grants (Section 40101c and Section 40107), this grant is an indirect 4 grant for which the Company cannot directly apply. Instead, EGLE applied for 5 DOE funding with the support of the MPSC. EGLE was awarded the grant on June 6 30, 2023 and the Request for Proposal (RFP) was posted on EGLE's website on 7 October 3, 2023. The objectives of this grant are similar to the 40101(c) grant, with 8 a focus on improving energy resilience and investing in modernized grid 9 infrastructure, and are restricted to large utilities applicants. Overall, EGLE intends 10 to award approximately \$8 million in funding between the two largest utilities in 11 the state of Michigan (DTE Electric and Consumers Energy). The Company filed 12 an application on November 17, 2023. The Company's grant proposal is to support 13 activities that will harden and modernize electric services for residential customers 14 in Detroit and Highland Park with the impact of reducing electrical service outages 15 during storm for disadvantaged communities. These outages can have significant economic impact due to loss of food or medicine, and cost of temporary shelter. 16 17 The proposal will investigate the most viable option to scale up a program to harden 18 electric service lines within the Company's service territory. Amongst the proposed 19 options for hardening services are (1) undergrounding overhead services, and (2) 20 replacing overhead services and tree trimming away from services. Additionally, 21 newly hardened residential services will be brought up to the Company's current 22 standard and will be capable of supporting future electrification.

23

Q98. Is the Company requesting funding in this rate case for investments or
expenses that may be partially covered by any of the grants discussed above?

Line	
No.	

1	A98.	Yes. The investment beyond the grant funding needed for the Section 40107 - Smart
2		Grid award is covered in the Adaptive Networked Microgrid section of Witness
3		Hartwick's testimony. The Company is not seeking funding for the other two grants
4		that are still being pursued in this rate case.
5		
6	Q99.	If the Company is successful at obtaining any of the grants discussed above
7		but not yet awarded, what will the Company's financial obligation be?
8	A99.	For the grants the Company is actively pursuing, a 1:1 funding match of federal
9		funds will be required. For example, in the 40101(c) grant application, if DOE
10		awards \$100 million of funding, DTE would need to contribute a minimum of \$100
11		million in matching funds. DTE Electric customers would receive system
12		improvements through the federal grants without having to fund the full investment
13		in the project(s) through electric rates. Because this case does not include any
14		requested investment for DTE Electric's match, it is expected that the cost recovery
15		for the Company's match amounts would be requested in future rate cases.
16		
17	Q100.	What happens if the grant requires that the Company provide matching
18		funding for a grant project before it can be presented for approval in a future
19		rate case?
20	A100.	The Company will notify the Commission through the ongoing docket on IIJA
21		grants (U-21227) and discuss needed adjustments to the capital plan and funding
22		allocations.
23		
24	<u>Part X</u>	<u> XI: Environmental Justice</u>

25 Q101. How does the Company define environmental justice (EJ)?

1	A101.	The Company defines EJ in the context of the State of Michigan's definition of
2		environmental justice as "the equitable treatment and meaningful involvement of
3		all people, regardless of race, color, national origin, ability, or income in the
4		development and application of laws, regulations, and policies that affect the
5		environment, as well as the places people live, work, play, worship, and learn."8
6		
7	Q102.	How did DTE Electric incorporate EJ in grid planning as described in the 2023
8		DGP?
9	A102.	Building on the 2021 DGP, the Company developed three key EJ objectives for the
10		2023 DGP; (1) incorporate EJ considerations in investment decisions by including
11		an EJ component in the Global Prioritization Model (GPM), (2) improve system
12		performance for vulnerable communities experiencing poor reliability through our
13		investment programs, and (3) provide support to vulnerable customers experiencing
14		outages during storms through community outreach efforts.
15		
16	Q103.	Does the Company continue to leverage the State of Michigan MiEJScreen tool
17		for environmental justice data and the identification of vulnerable
18		communities?
19	A103.	Yes. DO continues to use the MiEJScreen Tool for its EJ data in analyzing
20		investment impacts on disadvantaged customers and communities. EGLE released
21		the draft version of the MiEJScreen tool in March of 2022, following extensive
22		stakeholder involvement including a public comment process. ⁹ This tool combines
23		environmental conditions and population characteristics to highlight, by census

⁸ State of Michigan, Department of Environment, Great Lakes, and Energy,

https://www.michigan.gov/egle/public/learn/environmental-justice, accessed January 23, 2024.
 ⁹ MiEJScreen: Environmental Justice Screening Tool (DRAFT) (michigan.gov) available at https://www.michigan.gov/egle/maps-data/miejscreen?adlt=strict

<u>No.</u>	
1	tract, where the most vulnerable communities in Michigan are located. EGLE does
2	not explicitly define the threshold for which communities are vulnerable and which
3	ones are not vulnerable. A final MiEJScreen tool has not been released.
4	
5	Q104. How did DTE Electric Distribution Operations define a vulnerable community
6	for use with the draft MiEJScreen Tool?
7	A104. An 80% threshold definition was adopted for vulnerable communities using the
8	draft MiEJScreen Tool score, consistent with the U.S. EPA approach. ¹⁰ Following
9	this approach, census tracts with a MiEJScreen composite score at or above the 80^{th}
10	percentile are considered vulnerable communities for the purpose of this testimony
11	and associated analysis. The draft MiEJScreen composite score is calculated using
12	categories and indicators for environmental and population data as shown in Figure
13	11 below. On November 18, 2022 the Commission directed its Energy
14	Affordability and Accessibility Collaborative to address definitions of terms such
15	as environmental justice, grid equity, and energy justice (Case No. U-20836, pp
16	462-463).

Line

¹⁰ 80th percentile, EPA, https://www.epa.gov/ejscreen/frequent-questions-about-ejscreen#q5, accessed January 24, 2024.



1



Figure 11 MiEJScreen Overall Score Calculation

- Q105. Is the Company able to group reliability statistics by geographic area (i.e.,
 census tracts and zip codes) and align to scores from the draft MiEJScreen
 Tool?
- 6 A105. Yes. DTE Electric tracks reliability statistics by customer, which are then rolled up 7 to a circuit and substation. However, circuits often cross more than one census tract 8 or zip code. DTE Electric has matched residential meters to the census tracts 9 defined by the U.S. Census Bureau. Commercial properties are not surveyed as part 10 of the U.S. Census, and therefore, their addresses and associated meters are not 11 assigned to a census tract for the purposes of this analysis. There are some 12 residential meters, due to ongoing data cleaning work, that have yet to be placed in 13 a census tract/zip code. Currently, most meters have been successfully mapped to

Line No.

1

zip code and census tract. There are some small census tracts with a small number of customers where reliability statistics may be abnormally high or low due to small sample size.

4

3

2

5

6

Q106. Using available data, is the Company able to provide a geographic representation of 2023 electric reliability data by census tracts?

7 A106. Yes. Using the meters that are matched to census tracts, DTE Electric developed 8 reliability data for SAIFI and SAIDI by census tract and grouped the data into DTE 9 Electric reliability quartiles, with first quartile customers (shown below in green) 10 experiencing the best reliability and fourth quartile customers (shown below in red) 11 experiencing the worst reliability. Looking specifically at outage frequency, first 12 quartile reliability customers have a 2023 All-Weather SAIFI performance fewer 13 than 0.81 interruptions, second quartile customers range between 0.81 and 1.42 14 interruptions, third quartile customers are between 1.42 and 2.31 interruptions, and 15 fourth quartile customers have performance greater than 2.31 interruptions. 16 Looking at outage duration, first quartile reliability customers have a 2023 All-17 Weather SAIDI performance less than 331 minutes, second quartile customers range between 331 and 957 minutes, third quartile customers are between 957 18 19 minutes and 2,140 minutes, and fourth quartile customers have experienced outage 20 duration above 2,140 minutes. As discussed in Part I above, for 2023, a key impact 21 on All-Weather SAIDI was the single large ice/snow storm in February, 2023, 22 which significantly impacted both SAIDI and SAIFI reliability metrics. Maps for 23 SAIFI and SAIDI by census tract are included in **Figure 12 to Figure 15**.





Line





Line <u>No.</u>

1 Figure 15 2023 All Weather SAIDI by Census Tract for DTE Electric (Metro Detroit Area)

2

Line <u>No.</u>



1 Q107. Are all census tracts equal in geographic size and population?

2 A107. No. Census tracts vary in geographic size and population. According to the U.S. 3 Census Bureau, census tracts generally have a population size between 1,200 and 8,000 people, with an optimum size of 4,000 people.¹¹ In addition, the geographical 4 5 size of the tract does not represent how many people are in it. In some areas there 6 are large tracts (both first and fourth quartile) that have fewer customers in them, 7 compared to much smaller sized tracts in more dense urban areas. When the 8 reliability data is looked at in a map, as shown above, the lightly populated, 9 geographically large census tracts can visually skew the true reliability impact on 10 customers.

11

Q108. How many vulnerable census tracks are there in DTE Electric's service territory?

A108. In the DTE Electric service territory, there are 483 census tracts that fall into the
range of having a composite draft MiEJScreen score at or above 80th percentile.
These 483 census tracts represent 29% of the total census tracts in DTE Electric's
service area and account for approximately 550,000 residential customers.¹²
Additionally, these tracts include a total of 1,032 circuits out of DTE Electric's
3,273 distribution circuits (32% of total circuits) and contain 8,289 circuit miles
compared to 41,905 total distribution circuit miles (20% of total distribution miles).

21

Q109. What was the Commission's direction in Case No. U-21297 regarding more in depth EJ analysis?

¹¹ US Census Bureau, Glossary, available at <u>Glossary (census.gov)</u>, https://www.census.gov/programssurveys/geography/about/glossary.html?adlt=strict#par_textimage_13 accessed January 14, 2023. ¹² There are a total of 1,643 census tracts in DTE Electric's service territory.

1	A109.	The Commission stated in its order that future analysis of the MiEJScreen data
2		should be segmented in 5% gradations. As stated on page 93 of the U-21297 order:
3		"The Staff recommends, and the Commission agrees, that these gradations should
4		be defined initially as 0% to <5%, 5% to <10%, in 5% gradations up to 95%-100%
5		of the MiEJScreen composite score".
6		
7	Q110.	Has the Company performed analysis with 5% gradations of the MiEJScreen
8		relative to reliability performance?
9	A110.	Yes. The reliability performance in years 2020 through 2023, for SAIDI and SAIFI
10		metrics excluding MEDs and All-Weather compared to the systemwide levels are
11		shown in Tables 10-13.

<u>No.</u>

1

2

3

Table 10 All Weather SAIFI Reliability Performance of Census Tracts (MiEJ score of 0% to 100%) Versus System Average

Census Tract EJ %	C-4	2020	2021	2022	2023
Group	Category	SAIFI	SAIFI	SAIFI	SAIFI
0 to 5	AW	3.12	2.88	2.37	3.01
>5 to 10	AW	2.46	2.47	1.95	2.22
>10 to 15	AW	1.68	2.29	1.94	1.97
>15 to 20	AW	2.13	2.00	1.49	2.02
>20 to 25	AW	1.55	2.29	1.56	2.15
>25 to 30	AW	1.47	2.01	1.43	1.99
>30 to 35	AW	1.26	1.96	1.49	1.93
>35 to 40	AW	1.32	1.72	1.31	2.21
>40 to 45	AW	1.08	1.50	1.12	1.86
>45 to 50	AW	1.42	1.58	1.17	1.64
>50 to 55	AW	1.25	1.53	1.16	1.68
>55 to 60	AW	1.10	1.39	1.37	1.52
>60 to 65	AW	1.18	1.29	0.96	1.51
>65 to 70	AW	1.15	1.48	1.18	1.90
>70 to 75	AW	1.29	1.58	1.13	1.58
>75 to 80	AW	1.20	1.50	1.08	1.71
>80 to 85	AW	1.23	1.56	1.18	1.47
>85 to 90	AW	1.11	1.14	1.12	1.54
>90 to 95	AW	1.04	1.33	1.03	1.52
>95 to 100	AW	0.83	1.19	1.15	1.49
No EJ Score	AW	0.83	0.92	1.01	1.27
Sytem Average	AW	1.29	1.58	1.25	1.72

Over performing system average

Under performing system average

System average

Line

Table 11Excluding MEDs SAIFI Reliability Performance of CensusTracts (MiEJ score of 0% to 100%) Versus System Average

Line <u>No.</u>

2

1

3

Census Tract EJ %	C-4	2020	2021	2022	2023
Group	Category	SAIFI	SAIFI	SAIFI	SAIFI
0 to 5	Ex-MED	2.36	1.84	1.94	1.56
>5 to 10	Ex-MED	1.71	1.35	1.54	1.27
>10 to 15	Ex-MED	1.17	1.47	1.55	1.01
>15 to 20	Ex-MED	1.57	1.15	1.25	1.17
>20 to 25	Ex-MED	1.15	1.42	1.33	1.15
>25 to 30	Ex-MED	1.12	1.16	1.17	1.13
>30 to 35	Ex-MED	0.97	1.06	1.16	0.88
>35 to 40	Ex-MED	1.02	0.99	1.00	1.10
>40 to 45	Ex-MED	0.91	0.85	0.88	0.81
>45 to 50	Ex-MED	1.14	0.94	0.98	0.75
>50 to 55	Ex-MED	1.07	0.85	0.91	0.82
>55 to 60	Ex-MED	0.88	0.84	1.10	0.77
>60 to 65	Ex-MED	0.95	0.76	0.75	0.75
>65 to 70	Ex-MED	0.98	0.84	0.98	0.93
>70 to 75	Ex-MED	1.07	0.95	0.90	0.75
>75 to 80	Ex-MED	1.01	0.93	0.85	0.87
>80 to 85	Ex-MED	0.93	0.92	0.92	0.70
>85 to 90	Ex-MED	0.85	0.68	0.78	0.71
>90 to 95	Ex-MED	0.80	0.78	0.76	0.71
>95 to 100	Ex-MED	0.65	0.64	0.77	0.78
No EJ Score	Ex-MED	0.71	0.58	0.86	0.60
Sytem Average	Ex-MED	1.01	0.92	0.98	0.86

Over performing system average

Under performing system average

System average

Table 12All Weather SAIDI ReliabilityPerformance of Census Tracts(MiEJ score of 0% to 100%)Versus System Average

2 3

1

Census Tract EJ % Group	Category	2020 SAIDI	2021 SAIDI	2022 SAIDI	2023 SAIDI
0 to 5	AW	978	2656	1262	3278
>5 to 10	AW	863	1657	909	1604
>10 to 15	AW	384	930	916	1618
>15 to 20	AW	605	1096	576	1184
>20 to 25	AW	510	1291	527	1937
>25 to 30	AW	414	1174	611	1521
>30 to 35	AW	306	1211	692	1748
>35 to 40	AW	351	1027	666	1889
>40 to 45	AW	222	940	433	1834
>45 to 50	AW	330	999	426	1584
>50 to 55	AW	292	946	458	1482
>55 to 60	AW	300	775	531	1268
>60 to 65	AW	297	764	473	1363
>65 to 70	AW	228	816	416	1745
>70 to 75	AW	336	844	472	1515
>75 to 80	AW	325	820	389	1509
>80 to 85	AW	480	978	556	1419
>85 to 90	AW	351	705	735	1699
>90 to 95	AW	329	840	749	1675
>95 to 100	AW	266	804	923	1133
No EJ Score	AW	203	355	300	778
Sytem Average	AW	352	927	584	1542

Over performing system average

Under performing system average

System average

Table 13 Excluding MEDs SAIDI Reliability Performance of Census

Tracts (MiEJ score of 0% to 100%) Versus System Average

3

Census Tract EJ % Group	Category	2020 SAIDI	2021 SAIDI	2022 SAIDI	2023 SAIDI
0 to 5	Ex-MED	342	398	487	373
>5 to 10	Ex-MED	291	213	296	320
>10 to 15	Ex-MED	153	209	274	236
>15 to 20	Ex-MED	218	150	238	212
>20 to 25	Ex-MED	168	248	182	239
>25 to 30	Ex-MED	176	177	188	217
>30 to 35	Ex-MED	123	136	152	158
>35 to 40	Ex-MED	147	138	146	173
>40 to 45	Ex-MED	108	111	103	152
>45 to 50	Ex-MED	154	149	131	135
>50 to 55	Ex-MED	144	124	128	136
>55 to 60	Ex-MED	102	112	150	155
>60 to 65	Ex-MED	132	114	138	139
>65 to 70	Ex-MED	101	131	120	138
>70 to 75	Ex-MED	154	122	115	119
>75 to 80	Ex-MED	124	128	106	145
>80 to 85	Ex-MED	158	147	156	149
>85 to 90	Ex-MED	123	111	123	130
>90 to 95	Ex-MED	136	112	115	129
>95 to 100	Ex-MED	118	94	129	142
No EJ Score	Ex-MED	97	68	98	80
Sytem Average	Ex-MED	142	136	146	157



4

5 Q111. What is the distribution of residential customers in each EJ Gradation?

- 6 A111. The distribution of residential customer in each gradation is highlighted in **Table**
- 7

14 below. Approximately 27% of our residential customers fall into the 80% to

8 100% gradations.

Line <u>No.</u>

2

1

	Number of	%of
Census Tract EJ% Group	Residental	Residental
	Customers	Customers
0-5%	7,569	<1%
5-10%	39,705	2%
10-15%	62,143	3%
15-20%	43,497	2%
20-25%	59,888	3%
25-30%	88,033	4%
30-35%	100,487	5%
35-40%	99,318	5%
40-45%	102,680	5%
45-50%	114,416	6%
50-55%	120,730	6%
55-60%	135,206	7%
60-65%	124,240	6%
65-70%	126,463	6%
70-75%	100,278	5%
75-80%	146,161	7%
80-85%	127,270	6%
85-90%	162,145	8%
90-95%	143,144	7%
95-100%	114,874	6%
Unmapped/Unscored*	38,383	2%
Total Residential Customers	2 056 630	100%

Table 14 Residential Customers by EJ Gradations

2

3 Q112. How does the reliability performance of census tracts that have been identified 4 as vulnerable communities compare with the rest of the DTE Electric system? A112. As noted in **Table 10** and **Table 12**, vulnerable customers in the 80th percentile and 5 6 above see better reliability than the system average in SAIFI and SAIDI in both 7 All-Weather and Non-MED. All-Weather and Non-MEDs SAIFI is lower than the 8 system average in every year and every vulnerable community gradient. For Non-9 MED SAIDI, the vast majority of years and vulnerable community gradients are 10 better than the system average. All-Weather shows more year-gradient 11 combinations above the system average but even for this metric, the majority of 12 instances are better than the system average.
1 **Q113.** Has the company evaluated how its investment programs are reaching 2 vulnerable communities to improve electric distribution infrastructure and 3 reliability performance? 4 A113. Yes. The Company has evaluated some of its largest distribution investment 5 projects and programs, 4.8kV Hardening, 4.8kV Conversion, and tree trim, with 6 respect to if the investment was made in a vulnerable area. 7 8 **Q114.** What are the results of the investment analysis related to vulnerable 9 communities? 10 A114. The results are summarized in **Table 15** below and indicate that the Company's 11 investments are supporting vulnerable customers and communities in southeast 12 Michigan, including the City of Detroit. This analysis is based on the draft 13 MiEJScreen Tool census tract data and Company investment data on the circuits 14 addressed by the following three programs over the timeframe 2018-2023: 4.8kV 15 Hardening, Tree Trimming and Conversions. For each of these investment 16 programs, **Table 15** shows total investment dollars by program, total program 17 investment in vulnerable communities, and percentage of program investment in vulnerable communities. For example, of the nearly half billion dollars of 18 19 investment in the 4.8kV Hardening program since 2018, 85% of work performed 20 under the hardening program occurred in vulnerable communities. As discussed by 21 Witness Elliott Andahazy, the hardening program has resulted in documented 22 reliability and safety improvements, including reduction in the frequency and 23 duration of outages and fewer downed wires, through the program's clearing of 24 right of way, equipment upgrades, and removal of arc wire.

Table 15 2018 to 2023 Investment in Vulnerable Communities (Census Tracts with MiEJ Score of 80% to 100%)

Total Investment by % Of Investment in Investment Program **Total Investment by** Program in Vulnerable Vulnerable Census (2018 - 2023)Census Tracts (\$M) Program (\$M) Tracts \$396 Conversion \$255 64% 4.8kV Hardening \$494 \$418 85% Tree Trim \$962 \$242 25%

4

5 Q115. How will these distribution investment programs address vulnerable 6 communities in 2024-2025 based on the Company's planned execution of 7 investments in this case?

8 A115. For the purpose of this analysis, the Company focused on three of the largest 9 strategic investment programs, Witness Deol, Witness Elliott Andahazy, and 10 Witness Steudle address the Company's planned investments for 2024 and 2025 for conversions, hardening, and tree trimming, respectively. Table 16 below 11 12 summarizes total investment dollars by program, total program investment in 13 vulnerable communities, and percentage of program investment in vulnerable 14 communities in 2024-2025.

AJK-94

15

Line

1

2

3

No.

Table 162024-2025 Investment in Vulnerable Communities (CensusTracts with MiEJ Score of 80% to 100%)

3

1

2

Investment Program (2024-2025)	Total Investment by Program (\$M)	Total Investment by Program in Vulnerable Census Tracts (\$M)	% Of Investment in Vulnerable Census Tracts
Conversion	\$475	\$288	61%
4.8kV Hardening	\$205	\$185	90%
Tree Trim	\$285	\$81	28%

4

5 Q116. Is the Company also analyzing investments in 5% EJ gradations as directed 6 in the December 2023 order in Case No. U-21297? 7 A116. Yes. The Company analyzed investments pertaining to Hardening, Tree Trim, and 8 Conversion including City of Detroit Infrastructure (CODI) programs, to provide 9 information in EJ community gradations based on the MiEJScreen score as defined 10 in the December 2023 order. The gradations are defined as 0% to 5%, >5% to 10%, 11 in 5% gradations up to >95% - 100% of the MiEJScreen composite score, the same 12 as the reliability analysis above. Tables 17 to Table 22 below demonstrates the 13 Company's investment distribution for EJ gradations by year.

Line <u>No.</u>

1 2

Table 17Hardening Investments by EJ Gradations

EJ Gradations	2018 Investment (\$000)		2019 2020 Investment Investment (\$000) (\$000)		2021 Investment (\$000)		In	2022 Investment (\$000)		2023 Investment (\$000)		2024 Investment Forecast (\$000)		2025 Investment Forecast (\$000)	
0-5%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	1,710	\$	-	\$	-
5-10%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
10-15%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
15-20%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
20-25%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
25-30%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
30-35%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
35-40%	\$	-	\$	-	\$ -	\$	-	\$	1,955	\$	-	\$	-	\$	-
40-45%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
45-50%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
50-55%	\$	-	\$	-	\$ -	\$	6,284	\$	-	\$	-	\$	-	\$	-
55-60%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	211	\$	-
60-65%	\$	-	\$	-	\$ -	\$	1,669	\$	9,026	\$	-	\$	-	\$	-
65-70%	\$	-	\$	-	\$ -	\$	-	\$	-	\$	-	\$	-	\$	-
70-75%	\$	1,077	\$	2,300	\$ 1,821	\$	3,032	\$	2,747	\$	-	\$	-	\$	7,401
75-80%	\$	2,302	\$	-	\$ 868	\$	16,682	\$	1,691	\$	4,148	\$	2,177	\$	1,595
80-85%	\$	5,455	\$	12,499	\$ 2,343	\$	646	\$	8,354	\$	12,660	\$	-	\$	3,777
85-90%	\$	14,205	\$	18,366	\$ 24,086	\$	8,858	\$	22,658	\$	32,545	\$	7,681	\$	21,978
90-95%	\$	16,413	\$	13,456	\$ 15,495	\$	13,563	\$	39,625	\$	24,866	\$	20,547	\$	44,776
95-100%	\$	776	\$	1,644	\$ 9,505	\$	12,315	\$	65,540	\$	40,755	\$	45,717	\$	40,409
Unmapped/Unscored*	\$	95	\$	12	\$ 1,048	\$	2,313	\$	5,885	\$	10,326	\$	3,667	\$	5,063
Total Investment (\$)	\$	40,325	\$	48,278	\$ 55,165	\$	65,362	\$	157,482	\$	127,010	\$	80,000	\$	125,000

3

AJK-96

T	able 18	Perce	Percent of Hardening Investments by EJ Gradations										
EJ Gradations	2018 Investment (%)	2019 Investment (%)	2020 Investment (%)	2021 Investment (%)	2022 Investment (%)	2023 Investment (%)	2024 Investment Forecast (%)	2025 Investment Forecast (%)					
0-5%	0%	0%	0%	0%	0%	1%	0%	0%					
5-10%	0%	0%	0%	0%	0%	0%	0%	0%					
10-15%	0%	0%	0%	0%	0%	0%	0%	0%					
15-20%	0%	0%	0%	0%	0%	0%	0%	0%					
20-25%	0%	0%	0%	0%	0%	0%	0%	0%					
25-30%	0%	0%	0%	0%	0%	0%	0%	0%					
30-35%	0%	0%	0%	0%	0%	0%	0%	0%					
35-40%	0%	0%	0%	0%	1%	0%	0%	0%					
40-45%	0%	0%	0%	0%	0%	0%	0%	0%					
45-50%	0%	0%	0%	0%	0%	0%	0%	0%					
50-55%	0%	0%	0%	10%	0%	0%	0%	0%					
55-60%	0%	0%	0%	0%	0%	0%	0%	0%					
60-65%	0%	0%	0%	3%	6%	0%	0%	0%					
65-70%	0%	0%	0%	0%	0%	0%	0%	0%					
70-75%	3%	5%	3%	5%	2%	0%	0%	6%					
75-80%	6%	0%	2%	26%	1%	3%	3%	1%					
80-85%	14%	26%	4%	1%	5%	10%	0%	3%					
85-90%	35%	38%	44%	14%	14%	26%	10%	18%					
90-95%	41%	28%	28%	21%	25%	20%	26%	36%					
95-100%	2%	3%	17%	19%	42%	32%	57%	32%					
Unmapped/Unscored	0%	0%	2%	4%	4%	8%	5%	4%					
Total Investment (%)	100%	100%	100%	100%	100%	100%	100%	100%					

2

Table 19

Tree Trim Investments by EJ Gradations

EJ Gradations	Inv (2018 estment (\$000)	Inv	2019 vestment (\$000)	Inv	2020 vestment (\$000)	In	2021 vestment (\$000)	In	2022 vestment (\$000)	2023 Investment (\$000)		2024 Investment Forecast (\$000)		2025 Investment Forecast (\$000)	
0-5%	\$	553	\$	252	\$	948	\$	1,634	\$	3,055	\$	1,487	\$	501	\$	303
5-10%	\$	4,596	\$	4,355	\$	11,250	\$	9,290	\$	4,653	\$	9,113	\$	3,301	\$	494
10-15%	\$	7,087	\$	1,076	\$	9,756	\$	11,195	\$	12,626	\$	13,319	\$	5,131	\$	1,161
15-20%	\$	2,808	\$	2,407	\$	7,037	\$	7,118	\$	6,069	\$	8,227	\$	5,623	\$	5,258
20-25%	\$	2,809	\$	5,681	\$	8,683	\$	7,320	\$	11,946	\$	5,077	\$	11,032	\$	12,265
25-30%	\$	4,056	\$	3,714	\$	8,551	\$	15,421	\$	12,696	\$	8,208	\$	7,503	\$	5,232
30-35%	\$	3,008	\$	2,815	\$	14,158	\$	10,839	\$	16,395	\$	9,867	\$	5,498	\$	4,543
35-40%	\$	3,047	\$	5,011	\$	9,332	\$	7,666	\$	15,467	\$	8,204	\$	5,311	\$	8,483
40-45%	\$	3,415	\$	2,496	\$	4,657	\$	8,498	\$	13,595	\$	7,857	\$	3,986	\$	3,649
45-50%	\$	4,059	\$	6,039	\$	4,847	\$	7,315	\$	11,990	\$	11,789	\$	7,463	\$	5,331
50-55%	\$	2,204	\$	4,604	\$	4,730	\$	10,125	\$	13,127	\$	5,841	\$	6,768	\$	4,540
55-60%	\$	1,611	\$	4,281	\$	5,338	\$	6,987	\$	10,363	\$	6,555	\$	9,179	\$	5,565
60-65%	\$	1,746	\$	3,820	\$	5,864	\$	7,329	\$	9,856	\$	5,702	\$	3,664	\$	4,726
65-70%	\$	1,659	\$	2,560	\$	5,860	\$	4,182	\$	11,035	\$	4,402	\$	4,862	\$	7,786
70-75%	\$	1,028	\$	3,209	\$	4,676	\$	2,664	\$	4,782	\$	3,696	\$	5,259	\$	5,338
75-80%	\$	2,187	\$	3,831	\$	5,980	\$	5,654	\$	10,001	\$	5,855	\$	8,571	\$	9,488
80-85%	\$	4,758	\$	4,967	\$	3,119	\$	8,166	\$	15,094	\$	5,759	\$	8,316	\$	10,553
85-90%	\$	7,880	\$	23,046	\$	7,664	\$	6,750	\$	13,184	\$	8,647	\$	20,166	\$	5,072
90-95%	\$	7,856	\$	13,901	\$	14,559	\$	4,648	\$	16,324	\$	10,152	\$	16,101	\$	5,868
95-100%	\$	5,444	\$	14,573	\$	7,846	\$	8,734	\$	13,113	\$	15,055	\$	13,239	\$	981
Unmapped/Unscored*	\$	9,939	\$	14,193	\$	24,073	\$	10,699	\$	19,887	\$	22,648	\$	11,458	\$	15,819
Total Investment (%)	\$	81,752	\$	126,831	\$	168,926	\$	162,235	\$	245,260	\$	177,459	\$	162,930	\$	122,456

Table 20Percent of Tree Trim Investments by EJ Gradations

EJ Gradations	2018 Investment (%)	2019 Investment (%)	2020 Investment (%)	2021 Investment (%)	2022 Investment (%)	2023 Investment (%)	2024 Investment Forecast (%)	2025 Investment Forecast (%)
0-5%	1%	0%	1%	1%	1%	1%	0%	0%
5-10%	6%	3%	7%	6%	2%	5%	2%	0%
10-15%	9%	1%	6%	7%	5%	8%	3%	1%
15-20%	3%	2%	4%	4%	2%	5%	3%	4%
20-25%	3%	4%	5%	5%	5%	3%	7%	10%
25-30%	5%	3%	5%	10%	5%	5%	5%	4%
30-35%	4%	2%	8%	7%	7%	6%	3%	4%
35-40%	4%	4%	6%	5%	6%	5%	3%	7%
40-45%	4%	2%	3%	5%	6%	4%	2%	3%
45-50%	5%	5%	3%	5%	5%	7%	5%	4%
50-55%	3%	4%	3%	6%	5%	3%	4%	4%
55-60%	2%	3%	3%	4%	4%	4%	6%	5%
60-65%	2%	3%	3%	5%	4%	3%	2%	4%
65-70%	2%	2%	3%	3%	4%	2%	3%	6%
70-75%	1%	3%	3%	2%	2%	2%	3%	4%
75-80%	3%	3%	4%	3%	4%	3%	5%	8%
80-85%	6%	4%	2%	5%	6%	3%	5%	9%
85-90%	10%	18%	5%	4%	5%	5%	12%	4%
90-95%	10%	11%	9%	3%	7%	6%	10%	5%
95-100%	7%	11%	5%	5%	5%	8%	8%	1%
Unmapped/Unscored*	12%	11%	14%	7%	8%	13%	7%	13%
Total Investment (%)	100%	100%	100%	100%	100%	100%	100%	100%

т	
T	

Table 21

Conversion Investments by EJ Gradations

EJ Gradations	Inv	2018 /estment (\$000)	In	2019 vestment (\$000)	In	2020 vestment (\$000)	In	2021 vestment (\$000)	In	2022 vestment (\$000)	In	2023 vestment (\$000)	Inv F	2024 Vestment Forecast (\$000)	lnv F	2025 vestment orecast (\$000)
0-5%	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-	\$	-
5-10%	\$	-	\$	-	\$	-	\$	127	\$	51	\$	399	\$	2,079	\$	2,735
10-15%	\$	128	\$	583	\$	660	\$	464	\$	1,118	\$	439	\$	1,601	\$	2,788
15-20%	\$	203	\$	618	\$	665	\$	2,359	\$	5,468	\$	1,748	\$	5,341	\$	1,132
20-25%	\$	511	\$	1,142	\$	692	\$	2,423	\$	7,370	\$	3,787	\$	5,099	\$	5,971
25-30%	\$	201	\$	483	\$	324	\$	523	\$	480	\$	2,094	\$	6,093	\$	4,996
30-35%	\$	225	\$	811	\$	427	\$	3,753	\$	9,445	\$	3,464	\$	7,425	\$	13,410
35-40%	\$	339	\$	159	\$	112	\$	143	\$	329	\$	319	\$	484	\$	986
40-45%	\$	11	\$	66	\$	-	\$	16	\$	65	\$	235	\$	433	\$	1,824
45-50%	\$	60	\$	189	\$	14	\$	505	\$	4,188	\$	1,656	\$	1,617	\$	4,544
50-55%	\$	1,764	\$	784	\$	154	\$	380	\$	1,141	\$	887	\$	2,099	\$	5,312
55-60%	\$	82	\$	185	\$	50	\$	793	\$	2,362	\$	6,227	\$	9,902	\$	(27)
60-65%	\$	1,072	\$	413	\$	176	\$	340	\$	106	\$	497	\$	1,884	\$	6,280
65-70%	\$	877	\$	275	\$	58	\$	595	\$	1,101	\$	8,909	\$	16,676	\$	144
70-75%	\$	272	\$	75	\$	114	\$	1,001	\$	295	\$	833	\$	2,378	\$	2,818
75-80%	\$	2,313	\$	2,497	\$	3,125	\$	3,149	\$	4,188	\$	11,090	\$	21,576	\$	11,318
80-85%	\$	381	\$	187	\$	183	\$	816	\$	3,335	\$	11,149	\$	9,145	\$	15,499
85-90%	\$	1,440	\$	495	\$	297	\$	2,147	\$	4,319	\$	11,646	\$	9,212	\$	17,790
90-95%	\$	2,475	\$	1,102	\$	1,157	\$	4,732	\$	8,542	\$	18,081	\$	37,126	\$	35,191
95-100%	\$	11,423	\$	9,836	\$	15,814	\$	32,162	\$	44,649	\$	67,524	\$	73,157	\$	83,132
Unmapped/Unscored*	\$	1,653	\$	690	\$	437	\$	2,665	\$	5,930	\$	11,126	\$	15,237	\$	30,475
Total Investment (\$)	\$	25,429	\$	20,591	\$	24,460	\$	59,092	\$	104,483	\$	162,109	\$	228,563	\$	246,318

3

Table 22Perce

Percent of Conversion Investments by EJ Gradations

EJ Gradations	2018 Investment (%)	2019 Investment (%)	2020 Investment (%)	2021 Investment (%)	2022 Investment (%)	2023 Investment (%)	2024 Investment Forecast (%)	2025 Investment Forecast (%)
0-5%	0%	0%	0%	0%	0%	0%	0%	0%
5-10%	0%	0%	0%	0%	0%	0%	1%	1%
10-15%	1%	3%	3%	1%	1%	0%	1%	1%
15-20%	1%	3%	3%	4%	5%	1%	2%	0%
20-25%	2%	6%	3%	4%	7%	2%	2%	2%
25-30%	1%	2%	1%	1%	0%	1%	3%	2%
30-35%	1%	4%	2%	6%	9%	2%	3%	5%
35-40%	1%	1%	0%	0%	0%	0%	0%	0%
40-45%	0%	0%	0%	0%	0%	0%	0%	1%
45-50%	0%	1%	0%	1%	4%	1%	1%	2%
50-55%	7%	4%	1%	1%	1%	1%	1%	2%
55-60%	0%	1%	0%	1%	2%	4%	4%	0%
60-65%	4%	2%	1%	1%	0%	0%	1%	3%
65-70%	3%	1%	0%	1%	1%	5%	7%	0%
70-75%	1%	0%	0%	2%	0%	1%	1%	1%
75-80%	9%	12%	13%	5%	4%	7%	9%	5%
80-85%	1%	1%	1%	1%	3%	7%	4%	6%
85-90%	6%	2%	1%	4%	4%	7%	4%	7%
90-95%	10%	5%	5%	8%	8%	11%	16%	14%
95-100%	45%	48%	65%	54%	43%	42%	32%	34%
Unmapped/Unscored	6%	3%	2%	5%	6%	7%	7%	12%
Total Investment (%)	100%	100%	100%	100%	100%	100%	100%	100%

1 Q117. Is the investment in vulnerable communities reflective of DTE Electric's 2 ongoing efforts to improve reliability in vulnerable communities?

3 A117. Yes. As highlighted in Table 15, 85%, 64%, and 25 % of the investment in the 4 4.8kV Hardening, 4.8kV Conversion, and Tree Trim programs for the time period 5 2018 to 2023 was made in vulnerable communities. Significant investment is 6 expected to continue in these vulnerable communities in future years 2024-2025 as 7 illustrated in Table 16 including 90%, 61%, and 28% of the total investment in the 8 Hardening, Conversion, and Tree Trim. Both the Company's historical and future 9 projected investment, is consistent with DTE Electric's commitment to improving 10 reliability in vulnerable communities.

11

Q118. Has the Company incorporated Environmental Justice considerations into the GPM for future Distribution Operations investments, including investments in this case?

A118. Yes. As described in the DGP section of testimony above, the Company has
 included EJ scoring from the MiEJScreen tool in the GPM calculation. Projects in
 more vulnerable areas will receive a higher score and have a better chance of being
 selected for investment.

19

20 Q119. How is the Company addressing the circuits with the worst reliability that 21 have also been identified as serving vulnerable customers?

A119. The Company has either already invested in recent improvements or has plans to
 improve performance of the 4th quartile worst performing circuits that are in
 vulnerable communities through our investment programs, Tree Trim, PTMM,
 Conversion, Customer Excellence, and 4.8kV Hardening. The Company has

1 identified 191 distribution circuits in vulnerable communities which fall in the 2 fourth quartile for reliability performance based on a five-year historic average. 3 Approximately 55% of the fourth quartile circuits have recently had reliability work 4 performed, while 45% of the circuits are planned to be addressed in 2024-2026 5 investment programs. 6 7 Q120. What are the Company's future plans to address EJ in the context of 8 distribution planning and operations? 9 A120. DTE Electric plans to continue to analyze reliability and investment data using the 10 draft MiEJScreen tool, including the consideration of any updates based on the 11 state's release of the tool's final version. The company intends continue to include 12 EJ considerations in investment decisions for all areas, as well as continue to 13 address poor performing circuits in vulnerable communities. Finally, DTE Electric 14 will continue to look for potential IIJA grant opportunities that invest in infrastructure-related programs to benefit vulnerable communities in alignment 15 with the Biden Administration's Justice40 initiative.¹³ 16 17 18 **Part XII: Municipal Project Coordination** 19 Q121. What did the MPSC Case No. U-21297 order the Company to do with regard 20 to municipal project coordination?

21 A121. The Commission stated on page 375 that:

¹³ The White House, Justice40: A Whole-of-Government Initiative, available at: <u>Justice40 Initiative</u> <u>Environmental Justice | The White House</u>,

https://www.whitehouse.gov/environmentaljustice/justice40/?adlt=strict accessed January 14, 2023.

1 "In its next general rate case, DTE Electric Company shall demonstrate its efforts 2 to improve communication and coordination with local governments regarding 3 construction activities, as described in this order" (page 375). 4 5 Q122. How does the Company currently coordinate projects with municipalities? 6 A122. When DTE is ready to move forward with a capital project the Company 7 coordinates with the appropriate municipal personnel to set up a briefing meeting 8 to discuss the details of the project, benefits, and collaboration opportunities of the 9 work. We request that the municipality provide any potential conflicts to the project 10 before permits are sought. This provides both the municipality and DTE some 11 assurance that the planned project does not conflict with a municipal project, 12 whether it's in the conceptual or planned stage. 13 14 Once the project is in progress, periodic updates are provided to the municipality 15 and meetings may be held work through any questions that arise. 16 17 Q123. Does the Company have ongoing efforts to improve communication and 18 coordination with municipalities? 19 A123. Yes. The company is working to improve the frequency of updates to municipalities 20 and garnering feedback to determine their preferred methods to receiving these 21 updates. In addition, we are working with county road commission to support their 22 projects, and to coordinate where possible to avoid conflicts. 23 24 **Q124.** Does this complete your direct testimony? 25 A124. Yes, it does.

AJK-102

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

ROBERT J. LEE

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF ROBERT J. LEE

Line <u>No.</u>

1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Robert J. Lee (he/him/his) and my business address is One Energy
3		Plaza, Detroit, Michigan 48226-1279. I am employed by DTE Energy Corporate
4		Services, LLC within DTE's Environmental Management and Safety team and I
5		am currently the Manager of Environmental Strategy for the Company.
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric or Company).
9		
10	Q3.	What is your educational background?
11	A3.	I received a Bachelor of Science Degree in Geology in 1992 and a Master of
12		Science Degree in Environmental Geochemistry in 1994 from the University of
13		Wales.
14		
15	Q4.	What is your work experience?
16	A4.	Since completing my formal education, I have practiced continuously in the
17		environmental field with a focus on State and Federal programs mostly in
18		Michigan. My past and current responsibilities include management of several
19		environmental program areas, including Effluent Limitations Guidelines (ELG)
20		and water permit management, Coal Combustion Residual (CCR) program
21		management, remediation program management, State and Federal construction
22		permit programs, and coal plant retirement. Additionally, I have State and Federal
23		level experience supporting and developing legislative and rule-making initiatives.

Line No.

> 1 From 1994 to 2004, I worked in environmental consulting and environmental 2 engineering. I managed a wide variety of projects for various industries focusing 3 on remediation project management, solid waste compliance, coal ash 4 management, National Pollutant Discharge Elimination System (NPDES) permit 5 management and obtaining and managing State and Federal permits. I also 6 performed complex multi-site due diligence and liability management. I worked 7 for a variety of industries including utility, cement production, and landfill industry sectors. 8

9

10 Q5. What are your current duties and responsibilities?

11 A5. I have worked for DTE Energy for 19 years. I am currently the Manager of 12 Environmental Strategy, and my focus is on complex and strategic environmental 13 initiatives that are critical to DTE. In this role I focus on environmental strategy, 14 policy, and regulatory development and am responsible for key environmental 15 programs at the State and Federal level that are critical to the Company's 16 compliance, strategic direction, and generation strategy. I am responsible for the 17 Company's strategy and approach for compliance with the CCR and ELG 18 programs, coal plant retirement, asset reuse, waste program, and renewable energy 19 development.

20

21 Q6. Have you previously sponsored testimony before the Michigan Public Service 22 Commission (MPSC or Commission)?

- 23 A6. Yes. I have sponsored testimony in the following cases:
- 24 U-16999 2012 DTE Gas General Rate Case
- 25 U-17999 2015 DTE Gas General Rate Case

Line
No.

1	U-20642	2019 DTE Gas General Rate Case
2	U-20940	2021 DTE Gas General Rate Case
3	U-20836	2022 DTE Electric General Rate Case
4	U-21297	2023 DTE Electric General Rate Case

1	<u>Purp</u>	ose of Testimony
2	Q7.	What is the purpose of your testimony?
3	A7.	I will describe the status of two significant Environmental Protection Agency
4		(EPA) regulations, the Steam Electric Effluent Limitation Guidelines (ELG) Rule
5		and the Coal Combustion Residuals (CCR) Rule, which impact the Company's
6		coal-fired power plants. I will address the following additional topics in my
7		testimony:
8		1) I will explain the ELG Rule, recent revisions, and compliance strategies in
9		support of Witness Guillaumin's discussion of ELG-related capital
10		expenditures.
11		2) I will describe how the EPA's CCR Rule affects the Company's coal-fired units
12		in support of Witness Guillaumin's discussion of CCR-related capital
13		expenditures.
14		
15	Q8.	Are you sponsoring any exhibits in this proceeding?
16	A8.	No.
17		
18	Q9.	Is the Company requesting recovery of capital expenditures associated with
19		compliance with EPA regulations?
20	A9.	Yes. As shown in Company Witness Guillaumin's Exhibit A-12, Schedule B5.1,
21		the Company is in the process of developing and implementing several ELG and
22		CCR compliance projects necessitating capital expenditures, including:
23		• Monroe Dry Fly Ash Conversion (ELG)
24		Monroe Bottom Ash Conversion (ELG)
25		• Monroe FGD Wastewater (ELG)

Line No.		R. J. LEE U-21534
1		• Sibley Quarry Landfill Modification (CCR)
2		• Sibley Quarry Conveyor Installation (CCR)
3		• Sibley Quarry Infrastructure Modification (CCR)
4		• Sibley Quarry Landfill Dewatering and Discharging Line (CCR)
5		• Monroe Bottom Ash Basin Closure (CCR)
6		• St. Clair Bottom Ash Basin Closure (CCR)
7		• Belle River Bottom Ash Basin Modification (CCR)
8		• Monroe Fly Ash Basin Closure (CCR)
9		
10	<u>Efflue</u>	ent Limit Guidelines
11	Q10.	What are the Effluent Limit Guidelines (ELGs)?
12	A10.	Effluent Limit Guidelines are national wastewater discharge standards that are
13		developed by the EPA on an industry-by-industry basis. These are technology-
14		based regulations and are intended to represent the greatest pollutant reductions that
15		are economically achievable for an industry. EPA promulgated the Steam Electric
16		Power Generating ELGs in 1974, and amended the regulations in 1977, 1978, 1980,
17		1982, 2015 and 2020. The regulations cover wastewater discharges from steam
18		electric power plants operated by utilities. The Steam Electric ELGs are
19		incorporated into NPDES permits issued by the Michigan Department of
20		Environment, Great Lakes & Energy (EGLE).
21		
22	Q11.	Can you describe the recent revisions to EPA's Steam Electric Power
23		Generating (SEPG) ELGs?
24	A11.	Yes. The EPA's SEPG ELGs regulate how electric utilities must manage certain
25		wastewaters. On October 13, 2020, the EPA finalized the ELG Reconsideration

RJL-5

1 Rule which revised some requirements from the 2015 version of the ELG rule. The 2 Reconsideration Rule revised requirements for two specific waste streams 3 produced by steam electric power plants: flue gas desulfurization (FGD) wastewater and bottom ash transport water (BATW). The Reconsideration Rule 4 5 provides additional compliance opportunities by finalizing subcategories, such as 6 for the cessation of coal burning activities. Therefore, steam electric plants can 7 comply with ELG requirements for FGD and BATW by either meeting 8 requirements to discharge or meeting requirements of a subcategory.

9

10 Q12. When must DTE Electric comply with revised ELGs?

11 A12. The Reconsideration Rule provides opportunities for DTE Electric to evaluate 12 existing ELG compliance strategies and make any necessary adjustments to ensure 13 full compliance with the ELGs in a more cost-effective manner than prior ELG 14 rules. The EPA set the applicability dates for BATW and FGD wastewater retrofits 15 to be "as soon as possible" beginning October 13, 2021, and no later than December 16 31, 2025. For facilities pursuing the FGD wastewater Voluntary Incentives 17 Program (VIP), detailed further below, compliance shall be achieved no later than 18 December 31, 2028. Compliance schedules for individual facilities and individual 19 waste streams are determined through issuance of new NPDES permits by EGLE. 20 For Monroe Power Plant, the NPDES permit contains compliance deadlines of 21 December 31, 2023, for fly ash transport water, December 31, 2025, for BATW 22 and December 31, 2028, for FGD. For Belle River Power Plant, the NPDES permit 23 contains a compliance deadline of December 31, 2028, for BATW. 24

25 Q13. What are DTE Electric's options for ELG compliance?

1	A13.	The Company has two options to achieve compliance under the Reconsideration
2		Rule for BATW and FGD wastewater. The first option is to design and engineer
3		new technologies that are compliant with the ELG requirements for BATW and
4		FGD wastewater. The second option is to pursue a compliance subcategory for
5		BATW and FGD wastewater that EPA established within the Reconsideration
6		Rule.
7		
8	Q14.	What are the compliance subcategories established within the Reconsideration
9		Rule?
10	A14.	One compliance subcategory allows companies to attain compliance with the ELGs
11		for both BATW and FGD wastewater by ceasing coal burning activities, which
12		includes retiring coal-fired unit(s) or converting unit(s) to other fuels. If companies
13		certify that unit(s) would retire the use of coal (or refuel), they can continue to
14		operate those units until the unit's specified coal retirement date, which is required
15		to be before December 31, 2028. For the electrical generating unit(s) that certify
16		under this subcategory, companies need to maintain the existing standard limits
17		already in effect for BATW and FGD wastewater discharges until the day of unit
18		shut down.
19		

In addition to the cessation of coal burning activities subcategory, the Reconsideration Rule also provides a second compliance subcategory specific to FGD wastewater. The Reconsideration Rule established Best Available Technology (BAT) standard discharge limits for FGD wastewater discharges, and further, finalized a subcategory called the Voluntary Incentive Program (VIP). Under the VIP, companies could choose to meet more stringent effluent limits

RJL-7

Line		R. J. LEE U-21534
<u>No.</u>		
1		established by EPA based on the model technology of membrane filtration or zero-
2		liquid discharge. If a company chooses the VIP option, then the applicability date
3		for FGD wastewater compliance will be December 31, 2028.
4		
5	Q15.	How does a company pursue compliance under a compliance subcategory
6		from the ELG Rule?
7	A15.	To establish compliance for either of these subcategories, companies were required
8		to submit a Notice of Planned Participation (NOPP) to EGLE. Once submitted,
9		companies are required to submit annual progress reports to EGLE to ensure the
10		commitment of compliance under the subcategories.
11		
12	Q16.	When is a company required to submit a NOPP to enter a compliance
13		subcategory?
14	A16.	EPA has permitted two separate opportunities by which companies could submit
15		NOPPs to pursue and comply with compliance subcategories. The first opportunity
16		was from October 21, 2020, to October 21, 2021. The second opportunity was from
17		May 30, 2023, to June 27, 2023.
18		
19	Q17.	Did the Company submit an NOPP filing for ELG compliance subcategories?
20	A17.	Yes, three NOPPs have been submitted. A cessation of coal NOPP was submitted
21		for Belle River Power Plant on October 13, 2021. A VIP NOPP was submitted for
22		Monroe Power Plant on October 13, 2021. Lastly, a cessation of coal NOPP was
23		submitted for Units 3 and 4 at Monroe Power Plant on April 27, 2023.
24		
25	Q18.	Can you describe the Cessation of Coal NOPP filing?

Line		
<u>No.</u>		

1	A18.	Yes. To establish compliance for the cessation of coal compliance subcategory
2		detailed above, companies were required to submit an NOPP to the state permitting
3		agency (EGLE). The cessation of coal NOPP included:
4		(1) identification of the electric generating unit (EGU) intended to achieve
5		permanent cessation of coal combustion,
6		(2) expected date that each EGU is projected to achieve permanent cessation of coal
7		combustion,
8		(3) whether each date represents a retirement or a fuel conversion,
9		(4) whether each retirement or fuel conversion has been approved by a regulatory
10		body, and
11		(5) identification of the relevant regulatory body.
12		
13		In addition, the NOPP must include a copy of the most recent Integrated Resource
14		Plan (IRP) for which the applicable state agency approved the retirement or
15		repowering of the unit subject to the ELGs, certification of EGU cessation under
16		the CCR rule, or other documentation supporting that the EGU will permanently
17		cease the combustion of coal by December 31, 2028. The NOPP must include, for
18		each such EGU, a timeline to achieve the permanent cessation of coal combustion.
19		Each timeline must include interim milestones and the projected dates of
20		completion.
21		
22		At the time the cessation of coal NOPP was submitted for Belle River Power Plant,
23		preliminary modeling and strategy development related to the Company's long
24		term generation plan and IRP was ongoing. Due to those early efforts, the decision
25		to submit the NOPP for Belle River Power Plant was made to preserve some options

2

3

4

5

6

being evaluated in the strategy development. In November 2022, the Company submitted its IRP, Case No. U-21193, which included a proposed refueling of Belle River Power Plant units from coal to natural gas combustion. In July 2023, a final Order was issued that approved the refueling of Belle River Power Plant. The Company's NOPP that was submitted for Belle River Power Plant is reflective of the outcome of the IRP.

7

8 After the initial Reconsideration Rule NOPP filing date of October 13, 2021, had 9 passed, EPA learned in meetings with trade associations and utilities that additional 10 facilities wished to avail themselves of the compliance pathway for EGUs seeking 11 to retire or convert to a non-coal fuel source by December 31, 2028, but were unable 12 to make that commitment by October 13, 2021. Therefore, in March of 2023, EPA 13 published a direct final rule to extend the deadline for plants to opt-in to the 14 cessation of coal compliance subcategory promulgated in the Reconsideration Rule. 15 Consistent with the Order in the Company's 2022 IRP filing, Case No. U-21193, 16 the Company submitted a cessation of coal compliance subcategory NOPP for 17 Monroe Power Plant Units 3 and 4 during the extension of the deadline established 18 in EPA's direct final rule.

19

20 Q19. Can you describe the Voluntary Incentive Program (VIP) NOPP filing?

A19. Yes. To establish compliance for the VIP compliance subcategory detailed above,
companies were required to submit a VIP NOPP to the state permitting agency
(EGLE). The VIP NOPP for FGD wastewater included:

24 (1) Identification of the facility opting to comply with the VIP discharge25 requirements,

RJL-10

Line <u>No.</u>		R. J. LEE U-21534
1		(2) Specification of technology or technologies that are projected to be used to
2		comply with those requirements, and
3		(3) Detailed engineering dependency chart and accompanying narrative
4		demonstrating when and how the system(s) and any accompanying disposal
5		requirements will be achieved by December 31, 2028.
6		
7		Consistent with the Order in the Company's 2022 IRP filing, Case No. U-21193,
8		the Company submitted a cessation of coal compliance subcategory NOPP for
9		Monroe Power Plant Units 3 and 4 during the extension of the deadline established
10		in EPA's direct final rule. The VIP NOPP submitted on October 13, 2021, still
11		applies for Monroe Power Plant Units 1 and 2, as those units will continue
12		operations until 2032.
13		
14	Q20.	Why did DTE Electric submit the VIP NOPP for FGD ELG compliance?
15	A20.	For FGD compliance the Company evaluated a suite of technology options that
16		would achieve both BAT and VIP compliance requirements for ELG FGD
17		compliance. At the time of NOPP development, the Company was still evaluating
18		the suite of potential compliant technologies. To ensure the Company could
19		continue to evaluate all available technologies, including those that achieved VIP
20		compliance, the decision was made to submit the VIP NOPP. By submitting the
21		VIP NOPP, it allowed the Company to continue evaluating all technologies
22		available on the market and not just technologies capable of achieving BAT.
23		
24		In 2022, the Company identified an FGD compliance technology that met the VIP
25		compliance requirements and committed the Company to the VIP NOPP.

1		Consistent with the Order in the Company's 2022 IRP filing, Case No. U-21193,
2		Monroe Units 1 and 2 will continue to operate until 2032, and FGD compliance
3		will be achieved by December 31, 2028, for those two units by achieving zero liquid
4		discharge. As detailed above, Monroe Units 3 and 4 will achieve compliance via
5		cessation of coal as indicated by the Company's April 27, 2023, NOPP submittal.
6		
7	Q21.	What is DTE Electric's compliance strategy for Belle River Power Plant?
8	A21.	At Belle River Power Plant, fly ash is collected dry and therefore there is no Fly
9		Ash Transport Water (FATW). Additionally, the power plant was constructed and
10		operates without FGDs. Therefore, there is no FGD wastewater. However, the
11		bottom ash is collected using transport water and the ELG Reconsideration Rule
12		requires the Company to achieve compliance with BATW discharge requirements.
13		DTE Electric submitted the NOPP on October 13, 2021, for cessation of coal at
14		Belle River Power Plant. Please see Company Witness Guillaumin's testimony
15		regarding the Company's commitment to convert from coal-fired to natural gas-
16		fired operations by 2026.
17		
18	Q22.	What is DTE Electric's compliance strategy for Monroe Power Plant?
19	A22.	At the Monroe Power Plant, the Company completed projects for FATW ELG
20		compliance according to the 2015 ELG Rule and ceased water discharges related
21		to the transport of fly ash. For BATW wastewater ELG compliance, the Company
22		must achieve compliance by the end of 2025 and will terminate the use of water for
23		bottom ash transport at Monroe Unit 1 and 2. For Units 3 and 4 at Monroe, the
24		Company submitted a cessation of coal compliance subcategory NOPP on April
25		27, 2023. For FGD wastewater ELG compliance, the Company is pursuing

1		compliance using VIP technology for Units 1 and 2 and cessation of coal NOPP for
2		Units 3 and 4. The Company will install a VIP compliant system for Monroe Units
3		1 and 2 no later than the end of 2028. Monroe Units 3 and 4 will retire in 2028
4		according to the Company's 2022 IRP, therefore a cessation of coal NOPP was
5		submitted providing compliance with the FGD wastewater-portion of the ELG Rule
6		as retirement will eliminate FGD wastewater from these units. Please see Company
7		Witness Guillaumin's testimony for further details regarding ELG compliance.
8		
9	Q23.	Is the EPA currently revising the 2020 ELG Reconsideration Rule?
10	A23.	Yes. EPA has initiated a supplemental rulemaking to address discharge limits in
11		the Steam Electric Power Generating category. EPA conducted a science-based
12		review of the 2020 Steam Electric Reconsideration Rule under Executive Order
13		13990, finding that opportunities for improvement exist. Additionally, on January
14		3, 2023, the Unified Agenda of Regulatory and Deregulatory Actions (Regulatory
15		Agenda) published by the United States Office of Management and Budget was
16		updated and included a new action conducted by EPA related to ELGs. The Agenda
17		stated the EPA, "is taking direct final action to extend the date for existing coal-
18		fired power plants to submit a notice of planned participation (NOPP) for the
19		permanent cessation of coal combustion subcategory from October 13, 2021,
20		to 90 days after publication of this rule in the Federal Register." ¹ On March 29,
21		2023, EPA published the referenced direct final rule and it became effective on
22		May 30, 2023.

¹ <u>https://www.reginfo.gov/public/do/eAgendaViewRule?pubId=202210&RIN=2040-AG28</u>, accessed December 21, 2023

1		Also, on March 29, 2023, EPA published their proposed ELG rule titled
2		"Supplemental Effluent Limitations Guidelines and Standards for the Steam
3		Electric Power Generating Point Source Category". The public comment period for
4		the proposed rule closed on May 30, 2023. According to the Regulatory Agenda,
5		EPA plans to release their final supplemental ELG Rule by April of 2024.
6		
7	Q24.	Why is the Company requesting recovery of capital expenditures for projects
8		associated with the 2020 ELG Reconsideration Rule when it is currently under
9		revision?
10	A24.	On August 3, 2021, the EPA issued a Federal Register notice ² in which they
11		announced their supplemental rulemaking to revise the 2020 ELG Reconsideration
12		Rule as a result of their review conducted under Executive Order 13390. The Notice
13		from EPA states, "While the Agency undertakes this new rulemaking, facilities will
14		continue to be subject to the requirements of the 2015 Rule, as amended by the
15		2020 Rule, which are currently effective." The Notice goes on to also state, "EPA
16		expects permitting authorities to continue to implement the current regulations
17		while the Agency undertakes a new rulemaking." Based on these statements made
18		in the August 3, 2021, Federal Register notice by EPA, the Company was required
19		to move forward with the ELG compliance strategy and continue to implement the
20		ELG projects referenced in Q&A9 above. In addition to the Notice, other factors
21		specific to the project such as long lead equipment, construction seasons, and
22		utilizing periodic outages have also driven the need to move forward with ELG
23		compliance projects.
24		

² <u>https://www.federalregister.gov/documents/2021/08/03/2021-16354/effluent-limitations-guidelines-and-standards-for-the-steam-electric-power-generating-point-source, accessed January 19, 2023</u>

1	Q25.	Other than above, is there other documentation stating that the Company
2		must continue implementing ELG compliance projects based on the 2020
3		Reconsideration Rule even though EPA is revising it?
4	A25.	Yes, EPA's media release ³ from July 26, 2021, in which they announce their 2021
5		supplemental rulemaking to revise the 2020 Reconsideration Rule states, "While
6		the agency pursues the new rulemaking process to strengthen water pollution
7		requirements for coal power plants, the current regulations will be implemented and
8		enforced."
9		
10	Q26.	Can the Company avoid capital expenditure for bottom ash compliance on the
11		two units proposed to retire in 2028 at Monroe?
12	A26.	Yes. Compliance for bottom ash ELG requirements must be met no later than
13		December 31, 2025. However, as detailed above (Q&A23), the EPA finalized the
14		direct final rule on May 30, 2023, that reopened and extended the timeframe that
15		NOPPs for the cessation of coal compliance subcategory could be submitted. The
16		Company utilized the opportunity presented in the direct final rule and submitted a
17		cessation of coal NOPP for Monroe Units 3 and 4, which are committed to retire in
18		2028. Consistent with the Order in the Company's 2022 IRP filing, Case No. U-
19		21193, Monroe Power Plant Units 1 and 2 will continue to operate until 2032 and
20		so a bottom ash compliance project will still be implemented for ELG compliance.
21		
22	Q27.	If the EPA's supplemental ELG Rule update becomes final as proposed, would
23		it affect or alter planned capital projects to comply with the current ELG rule?

³ <u>https://www.epa.gov/newsreleases/epa-announces-intent-bolster-limits-water-pollution-power-plants</u>, accessed March 21, 2024

1	A27.	No. The capital projects for BATW and FGD compliance on Monroe Units 1 and
2		2 both rely on technologies that will ultimately result in no discharge of BATW or
3		FGD wastewater. Zero liquid discharge technologies will always be compliant with
4		ELG requirements as there is no discharge to regulate.
5		
6	<u>Coal</u>	Combustion Residuals
7	Q28.	Can you describe the EPA's Coal Combustion Residuals (CCR) Rule and its
8		impact on the Company's coal-fired units?
9	A28.	Yes. The EPA's CCR Rule regulates how electric utilities must manage and dispose
10		of coal combustion residuals in landfills and impoundments. On August 28, 2020,
11		the EPA published an amendment to the CCR rule (the Part A Rule) that requires
12		all unlined surface impoundments to cease receipt of waste and initiate closure as
13		soon as technically feasible but by no later than April 11, 2021. The August 28,
14		2020, amendment also provided utilities the ability to request site-specific
15		alternative closure deadlines through a demonstration process requiring EPA
16		approval. On November 12, 2020, EPA published an additional amendment to the
17		CCR rule (the Part B Rule) that allows utilities the opportunity to demonstrate that
18		their unlined surface impoundments have an alternate liner system that is as
19		protective as a CCR rule compliant liner system. The demonstration processes
20		included in the Part A Rule and Part B Rule require EPA approval to continue
21		operating CCR surface impoundments.
22		
23	Q29.	Can you describe the Company's strategy for each CCR unit to comply with
24		the "Part A" amended closure provisions of the CCR Rule?

<u>No.</u>		
1	A29.	Yes. The Company submitted a Part A Rule demonstration for the St. Clair Bottom
2		Ash Basins on November 25, 2020, in accordance with 40 C.F.R. §257.103(f)(2).
3		The demonstration requested an alternative closure deadline based on cessation of
4		coal fired generation in spring of 2022, and a commitment to complete closure of
5		the unit by October 17, 2023. Submission of the Part A Rule demonstration paused
6		the April 11, 2021, deadline for the unit to cease receipt of waste. On January 11,
7		2022, the Company received written notice that the Part A Rule demonstration was
8		administratively complete and confirmed that the cease receipt of waste deadline
9		had been paused until EPA issues a final decision on the demonstration. The
10		Company ceased operation of the coal-fired boilers at St. Clair Power Plant on May
11		31, 2022, completed washdowns of CCR containing equipment on August 12,
12		2022, and commenced physical isolation of the St. Clair Bottom Ash Basins from
13		power plant infrastructure on September 1, 2022. These actions demonstrate that
14		the Company has permanently ceased receipt of CCR and non-CCR waste streams
15		at the St. Clair Bottom Ash Basins and has initiated closure by removal pursuant to
16		40 C.F.R. §257.102(c). The Company has therefore withdrawn the Part A
17		demonstration, as it has already ceased receipt of waste. The Company
18		subsequently completed dewatering and CCR removal activities in February 2023.
19		The St. Clair Bottom Ash Basins were backfilled concurrent with and following
20		CCR removal, and topsoil, seed and mulch placement were complete by May 2023.
21		
22		On September 13, 2023, EPA acknowledged withdrawal of the Part A

Line

demonstration, stating that "EPA reviewed the Demonstration and determined that
it included the required information, analyses and documentation specified under
40 C.F.R § 257.103(f)(2), and consequently determined on January 11, 2022, that

1		the Demonstration was complete. The deadline to cease receipt of waste at the
2		Bottom Ash Basins, the CCR units covered by the Demonstration, was paused
3		between April 11, 2021, and September 1, 2022, when the unit ceased receipt of
4		waste. See, 40 C.F.R. § 257.103(f)(3)(ii). Accordingly, EPA updated the Part A
5		webpage ⁴ to reflect that the Bottom Ash Basins no longer receive waste and that
6		DTE has withdrawn its Demonstration."
7		
8		Following closure by removal activities, two rounds of samples were collected from
9		the St. Clair Bottom Ash Basins groundwater monitoring well network.
10		Groundwater constituent concentrations fall below groundwater protection
11		standards as documented in the Company's Annual Groundwater Monitoring and
12		Corrective Action Report (January 2024). Therefore, the Company completed a
13		notification of closure in accordance with C.F.R. § 257.102(h).
14		
15	Q30.	Can you describe the Company's strategy for each CCR unit to comply with
16		the "Part B" alternate liner provisions of the CCR Rule?
17	A30.	Yes. The Company submitted Part B applications to EPA on November 30, 2020,
18		to perform Alternate Liner Demonstrations for Belle River Bottom Ash Basins,
19		Belle River Diversion Basin, and Monroe Fly Ash Basin. The Company received
20		notice of EPA's proposed denial on January 25, 2023. The Company is continuing
21		with projects at each facility to comply with the CCR rules and support operating
22		the plants. The proposed denials affect each facility as follows:
23		

⁴ <u>Coal Combustion Residuals (CCR) Part A Implementation | US EPA available at https://www.epa.gov/coalash/coal-combustion-residuals-ccr-part-implementation</u>

1	Belle River Bottom Ash Basins and Diversion Basin:
2	As discussed in Witness Guillaumin's testimony, the Company has executed a
3	project to retrofit the Bottom Ash Basins with a CCR-compliant liner system and
4	close the Diversion Basin by removal. The project was completed in 2023 in
5	accordance with regulatory timelines. On September 21, 2023, the Company
6	withdrew the Part B application, as it had already ceased receipt of waste in any
7	unlined portion of the units.
8	
9	On October 30, 2023, EPA acknowledged withdrawal of the Part B application,
10	stating that "EPA reviewed the application and determined that it included the
11	required information, analyses and documentation specified under 40 C.F.R. §
12	257.71(d)(1), and consequently determined on January 11, 2022, that the
13	application for the Bottom Ash Basins and the Diversion Basin was complete. On
14	January 25, 2023, EPA issued a proposed decision to deny the application for both
15	the Bottom Ash Basins and the Diversion Basin. In accordance with 40 C.F.R. §
16	257.71(d)(1)(iii)(A), the deadline to cease receipt of waste for the Bottom Ash
17	Basins and the Diversion Basin was tolled the entire period between April 11, 2021,
18	and July 6, 2023, and May 16, 2023, respectively, when the units ceased receipt of
19	waste."
20	
21	Estlowing classing by new could activities for the Diversion Design true neurals of

Following closure by removal activities for the Diversion Basin, two rounds of samples will be collected from the groundwater monitoring well network to certify that closure by removal is complete. Final notification of closure completion is expected in 2024.

Monroe Fly Ash Basin:

The Company was already in process of developing alternative capacity at Monroe by converting the existing wet fly ash handling system to a dry system in accordance with the 2015 ELG rule. The dry fly ash conversion is complete, and the Fly Ash Basin received its last known shipment of waste on December 29, 2023, and as discussed in the Notification of Intent to Close, the Company has initiated closure within the appropriate regulatory timeframes. Therefore, on January 25, 2024, the Company withdrew the Monroe Fly Ash Basin Part B Application.

9

Q31. Can you describe the Company's strategy for closure of Monroe Bottom Ash Basin?

12 A31. Yes. The Company ceased receipt of CCR at the Monroe Bottom Ash Basin prior 13 to the effective date of the 2015 CCR rule. Consequently, the Company prepared 14 and placed in the facility's operating record a notice of intent to initiate closure on 15 December 11, 2015, in accordance with §257.100. The Monroe Bottom Ash Basin 16 was therefore considered an inactive CCR surface impoundment. Section 257.100 17 was later remanded and revised by EPA, subjecting inactive CCR surface 18 impoundments to all the requirements applicable to existing CCR surface 19 impoundments but on an alternative timeframe. In April 2020, it was determined 20 that the Monroe Bottom Ash Basin did not meet the requirements of §257.60 21 (placement above the uppermost aquifer) and was subject to closure under the 22 requirements of \$257.101(b)(1)(i) and therefore must cease receipt of both CCR 23 and non-CCR waste streams as soon as technically feasible, but no later than April 24 11, 2021, and close in accordance with §257.102. The Company ceased receipt of

- non-CCR waste streams and initiated closure on October 21, 2020 and is currently
 progressing through final steps of closure by removal of all CCR.
- 3

4 Q32. Please explain why the site improvements at Sibley Quarry Landfill are 5 necessary and needed to support CCR compliance.

- 6 A32. Improvements to infrastructure at Sibley Quarry Landfill have been made to 7 enhance the storage capability to accept the CCR material from the Monroe Bottom 8 Ash Basin and Monroe Power Plant production CCR. These improvement projects 9 were necessary because the Monroe Fly Ash Basin and Vertical Extension Landfill 10 could not accept CCR beyond 2023. Sibley Quarry Landfill has ample permitted 11 capacity and was therefore selected as the disposal location for the CCR material 12 removed from the Monroe Bottom Ash Basin, and Monroe production CCR. The 13 Company has transported nearly 1,000,000 tons of CCR from the Monroe Bottom 14 Ash Basin through 2023 and will receive additional CCR material in 2024. 15 Certification of the CCR removal from the Monroe Bottom Ash Basin is expected 16 by late 2024. Company Witness Guillaumin details the costs associated with these 17 improvement projects.
- 18

Q33. Please explain why the Monroe Fly Ash Basin Closure project is necessary and what are the required closure time frames.

A33. The Monroe Fly Ash Basin is an existing unlined CCR surface impoundment as
determined under 40 C.F.R. §257.71(a). Therefore, it is subject to the requirements
of 40 C.F.R. §257.101(a)(1), which states that the unit must cease receipt of waste
and initiate closure as soon as technically feasible, but by no later than April 11,
2021. As discussed in Question 26 above, the Company submitted a Part B

1		Alternate Liner Demonstration Application for the Monroe Fly Ash Basin on
2		November 30, 2020, in accordance with 40 C.F.R. §257.71(d)(1). On January 11,
3		2022, EPA notified the Company that the application was administratively
4		complete, and that EPA will pause the facility's deadline to cease receipt of waste
5		until issuance of a final decision under 40 C.F.R. §257.71(d)(2)(iii)(C). The
6		Company has not received a final decision under 40 C.F.R. §257.71(d)(2)(iii)(C)
7		as of this filing. However, the Monroe Fly Ash Basin received the known final
8		receipt of waste on December 29, 2023, and initiated closure within 30 days to
9		comply with 40 C.F.R. §257.102(e)(1). As documented in the Notification of Intent
10		to Close, the Company has ceased receipt of waste and initiated closure.
11		
12		To comply with the closure timeframes of 40 C.F.R. §257.102(f)(1), the Company
13		must complete closure within five years of commencing closure activities.
14		Therefore, the Company is targeting 2029 to complete the closure of this 410-acre
15		basin. If needed, 40 C.F.R. §257.102(f)(2) provides an opportunity for up to five
16		2-year extensions, provided the owner or operator can demonstrate the factual
17		circumstances which prevented completion of closure within the baseline five
18		years.
19		
20	Q34.	Can you describe how EPA's proposed Legacy CCR Rule could affect or alter
21		planned capital projects to comply with the current CCR rule?
22	A34.	Yes. The proposed Legacy CCR Rule does not affect the planned capital projects
23		being implemented to comply with the current CCR Rule. On May 18, 2023, EPA
24		published a proposed rule titled Hazardous and Solid Waste Management System:
25		Disposal of Coal Combustion Residuals From Electric Utilities; Legacy CCR

1	Surface Impoundments. The draft rule proposes to establish regulatory
2	requirements for inactive surface impoundments at inactive facilities, and also
3	apply groundwater monitoring, corrective action, closure, and post closure care
4	requirements for all CCR Management Units (CCRMU) at regulated CCR
5	facilities. Importantly, the proposed rule applies to currently unregulated CCR, and
6	the CCR-related capital projects described in Witness Guillaumin's testimony are
7	tied to regulated CCR units that will proceed as planned.
8	

9 Q35. Does this complete your direct testimony?

10 A35. Yes, it does.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the Application of)
DTE ELECTRIC COMPANY)
for authority to increase its rates, amend)
its rate schedules and rules governing the)
distribution and supply of electric energy, and)
for miscellaneous accounting authority.)

Case No. U-21534

QUALIFICATIONS

AND

DIRECT TESTIMONY

OF

TIMOTHY J. LEPCZYK

DTE ELECTRIC COMPANY QUALIFICATIONS AND DIRECT TESTIMONY OF TIMOTHY J. LEPCZYK

Line <u>No.</u>

10.		
1	Q1.	What is your name, business address and by whom are you employed?
2	A1.	My name is Timothy J. Lepczyk (he/him/his). My business address is DTE Energy
3		Company, One Energy Plaza, Detroit, Michigan 48226. I am employed by DTE
4		Energy Corporate Services, LLC as Assistant Treasurer and Director of Corporate
5		Finance, Insurance and Development.
6		
7	Q2.	On whose behalf are you testifying?
8	A2.	I am testifying on behalf of DTE Electric Company (DTE Electric or Company).
9		
10	Q3.	What is your educational background?
11	A3.	I graduated from Georgetown University in 2004 with a Bachelor of Business
12		Administration degree, with a concentration in International Business. In 2008, I
13		graduated with my MBA from the University of Michigan, with a focus in Finance
14		and Corporate Strategy.
15		
16	Q4.	What is your work experience?
17	A4.	I began my employment with Ford Motor Company in the summer of 2004 as a
18		financial analyst within that company's Dearborn Stamping facility. In 2006, I left
19		to pursue my MBA. In 2008, after graduation, I went to work for Booz & Company,
20		a management consultancy, where I focused on the automotive and industrial
21		sectors. I worked at Booz & Company from 2008 until 2013 when I joined DTE
22		Energy.
23		
24		In 2013, I joined DTE Energy as a Manager on the Corporate Strategy team where
25		I was the lead analyst for various projects and studies primarily relating to the Gas
	Storage and Pipeline business. In 2014, I formally accepted a position within the	
-------------------	--	
	Gas Storage and Pipeline team as Manager in their strategy group where I was	
	responsible for various economic analyses (e.g., natural gas supply and demand	
	fundamentals) and for assessing potential new acquisition opportunities. In 2016, I	
	accepted the position of Manager for the Corporate Development team where I was	
	responsible for managing DTE Energy's capital investment process and various	
	valuation processes (for example, DTE Energy's annual Goodwill impairment	
	assessment). In addition, I led broader strategy initiatives including the analysis,	
	which ultimately led to our decision to spin off the Midstream business segment.	
	In 2021, I accepted my current position, Assistant Treasurer and Director of	
	Corporate Finance, Insurance and Development.	
	Corporate Finance, Insurance and Development.	
Q5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities?	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist in maintaining relationships with the commercial and investment banking	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist in maintaining relationships with the commercial and investment banking community, interact with the rating agencies, and execute corporate financial	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist in maintaining relationships with the commercial and investment banking community, interact with the rating agencies, and execute corporate financial policies, particularly in the areas of balance sheet management, debt issuances, and	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist in maintaining relationships with the commercial and investment banking community, interact with the rating agencies, and execute corporate financial policies, particularly in the areas of balance sheet management, debt issuances, and agency ratings. In addition, I manage the Company's capital investment approval	
Q5. A5.	Corporate Finance, Insurance and Development. What are your current duties and responsibilities? I am responsible for assisting the Treasurer in managing the capital needs of the Company. These responsibilities include managing corporate liquidity and financing activities such as the raising of both equity capital and capital markets debt for DTE Energy, DTE Electric, and DTE Gas Company (DTE Gas). I assist in maintaining relationships with the commercial and investment banking community, interact with the rating agencies, and execute corporate financial policies, particularly in the areas of balance sheet management, debt issuances, and agency ratings. In addition, I manage the Company's capital investment approval and review process along with managing the Company's property and liability	

Line <u>No.</u>

1	Q6.	Have you pr	reviously sponsored testimony before the Michigan Public Service
2		Commission	(MPSC or Commission)?
3	A6.	Yes, I have.	I have sponsored testimony in the following cases:
4		U-20836	DTE Electric 2022 General Rate Case
5		U-21193	DTE Electric 2022 Integrated Resource Plan
6		U-21338	DTE Electric 2023 Securitization
7		U-21291	DTE Gas 2024 General Rate Case
8		U-21297	DTE Electric 2023 General Rate Case

Line

Ν	0	•

Purpose of Testimony O7 What is the nurpose of your testimony in this proceeding?

Z	Q/.	what is the purpose of your testimony in this proceeding:		
3	A7.	The purpo	se of my testir	nony is to support DTE Electric's projected capital
4		structure ar	nd the cost of its	long- and short-term debt to be used in the determination
5		of DTE Ele	ectric's overall r	ate of return in this proceeding.
6				
7	Q8.	How is you	ur testimony or	ganized?
8	A8.	My testime	ony is organized	as follows:
9		I. Sur	nmary of Recom	nmendations
10		II. Dev	velopment of Ca	pital Structure
11		III. Dev	velopment of Co	ost Rates
12		IV. Sec	curitization	
13		V. Sur	nmary and Conc	lusions
14				
15	Q9.	Are you sp	oonsoring any e	xhibits in this proceeding?
16	A9.	Yes. I am	supporting the f	ollowing exhibits:
17		<u>Exhibit</u>	Schedule	Description
18		A-1	A2	Historical Financial Metrics
19		A-4	D2	Historical Cost of Long-Term Debt
20		A-4	D3	Historical Cost of Short-Term Debt
21		A-4	D4	Historical Cost of Preferred and Preference Stock
22		A-4	D5	Historical Cost of Common Shareholders' Equity
23		A-11	A2	Projected Financial Metrics
24		A-14	D1.1	Peer Group Common Equity
25		A-14	D2	Projected Cost of Long-Term Debt

Lina				T. J. LEPCZYK
<u>No.</u>				0-21554
1		A-14	D3	Projected Cost of Short-Term Debt
2		A-14	D4	Projected Cost of Preferred and Preference Stock
3		A-18	H1	Current and Historical Credit Ratings
4		A-18	H2	Recent Utility Corporate Bond Issuances
5				
6	Q10.	Were these e	exhibits prepa	red by you or under your direction?
7	A10.	Yes, they we	re.	
8				
9	<u>I.</u>	SUMMARY	OF RECOM	MENDATIONS
10	Q11.	What perma	ment capital	structure are you recommending for the projected
11		test year to b	e utilized in d	letermining the overall rate of return calculation for
12		DTE Electric	c?	
13	A11.	I am recomm	ending a proje	cted permanent capital structure of 50% long-term debt
14		and 50% co	mmon equity.	Permanent capital is long-term perpetual capital.
15		Common equ	uity, preferred	stock and long-term debt are sources of permanent
16		capital. Since	e the Company	does not have any preferred stock, I am recommending
17		the permaner	nt capital struc	cture to be made up of 50% long-term debt and 50%
18		common equ	ity. This perr	nanent capital structure is reflected in DTE Electric's
19		projected per	manent capital	structure as of December 31, 2025, as shown in Exhibit
20		A-14, Schedu	ule D1, which	is supported by Company Witness Vangilder. This
21		capital structu	ure is necessita	ted by the business and financial risks confronting DTE
22		Electric, whic	ch I will discus	ss in greater detail later in my testimony.
23				
24	Q12.	What is you	r forecast for	DTE Electric's cost of long-term debt, short-term
25		debt, and pro	eferred stock	for the 12-month period ending December 31, 2025?

A12. I am forecasting 4.24% for the cost of DTE Electric's long-term debt, and 5.76%
 for the cost of DTE Electric's short-term debt. The Company does not have
 preferred stock, and therefore it has no cost rate. Exhibit A-14, Schedule D2
 supports the cost rate for long-term debt. Exhibit A-14, Schedule D3 supports the
 cost rate for short-term debt.

6

7 II. DEVELOPMENT OF CAPITAL STRUCTURE

8 Q13. What do you mean by capital structure?

9 A13. A company's capital structure includes the amount of equity and debt necessary to 10 support the operations of its business and is defined differently by regulators, 11 finance professionals, and rating agencies. Total regulatory capital structure 12 typically includes long-term debt, short-term debt, preferred stock, common equity, 13 deferred taxes, deferred job development investment tax credits, and deferred 14 investment tax credits. Permanent capital structure includes only long-term debt 15 and equity. Rating agencies calculate a company's capital structure using short-16 term debt, long-term debt, preferred stock, common equity, and other adjustments. 17 The rating agencies adjust debt to include items like capital and operating leases, 18 unfunded pension liabilities, power purchase agreements, and asset retirement 19 obligations.

20

21 Q14. Why is a sound capital structure important?

A14. It is important to have a financially sound capital structure in order to ensure that a
 company can obtain needed capital. A sound capital structure produces capital
 costs that are reasonable and equitable. Also, it is important that the overall return
 on capital be sufficient to assure financial confidence in a firm and to allow it to

Line <u>No.</u> Line

<u>No.</u>

1

2

raise the funds that are necessary to operate its business at reasonable costs and terms. A sound capital structure is in the best interests of the customers as it ensures the continued viability of the company.

4

3

5 Q15. How does risk affect a firm's capital structure?

6 A15. In general, a firm such as DTE Electric faces two types of risk: business risk and 7 financial risk. Business risk is a result of systemic and non-systemic risk. Systemic 8 risks are broad economic risks faced by all firms. Non-systemic risks are risks 9 specifically identified as those faced by the individual firm. Financial risk is the 10 risk that common equity shareholders face to the extent that a firm issues debt to 11 finance real assets. Debtholders (also known as bondholders) have priority over 12 equity shareholders in the event of corporate bankruptcy. Thus, the greater the 13 amount of debt held by a firm, the greater the risk to equity shareholders. It is 14 essential that a firm recognizes the dynamics of these risks and adjusts its 15 underlying debt and equity components to produce a sound capital structure.

16

17 Q16. How does a company's capital structure impact its ability to attract capital?

18 A16. Having a weak or highly leveraged capital structure may lead to higher required 19 returns on equity and a higher cost of debt. It also can impact the company's ability 20 to obtain capital. For example, a company with a highly leveraged capital structure 21 may lose its investment grade rating from the rating agencies. Non-investment 22 grade companies have a limited investor base and a more limited access to capital 23 than investment grade companies. Moreover, during periods of diminished capital 24 liquidity, even investment grade companies can have limited access to new capital 25 sources. It is important to consider how extreme market reactions to singular events

1		impact how easily capital will be able to be accessed during the future test period
2		should an unforeseen market shock occur. Furthermore, rating agencies allow little
3		or no time for a company to correct and improve its capital structure before
4		lowering its credit rating. Conversely, companies must be proactive to target and
5		achieve the midpoint of the range of rating agency financial metrics to have a better
6		chance to maintain current ratings.
7		
8	Q17.	Will higher debt levels in a capital structure affect the cost of debt?
9	A17.	Yes. The cost of debt increases as more debt is added to the capital structure.
10		Further, higher debt levels can increase the risk of a downgrade by the rating
11		agencies. A lower credit rating means greater credit risk such that investors will
12		require a higher return to invest in a company, thereby increasing the cost of debt
13		for that company.
14		
15	Q18.	For DTE Electric's defined projected test year, what capital structure are you
16		recommending for DTE Electric in the instant case?
17	A18.	For the projected test year, the permanent capital structure that I am recommending
18		includes long-term debt and equity as shown on Exhibit A-14, Schedule D1, that is
19		supported by Witness Vangilder. Within this regulatory capital structure, I am
20		recommending a projected test year permanent capital structure that has 50% long-
21		term debt and 50% common equity. This is the same permanent capital structure
22		authorized by the Commission in the last general rate case, Case No. U-21297.
23		
24	Q19.	Does the Company believe that a 50/50 capital structure is the optimal capital
25		structure for DTE Electric?

Line
<u>No.</u>

1	A19.	No. To reduce the number of contested positions in the instant case, the Company
2		is using the structure authorized in the December 1, 2023 order in Case No. U-
3		21297. However, as the Company has argued in past rate cases, it believes the more
4		appropriate capital structure for DTE Electric is closer to that of its peers. Exhibit
5		A-14, Schedule D1.1 shows DTE Electric peers having a capital structure made up
6		of 48% long-term debt and 52% common equity. A 50% equity level gives the
7		Company less protection in the event of an unforeseen market event and may
8		impact DTE Electric's ability to access capital during the future test period should
9		an unforeseen market shock occur.
10		
11	Q20.	Is the proposed ratio of 50% common equity to total permanent capitalization
12		in line with DTE Electric's peers?
13	A20.	No. The common equity ratio requested in the instant case is lower than that of the
14		Company's peers. As shown on Exhibit A-14 Schedule D1.1, the average equity
15		ratio for DTE Electric peers was approximately 52%. DTE Electric's targeted 50%
16		equity ratio is a reasonable level given that the average ratio of the peer group is
17		higher at 52%. The data was obtained from S&P Global Market Intelligence (SNL)
18		for the most recent fiscal year available per peer company. DTE Electric believes
19		its requested 50% is reasonable and below the equity ratio of its peers across the
20		country and within Michigan.
21		
22	Q21.	Does the intense capital investment program contribute to the need for a
23		higher level of equity in general within the capital structure?
24	A21.	Yes, it is imperative that DTE Electric be viewed as a financially sound firm with
25		a solid investment grade rating to ensure the reasonableness and competitiveness

1		of capital costs. DTE Electric will be financing and funding over \$7.9 billion of
2		electric capital expenditures for the period January 2023 through December 2025
3		(see Exhibit A-12 Schedule B5). In a period of intense capital investment, a sound
4		capital structure and a favorable regulatory environment are essential to maintain
5		the financial well-being of the Company. Should the Company face any unforeseen
6		or negative impacts to its financial health, a higher equity balance may be needed.
7		The common equity balance and equity ratio projected for the test year in the instant
8		case will hopefully enable the Company to maintain strong credit ratings and
9		withstand any shocks in the financial markets, thereby ensuring a smooth
10		implementation of its capital expenditure program.
11		
12	Q22.	Is DTE Electric committed to maintaining a 50% equity ratio in its capital
13		structure?
14	A22.	Yes. At December 31, 2022, DTE Electric's equity ratio was 50%. DTE Electric
15		is committed to maintaining a 50% equity ratio and has demonstrated its
16		commitment to its targeted equity ratio by receiving equity infusions from DTE
17		Energy. DTE Energy has made reasonable efforts to strengthen DTE Electric's
18		credit quality by infusing over \$2.3 billion of common equity from 2018-2022.
19		DTE Electric has received equity infusions totaling \$760 million in 2023 and will
20		infuse the amounts necessary in future years to maintain a 50% common equity
21		ratio.
22		
23	<u>III.</u>	DEVELOPMENT OF COST RATES

Q23. What were DTE Electric's historical financial and ratemaking metrics from
25 2018 through 2022?

TJL-10

Line	
No.	

1	A23.	DTE Electric's historical financial and ratemaking metrics for each of the previous
2		five years (2018 through 2022) are detailed in Exhibit A-1, Schedule A2. The
3		historical financial calculations include year-end financial metrics and are
4		calculated on a financial basis from DTE Electric's financial reports. The historical
5		ratemaking metrics include year-end financial metrics and are calculated from DTE
6		Electric's annual regulatory filings.
7		
8	Q24.	What is the cost of long-term debt outstanding at December 31, 2022?
9	A24.	Exhibit A-4, Schedule D2 calculates the cost of the long-term debt outstanding at
10		December 31, 2022. As shown in the exhibit and schedule, the cost of long-term
11		debt also includes agent's fees, commissions, and financing expenses and is
12		calculated on the net proceeds to the Company. The weighted average cost of debt
13		is computed based on the total annual costs to the Company divided by the total
14		principal amount outstanding at year-end. The cost of long-term debt at December
15		31, 2022 was 3.77%.
16		
17	Q25.	What is the cost of short-term debt outstanding at December 31, 2022?
18	A25.	The cost of short-term borrowings for the 13-month period ended December 31,
19		2022 was 2.75%. The cost of short-term debt consists of the 1) interest rate on short-
20		term borrowings, and 2) credit facility fees associated with the credit agreements
21		necessary for the issuance of short-term debt. See Exhibit A-4, Schedule D3.
22		
23	Q26.	What was the approved cost of equity as of December 31, 2022?

e U-215	' K 34
A26. DTE Electric's authorized cost of common shareholders' equity as of Decemb	ber
31, 2022 was 9.9% and was approved in Case No. U-20836. DTE Electric does r	ıot
have any preferred stock. See Exhibit A-4, Schedules D4 and D5.	
Q27. What does DTE Electric project its financial metrics to be in the projected to	est
year?	
A27. DTE Electric's forecasted ratemaking metrics are available in Exhibit A-1	11,
Schedule A2. Forecasted calculations include metrics for the fully projected to	est
year. The forecasted ratemaking metrics for the projected test year are to	be
reported assuming (i) full rate relief as requested, and (ii) zero rate relief.	
Q28. What is the purpose of Exhibit A-14, Schedule D2?	
A28. The purpose of Exhibit A-14, Schedule D2 is to calculate DTE Electric's project	ed
weighted average long-term debt costs as of December 31, 2025. Starting with t	he
actual December 31, 2022 long-term debt outstanding, any known and measural	ole
changes for each year were made to arrive at the projected balance as of Decemb	ber
31, 2025. Known and measurable changes that have occurred or are projected	to
occur from January 1, 2023 through December 31, 2025 include:	

Line <u>No.</u>

1

Long-Term Debt Activity	Amount	Date	Interest
Long-Term Debt Activity	(\$000)	Date	Rate
Issuance	600,000	Mar-23	5.20%
Issuance	600,000	Mar-23	5.40%
Issuance	100,000	Jun-23	3.88%
Redemption	(102,000)	Sep-23	4.31%
Redemption	(100,000)	Oct-23	5.19%
Redemption	(300,000)	Dec-23	3.65%
Issuance	575,000	Mar-24	5.65%
Redemption	(100,000)	Mar-24	3.65%
Issuance	800,000	Mar-25	5.62%
Redemption	(350,000)	Mar-25	3.38%
Issuance	500,000	Jul-25	5.62%
Net change in debt	2,223,000		

Table 1Issuances and Redemptions

2

The 2024 and 2025 debt issuances are assumed to be 30-year fixed rate bonds with an interest rate of 5.65% and 5.62%, respectively. The interest rate for the debt issuances is based on forward 30-year Treasury rates and adding a spread of 148 basis points which is the spread on the Company's last 30-year debt issuance. Including the planned long-term debt issuance, the weighted average long-term debt cost as of December 31, 2025 is projected to be 4.24%.

9

10 Q29. Why did you use long-term debt cost on a net proceeds basis?

11 A29. The actual costs would be understated if the net proceeds were not used in the base 12 calculation. The net proceeds methodology accounts for underwriters' 13 compensation and other financing expenses and is shown on Exhibit A-14, 14 Schedule D2. A portion of any amount financed is used to fund these costs, such 15 that the Company has access to less than the full amount financed. As a result,

Line <u>No.</u>		T. J. LEPCZYK U-21534
1		these fees and expenses are shown as a reduction in proceeds from the issuance of
2		new securities, thereby increasing the effective cost of the issuance above the stated
3		coupon rate.
4		
5	Q30.	How did you determine the interest rate on short-term debt on Exhibit A-14,
6		Schedule D3?
7	A30.	The total cost of short-term debt is comprised of the interest rate on the short-term
8		debt plus associated facility fees. Supporting credit facilities are required by the
9		rating agencies and investors for DTE Electric to issue commercial paper. These
10		facilities have costs associated with them. The interest rate on the short-term debt
11		was determined by adding 20 basis points (bps) to the 1-month short-term index.
12		Due to the uncertainty of interest rates and Fed Fund rate changes, the Company is
13		using the short-term debt index and short-term debt rate in effect as of December
14		2023. Interest rates have been very volatile recently with market uncertainty around
15		when and if the Fed will lower the Fed Funds rate. Given this unpredictability, the
16		Company feels it is prudent to use the current and known rate. A spread of 20 bps
17		was added to the index because that is the current spread on DTE Electric's
18		commercial paper issuances. See Exhibit A-14, Schedule D3.
19		
20		The current 1-month short-term index is 5.31%. Adding the spread of 20 bps to the
21		index brings the interest rate on short-term borrowings to a total of 5.51%. The
22		cost of the facility fees for the 12-month period ending December 31, 2025, is \$1.3
23		million. This cost was divided by the average outstanding short-term debt balance

24

of \$509 million and equates to 0.25% of the cost of short-term debt. Adding the

Line <u>No.</u>		T. J. LEPCZYK U-21534
1		interest rate on short-term debt of 5.51% to the facility fee cost of 0.25%, results in
2		the total cost of short-term debt of 5.76%.
3		
4	Q31.	What is the purpose of Exhibit A-14, Schedule D4?
5	A31.	Exhibit A-14, Schedule D4 shows that DTE Electric does not plan to have preferred
6		or preference stock during the projected test period.
7		
8	Q32.	What are the Company's current and historical credit ratings?
9	A32.	Exhibit A-18, Schedule H1 shows DTE Electric's and DTE Energy's current and
10		historical credit ratings, along with associated rating agency outlooks, for the
11		previous five years as published by Standard & Poor's (S&P), Moody's Investors
12		Service (Moody's), and Fitch Ratings. The credit ratings include senior unsecured
13		debt, senior secured debt, and commercial paper ratings.
14		
15	Q33.	Have there been recent public utility bond issuances?
16	A33.	Yes. I have provided details of public utility bond issuances for the three-month
17		period prior to, through the three-month period after, each of DTE Electric's long-
18		term debt offerings issued during the 24 months prior to December of 2023. This
19		summary includes the offer date, issuing company, type of offering (either secured
20		or unsecured), Moody's and S&P credit ratings, maturity, tenor, amount of offering,
21		coupon, and issue spread. See Exhibit A-18, Schedule H2.
22		
23	IV.	SECURITIZATION
24	Q34.	Does the Company intend to securitize additional regulatory assets?

Line
<u>No.</u>

1	A34.	Yes. On June 22, 2023, in Case No. U-21338, the Commission approved DTE
2		Electric's application to issue securitization bonds for up to \$601.6 million in costs
3		associated with the closure of the Trenton Channel and St. Clair coal-fired
4		generation plants. The securitization financing was completed in November of
5		2023. The Company is planning a future securitization of the tree trim regulatory
6		assets once the balance is large enough to make a financing feasible.
7		
8	Q35.	How has the tree trim surge regulatory asset been financed in prior rate cases?
9	A35.	On May 2, 2019, the Commission issued its order in Case No. U-20162 whereby
10		the Company was authorized a return on the tree trim surge regulatory asset at the
11		short-term debt cost rate of 3.56%. (p. 80). In Case No. U-20561, Case No. U-
12		20836, and Case No. U-21297 the return on tree trim surge regulatory asset was
13		calculated at the authorized short-term debt rate.
14		
15	Q36.	What does the Company believe is the appropriate financing rate for tree-trim
16		assets?
17	A36.	Given the temporary status, defined in Case No. U-20162, of the tree trim surge
18		regulatory asset, the Company did not pursue financing with permanent long-term
19		debt and equity capital, but rather financed with short-term working capital
20		including short-term debt. Thus, this was matching the financing costs with the
21		return the Company was earning on the regulatory asset. In securitization Case No.
22		U-21015 and Case No. U-21338, the Commission considered the regulatory asset
23		to have been financed with permanent capital and specified that proceeds of the
24		securitization should be used for the repayment of long-term debt and equity.
25		Consistent with that financing order, the Company's position is that any future tree

No.	
-	

1

2

trim surge regulatory asset amounts should be treated as being financed with permanent long-term debt and equity capital and receive the respective return.

3

4 Q37. How does the Company propose to treat the tree trim surge regulatory asset 5 in this instant case?

A37. In Case No. U-21297, the Company reiterated its position that any future tree trimming surge expenditures be financed through the issuance of long-term debt and equity until the time the Company can execute a securitization financing for these amounts., I have directed Witness Vangilder to calculate the return on projected tree trim surge regulatory assets using the cost of permanent long-term debt and equity capital.

12

13 V. SUMMARY AND CONCLUSIONS

14 Q38. Can you summarize your recommendation and conclusions?

15 A38. Due to the financial and business risks faced by the Company, a projected 16 permanent capital structure of 50% long-term debt and 50% common equity is 17 reasonable and prudent. DTE Energy has taken reasonable actions to strengthen 18 DTE Electric's credit quality and has done so by infusing over \$2.3 billion of 19 common equity from 2018 through 2022 and will continue to do so as needed. The 20 plan calls for additional equity infusions and retained earnings growth through the 21 projected test period in the amount necessary to maintain the Company at no less 22 than a ratio of 50% equity to permanent capital at December 31, 2025. For the 23 projected year, the cost of short-term debt is projected to be 5.76%, and the cost of 24 long-term debt is projected to be 4.24%. I believe these expenses and measures are 25 reasonable, prudent and necessary.

Line <u>No.</u>

1 Q39. Does this complete your direct testimony?

2 A39. Yes, it does.