

November 6, 2025

Ms. Lisa Felice
Executive Secretary
Michigan Public Service Commission
7109 W. Saginaw Hwy., 3rd Floor
Lansing, MI 48917

Re: Case No. U-21870 – In the matter of the application of Consumers Energy Company for authority to increase its rates for the generation and distribution of electricity and for other relief.

Dear Ms. Felice:

Enclosed for electronic filing in the above-captioned case, please find the Redacted Version of **Consumers Energy Company's Supplement to Oral Argument**. A **confidential** version will be filed with the Executive Secretary under seal.

This is a paperless filing and is therefore being filed only in a PDF. Also included is a Proof of Service showing electronic service upon the persons included in Attachment 1.

Sincerely,

 Digitally signed by
Bret A. Totoraitis
Date: 2025.11.06
15:15:44 -05'00'

Bret A. Totoraitis
Phone: 517-788-0835
Email: bret.totoraitis@cmsenergy.com
cc: Parties per Attachment 1 to the Proof of Service.

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION

In the matter of the application of)
CONSUMERS ENERGY COMPANY)
for authority to increase its rates for)
the generation and distribution of)
electricity and for other relief.)
_____)

Case No. U-21870

SUPPLEMENT TO ORAL ARGUMENT

SUPPLEMENT TO ORAL ARGUMENT

Per ALJ Jonathan F. Thoits' direction during oral arguments at the November 4, 2025 hearing in the above captioned case, attached are Consumers Energy's responses to MEC's discovery requests identified by the Company as U21870-MNSC-CE-0768 and U21870-MNSC-CE-0769. Because these two discovery responses refer to and rely on numerous other materials previously provided to MEC for a complete response to those questions, the pertinent materials referenced in U21870-MNSC-CE-0768 and U21870-MNSC-CE-0769 are also attached.

Broadly speaking, discovery requests U21870-MNSC-CE-0768 and U21870-MNSC-CE-0769 asked for (i) "documents, workpapers, and analyses" used to develop Consumers Energy's rebuttal exhibits A-202 (RTB-24) and A-203 (RTB-25), (ii) "supporting calculations" for the NPV's in those two exhibits, and (iii) "supporting sources" for all assumed and calculated costs and benefits in those exhibits. During oral arguments, counsel for MEC acknowledged that MEC received the discovery responses and claimed they were deficient, in part, because they "[d]id not include access to the model used to create the new analysis." 2 TR 93¹. However, as the attached discovery materials show, MEC did not request access to the model which the Company could have provided. MEC is aware of this practice as the Company has provided MEC licenses to utilize other third-party modeling software when requested in the past.

The only requested item that the Company was unable to provide was the exact calculation of the NPVs because that calculation is performed by the Copperleaf modeling software, which does not have the capability to display or print the actual calculation. Consumers Energy has no capability to view the exact calculations performed by the software. However, Consumers Energy provided an Excel-based replication of Copperleaf's NPV calculation (see U21870-MNSC-CE-

¹ Citation based on the erroneous volume and page numbering in the transcript filed on November 5, 2025.

0224_ATT_0003) in order to be as responsive as possible given that Consumers Energy does not have possession, custody, or control over Copperleaf’s software code. A party has no legal obligation to produce materials over which it has no possession, custody, or control. See *Lancashire v Moynihan*, 218 Mich 16, 19; 187 NW 319 (1922).

With respect to computer models, such as Copperleaf, the Commission has been clear that utilities cannot take a “go buy it yourself” approach, which is why the Company’s practice has been to provide limited licenses to intervenors upon request. MPSC Case No. U-17678, June 9, 2016 Order, pages 13-14. However, the Commission has also declined to be “overly prescriptive in recommending a course of action” as it relates to discovery access to third-party modeling software. *Id.* at 14. Instead, the Commission has held that “the company should be prepared with any model to present sensitivity analyses to show the significance of underlying assumptions.” *Id.* But, that is exactly what Exhibits A-202 (RTB-24) and A-203 (RTB-25) do. They respond to MEC’s claims of inappropriate underlying assumptions in the Company’s original modeling² by presenting sensitivities consistent with MEC’s preferred assumptions. In Case No. U-17678, the Commission stated that it “reinforces the importance of transparency, evidentiary standards, and understanding the impacts of key assumptions for the Commission to assess the reasonableness of the company’s . . . decisions.” As the attached documents show, the Company has been very transparent and provided as much information as it possesses in its effort to respond to MEC’s discovery. The Company’s responses have, at all times, been consistent with prior Commission direction regarding the third-party computer models as support in rate proceedings.

² During oral argument, MEC also made much of the fact that the original modeling was performed using the new Copperleaf modeling software, as opposed to the original AURORA modeling software. However, that is simply a function of the fact that Consumers Energy started using Copperleaf in October 2024 for all of this type of modeling.

Respectfully submitted,

CONSUMERS ENERGY COMPANY

Dated: November 6, 2025

By: *Bret Totoraitis*
Bret A. Totoraitis (P72654)
Gary A. Gensch, Jr. (P66912)
Anne M. Uitvlugt (P71641)
Spencer A. Sattler (P70524)
Evan B. Keimach (P83418)
One Energy Plaza
Jackson, Michigan 49201
Attorneys for Consumers Energy Company
(517) 788-0835

Question:

5. Refer to Exhibit No. A-202 (RTB-24).
 - a. Please provide all supporting documents, workpapers, and analyses used in developing this new concept approval, in electronic format with formulas intact where applicable.
 - b. Please provide the supporting calculation for all NPVs, in electronic format with formulas intact where applicable.
 - c. Please provide the supporting sources for all assumed or calculated costs and benefits of each alternative.
 - d. Please provide support for the calculation of annual capacity value, including the application of probabilities, in electronic format with formulas intact where applicable.
 - e. Please describe why the probabilities were applied after 2028 and describe how these post-2028 values were used in the calculation.
 - f. Regarding energy value, confirm that even under a 104 MW derate there would be hours of no energy losses because the plant would not be operating at a high level regardless of the derate.
 - g. Confirm that there is potential for the Company to replace the derated capacity for a three-year period at a cost lower than 75% of CONE. If denied, please explain.

Response:

- a. The supporting documentation is reflected in the PSCR case values that are embedded in the Copperleaf models as discussed in prior discovery responses. These values were provided in response to discovery questions U21870-MNSC-CE-071 and U-21870-MNSC-CE-072. The differences between the modeling previously provided and those represented in Exhibit A-202 (RTB-24) are discussed in my rebuttal testimony beginning on page 29. The calculations that the Copperleaf software utilizes are described in the following screen clipping from the software. The assumptions are detailed in the Exhibit. The software provides the results, but it does not have an excel type document that has calculations intact.

Lost Generation Risk

Lost Generation Risk - Outcome

Questionnaire Prompts

Time Invariant (All-Time)

1. Avoided Impact Type: `LGB@avoidedImpactType` (Required)
2. Provide a rationale or assumptions for the numbers provided: `Rationale@timeInvariant` (Required)

Time Variant

1. Unit Derate in MW: `LGB@derate@atts`
2. Time to replace (days): `LGB@timeToReplace`
3. What is the probability of an event occurring?: `RiskLikelihood` (Required)
4. What is the probability of this event occurring?: `Override@likelihood`

Configurable Fields

Investment Facility

- Capacity Factor
- Net Energy Value

Investment Operating Units

- Capacity Factor
- Net Demonstrated Capability (MW)
- Net Energy Value

System

- Currency to Value Units Conversion Factor

Lost Generation Risk - Description

Measure Description

Lost Generation Risk measures the mitigation of risk associated to lost generation capacity in terms of revenue foregone due to unexpected outages. System will default with risk fully mitigated to a value of zero from the month following the last month of the investment spend. User may override and specify an outcome risk profile or a non-default impact date using the Outcome questionnaire.

Measure Calculation

Lost Generation Risk = Lost Generation Consequence * Time To Replace (days) * 24 hours/day * Capacity Factor * Net Energy Value * Risk Likelihood

When Avoided Impact Type is Complete Unit Outage:
Lost Generation Consequence = Operating Unit Net Demonstrated Capability

When Avoided Impact Type is Unit Derate:
Lost Generation Consequence = Derate MW

Where:

- Risk Likelihood = Risk Matrix Likelihood Levels, with a Risk Likelihood discrete override.
- Capacity Factor = Operating Unit Capacity Factor, then Facility Capacity Factor.
- Net Energy Value = Operating Unit Net Energy Value, then Facility Net Energy Value.

Questionnaire Prompt

Configurable Field

The risk mitigated for this Measure is equal to:

Lost Generation Risk = Baseline - Outcome

This Measure is calculated in Dollar.

Financial Risk

Financial Risk Matrix - Outcome

Questionnaire Prompts

Time Variant

1. What is the consequence of a potential event?: `RiskConsequence` (Required)
2. What is the probability of an event occurring?: `RiskLikelihood` (Required)

Financial Risk - Description

Measure Description

Financial Risk measures the mitigation of potential financial risks such as financial losses due to damage to equipment or company assets if the Investment is not completed. This Measure is calculated in Value Units using the standard approach for all Risk Matrix Measures. System will default with risk fully mitigated to a value of zero from the month following the last month of the investment spend. User may override and specify an outcome risk profile or a non-default impact date using the Outcome questionnaire.

Measure Calculation

Financial Risk = Risk Consequence * Risk Likelihood

Questionnaire Prompt

The risk mitigated for this Measure is equal to:

Financial Risk = Baseline - Outcome

This Measure is calculated in Value Units.

- The Company provided examples of the NPV calculations that Copperleaf performs and a document that explains in detail how those are calculated (see Exhibit A-205 (RTB-27)) and example in U21870-MNSC-CE-0224_ATT_0003. See my rebuttal testimony beginning on page 33.
- See the response to subparts b and d.
- For annual capacity value and application of probability, the Company provided the generic calculator used for estimating potential capacity lost revenue as well as a document explaining in detail how it works (see Exhibit A-205 (RTB-27)). The probability portion of this question is related to the financial risk model in Copperleaf as captured in subpart a. For the assumed values for Capacity Factor by month see U21870-MNSC-CE-0768_ATT_0001. This document includes all the data for the

background calculations for the Jackson site. In row 2 the assumed capacity factors are listed by month starting January 2024 in column O progressing by month moving to the right. These values are the same as the latest approved PSCR case.

- e. Copperleaf's valuation methodology begins by establishing a baseline risk scenario—representing the cumulative risk of inaction through 2039. This baseline serves as the foundation for comparison. To determine the value of a proposed project, Copperleaf subtracts both the risk that would be mitigated prior to the project's completion and the associated project costs from the total baseline risk. The result is the net value of the project, expressed as the amount of risk mitigated. $\text{Value} = \text{Baseline Risk} - (\text{Residual Risk} + \text{Project Cost})$
- f. Confirmed. However, the updated calculations include capacity factor projections and therefore are reflected in the new results.
- g. The 75% of CONE value is simply a planning assumption and is not a value based on specific market intelligence. I am unable to confirm the availability of capacity, nor the cost of any such capacity.

Witness: RICHARD T. BLUMENSTOCK

Date: October 29, 2025

U21870-MNSC-CE-0768-ATT-0001

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

[Illegible text]

U21870-MNSC-CE-0768-ATT-0001

U21870-MNSC-CE-0768-ATT-0001

Question:

6. Refer to Exhibit No. A-203 (RTB-25).
 - a. Please provide all supporting documents, workpapers, and analyses used in developing this new concept approval, in electronic format with formulas intact where applicable.
 - b. Please provide the supporting calculation for all NPVs, in electronic format with formulas intact where applicable.
 - c. Please provide the supporting sources for all assumed or calculated costs and benefits of each alternative, in electronic format with formulas intact where applicable.

Response:

- a. For the LM VIGV project benefits (heat rate during duct burning (286 Btu/kWh) and non-duct burning (189 Btu/kWh)), GE provided us with a fact sheet on the VIGV enhancement as well as performance estimate graphs. This simple cycle info was entered into our EBSILON® Professional modeling software program to get the estimated heat rate changes for the JGS combined cycle plant. Attached as U21870-MNSC-CE-0769_ATT_0001, U21870-MNSC-CE-0769_ATT_0002_CONF, and U21870-MNSC-CE-0769_ATT_0003_CONF are copies of the VIGV fact sheet and budgetary estimates/ proposals which have info utilized for modeling, and communication of EBSILON® modeling results. The calculation for Heat Rate that the Copperleaf software utilizes are described in the following screen clipping from the software. The calculations for Lost Generation Risk and Financial Risk are included in U21870-MNSC-CE-0768 part a. The assumptions for each calculation are detailed in the Exhibit. The software provides the results, but it does not have an excel type document that has calculations intact. The Fuel Cost assumptions are included in U21870-MNSC-CE-0768_ATT_0001, row 3.

Heat Rate

The screenshot displays a software interface for 'Heat Rate - Outcome'. The main window is titled 'Heat Rate - Outcome' and contains 'Questionnaire Prompts' and 'Configurable Fields'. The 'Questionnaire Prompts' section includes a 'Time Invariant (All-Time)' prompt asking for a rationale or assumptions, and a 'Time Variant' prompt asking for heat rate improvement and fuel cost. The 'Configurable Fields' section lists 'Investment Operating Units' (Capacity Factor, Fuel Cost, Net Demonstrated Capability) and 'System' (Currency to Value Units Conversion Factor). A secondary window titled 'Fuel Savings Description' is open on the right, showing the measure description, calculation formula, and questionnaire prompt.

Heat Rate - Outcome

Questionnaire Prompts

Time Invariant (All-Time)

1. Provide a rationale or assumptions for the numbers provided. *RationaleTimeInvariant* (Required)

Time Variant

1. What is the Heat Rate Improvement at Full Load (Btu/kWh) after completing this investment? *HeatRateImprovement* (Required)

2. If there is a change in the fuel blend, what is the new fuel cost (\$/MMBtu)? *HeatRateFuelCostOverride*

Configurable Fields

Investment Operating Units

- Capacity Factor
- Fuel Cost (\$/MMBtu)
- Net Demonstrated Capability (MW)

System

- Currency to Value Units Conversion Factor

Fuel Savings Description

Measure Description

Fuel Savings measures the impact of a heat rate improvement when it results in a decrease in fuel consumption.

Measure Calculation

$$\text{Fuel Savings} = \text{Heat Rate Improvement} * 1,000 * \text{Operating Unit Net Demonstrated Capacity} * \text{Operating Unit Capacity Factor} * \text{Fuel Cost} (\$/\text{MMBtu}) / 1,000,000 * 8760 \text{ hours/year}$$

Where: Fuel Cost = Fuel Cost Override if answered. If not, Operating Unit Fuel Cost.

Questionnaire Prompt

Configurable Field

The benefit generated for this Measure is equal to:

Fuel Savings = Outcome

This Measure is calculated in Dollar.

- b. The concept approval and the NPV calculations are performed in Copperleaf pursuant to the procedure provided in both discovery and as Exhibit A-203 (RTB-25). No other NPV support is available in electronic format other than the detailed discussion of how Copperleaf models NPV as provided in Exhibit A-205 (RTB-27).
- c. Please see attachments U21870-MNSC-CE-0769_ATT_0004_CONF, U21870-MNSC-CE-0769_ATT_0005_CONF, and U21870-MNSC-CE-0769_ATT_0006_CONF, which reflect the costs for the stalled engine. This represents the bulk of the total cost.

Witness: RICHARD T. BLUMENSTOCK

Date: October 27, 2025

Variable Inlet Guide Vane (VIGV)


Product Description

- Variable Inlet Air vanes help guide inlet airflow to maximize engine performance.
- Assembly located in front of Low Pressure Compressor (LPC), consisting of 43 stationary leading-edge vanes and variable trailing flaps (rotate -10 to +60 degrees).
- Variable Differential Transformers (LVDTs) on actuator ring drivetwin hydraulic actuators.
- LVDTs and VIGV positions are controlled by continuous measurement of LPC inlet temperature and HPC discharge static pressure.
- If turbine has Fixed Inlet Guide Vanes, the upgrade involves adding VIGVs, Hydraulic Control Unit (if applicable), off-engine Cables, hydraulic lines and updating the software.



Variable Inlet Guide Vanes Assembly

Temp. (F)	Power Increase
70	2.0%
80	5.8%
90	7.2%
100	11.5%
110	13.5%



Customer Benefits

- Increases generator power output by up to 3.25 MW.
- Improves performance for simple and heat recovery cycles at less than full load; reduces engine waste heat.
- Minimizes variable bypass valve (VBV) flow and pressure levels thereby reducing associated flow noise

For LM6000PC SPRINT Gas Turbine with EFS

- Average power increase of 2 MW.
- Greater than 2% fuel efficiency increase at 70% power.
- Exhaust energy increase of 3%.
- Flaps close during large power reductions to quickly reduce LPC flow rate, helping maintain LPC stall margin.

Applicable Units

LM6000*	✓	LM2500	
LMS100		LM5000	
LM1600		TM2500	

* Configured for LM6000 PC units only

To learn more about this product and its applicability to your gas turbine, please contact your GE Gas Power sales representative.

gepower.com



**Discovery Response U21870-MNSC-CE-0769
Attachments 0002 through 0006
are confidential and being filed Under Seal with
the MPSC**

Methodology for Quantifying Capital Investment Risk with Copperleaf Value Models – Consumers Energy

Purpose and scope

This document explains how the Company converts engineering and operational risk into dollar-denominated values for investment evaluation. It is intended for the reader to understand the logic behind the results; it does not require access to internal tools or data libraries. The same expected-value reasoning is applied year by year and results are discounted to present value using the Company's approved discount rate.

Model overview

The Company employs multiple model families; this document illustrates three commonly used examples:

1. Financial Risk Matrix — converts the chance of an adverse event and its consequence into an expected annual cost; value equals the risk avoided by the investment.
2. Lost Generation Risk (Energy Only) — quantifies the dollar value of lost energy (MWh) from derates or outages; value equals the avoided energy loss.
3. Financial Benefits & Costs — prices direct financial effects (costs avoided, revenues, and ongoing costs).

Principal value drivers

In practice, the Financial Risk Matrix and Lost Generation Risk models are the most widely used and account for the majority of risk-mitigation value in the Company's Long-Term Financial Plan. Capacity value lost risk is handled within the Financial Risk Matrix to avoid overlap with energy-only valuation.

Common frame (applies to all models)

- Baseline vs With-Project ("Outcome"): Baseline represents conditions if we do nothing; Outcome represents conditions after the investment. Annual value is the difference: Annual Value (\$) = Baseline Expected Impact (\$) – Outcome Expected Impact (\$).
- Expected value: Uncertain events are priced by multiplying their consequence (in \$ if they occur) by how likely they are to occur that year. This yields a single expected \$ figure for the year.
- Discounting: After computing annual values across the planning horizon, we calculate NPV using a constant discount rate specified by Company finance policy.
- Evidence base (examples): work orders and repair history; outage/derate logs and time-to-restore; unit operating profile and duty cycle; inspection findings and sensor trends; OEM notices; age/obsolescence; supply-chain lead times; peer and industry

experience (including EPRI guidance); and structured SME judgments recorded through Company procedures.

1) Financial Risk Matrix (general risk in dollars)

What it measures: the expected annual cost of a defined hazard (safety, environmental, compliance, or financial), and the amount of that cost the project removes.

How it works, step by step

- Define the hazard and pathway. We state what can go wrong, how it unfolds, and which impact categories it touches. This ensures the risk we price is specific and non-overlapping with other models.
- Monetize the consequence. For each year, we determine the dollar impact if the event occurs in that year. This can include response and repair cost, regulatory or contractual impacts, and business effects appropriate for that hazard. Values are drawn from Company-maintained sources that reflect current costs and obligations.
- Quantify how often it may occur. For each year, we express likelihood as either a frequency (events per year) or a probability for that year. Figures are derived from the evidence base above and recorded through our governance process.
- Convert uncertainty into dollars. Expected annual risk equals consequence \times likelihood. This yields a single dollar amount for that year under Baseline.
- Reflect the project's effect. With the project in place, severity and/or frequency typically decline. We determine the with-project consequence and likelihood in the same manner and compute the Outcome expected risk.
- Value created. Annual value is the avoided risk (Baseline minus Outcome). We then discount and sum across years to get NPV.

Capacity value lost risk (handled here)

- Use Capacity Calculator outputs for each year to identify the magnitude and timing of potential capacity exposure relative to accreditation or obligations. These exposure drivers are not re-estimated here.
- Monetize the exposure by applying the Company's capacity valuation parameters for the relevant years (market/regulatory cost components for our jurisdiction and obligations). These parameters are maintained internally and updated on defined cycles as conditions change. The result is a dollar consequence if the exposure materializes in that year.
- Account for chance by assigning, for each year, the likelihood that the exposure will materialize as a dollar impact, consistent with the same evidence base and governance protocols used elsewhere.
- Compute expected annual capacity value loss under Baseline and re-compute under Outcome if the project reduces the exposure (magnitude, timing, or likelihood). The difference is the annual value attributable to mitigating capacity value risk.

2) Lost Generation Risk (energy only)

What it measures: the dollar value of lost energy production due to unit derates or full outages and the portion of that loss the project avoids. This model does not address capacity market value or capacity accreditation.

How it works, step by step

- Describe the operational shortfall for each year: either a derate (the unit can run but at reduced MW) or a complete outage (the unit cannot produce). Specify the MW affected and the expected duration to restore normal operation.
- Translate MW and time into energy. Lost MWh per event equals MW affected × 24 hours × number of days, adjusted for how the unit is expected to operate during that period (capacity factor for the affected window). Operating profiles come from Company-maintained sources that reflect expected duty cycles.
- Monetize the lost energy. Multiply lost MWh by the applicable energy value (\$/MWh) for that year (net of costs as appropriate). Energy values are obtained from Company-maintained price/valuation sources refreshed on defined cycles.
- Account for chance. Express how often such a derate/outage is expected in that year (frequency or probability) based on history, condition, and SME protocols, and multiply by the dollar consequence to get the expected annual loss under Baseline.
- Project effect. The project may shorten the duration, reduce the MW affected, reduce the likelihood, or some combination. Recompute the Outcome expected loss with those changes.
- Value created. Annual value is the avoided energy loss; NPV aggregates those annual values.

3) Financial Benefits & Costs

Note: This model does not include capacity value lost risk; those impacts are valued within the Financial Risk Matrix using outputs from the Capacity Calculator.

What it measures: direct financial effects that show up as dollars—costs we avoid, revenues we gain, or ongoing costs attributable to the project.

How it works, step by step

- Identify the financial streams that the project influences (e.g., avoided corrective capex, avoided O&M, incremental revenue, or ongoing costs attributable to the project). Streams are kept distinct to prevent double-counting.
- Size the dollar amounts for each stream by year, using Company-maintained financial and operational sources (e.g., standard labor/material costs, contract terms, or tariff mechanisms).
- Represent uncertainty by assigning a likelihood (0–1) for each stream in each year, following the same governance used elsewhere.

- Compute expected value for each stream and year (amount × likelihood) and sum across streams to obtain the net annual financial effect.
- Value created is the net with-project improvement relative to Baseline, discounted to NPV.

Additional model families employed

- Safety Risk (personnel and public harm, medical/claim costs, and associated operational impacts)
- Regulatory Compliance Risk (violations, penalties, corrective actions, and programmatic impacts)
- Environmental Risk (releases, remediation/response, permitting, and stewardship commitments)
- Other specialized models are applied as warranted by the investment context. All follow the same expected-value logic and governance described in this document.

Relationship to prior business-case practice

- Alignment with prior business-case practice.
 - These value models formalize the same expected-value logic historically used in our narrative business cases (likelihood × impact by year, discounted to present value).
- Structured improvements introduced by Copperleaf.
 - The platform enforces a consistent, systematic structure across all investments: common Baseline vs Outcome framing; governed, Company-maintained input sources updated on defined cycles; a uniform year-by-year treatment of uncertainty; and a single NPV roll-up.
- Implications for portfolio decision-making.
 - This removes variability in author style and assumptions, places projects on a level playing field, enables like-for-like comparison across technologies and sites, and gives leadership a clear portfolio view of risk and value.
- Impact for customers and ratepayers.
 - A more objective, repeatable method for selecting the optimal risk-mitigation portfolio—supporting lower total cost and better reliability outcomes.

Governance, transparency, and QA

- Recorded reference values: For each plant, we keep the values that drive the calculations—Net Energy Value (NEV), Net Demonstrated Capacity (NDC), fuel cost, and capacity factor—and update them on defined cycles as those inputs change. Other supporting engineering context is maintained separately; we don't time-stamp every data point inside the value model.

- Consistency: The same rules are applied to Baseline and Outcome; differences in value come from the project's effect, not from changing the standard.
- Reasonableness checks: Unit consistency (e.g., MW→MWh, \$/MWh→\$), bounds on probabilities, and year-to-year continuity are verified.
- Change control: When inputs are updated, the prior set and the new set are retained; impacts of changes can be traced year by year.

Question:

2. Refer to Exhibits RTB-5 through RTB-12. Please provide the supporting calculations and analyses used to evaluate the costs and benefits of each project, in Excel format where possible.

Response:

Please see Attachment U21870-MNSC-CE-0071_ATT_0001 which provides a summary table containing relevant modeling information for the eight projects presented in Exhibits RTB-5 through RTB-12. The table provides details regarding the applicable calculation methodology for the net energy value (NEV), the applicable NEV calculation details, the applicable methodology used for capacity losses, and the applicable capacity loss analysis. The Company did not retain the modeled version of the outputs for each project, however the calculator used and the draft procedure for the calculator are provided as Attachments U21870-MNSC-CE-0071_ATT_0002 and U21870-MNSC-CE-0071_ATT_0004 respectively.

Attachments U21870-MNSC-CE-0071_ATT_0003, 0005, and 0006 are also attached and support NEV calculations for several of the projects as referenced in Attachment U21870-MNSC-CE-0071_ATT_0001. Other details are contained in attachments provided in separate discovery response attachments, also as referenced in Attachment U21870-MNSC-CE-0071_ATT_0001.

Witness: RICHARD T. BLUMENSTOCK

Date: July 24, 2025

project	NEV calculation method	NEV calculation details or location	Capacity losses calc method	Capacity losses analysis Method location
ZGS PH 1/2 turbine upgrades	aurora model and NPV analysis	U21870-ST-CE-0007_ATT_0001_CONF U21870-ST-CE-0007_ATT_0002_CONF	included in formal Analysis	U21870-ST-CE-0007_ATT_0001_CONF U21870-ST-CE-0007_ATT_0002_CONF U21870-MNSC-CE-0071_0002
Jackson Site spare GSU	aurora model	U21870-MNSC-CE-0071_0003	calculator	U21870-MNSC-CE-0071_0004 U21870-MNSC-CE-0071_0002
Covert Load Commutated Inverter Static Frequency	aurora model	U21870-MNSC-CE-0071_0006	calculator	U21870-MNSC-CE-0071_0004
		U21870-MNSC-CE-0071_0005		
		This is a 2023 CA. Prior to Aurora modeling by SME, The reported PSCR plan was used to estimate NEV. The potential NEV losses calculated for this CA were obtained by taking the 3 unit average of the 2025 NEV for the site since the assumption is that the potentially affected unit would not be able to operate for at least a year should the corresponding GSU fail with no spare on site. PSCR results sheet provided.		
Covert Site Spare GSU Transformer Concept Approval	PSCR case U-21225, NEV and LPM section, 2025 average no econ modeling needed, compliance based CA	no econ modeling needed, compliance based CA	Manual calculation detailed in CA. Prior to current calculator. Similar inputs and assumptions	U21870-ST-CE-0004_0004
Covert Control System Project Concept Approval	no econ modeling needed, compliance based CA	no econ modeling needed, compliance based CA	no econ modeling needed, compliance based CA	U21870-MNSC-CE-0072_0009
Covert Units 1 through 3 Emerson DCS Evergreen	no econ modeling needed, compliance based CA	no econ modeling needed, compliance based CA	no econ modeling needed, compliance based CA	U21870-MNSC-CE-0072_0008
Karn Unit 4 ID Fan Inlet Damper Replacements	No NEV calc since Karn is assumed to be zero	N/A	calculator	U21870-MNSC-CE-0071_0002 U21870-MNSC-CE-0071_0004
Karn Units 3 & 4 Combustion Air Heater Replacement	No NEV calc since Karn is assumed to be zero	N/A	calculator	U21870-MNSC-CE-0071_0002 U21870-MNSC-CE-0071_0004

Owned Capacity Values	Summer				Fall				Winter				Spring				Low Gas										High Gas				3 yr Historical											
	GVTC	SAC	GVTC	SAC	GVTC	SAC	GVTC	SAC	GVTC	SAC	GVTC	SAC	GVTC	SAC	2025	2026	2027	2028	2029	2025h	2026h	2027h	2028h	2029h	2025	2026	2027	2028	2029													
Gratiot Farms Wind Project	150	36.3	150	32.5	150	36.4	150	28.8						(45.45)	(43.63)	(71.11)	(8.99)	(7.91)		(45.36)	(43.62)	(71.11)	(9.04)	(8.00)	24,701,222									74103666.02								
Alcona 1-2	2.7	2.7	2.8	2.8	2.9	2.9	3.7	3.7						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00												\$3,697,789						
Alligan 1-3	1.2	1.2	0.9	0.9	1.4	1.4	1.9	2						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00													\$80,151,730					
Campbell 1	0	0	0	0	0	0	0	0						5.09	-	-	-	-		5.19	-	-	-	-												\$62,710,988						
Campbell 2	0	0	0	0	0	0	0	0						7.15	-	-	-	-		7.26	-	-	-	-												\$296,990,986						
Campbell 3	0	0	0	0	0	0	0	0						5.95	-	-	-	-		6.06	-	-	-	-																		
Circuit West	0.2	0.2	0.1	0.1	0	0	0	0						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Cooke 1	1.6	1.5	1.6	1.5	1.5	1.5	1.6	1.5						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Cooke 2	2.9	2.7	2.9	2.8	2.9	2.7	2.9	2.7						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Cooke 3	2.7	2.6	2.7	2.6	2.8	2.6	2.7	2.5						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Crescent Wind	150	24.4	150	27.6	150	30.4	150	26						(36.43)	(34.31)	(3.11)	(4.99)	(3.91)		(36.34)	(34.30)	(3.11)	(5.04)	(4.00)	22,995,268												\$68,965,803					
Cross Winds Phase 1	110.98	25.5	110.98	24.4	110.98	32.2	110.98	26.6						(40.74)	(38.86)	(14.11)	(15.99)	(14.91)		(40.65)	(38.85)	(14.11)	(16.04)	(15.00)	44,951,425												\$139,854,274					
Cross Winds Phase 2	43.7	10	43.7	9.6	43.7	12.7	43.7	10.5						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Cross Winds Phase 3	75.9	17.4	75.9	16.7	75.9	22	75.9	18.2						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Croton 1-4	2.1	2.1	2.1	2.1	3.7	3.7	3.9	3.9						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00	1,260,828												\$3,782,484					
Five Channels 1	3.2	3	3.3	3.1	3.3	3	3.2	2.9						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Five Channels 2	3	2.8	3.1	2.9	3.1	2.8	3	2.8						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Footie 1-3	2.7	2.8	2.8	2.9	2.9	3	4	4.1						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
GVSU Solar Garden	1.6	1.7	0.8	0.8	0	0	1.3	1.3						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Hardy 1	10.6	10.3	10.6	10	9.8	9.7	9.8	9.8						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00	3,767,600													\$11,302,800				
Hardy 2	10.6	10.3	10.6	10	9.8	9.7	9.9	9.9						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Hardy 3	12.1	11.8	12.1	11.4	11.4	11.3	11.4	11.4						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Heartland	200	31.5	200	61.4	200	46.7	200	27.3						(24.14)	(22.78)	(12.86)	(14.74)	(13.66)		(24.05)	(22.77)	(12.86)	(14.79)	(13.75)	66,858													\$200,574				
Hodensly 1-2	4.1	4.1	4.4	4.4	5.1	5.1	6	6						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00	1,627,559													\$4,880,676				
Jackson Plant	531.1	505.6	536.9	503.6	568.9	575.1	544.9	547.1						17.46	17.64	16.82	14.53	16.83		17.51	17.65	16.71	14.42	16.87	31,819,280													\$95,457,840				
Karn 3	602.2	326.9	604.8	225	614.9	322.1	609	177.8						10.75	4.29	1.62	1.61	1.40		10.78	4.33	1.45	1.59	1.41	(1,826,731)														\$5,480,193			
Karn 4	586.7	539	591.4	437.9	615.2	390.8	600.5	374.2						5.21	4.61	-	-	-		5.14	4.60	-	-	-	(2,451,743)														\$7,355,228			
Lake Winds Energy Park	100.8	17.9	100.8	20.9	100.8	25.9	100.8	16.9						(81.94)	(83.36)	(78.72)	(82.72)	(83.84)		(81.84)	(83.34)	(78.72)	(82.77)	(83.93)	10,284,201														\$30,852,602			
Loud 1	2.5	2.4	2.5	2.4	2.5	2.3	2.5	2.3						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Loud 2	2.5	2.4	2.5	2.4	2.5	2.3	2.5	2.3						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Ludington 1	187.017	185.2	190.179	171	187.68	180.6	187.374	178.2						42.75	47.08	35.75	47.06	48.95		43.06	46.85	35.77	47.18	48.70	(2,837,851)															\$8,513,522		
Ludington 2	186.507	185.4	189.669	172.7	187.17	177.5	186.864	177.4						42.60	48.15	25.82	29.20	48.92		43.20	47.18	25.43	19.33	48.66	(7,984,455)															\$23,953,365		
Ludington 3	185.997	184.6	189.159	161.7	186.66	186.2	186.354	176.2						42.11	36.84	46.39	46.66	48.97		42.10	36.33	46.32	45.91	48.74	(1,725,398)																\$5,176,193	
Ludington 4	187.017	185.4	190.179	146.3	187.68	173.3	187.374	186.7						42.23	20.38	23.24	46.12	48.98		42.18	20.28	23.10	45.82	48.70	(8,392,817)															\$25,178,451		
Ludington 5	187.017	185.4	190.179	172.3	187.68	178.9	187.374	182.6						42.44	46.73	46.65	28.44	12.22		42.79	46.42	47.00	28.50	12.28	(7,971,533)																	
Ludington 6	185.487	184	188.649	181.4	186.15	179.2	185.844	185.4						42.74	46.94	45.36	31.71	48.91		42.71	46.50	48.10	31.71	48.64	(5,770,842)																	
Mio 1-2	1.3	1.3	1.5	1.6	1.6	1.6	2	2.1						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Cadillac Solar Garden	0.2	0.2	0.2	0.2	0	0	0.2	0.2						41.57	44.83	44.89	43.01	44.09		41.66	44.84	44.89	42.96	44.00																		
Rogers 1-4	2	2.1	2.6	2.7	2.9	3	3	3.1																																		

Outage Exemptions

Annual

	Maint Margin* ≥ 0 for duration of outage	Maint Margin < 0 for duration of outage
>120 days notice of outage	Exempt Tier 1&2	Exempt Tier 1&2
14-119 days notice of outage	Exempt Tier 1&2	No Exemption

* No harm = MISO discretion

Seasonal

	Maint Margin ≥ 0 for duration of outage	Maint Margin < 0 for duration of outage
>120 days notice of outage, no outage in previous 120 days	Exempt Tier 1&2	Exempt Tier 1 Only I
>120 days notice of outage, outage in previous 120 days	Exempt Tier 1 Only	No Exemption
31-119 days notice of outage	Exempt Tier 1 Only	No Exemption
14-30 days and *no harm	Exempt Tier 1 Only	No Exemption
Outage moved per MISO Request	Fully Exempt (Weather, forced, conditions BPM-008 section 4.3)	N/A
	Rescheduled to better margin	

*See Definitions in the Appendix

Y filing.

6.4.3 Transfer of Resource Adequacy Requirement and Performance Requirements through ZRC Replacement

ZRC replacement is available for use by Planning Resources that cleared a Season in the Planning Year and that go on suspension, retirement, catastrophic outage, ICAP Deferral, or that experience a Generator Planned Outage or derate greater than 31 days in that Season. In the event of such ZRC Replacement any performance requirements associated with the Resource that is being replaced (e.g., must offer obligation) will be transferred to the substituting Resource(s) for the duration of the ZRC Replacement period. ZRC Replacement is forward looking, MPs cannot replace ZRCs retroactively.

A Resource being used for ZRC replacement must not be on a full or partial Generator Planned Outage during the term of the ZRC replacement and must otherwise meet the applicable performance requirements set forth in section 69.A.3.1.h of Module E-1 of the Tariff.

Jackson Spare Analysis

11/13/2024

The analysis considers two scenarios:

Base: No changes made**90 Day Outage:** Jackson has 104 MW on maintenance from June 1st to August 31st, 2025**1080 Day Outage:** Jackson has 104 MW on maintenance from June 1st to May 16th, 2028Values are represented as **negative** (reduction to customer cost)Expenses are represented as **positive** (customer expense)

Net Present Value Results	90 Day Outage	1080 Day Outage
Current Nameplate Capacity (MW)	547	547
Upgraded Capacity (MW)	547	547
Incremental Energy(K\$)	\$8,809	\$79,392
Incremental Capacity Revenue (K\$)	\$0	\$0
Incremental Operating Costs (K\$)	(\$5,694)	(\$58,142)
Total Value of Phase 2 Upgrade (K\$)	\$3,115	\$21,251

Annual Detailed Results	90 Day Outage	
	Incremental Energy Revenue (K\$)	Incremental Operating Costs (K\$)
2025	\$8,809	(\$5,694)
2026	\$0	\$0
2027	\$0	\$0
2028	\$0	\$0

Annual Detailed Results	1080 Day Outage	
	Incremental Energy Revenue (K\$)	Incremental Operating Costs (K\$)
2025	\$16,863	(\$11,532)
2026	\$28,262	(\$20,909)
2027	\$24,911	(\$18,217)
2028	\$9,357	(\$7,483)

Helper	Run ID	Year	Name	Capacity	Capacity Factor	Energy Revenue(000s)	Energy Revenue	Capacity Revenue	Total Revenue	Total Cost MWh	Total Cost	Total Value	Dispatch Cost	Output (MWh)	Fuel Usage (mmBTU)
Jackson O Base-2025-Jackson	Jackson O Base	2025	Jackson	547	84%	\$ 154,725	\$ 154,724,700	\$ 49,029,563	\$ 203,754,263	\$ 27	\$ 158,129,775.36	\$ 65,624,487.16	\$ 30	4,008,741	21,203,650
Jackson O Base-2026-Jackson	Jackson O Base	2026	Jackson	547	72%	\$ 139,979	\$ 139,978,900	\$ 50,108,213	\$ 190,087,113	\$ 30	\$ 183,827,654.16	\$ 66,259,458.73	\$ 30	3,468,329	28,403,600
Jackson O Base-2027-Jackson	Jackson O Base	2027	Jackson	547	65%	\$ 125,390	\$ 125,389,200	\$ 52,210,594	\$ 176,600,794	\$ 29	\$ 161,557,404.67	\$ 65,043,388.91	\$ 30	3,111,486	25,270,250
Jackson O Base-2028-Jackson	Jackson O Base	2028	Jackson	547	70%	\$ 135,090	\$ 135,089,500	\$ 52,337,227	\$ 187,426,727	\$ 30	\$ 180,619,908.44	\$ 66,806,818.20	\$ 30	3,356,196	27,230,460
					NPV	\$ 555,183	\$ 555,183,300	\$ 202,685,596	\$ 757,868,896		\$ 404,134,743	\$ 353,734,153	\$ 30	\$ 13,944,702	\$ 113,197,360
						\$ 472,280	\$ 472,280,400	\$ 177,319,393	\$ 649,599,796		\$ 343,183,520	\$ 300,356,275			

Helper	Run ID	Year	Name	Capacity	Capacity Factor	Energy Revenue(000s)	Energy Revenue	Capacity Revenue	Total Revenue	Total Cost MWh	Total Cost	Total Value	Dispatch Cost	Output (MWh)	Fuel Usage (mmBTU)
Jackson 90 Days-2025-Jackson	Jackson 90 Days	2025	Jackson	547	79%	\$ 145,916	\$ 145,915,700	\$ 49,029,563	\$ 194,945,263	\$ 27	\$ 182,435,926.26	\$ 62,509,338.26	\$ 28	3,794,699	30,846,000
Jackson 90 Days-2026-Jackson	Jackson 90 Days	2026	Jackson	547	72%	\$ 139,979	\$ 139,978,900	\$ 50,108,213	\$ 190,087,113	\$ 30	\$ 183,827,654.16	\$ 66,259,458.73	\$ 30	3,468,329	28,403,600
Jackson 90 Days-2027-Jackson	Jackson 90 Days	2027	Jackson	547	65%	\$ 125,390	\$ 125,389,200	\$ 52,210,594	\$ 176,600,794	\$ 29	\$ 161,557,404.67	\$ 65,043,388.91	\$ 30	3,111,486	25,270,250
Jackson 90 Days-2028-Jackson	Jackson 90 Days	2028	Jackson	547	70%	\$ 135,090	\$ 135,089,500	\$ 52,337,227	\$ 187,426,727	\$ 30	\$ 180,619,908.44	\$ 66,806,818.20	\$ 30	3,356,196	27,230,460
					NPV	\$ 546,874	\$ 546,874,300	\$ 202,685,596	\$ 749,559,896		\$ 398,440,394	\$ 350,619,002	\$ 30	\$ 13,790,660	\$ 114,460,360
						\$ 464,048	\$ 464,047,600	\$ 177,319,393	\$ 641,367,000		\$ 337,922,166	\$ 297,444,919			

Helper	Run ID	Year	Name	Capacity	Capacity Factor	Energy Revenue(000s)	Energy Revenue	Capacity Revenue	Total Revenue	Total Cost MWh	Total Cost	Total Value	Dispatch Cost	Output (MWh)	Fuel Usage (mmBTU)
Jackson 1080 Days-2025-Jackson	Jackson 1080 Days	2025	Jackson	547	75%	\$ 137,861	\$ 137,861,100	\$ 49,029,563	\$ 186,890,663	\$ 17	\$ 185,977,504.41	\$ 60,293,358.11	\$ 28	3,528,960	29,181,050
Jackson 1080 Days-2026-Jackson	Jackson 1080 Days	2026	Jackson	547	58%	\$ 111,717	\$ 111,717,400	\$ 50,108,213	\$ 161,825,613	\$ 30	\$ 162,918,538.72	\$ 66,907,074.18	\$ 30	2,761,890	23,380,400
Jackson 1080 Days-2027-Jackson	Jackson 1080 Days	2027	Jackson	547	53%	\$ 100,480	\$ 100,479,500	\$ 52,210,594	\$ 152,690,094	\$ 29	\$ 153,240,078.62	\$ 68,250,054.96	\$ 30	2,494,032	20,257,700
Jackson 1080 Days-2028-Jackson	Jackson 1080 Days	2028	Jackson	547	65%	\$ 125,733	\$ 125,732,800	\$ 52,337,227	\$ 178,070,027	\$ 30	\$ 181,336,830.13	\$ 64,933,198.51	\$ 30	3,118,555	25,905,690
					NPV	\$ 475,791	\$ 475,791,000	\$ 202,685,596	\$ 678,476,596		\$ 345,192,252	\$ 332,483,644	\$ 29	\$ 11,963,437	\$ 97,124,860
						\$ 466,363	\$ 466,362,700	\$ 177,319,393	\$ 643,682,100		\$ 329,623,297	\$ 320,058,990			

Output DB 2024P1ce08Dispatch Jacksonspare 1080Days 2

Year	Capacity Price (\$/Mwh-yr)	#FOR	Capacity (MW)
2023	127.130		
2024	129.214	0.9	
2025	132.790	CONE	75%
2026	138.710		
2027	138.698		
2028	141.740		
2029	143.861		
2030	146.054		
2031	151.310		
2032	156.640		
2033	159.640		
2034	161.520		
2035	165.071		
2036	168.700		
2037	174.451		
2038	179.200		
2039	181.080		
2040	184.048		

Consumers Energy Lost Capacity Calculator – Methodology & Regulatory Notes

Draft workpaper for discussion with Michigan Public Service Commission (MPSC)

Version 1.0 (2025-07-17 build)

Prepared by: Consumers Energy Generation Asset Strategy & Forecasting Teams

Contact: [insert name / email]

CONFIDENTIAL DRAFT – Do not distribute outside Consumers Energy / MPSC Staff without approval.

1. Purpose

Extended forced outages (or material derates) on generating units can reduce the accredited capacity we rely on to meet MISO Planning Reserve Margin Requirements (PRMR) and to earn capacity revenue. Because actual market outcomes (Planning Resource Auction clearing prices, bilateral forwards, accreditation rules) are uncertain and can span multiple future planning years, we use a streamlined calculator to produce a conservative, internally consistent estimate of the potential capacity value at risk when evaluating investment alternatives and responding to Michigan Public Service Commission (MPSC) data requests.

This document describes the logic in the Lost Capacity Calculator workbook supplied by the Forecasting Team, explains key inputs, shows the Excel formulas, demonstrates a worked example, and identifies the embedded conservatism that makes the results a lower-bound (60–70% view) of potential capacity losses. It is intended to accompany the calculator when provided to MPSC Staff.

2. Overview: Capacity Value Streams & What the Tool Captures

Capacity value at risk from an outage can manifest in several ways:

- Loss or reduction of Zonal Resource Credits (ZRCs) used to meet PRMR compliance.
- Reduced ability to clear ZRCs in the MISO Planning Resource Auction (PRA).
- Lower bilateral capacity revenues or increased replacement capacity purchases.
- Possible penalties / deficiency charges if PRMR not met (not modeled here).

The calculator focuses on two modeled outputs: (1) Lost Capacity in ZRCs and (2) Lost Capacity Revenue in \$. It does not attempt to forecast PRA clearing prices or deficiency penalties; instead, it uses a Cost of New Entry (CONE) proxy, with an additional haircut (75% of CONE) where appropriate, to remain conservative.

3. Tool Outputs

3.1 Lost Capacity (ZRCs)

Estimates the reduction in accredited capacity attributable to the outage, expressed in ZRCs, allocated evenly across the three planning years following the Planning Year (Planning Year +1, +2, +3).

3.2 Lost Capacity Revenue (\$)

Converts the ZRC impact (or, in one case, outage days) into an estimated \$ value. If the outage occurs in the Planning Year being calculated and extends beyond 31 days, the model values the days past 31 at a daily CONE rate times the seasonal factor. In all other cases, the model multiplies the Lost Capacity (ZRCs) by 75% of CONE.

4. Key Inputs & Definitions

Table 1 lists the input fields referenced in the workbook and used in the formulas. Cell references (in parentheses) match the example screenshot you provided; actual cell addresses may differ in your production workbook.

Input / Variable (Excel Ref)	Definition / Notes
Unit Name (E2)	Text label only; identifies the generating unit modeled.
GVTC of Unit (MW) (E3)	Generator Verification Test Capacity (latest tested dependable MW on the GVTC basis). Denominator in the SAC/GVTC ratio: $N2 = E4 \div E3$.
Planning Year (N5)	Forecast planning year for which ZRC accreditation and resource adequacy compliance is being evaluated.
Lost Capacity (ZRCs) row 12	Formula: $=IF(OR(Year=N5+1,Year=N5+2,Year=N5+3),(N4/365*N3)/3,0)$. Books the ZRC impact evenly across the three planning years following the Planning Year; 0 elsewhere.
Planned Capacity (ZRCs) row 11	Baseline accredited capacity with no outage. Formula copies $E4$ (SAC Value) across all year columns for comparison.
SAC Value of Unit (ZRC) (E4)	Seasonal Accredited Capacity for the Planning Year, expressed in Zonal Resource Credits. Also populates the "Planned Capacity (ZRCs)" row across all year columns (row 11).
# of MW derate (E5)	Magnitude of the outage/derate to model in MW on the GVTC basis. Enter full GVTC for a total unit outage; enter expected MW out for a partial derate. Used in $N3 = E5 \times N2$ to convert the MW derate into accredited ZRCs impacted.
Year Being Calculated (C10 row label)	Year for which potential capacity loss is being booked in the model. May equal the Planning Year or Planning Year +1/+2/+3.
Days Offline / Derated (N4)	Outage duration in days. Used in both Lost Capacity (row 12) and Lost Capacity Revenue (row 14) formulas. Threshold: if $N4 > 31$ and Year = Planning Year, the Planning-Year revenue branch activates.

SAC Derate (ZRCs impacted) (N3) – Derived	Converts the outage magnitude entered in # of MW derate (E5) into accredited capacity (ZRCs) at risk using the unit’s Seasonal Accredited Capacity ratio. Calculations: $N2 = SAC_ZRC (E4) \div GVTC_MW (E3)$; $N3 = MW_derate (E5) \times N2$. Interprets how many accredited ZRCs are unavailable if the specified MW are out. Full-unit outage $\Rightarrow N3 = unit\ SAC (ZRCs)$. Because SAC is usually $< GVTC$, this translation from MW to ZRCs typically lowers the bookable exposure vs a raw $MW \times price$ approach (conservative).
Cost of New Entry – CONE (\$/ZRC-Year) (J5)	CONE (\$/ZRC-yr) (J5) – Cost of New Entry benchmark used to monetize ZRC impacts. Applied at 100% in the Planning-Year >31 -day branch; discounted to 75% ($0.75 \times CONE$) in all other years to remain conservative.
Lost Capacity (ZRCs) (D12)	Model output: estimated ZRCs potentially lost due to the outage, averaged across the 3 accreditation years following the Planning Year.
Lost Capacity Revenue (\$) (D14)	Model output: estimated \$ value of at-risk capacity revenue, using conditional logic (Planning-Year outage >31 days vs all other cases). Formula: $=IF(AND(N4>31, N5=Year), J5/365*(N4-31)*N3, LostCapZRC*0.75*J5)$. Uses daily CONE \times days beyond 31 \times ZRCs impacted for long Planning-Year outages; otherwise multiplies Lost Capacity (ZRCs) by $0.75 \times CONE$.

All monetary values are in nominal \$ unless noted. 1 ZRC = 1 MW UCAP-Year in MISO terminology.

5. Calculation Logic

The workbook contains two principal formulas: Lost Capacity (ZRCs) and Lost Capacity Revenue (\$). Both are wrapped in conditional logic that gates the calculation so we only book losses in the years affected.

5.1 Lost Capacity (ZRCs) Formula

Excel syntax:

$$=IF(OR(C20=(\$N\$5+1),C20=(\$N\$5+2),C20=(\$N\$5+3)),(\$N\$4/365*\$N\$3)/3,0)$$

Where:

- C20 is the year being calculated.
- \$N\$5 is the Planning Year (NS).

- \$N\$4 is Days Offline / Derated.
- \$N\$3 = SAC Derate (ZRCs impacted) – the number of accredited ZRCs out of service, derived as (# MW derate × SAC_ZRC ÷ GVTC_MW).

Plain-language steps:

1. Check if the year being calculated equals Planning Year +1, +2, or +3.
2. If none match, return 0 (no capacity loss booked in that year).
3. If a match, compute lost ZRCs = (Days Offline / 365) * Seasonal Factor / 3.
4. Dividing by 3 spreads the single outage's effect evenly over the three subsequent accreditation years.

Algebraic form: $Lost_ZRC_perYear = ((Days_offline \div 365) \times Seasonal_Factor) \div 3$, conditional on Year = PlanningYear +1/+2/+3; else 0.

5.2 Lost Capacity Revenue (\$) Formula

Excel syntax:

=IF(AND(\$N\$4>31,\$N\$5=D20),\$J\$5/365*(\$N\$4-31)*\$N\$3,D22*0.75*\$J\$5)

Where:

- \$N\$4 is Days Offline / Derated.
- \$N\$5 is Planning Year (NS).
- D20 is the year being calculated (Planning Year row).
- \$J\$5 is CONE (\$/ZRC-Year).
- \$N\$3 = SAC Derate (ZRCs impacted) – accredited ZRCs affected by the outage (see Section 4)
- D22 is Lost Capacity (ZRCs) calculated above.

Plain-language steps:

1. Test if two conditions are both TRUE:
 - a. Days Offline > 31.
 - b. Year being calculated = Planning Year.
2. If BOTH true (Planning-Year outage >31 days):
 - Compute daily CONE = CONE / 365.
 - Compute Days Beyond 31 = Days Offline - 31.
 - Lost Capacity Revenue = (CONE ÷ 365) × Days Beyond 31 × ZRCs impacted (This values the accredited ZRCs out during the extended outage days.).
3. ELSE (all other years / shorter Planning-Year outages):

- Lost Capacity Revenue = Lost Capacity (ZRCs) * 0.75 * CONE.

The 31-day deductible recognizes that short outages inside a Planning Year generally do not reduce the auction-accredited capacity we can count, and it avoids over-stating risk from brief events. Using only 75% of CONE in the ELSE branch is an explicit conservatism that discounts the long-run capacity value proxy.

6. Why Results Are Conservative (Lower-Bound)

Multiple structural and parametric choices bias results low relative to potential market exposure:

1. Only a 60–70% view: Seasonal factors supplied by Forecasting intentionally haircut expected ZRC exposure.
2. Accreditation conversion (SAC ÷ GVTC): We translate MW derates into accredited ZRCs using the unit's SAC/GVTC ratio. Because SAC is typically less than the tested MW capability, this step alone reduces the dollar impact vs valuing the full MW outage. Conservative.
4. Loss spread across 3 years (÷3) dilutes impact vs booking full loss up front.
4. 31-day deductible before valuing Planning-Year outages.
5. 0.75 × CONE multiplier further discounts value in ELSE case.
6. No escalation for scarcity premiums when PRA clears >CONE.
7. Excludes replacement energy purchases, RSG uplift, unit commitment effects, or penalty adders.
8. Does not model correlated fleet outages that could increase zonal tightness.

Taken together, these elements make the calculator a conservative screen; real-world financial exposure could be higher.

7. Appropriate Use Cases & Boundaries

Appropriate:

- Screening capital project justifications and comparing outage-avoidance benefits.
- Internal risk ranking across fleet assets.

Not Intended For:

- Settlements, actual PRA offer strategy, or bilateral contracting decisions.
- Recording GAAP revenues or impairment testing.
- Short-term outage scheduling optimization.

8. Revision History

Date	Version	Author	Key Changes
2025-07-17	1.0	[name]	Initial draft for MPSC discussion.

Appendix A – Detailed Input Field Definitions

Planning Year (NS): Forward compliance year used in resource adequacy planning.

Year Being Calculated: Each row in the model corresponds to a Planning Year or one of the three subsequent years.

Days Offline / Derated: Count of calendar days; if partial derate, convert to equivalent full-derate days (MW-weighted).

SAC Derate (ZRCs impacted): N3. Derived as $(\# \text{ MW derate} \times \text{SAC_ZRC} \div \text{GVTC_MW})$. Represents the accredited capacity (ZRCs) unavailable during the modeled outage. Use full-unit MW if modeling a total outage; otherwise use the expected derated MW.

CONE: Cost of New Entry proxy. Source: Forecasting / MISO data / MPSC filings.

Appendix B – Seasonal Derate Factor Development (Summary)

Forecasting derived N3 factors by mapping historic seasonal PRA accreditation rules and expected zonal reserve margins to quarterly weighting factors. Factors are typically lower in shoulder months and higher in peak summer but always ≤ 1.0 to maintain conservatism. Documentation available on request.

Appendix C – Sensitivity Cases

- - High Case: Replace $0.75 \times \text{CONE}$ with $1.0 \times \text{CONE}$.
- - Peak-Summer Outage: Seasonal Factor = 1.0.
- - Short Outage: Days Offline = 20; demonstrates 31-day deductible effect.
- - Severe Outage Duration Sweep: 30/60/90/180 days.

Appendix D – FAQ for MPSC Staff

Q1. Why not use actual PRA clearing prices?

A1. Forward clearing prices are unknown; CONE provides stable benchmark; 75% haircut keeps results conservative.

Q2. Why spread across 3 years?

A2. Reflects multi-year accreditation effects and avoids double counting; aligns with internal planning horizon.

Q3. What if outage straddles two Planning Years?

A3. Use total equivalent days in each year or model two scenarios; tool is flexible.

Q4. Can Staff change the CONE multiplier?

A4. Yes; cell is unlocked; change 0.75 to 1.0 to view upper bound.

Question:

3. Refer to Company's filing Part III, Attachment 131, for all projects at the Covert, Jackson and Zeeland plants, please provide (where applicable):

- a. The earliest and latest project charter.
- b. Any economic analysis performed, including present value ratio (PVR) or internal rate of return (IRR) calculations, including all supporting analyses and documentation used in such calculations (preferably in Excel format).
- c. Please identify those projects which the Company deems required for safety purposes, including an explanation for why that is the case.
- d. Please identify those projects which the Company believes that, if not performed, the unit would not operate, including an explanation for why that is the case.

Response:

- a. Per discussion with MNSC council, the Company has provided concept approvals which provide an analysis of the work to be performed, a discussion of alternatives, including doing nothing, and a selected alternative. Attachment U21870-MNSC-CE-0072_ATT_0001 reproduces select fields from Part III Attachment 131 for all projects at the Covert, Jackson, and Zeeland generating stations. This attachment identifies the work type and category, job description, reason for the work to be performed, and the applicable attachment representing the concept approval for the project. 8 other attachments are attached to this response which reflect concept approvals not previously provided in discovery in this proceeding.

The projected capital investment for certain routine capital projects such as small capital and base outage for each generating station are primarily based upon historical spend. Sheet 2 of this attachment provides 5 years of history of investment for each of these work categories for both the Jackson and Zeeland generating stations and all available investment history for Covert generating station since its acquisition on June 1, 2023.

- b. The only projects identified as economic in nature are the Zeeland Phase I and II turbine projects. Please refer to confidential Attachments U21870-ST-CE-0007_ATT_0001_CONF and U21870-ST-CE-0007_ATT_0002_CONF for the economic analysis. Also refer to the Company's response to discovery question U21870-MNSC-CE-0071.
- c. None of the projects for the Covert, Jackson, and Zeeland generating stations are being performed based upon safety.
- d. Please see concept approval documents identified in Attachment U21870-MNSC-CE-0072_ATT_0001 for the basis for the specific work. Some work is required for warranty such as the LTSAs, some of it is based upon economics (Zeeland Phase I and II), some is performed based on failed equipment, some

of it is performed based upon required computer-related equipment upgrades in order to continue to operate the generating units.

Witness: RICHARD T. BLUMENSTOCK

Date: July 24, 2025

PT Number	ProjectID	Work Type (Tier 3)	Site (Tier 2)	Work Category	Title	Funding Type	21870-MNSC-CE-0072	Reason(s) for the work to be performed (for example insurance, aging equipment, warranty, federal/state regulation, etc.).
PP-00524	12817	Operations	Covert	Operate	(12817) COVERT - Long Term Service Agreement - Running capital contract	Capital	U21870-ST-CE-0004_0010_CONF	Reliability Maintenance
PP-00579	13583	Reliability	Covert	Maintain	(13583) CGS - Netmation (MHPSA Operating System & 45)- Unit 1-3	Capital	U21870-MNSC-CE-0072_0009	The Covert gas generating station, operational since 2004, faces critical challenges with its outdated control systems. These challenges impact both operational efficiency and cybersecurity, necessitating an urgent upgrade to modern standards.
PP-00545	13570	Reliability	Covert	Operate	(13570) Covert - Unit 2 - Non LTSA Capital - Extras not included in contract	Capital	U21870-ST-CE-0004_ATT_0037	Covert - Unit 2 - Non LTSA Capital - Extras not included in contract
PP-00584	PP-00584	Reliability	Covert	Maintain	PP-00584: CGS HRSG Expansion Joint Replacements	Capital	U21870-ST-CE-0004_0034	The expansion joint has a design life of 6-8 yrs, and replacement occurs during the turbine major outages. So the existing expansion joints will be at least 4 years beyond their design if delayed until the next major. Assuming 60%-100% beyond design life, then the probability of a failure would be high. Failure of the joint could start as a tear and found by thermography if it is small. There is no way of expecting a failure will be small or a large rip but the result is that exhaust gasses could bypass the stack and environmental monitoring equipment, exhausting high temp gas inside the building which is a personnel hazard. It is also a significant hit on overall heat rate efficiency that would depend on the unpredictable size of the failure.
PP-00050	PP-00050	Reliability	Covert	Maintain	(13618) CGS - LCI Replacements (SFC)	Capital	A-46 (RTB-7)	The Covert Generating Station (CGS) Static Frequency Converter (SFC) Controls Replacement project is essential to address significant operational and reliability issues stemming from the obsolescence of the current SFC controls. This project is critical for maintaining the operational integrity and reliability of the plant's turbine generators, which rely on the SFCs for startup.
PP-00109	12818	Operations	Covert	Operate	(12818) Covert - Unit 1 Non LTSA Capital - Extras not included in contract	Capital	U21870-ST-CE-0004_ATT_0037	Reliability Maintenance
PP-00111	13571	Regulatory	Covert	Operate	(13571) Covert - Unit 3 - Non LTSA Capital - Extras not included in contract	Capital	U21870-ST-CE-0004_ATT_0037	Covert - Unit 3 - Non LTSA Capital - Extras not included in contract
PP-00565	PP-00565	Reliability	Covert	Operate	PP-00565: CGS BASE OUTAGE - 2024	Capital		The Company invested \$0.789 million in base outage capital during the seven month period beginning June 1, 2023 and ending December 31, 2023 at Covert. The base outage expenditure for 2024 was \$197,942. These figures are consistent with historical spends from the other gas plants and aligned with the normalized forecasted figure of \$400k/year. Outages require funding for site priority #1 work orders, this will cover those issues
PP-00596	PP-00596	Reliability	Covert	Maintain	PP-00596: CGS 1 GTG and STG Auto Voltage Regulator	Capital	U21870-MNSC-CE-0072_0002	The excitation system is due for an overhaul
PP-00597	PP-00597	Reliability	Covert	Maintain	PP-00597: CGS 3 GTG and STG Auto Voltage Regulator	Capital	U21870-MNSC-CE-0072_0002	The excitation system is due for an overhaul
PP-00589	13446	Regulatory	Covert	Comply	(13446) CGS - 1-3 Emerson DCS Evergreen	Capital	U21870-MNSC-CE-0072_0008	The newly acquired gas generation plant at Covert, which started commercial operation in 2004, has many components of its original control system in operation. The Distributed Control System (DCS) that controls all equipment in the plant (along with the Mitsubishi gas turbine controls), is Emerson Ovation DCS. It was upgraded about 10 years ago to the current version. Emerson Ovation version 3.5.1 is no longer supported by Emerson or Microsoft. The Emerson Ovation version 3.5 system entered a retired status in June 2019. The Windows operating systems that are used by this version of Ovation are Windows 7 and Windows Server 2008R2. Microsoft ended extended support of Server 2008R2 in January 2020. The generation plant control systems are an important part of our nation's Critical Infrastructure and fall under NERC Critical Infrastructure Protection (CIP) requirements. To keep our control systems secure, we must patch the operating systems and applications that run our plants. We are no longer able to patch and maintain these operating systems, such as Microsoft Windows, or applications, such as Ovation, when they are no longer supported by the manufacturers. Vulnerabilities may be found in this software that may provide a target for bad actors and nation states to exploit and leave our critical infrastructure vulnerable. Malware protection must be kept up to date and is limited on the older operating systems. The systems at Covert do not meet our corporate cybersecurity standards and are operating with security exceptions to our standards. The cybersecurity tools (Power & Water Cybersecurity Suite - PWCS) being utilized for the Covert control network device patching and antivirus protection require replacement to allow continued patching and protection with a new DCS version. The current version of PWCS is nearing end of support and requires updating to allow support of the latest Ovation versions. The Balance of Plant (BOP) control is achieved with the Ovation DCS. Its architecture is comprised of controller and operator "drops" (processors and PCs) that provide the control of the equipment with input/output (I/O) modules. Some of these I/O modules are in the same electrical cabinets that contain the "controller drops" (processors). Other I/O is in "remote" electrical cabinets, away from the "controller drops". The existing plant control is comprised of many remote I/O cabinets throughout the site. The communication modules to these cabinets have experienced failures in the past that can trip the generating units offline. Power supplies in the Ovation cabinets have reached the end of their recommend life and need to be replaced. The architecture and components need to be upgraded and replaced with the latest Ovation design. The main controller drop that operates a large part of the BOP equipment has had equipment and data link controls added to it over the years. It controls equipment for all three (3) generating units. The controller drop needs to have part of its I/O and logic split off to new controller drops. The partitioning of I/O to other drops should allow the upgrade and maintenance procedures to occur and
PP-00542	13573	Reliability	Covert	Operate	(13573) CGS - Purchase of site spare GSU	Capital	U21870-ST-CE-0004_0004	The Covert Generating Station features a combination of three gas turbine-powered plants and three steam turbine-powered plants, arranged in a one-on-one combined cycle configuration. This setup entails that each gas turbine unit powers the secondary winding of a three-winding transformer (GSU), while the corresponding steam-powered unit powers the tertiary winding. A GSU's failure can lead to significant power generation issues. Specifically, the GSU at Covert are rated for 500 MVA and are equipped with forced oil and forced air cooling mechanisms. If a GSU were to fail, both the gas and steam turbine units connected to it would be unable to transmit power, leading to a potential loss of up to 400 MVA of generation capacity. This would prevent the generation of market value for Consumers Energy and its customers. Further complicating the situation is the long lead time of 2 to 4 years for procuring a replacement GSU, and the lack of spare units at other facilities. The plant is projected to operating until at least 2040, thus making it crucial to have a reliable GSU ready for replacement.
PP-00577	13604	Reliability	Covert	Maintain	(13604) CGS - Cooling Tower Gearboxes	Capital	U21870-MNSC-CE-0072_0003	The Covert Generating Station Cooling Tower Fan Gearbox Replacement Project addresses critical operational issues stemming from the end-of-life status of gearboxes after over 20 years of service. These gearboxes are essential for cooling tower fan operations, affecting the station's overall efficiency and reliability.
PP-00535	PP-00535	Regulatory	Covert	Comply	Covert Security and Network	Capital		This project was completed in 2023 and is not included in this rate case. The project is not included in the revenue requirement Installation of Information Technology room for Corporate systems. The current infrastructure is not in place for connectivity to corporate.
PP-00560	PP-00560	Reliability	Covert	Operate	PP-00560: CGS SMALL SITE CAPITAL-2024	Capital	CGSII YearInvestment 2023\$180,071.00 2024\$66,325.00 Average\$423,198.00	See historical spending for Small site capital. This number typically include Small valves and instrumentation, pumps, motors, and tools. The spending is consistent with the rest of the gas plants figures. Multiple small items fail throughout a year. This is to anticipate those failures and reserve budget for them.
PP-00554	PP-00554	Reliability	Jackson	Maintain	PP-00554: JGS - 1-6 Feedwater Desuperheater Valve	Capital	U21870-ST-CE-0004_0025	The HRSG 1-6 SH Steam Desuperheater Feedwater valves have had very short life spans since original construction. There are several issues that cause the valves to wear out quickly. The valves inherently cycle frequently open and closed due to the boiler running close to HP Steam Outlet temperature setpoint at gas turbine baseload, without duct firing. This has been reduced recently by a study completed by engineering and GE to allow the HP Steam temperature to be increased from the original 750 deg F up to 770 deg F. This change did cause the valves to cycle open/close less frequently, but it did not result in a substantial improvement in valve life. The brunt of the wear is absorbed by the HP FW Autotank valve, which when it begins to leak by, causes the SH Steam temperature to fall. The HP FW Control Valve wears out quickly as well. Typically, when this occurs the leak by accelerates quickly to the point which the manual HP FW isolation valve upstream must be closed when the unit is not duct firing in order to maintain adequate superheated steam temperature.
PP-00242	6006	Reliability	Jackson	Operate	(6006) Jackson GE Long Term Service Agreement FFH	Capital	U21870-ST-CE-0004_0028-0033_CONF	Reliability Maintenance

PP-00302 PP-00487 PP-00570	5921	Reliability	Jackson	Operate	(5921) Jackson GE LTSA Historical Extra Work Expected	Capital	U21870-ST-CE-0004_0028-0033_CONF	Reliability Maintenance
<p>See historical spending for base outage at this site below. The amount in this rate case is consistent with the required base outage spending needed to safely execute an outage.</p>								
PP-00568	PP-00568	Infrastructure	Jackson	Operate	PP-00568: JGS 2024 Base Outage	Capital	<p>JGS YearInvestment 2018\$437,047.00 2019\$480,062.00 2020\$596,042.00 2021\$477,497.00 2022\$685,888.00 2023\$983,951.00 2024\$738,974.00 Average\$628,494.43</p>	Outage work
PP-00166	13478	Reliability	Jackson	Maintain	(13478) JGS - Generator Step Up Transformer (GSU) Site Spare	Capital	U21870-MNSC-CE-0072_0007	During Unit 7 Major Outage GE found cracking within the casing that was acceptable during this interval (Spring '18). Cracking will likely be out of tolerance during the next Hot Gas Path inspection. GE has recommended replacement be procured.
PP-00178	PP-00178	Reliability	Jackson	Maintain	JGS - LM6000 ESN 191-306 HP Turbine S2 Nozzle replacement	Capital	U21870-ST-CE-0004_0023	During the bi-annual borescope inspection in April 2024 for the LM6000 gas turbines at Jackson Generating Station, damage was identified at the High-Pressure Turbine (HPT) Stage 2 Nozzle (S2N) Impingement Ring of Engine Serial Number (ESN) 191-306. The gas turbine with ESN 191-306 was placed in an 'on watch' period per OEM guidance that results in a 250 running hour inspection frequency to determine if the damage progresses. There is potential for the inspection frequency period to increase based on multiple inspections. Ultimately the S2N assembly of the gas turbine that is damaged needs to be replaced to restore the gas turbine to a serviceable condition.
		Reliability	Jackson	Maintain	JGS - Engine 191-306 Overhaul	Capital	U21870-ST-CE-0004_0024	Reliability Maintenance, discovered during inspections
		Reliability	Jackson	Maintain	JGS - Unit 7 Gas turbine rotor replacement	Capital	U21870-ST-CE-0004_0015	The rotor for a GE 7EA gas turbine has a life limit of either 5000 starts or 250,000 running hours. JGS Unit 7 (GE 7EA CT) gas turbine rotor is expected to hit its limit for starts before hitting its limit for running hours in the year 2032. JGS Unit 7 has planned maintenance intervals, either major overhaul or hot gas path, approximately every 5 years. The next major overhaul is tentatively in 2029 and the next hot gas path tentatively 2034. Based on the running profile of JGS, the unit will not be allowed to operate with the current rotor until 2034, and it would be unwise to take an additional outage between 2029 & 2034 to replace the rotor when it can be done in 2029.
PP-00574	13475	Reliability	Jackson	Operate	(13475) JGS - LM1-6 VIGV(variable inlet guide vane) Project	Capital	U21870-MNSC-CE-0072_0004	Inlet Guide Vanes (IGV's) located in the air intake of the gas turbine are used to direct and control the airflow into the engine. The angle of the IGV's relative to the oncoming flow is a critical driver of performance; opening the IGV's will allow more airflow into the gas turbine and therefore more power. However, opening the IGV's beyond the optimum angle will result in a significant loss in efficiency with minimal increase in power. The setting of the optimum angle is not a constant and is dependent on the corrected speed of the compressor rotor. For this reason, Variable Inlet Guide Vanes (VIGV's) are required to operate at peak power and efficiency over a range of ambient conditions and gas turbine power settings. The VIGV assembly is located at the front of the Low-Pressure Compressor (LPC). It allows flow modulation at partial power, resulting in increased engine efficiency. The VIGV system consists of 43 stationary leading-edge vanes and variable trailing flaps. The variable flaps can be rotated from -10 degrees open to +60 degrees closed by means of an actuation ring, which is driven by twin hydraulic actuators installed at the 3 o'clock and 9 o'clock positions. Both actuators are equipped with Linear Variable Differential Transformers (LVDT's). Normal engine operation is approximately -5 degrees open (full power) to +35 degrees closed (idle power). The flaps will also close during large power reductions to quickly reduce the LPC flow rate in order to maintain the LPC stall margin. An engine stall has the potential to cause catastrophic damage to the gas turbine. The package-supplied control is designed to provide excitation and signal conditioning for both LVDT's and to control VIGV position by means of closed loop scheduling of VIGV actuator position, based on LPC inlet temperature (T2) and High-Pressure Compressor (HPC) discharge static pressure (P53) corrected to gas turbine inlet pressure conditions (P0). The VIGV system improves performance for both simple cycle and heat-recovery cycles when operating at less than full load. For LM6000PC SPRINT gas turbines, which Jackson Generating Station has, the VIGV upgrade is expected to yield a significant fuel efficiency improvement at part power. The average fuel efficiency improvement at 70% of maximum power is greater than 2%. The VIGV also helps minimize variable bypass valve (VBV) flow and pressure levels, thereby reducing associated flow noise. The project will look to install new VIGV systems on six LM6000PC engines (S/N's: 191306, 191307, 191312, 191339, 191345, 191351) at Jackson Generating Station. The seventh LM6000PC engine (S/N 185132) has a partial installation already, and the project will look to complete the VIGV system for this engine.
PP-00551	PP-00551	Reliability	Jackson	Operate	PP-00551: JGS Small Site Capital	Capital	<p>See historical spending for Small site capital. This number typically include Small valves and instrumentation, pumps, motors, and tools. The spending is consistent with the rest of the gas plants figures.</p> <p>JGS YearInvestment \$ 2020\$289,768.00 2021\$487,796.00 2022\$391,377.00 2023\$637,369.00 2024\$672,338.00 Average\$495,729.60</p>	Multiple small items fail throughout a year. This is to anticipate those failures and reserve budget for them.
PP-00507	13499	Reliability	Zeeland	Maintain	(13499) ZGS - 2C GSU Rewind	Capital	U21870-ST-CE-0004_0014	The 2C Generator Step Up Transformer (GSU) which outputs electricity from the generator to the grid is showing signs of imminent failure as indicated by hydrocarbon gasses being continuously generated at rates above Institute of Electrical and Electronics Engineers (IEEE) recommended levels. Time to failure cannot be predicted and could be catastrophic in nature. Previous intrusive internal inspection and testing work in fall of 2022 was able to identify and replace some degraded parts but ultimately not able to locate the source of gas generation.
PP-00488	12833	Reliability	Zeeland	Maintain	(12833) ZGS - Site Spare GSU	Capital	A-47 (RTB-8)	Zeeland Generating Station consists of four gas turbine powered plants and one steam turbine powered plant. The units transmit their power to the grid via Generator Step Up (GSU) transformers. If a GSU were to fail, then the associated turbine would not be able to transmit power and would not be able to generate energy and capacity market value for Consumers Energy and its customers. For Zeeland Phase 2 combined cycle plants, the combustion turbine requires the operation of the steam turbine, therefore the loss of the steam turbine GSU would effectively limit operation of two connected combustion turbine units. The lead time for a GSU is currently 100 weeks and spare units at other facilities typically do not exist. The site is currently projecting retirement in the 2050 timeframe. This project would purchase a spare GSU that is sized to be able to replace any of the existing transformers on site and develop redundancy for any minor power upgrades in the future.
PP-00478	PP-00478	Reliability	Zeeland	Maintain	PP-00478: ZGS-P2 599 699 345kV Breaker Replacement	Capital	U21870-ST-CE-0004_0017	The installed Hitachi HVB breakers have a critical design flaw such that an individual pole or poles may not latch open when required. This has the potential to result in lost generation, loss of power to the entire Zeeland substation, and/or generator damage.
PP-00039 PP-00040 PP-00041	6593	Reliability	Zeeland	Operate	(6593) Zeeland Long Term Service Agreement - Running Capital Contract	Capital	U21870-ST-CE-0004_0028-0033_CONF	Reliability Maintenance
PP-00430	9694	Reliability	Zeeland	Maintain	(9694) ZGS - HRSO Casing Replacement	Capital	U21870-ST-CE-0004_0018	During recent inspections of the heat recovery steam generators (HRSGs) at Zeeland, extensive outer casing corrosion has been identified in particular sections of the units. This condition creates the risk of the studs which hold on the insulation and liner panels breaking loose and liberating both insulation and liner sheets. The insulation then blows downstream and fouls the HRSG tubes, requiring the unit to be shut down and cleaned, then subsequent casing, insulation and liner replacement. The affected areas of casing need to be cut out and replaced with new casing. A study is required to determine the exact scope of repairs, the cost, and the execution schedule.
PP-00426 00023	PP-9943	Reliability	Zeeland	Operate	(9943) ZGS - LTSA - Extras not included in contract (cranes, mobile equipment)	Capital	U21870-ST-CE-0004_0028-0033_CONF	Reliability Maintenance

PP-00517 00564	PP- 6596	Reliability	Zeeland	Operate	(6596) ZGS Base Outage Capital	Capital	<p>See historical spending for base outage at this site below. The amount in this rate case is consistent with the required base outage spending needed to safely execute an outage.</p> <p>ZGS Year Investment 2018\$2,421,434.00 2019\$341,144.00 2020\$796,316.00 2021\$260,129.00 2022\$522,636.00 2023\$547,912.00 2024\$849,528.00 Average\$819,871.29</p>	Outage work
PP-00170	11712	Reliability	Zeeland	Maintain	(11712) ZGS - Phase II Turbine Replacements	Capital	U21870-ST-CE-0004_0016	Scheduled Major Inspection outages in 2028 for Phase II turbines.
PP-00171	13497	Reliability	Zeeland	Maintain	(13497) ZGS - Phase 2 Gas Turbine Advanced gas path replacement and axial fuel staging	Capital	U21870-ST-CE-0004_0027	Scheduled Major Inspection outages in 2025 for Phase 1 turbines provide a strategic opportunity for substantial improvements through the implementation of Advanced Gas Path (AGP) and Axial Fuel Staging (AFS) technologies. These upgrades aim to boost turbine performance, efficiency, and operational flexibility, aligning with the shift towards a more renewable-centric energy mix.
PP-00562	PP-00562	Regulatory	Zeeland	Comply	PP-00562: ZGS - ABB DCS Evergreen	Capital	U21870-MNSC-CE-0072_0005 U21870-MNSC-CE-0072_0006	The Distributed Control System (DCS) must be upgraded at a four to five year upgrade cycle to maintain reliable control and recent operating systems and applications that are patchable. Vendor life cycle for DCS versions is generally a five year cycle. After 5 years they enter a retired state and are no longer patched. Microsoft Operating Systems (O/S) are on a limited life basis and they reach the end of "extended support" and no longer get security patches. Corporate policies require all systems to be patched regularly along with Anti-Virus updates.

base outage

JGS		ZGS		CGS	
Year	Investment	Year	Investment	Year	Investment
2018	\$437,047.00	2018	\$2,421,434.00		
2019	\$480,062.00	2019	\$341,144.00	2023	\$789,000.00
2020	\$596,042.00	2020	\$796,316.00	2024	\$197,942.00
2021	\$477,497.00	2021	\$260,129.00	Average	\$493,471.00
2022	\$685,888.00	2022	\$522,636.00		
2023	\$983,951.00	2023	\$547,912.00		
2024	\$738,974.00	2024	\$849,528.00		
Average	\$628,494.43	Average	\$819,871.29		

small capital

JGS		ZGS		CGS	
Year	Investment	Year	Investment	Year	Investment
2020	\$289,768.00	2020	\$194,543.00	2023	\$180,071.00
2021	\$487,796.00	2021	\$191,168.00	2024	\$666,325.00
2022	\$391,377.00	2022	\$189,994.00	Average	\$423,198.00
2023	\$637,369.00	2023	\$136,035.00		
2024	\$672,338.00	2024	\$426,391.00		
Average	\$495,729.60	Average	\$227,626.20		



Concept Approval

Jackson Generating Station Variable inlet guide vane upgrade

Date: 10/17/2024

Prepared by: Paul Ohep



Figure 1. Jackson Generating Station.

Executive Summary

The Jackson Generating Station Variable Inlet Guide Vane (VIGV) upgrade project is designed to enhance the efficiency, reliability, and operational performance of six LM6000PC gas turbines. The current fixed Inlet Guide Vanes (IGVs) limit the station's ability to optimize airflow based on varying load conditions, resulting in reduced fuel efficiency, limited power output, and an increased risk of engine stalls. By upgrading to a variable system, the project will enable the turbines to operate more efficiently across a wider range of loads, significantly improving both base load performance and overall station reliability.

Key Drivers for the Upgrade:

- **Shift from Duct Firing to Base Load:** The VIGV upgrade allows for a shift of **12 MW** from duct-fired generation to base load generation plus an increase in exhaust energy resulting in 15MW steam load for an overall base load increase of 27 MW, improving the plant's fuel efficiency and reducing reliance on less efficient duct burners. After the upgrade, the maximum output of the plant will remain **560 MWn**, but the power generation will shift from duct firing to more efficient base load capacity.
- **Improved Fuel Efficiency:** The upgrade is projected to reduce the heat rate by **189 Btu/kWh** during base load operation and 286 Btu/kWh at full duct firing operation, leading to a **2% fuel efficiency improvement at 70% power**. This translates to substantial fuel cost savings and enhanced performance across the plant's operational range.
- **Enhanced Reliability:** The VIGV system will increase the stall margin, reducing the risk of catastrophic engine stalls. This improvement in reliability will minimize the likelihood of unplanned outages and costly repairs, enhancing the station's long-term operational stability.

Economic Impact:

The financial analysis projects a **Net Present Value (NPV) of \$29.609 million** in total benefits from the VIGV upgrade. This value is derived from fuel savings, increased base load generation, reduced reliance on duct firing, and the avoidance of potential repair costs due to engine stalls.

Key economic factors include:

- **Fuel Savings:** The reduction in heat rate will lead to significant cost savings in fuel consumption over the lifespan of the turbines.
- **Avoided Repair Costs:** By reducing the risk of engine stalls, the station could avoid up to **\$12 million** in repair costs over the next 15 years.

Project Scope and Timeline:

- **Turbine Coverage:** The VIGV system will be installed on six LM6000PC gas turbines and completed on a spare turbine.
- **Implementation Schedule:** The installation is scheduled to occur between 2026 and 2029, aligning with planned maintenance intervals to minimize operational disruption.

Rate Case status:

This Project is included in the 2024 electric rate case.

Financial Summary

Funding Type:	Capital
Estimated Total Cost:	\$3,704,350

Proposed Start Implementation Year

First year spend: 2024

Installation year: 2025-2029

Project Span Whole Years

6 Years

Problem Description

The gas turbines at Jackson Generating Station currently use fixed Inlet Guide Vanes (IGVs) that limit their ability to adapt to varying operating conditions. This results in suboptimal performance, reduced efficiency, and increased risks to turbine reliability. The following are the key challenges associated with the current system:

- **Inefficiency of Fixed IGVs:** The fixed angle of the IGVs restricts airflow modulation, preventing the turbines from operating at peak efficiency across different ambient conditions and power settings. This leads to inefficient fuel use, particularly at part load, which is common in load-following operations at Jackson Generating Station.
- **Fuel Consumption and Heat Rate:** Due to the inability of the current system to adjust for optimal airflow, the heat rate of the turbines is higher than necessary, which increases fuel consumption. The inefficiency becomes more pronounced during partial load conditions, where fuel savings are critical for economic operation.
- **Increased Risk of Engine Stall:** Without dynamic control of the IGV angles, the turbines are more susceptible to engine stalls during rapid power reductions or operational fluctuations. An engine stall can cause significant damage to the turbines, resulting in costly repairs and extended downtime.
- **Dependence on Duct Firing:** To meet power demands, the station relies on duct firing, which is less efficient, consumes more fuel, and places additional stress on the system. This dependency results in higher operational costs and increased emissions.

Project Objective

To address these issues, the Jackson LM1-6 Variable Inlet Guide Vane (VIGV) upgrade will replace the fixed IGVs with a variable system, enabling dynamic airflow modulation. This upgrade will:

- **Increase Base Load Output:** The VIGV system will enhance the base load capacity of the gas turbines by 12 MW and contribute to a total site-wide increase of 27 MW when combined with steam turbine improvements. This increase will reduce the reliance on inefficient duct firing.
- **Improve Fuel Efficiency:** The upgrade will improve the baseload heat rate by approximately 189 Btu/kWh (without duct firing) and 286 Btu/kWh (with duct firing).
- **Enhance Stall Margin:** By allowing better airflow control, the VIGV system will improve the stall margin, reducing the risk of turbine failure during rapid load changes and ensuring more reliable operation.

This project is critical for improving the overall performance and efficiency of the turbines, reducing operational costs, and minimizing the risk of unplanned outages due to engine stalls.

Alternative Solutions/Alternatives Considered

1. Do Nothing – Cost: \$29.6 million (\$29.6M of unrealized value to our customers)

In the "Do Nothing" scenario, Jackson Generating Station would continue to operate with its current fixed Inlet Guide Vane (IGV) system, foregoing the implementation of the Variable Inlet Guide Vane (VIGV) upgrade on the six LM6000PC gas turbines. The consequence of not upgrading the IGV system is the loss of significant operational improvements that would otherwise be realized in efficiency, power output, and reliability. Below is a detailed analysis of the impacts and missed opportunities if the VIGV upgrade is not implemented:

Missed Incremental Power Output

- **Shift from Duct Firing to Base Load:** Without the VIGV upgrade, the station will miss the opportunity to shift **12 MW of capacity** from duct firing to base load generation. The VIGV upgrade does not increase the overall maximum output of the plant but redistributes capacity more efficiently. Currently, with duct burners on, the station reaches a peak output of **546.57 MWn**. With the VIGV upgrade, the plant would be capable of **560 MWn** under the same duct burner conditions, while limiting output to the interconnect constraint during cooler weather by reducing duct burner flow.
- **Improved Base Load Efficiency:** The expected gain of **13.4 MW in base load** would be realized without relying on duct firing, thus increasing the efficiency of base generation. This means that the station would achieve the same overall power output but with a shift of capacity from less efficient duct-fired generation to more efficient base load operation. Without the upgrade, the station will remain dependent on duct firing to achieve higher outputs, losing out on this improved operational profile.

Fuel Efficiency Improvement Missed

- **No Heat Rate Reduction:** Without the upgrade, the station will continue to operate with a heat rate of **8,004 Btu/kWh (LHV)** for each LM6000PC turbine during base load operations. The VIGV upgrade would have reduced this heat rate to **7,958 Btu/kWh (LHV)**, leading to more efficient fuel usage and cost savings.

The following table summarizes the increase in generation and heat rate impacts with and without VIGV:

VIGV	Duct Burner	LM6000 kWg	GT HR LHV Btu/kWh	MWn	NUHR Btu/kWh	ΔMW	ΔNUHR Btu/kWh
No	Yes	47,321	8,004	546.57	8,928		
Yes	Yes	49,958	7,974	560.00	8,642	13.43	286
No	No	47,321	8,004	427.45	7,951		
Yes	No	50,063	7,958	454.71	7,761	27.26	189

By not upgrading, the plant misses a significant MW improvement in output at lower heat rates without duct burners, and a considerable heat rate improvement of **189 Btu/kWh** across the entire load range. This represents a significant loss in fuel savings and operational efficiency over time.

Increased Risk of Engine Stalls and Repair Costs

- **Stall Risk:** The existing fixed IGV system increases the risk of engine stalls, particularly during rapid load reductions. An engine stall is a critical failure that can lead to catastrophic damage, requiring costly repairs. The estimated cost of an engine stall repair is up to **\$4 million per turbine**, with an average stall probability of **one occurrence every five years**. Over the next 15 years, this could result in up to **\$12 million** in repair costs that could have been mitigated by the VIGV system.

Economic Losses

The total economic impact of not implementing the VIGV upgrade can be summarized as follows:

- **Value Loss:** The total projected value of the VIGV upgrade, including improved heat rates, increased base load capacity, and reduced reliance on duct firing, has been calculated at **\$29.609 million**. By not proceeding with the upgrade, this value will be lost.

Below is a summary of the results from the Aurora economic model used to calculate the economic impact of this upgrade until 2040:

Net Present Value Results	VIGV
Current Nameplate Capacity (MW)	547
Incremental Energy, NPV (K\$)	\$26,781
Incremental Operating Costs, NPV (K\$)	\$7,921
Investment Cost, NPV (K\$)	(\$5,093)
Total Value of VIGV Upgrade (K\$)	\$29,609

Table 1. Summary of Aurora model results listing economic impacts of the VIGV upgrade.

By not implementing the VIGV upgrade, Jackson Generating Station will forfeit key operational improvements, including enhanced efficiency, greater base load capacity, and reduced maintenance risks. This "Do Nothing" scenario results in higher operational costs, increased reliance on less efficient duct firing, and greater exposure to potential repair costs from engine stalls.

2. Upgrade gas turbines to Variable inlet guide vane systems -\$3.7 Million

Following the analysis of the "Do Nothing" scenario, it is recommended to proceed with the installation of the Variable Inlet Guide Vane (VIGV) system on the six LM6000PC gas turbines at Jackson Generating Station. This upgrade offers clear operational benefits by enabling a shift in capacity from duct firing to base load generation, improving overall efficiency, and reducing operational costs. Below is a picture of the VIGV assembly.



Variable Inlet Guide Vanes Assembly

Scope of the Upgrade:

- **Turbine Coverage:** The VIGV system will be installed on six LM6000PC gas turbines (S/Ns: 191306, 191307, 191312, 191339, 191345, 191351) and completed on the spare engine (S/N: 185132).
- **Installation Schedule:** The work will be scheduled during the turbines' planned maintenance intervals between 2026 and 2029, ensuring minimal impact on normal operations.

Key Benefits of the Upgrade:

- **Capacity Shift:** The primary benefit of the VIGV upgrade is the shift of **13.4 MW** from duct-fired capacity to base load generation. This does not increase the total site output but redistributes capacity more efficiently, improving the station's ability to generate power without relying on duct burners. After the upgrade, the maximum output will remain **560 MWn**, but with reduced dependence on less efficient duct burners.
- **Efficiency Gains:** The upgrade will result in a **189 Btu/kWh heat rate reduction** during base load operations, leading to significant fuel savings.
- **Increased Reliability:** The upgrade will also mitigate the risk of engine stalls by improving the stall margin, thereby reducing the likelihood of costly repairs and unplanned outages. This provides operational stability and long-term cost savings.

Economic Justification:

The economic value of the upgrade has been assessed at **\$29.609 million**, considering the efficiency gains, improved base load performance, and avoided repair costs. These benefits will result in long-term fuel savings, enhanced revenue from optimized power generation, and reduced maintenance expenses.

For a full breakdown of the economic analysis, please refer to the preceding section.

Conclusion:

Implementing the VIGV upgrade is the most effective option to enhance the efficiency and reliability of Jackson Generating Station. It optimizes the station's capacity by shifting power generation from duct firing to base load, while reducing operational costs and increasing reliability. The upgrade ensures that the station can meet its future energy needs with improved efficiency and reduced risk of costly repairs.

Funding and Timing

- No funding has been previously committed for this project.
- No outage is required for this project.
- Desired implementation year: First year spend 2024, 2029 final install and spend year.
- Impact if the recommended implementation year is changed:

If the recommended implementation years for the VIGV upgrade are changed, the project would face several potential negative impacts. Delaying the upgrade could result in missing planned maintenance intervals, leading to increased costs for additional engine swaps outside of these windows. Additionally, the station would continue to operate with less efficiency and higher fuel consumption during the delay, losing out on the projected fuel savings and incremental power gains. Furthermore, the risk of engine stalls would remain elevated, increasing the likelihood of costly unplanned repairs during the extended period without the upgrade.

System Engineer

- System Engineer: Joseph Brooks

Conceptual Estimate

Year	Loaded Cost	Description
2024	\$120,900	Request for Purchase work, Engineering work, Initial PO creation, Computer hardware & configuration, software design work.
2025	\$970,840	Milestone payment, Engineering work.
2026	\$1,046,370	Installation of VIGV upgrade on first two engines 185132, 191307
2027	\$1,107,600	Installation of VIGV upgrade on next two engines 191345, 191312
2028	\$305,760	Installation of VIGV upgrade on next two engines 191351, 191306
2029	\$152,880	Installation of VIGV upgrade on final engine 191339, closeout

Total Cost: \$3,704,350

Asset Strategy Approval Comments

The Asset Strategy Group strongly recommends approval based on economic analysis.

Approvals

Title	Approver Name	Date
Generation Planning Manager		
Director of Generation Asset Strategy		
Exec Director of Electric Supply Engineering		
VP of Electric Supply		

U21870-MNSC-CE-0024-ATT-0003

1 00
2 00
3 00
4 00
5 00
6 00
7 00
8 00
9 00
10 00
11 00
12 00
13 00
14 00
15 00
16 00
17 00
18 00
19 00
20 00
21 00
22 00
23 00
24 00
25 00
26 00
27 00
28 00
29 00
30 00
31 00
32 00
33 00
34 00
35 00
36 00
37 00
38 00
39 00
40 00
41 00
42 00
43 00
44 00
45 00
46 00
47 00
48 00
49 00
50 00
51 00
52 00
53 00
54 00
55 00
56 00
57 00
58 00
59 00
60 00
61 00
62 00
63 00
64 00
65 00
66 00
67 00
68 00
69 00
70 00
71 00
72 00
73 00
74 00
75 00
76 00
77 00
78 00
79 00
80 00
81 00
82 00
83 00
84 00
85 00
86 00
87 00
88 00
89 00
90 00
91 00
92 00
93 00
94 00
95 00
96 00
97 00
98 00
99 00
100 00

U21870-MNSC-CE-0024-ATT-0003

Month starts with 12 because Spending starts 12 months after start of current fiscal year

Period (t)	12	13	14	15	16	17	18	19	20	21	22	23
Month (update this with the periods)												
Raw (update this with inflated values)	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667	-653469.667
Discounted	-607878.76	-604226.261	-600595.708	-596986.971	-593399.916	-589834.415	-586290.337	-582767.555	-579265.939	-575785.363	-572325.7	-568886.826

Discount rate (yearly) - update this	7.500%
Discount rate (monthly) - auto-updated	0.006044919

Starting from Jan 2025 as '0' \$ (7,058,243.75) ← simulates the Copperleaf calculation

the NPV function in Excel treats the first cashflow amount as month '1', meaning that it discounts it when it shouldn't, but Copperleaf treats the first cashflow as month '0', which creates a different output between them

Total investment cost from Copperleaf

FY26
-7841636

The screenshot shows a software interface for 'Answer Questionnaires'. The main table displays financial data for 'JCS - LM Engine ESN 191-306 Repair at GE Depot' from FY24 to FY23. The table includes columns for Name, Unit, and various fiscal years. Key rows include 'Capital - # Capital', 'DGM - # DGM', 'Cost Of Removal - # Cost Of Removal', and 'Total Cost - # Total Investment Cost'. The 'Total Investment Cost' row shows a value of \$7,841,636 in FY26.

Name	Unit	FY24	FY25	FY26	FY27	FY28	FY29	FY30	FY31	FY32	FY33
Capital - # Capital											
Outcome	#			\$7,841,636							
DGM - # DGM											
Outcome	#										
Cost Of Removal - # Cost Of Removal											
Outcome	#										
Capital And Cost of Removal - # Capital											
Outcome	#			\$7,841,636							
Total Cost - # Total Investment Cost											
Outcome	#			\$7,841,636							

Investment Summary

Submit | Initiate Workflow | 4 | Reports | Follow Investment

Overview

JGS - LM Engine ESN 191-306 Repair at GE Depot

Engine ESN 191-306 had a stall event on 03/09/25 while in LMS package which made it inoperable and later determined to be unserviceable. The engine was removed from its package and a lease engine was installed so the plant could return to full capability. The engine was shipped from JGS to GE Depot (Houston) on 03/03/25.

Owner: Cummings, Jeffrey (Jeffrey.Cummings@comenergy.com)

Planning Portfolio: Jackson

Stage: Initial

Alternatives

Name	Value	Draft Forecast	Spend Date Range
overhaul engine	-4,317	\$7,841,636	Jan FY26 to Dec FY26


Risks Impacted for overhaul engine

Asset Unique ID	Value Measure	Value Model	Impact Date
	Lost Generation Risk	Lost Generation Risk	01/01/2027

1 - 1 of 1 items

Financial Metrics

Metrics	Value
Cost Present Value	\$7,058,244
Benefit Present Value	\$11,375,002
Net Present Value	\$4,316,758
Payback Period	91 months
Internal Rate Of Return	16.14%
Benefit/Cost Ratio	1.61
Value/Cost Ratio	0.61



Draft Investment Value

JGS - LM Engine ESN 191-306 Repair at GE Depot

Value Measure	Value
Cost Avoidance - ...	10,637
Lost Generation Ri...	738
Cost Avoidance - C...	0
Financial Benefits ...	0
Financial Benefits ...	0
Revenue Increase	0
Total Investment C...	-7,058
Total	-4,317

Edit Value for Recommended Alternative

STATE OF MICHIGAN

BEFORE THE MICHIGAN PUBLIC SERVICE COMMISSION


In the matter of the application of)
CONSUMERS ENERGY COMPANY)
for authority to increase its rates for)
the generation and distribution of)
electricity and for other relief.)
_____)

Case No. U-21870

PROOF OF SERVICE

STATE OF MICHIGAN)
) SS
COUNTY OF JACKSON)

Melissa K. Harris, being first duly sworn, deposes and says that she is employed in the Legal Department of Consumers Energy Company; that on November 6, 2025, she served an electronic copy of the Redacted Version of **Consumers Energy Company’s Supplement to Oral Argument** upon the persons listed in Attachment 1 hereto, at the e-mail addresses listed therein.



Melissa K. Harris

Subscribed and sworn to before me this 6th day of November, 2025.



Crystal L. Chacon, Notary Public
State of Michigan, County of Eaton
My Commission Expires: 05/25/30
Acting in the County of Jackson

ATTACHMENT 1 TO CASE NO. U-21870

Party	Email Address
Administrative Law Judge	
Jonathan F. Thoits	thoitsj@michigan.gov
Counsel for Consumers Energy Company	
Gary A. Gensch, Jr., Esq. Bret A. Totoraitis, Esq. Anne M. Uitvlugt, Esq. Spencer A. Sattler, Esq. Evan B. Keimach, Esq. Mark R. Ruskiewicz, Esq.	gary.genschjr@cmsenergy.com bret.totoraitis@cmsenergy.com anne.uitvlugt@cmsenergy.com spencer.sattler@cmsenergy.com evan.keimach@cmsenergy.com mark.ruskiewicz@cmsenergy.com mpsc.filings@cmsenergy.com
Counsel for the Michigan Public Service Commission Staff	
*Amit B. Singh, Esq. *Michael J. Orris, Esq. *Adam M. Cozort, Esq. *Nicholas Q. Taylor, Esq. *Alena M. Clark, Esq. *Daniel E. Sonneveldt, Esq.	singha9@michigan.gov orrism@michigan.gov cozortal@michigan.gov taylorn10@michigan.gov clarkA55@michigan.gov sonneveldtd@michigan.gov
Michigan Public Service Commission Staff	
*Mike Byrne *Bill Stosik *David Chislea *Bob Nichols *Nick Revere *Lori Mayabb	byrneM@michigan.gov stosikb@michigan.gov chislead@michigan.gov nicholsb1@michigan.gov reveren@michigan.gov mayabb1@michigan.gov
Counsel for Attorney General Dana Nessel	
*Lucas Wollenzien, Esq. *Celeste R. Gill, Esq. *Amanda Churchill	wollenzienl@michigan.gov gillc1@michigan.gov AG-ENRA-Spec-Lit@michigan.gov
Consultant for the Attorney General	
*Sebastian Coppola	sebpcoppola@corpalytics.com
Counsel for the Michigan Cable Telecommunications Association (“MCTA”)	
Sean P. Gallagher, Esq. Jon Austin	sgallagher@fraserlawfirm.com jaustin@fraserlawfirm.com
Counsel for the Michigan Environmental Council, Natural Resources Defense Council, Sierra Club, and Citizens Utility Board of Michigan (collectively “MNSC”)	
*Holly L. Hillyer, Esq. *Christopher M. Bzdok, Esq. *Tracy Jane Andrews, Esq. *Natasha Fowles *Tanya Stasio *Jordan Burt *Tyler Comings *Caroline Palmer *Rick Bunch *Julielyn Gibbons *Matt Bandyk *Sean Clark	holly@tropospherelegal.com chris@tropospherelegal.com tjandrews@tropospherelegal.com natasha@tropospherelegal.com tanya.stasio@aeclinic.org jordan.burt@aeclinic.org Tyler.comings@aeclinic.org cpalmer@synapse-energy.com rbunch@5lakesenergy.com jgibbons@5lakesenergy.com mbandyk@synapse-energy.com sean@tropospherelegal.com

* Receives Confidential Materials

ATTACHMENT 1 TO CASE NO. U-21870

Counsel for the Citizens Utility Board of Michigan (“CUB”)	
John Liskey, Esq.	john@liskeypllc.com
Counsel for The Kroger Co. (“Kroger”)	
Kurt J. Boehm, Esq.	kboehm@bkllawfirm.com
Jody Kyler Cohn, Esq.	jkylercohn@bkllawfirm.com
Michael L. Kurtz, Esq.	mkurtz@bkllawfirm.com
Consultant for Kroger	
Justin Bieber	jbieber@energystrat.com
Counsel for Michigan Energy Innovation Business Council (“Michigan EIBC”), Institute for Energy Innovation (“IEI”), Advanced Energy United (“United”), Energy Michigan, Inc., and The Foundry Association of Michigan.	
*Timothy J. Lundgren, Esq.	tjlundgren@varnumlaw.com
Laura A. Chappelle, Esq.	lachappelle@varnumlaw.com
*Justin K. Ooms, Esq.	jkooms@varnumlaw.com
Counsel for The Ecology Center, The Environmental Law & Policy Center (“ELPC”), Union of Concerned Scientists (“USC”), and Vote Solar (Collectively referred to as “CEO”)	
*Daniel Abrams, Esq.	dabrams@elpc.org
*Katie Duckworth, Esq.	kduckworth@elpc.org
*Alondra Estrada	astrada@elpc.org
*Katie Toolan	ktoolan@elpc.org
	mpscdockets@elpc.org
Counsel for Michigan Electric Transmission Company, LLC (“METC”)	
*Richard J. Aaron, Esq.	raaron@dykema.com
*Olivia R.C.A. Flower, Esq.	oflower@dykema.com
*Hannah Buzolits, Esq.	HBuzolits@dykema.com
*Courtney F. Kissel, Esq.	ckissel@dykema.com
	mpscfilings@dykema.com
Counsel for Urban Core Collective (“UCC”)	
*Mark Templeton, Esq.	templeton@uchicago.edu
*Jacob R. Schuhardt, Esq.	jschuhardt@uchicago.edu
*Emma Young	eyoung28@uchicago.edu
*Alexandria Miskho	amiskho@uchicago.edu
*Heidi Peng	hhpeng@lawclinic.uchicago.edu
*Willow Perlick	willowperlick@lawclinic.uchicago.edu
*Aashney Shah	aashney@lawclinic.uchicago.edu
	aelc_mpsc@lawclinic.uchicago.edu
Counsel for the Association of Businesses Advocating Tariff Equity (“ABATE”)	
*Stephen A. Campbell, Esq.	scampbell@clarkhill.com
*Michael J. Pattwell, Esq.	mpattwell@clarkhill.com
*Benjamin J. Holwerda, Esq.	bholwerda@clarkhill.com
Lauren Degnan	ldegnan@clarkhill.com
Consultants for ABATE	
*James Dauphinais	jdauphinais@consultbai.com
*Jessica York	jyork@consultbai.com
*Christina Hildebrandt	childebrandt@consultbai.com
Counsel for Hemlock Semiconductor Operations LLC (“HSC”) and Solar Technology LLC	
*Jennifer Utter Heston, Esq.	jheston@potomacclaw.com
Counsel for Great Lakes Renewable Energy Association (“GLREA”)	
Don L. Keskey, Esq.	donkeskey@publiclawresourcecenter.com
Counsel for Walmart, Inc. (“Walmart”)	
Melissa M. Horne, Esq.	mhorne@hcc-law.com

* Receives Confidential Materials